

NRC FORM 264  
REV 1  
U.S. NUCLEAR REGULATORY COMMISSION  
OPERATIONS CENTER

## EVENT NOTIFICATION WORKSHEET

NOTIFICATION TIME <b>1430</b>	FACILITY OR ORGANIZATION <b>Watts Bar Nuclear Plant</b>	UNIT <b>1</b>	CALLER NAME <b>Paul L. Pace</b>	CALL BACK #: ENS <b>N/A</b> or <b>(615)365-1824</b>
VENT TIME ZONE <b>N/A</b>	EVENT DATE <b>1-27-95</b>	<del>4-Hr Non-Emergency 10 CFR 50.72(b)(1)</del>		<del>(1a) Lost Office Comm. (1b) Fire (1c) Toxic Em (1d) Rad Release (1e) Off Hemispherical Cut Up.</del>
POWER/MODE BEFORE <b>N/A</b>	POWER/MODE AFTER <b>N/A</b>	<del>(2a) 15 Days from (2b) Extended Condition (2c) Unintended Condition (2d) Outside Design Basis</del>		<del>4-Hr Non-Emergency 10 CFR 50.72(b)(2)</del>
EVENT CLASSIFICATIONS  <b>GENERAL EMERGENCY</b>		<del>(3a) Not Covered by CDR/EP (3b) Earthquake (3c) Flood (3d) Hurricane (3e) Ice/Melt (3f) Lightning (3g) Tornado (3h) Other Natural Phenomenon (3i) FCCB Discharge to RCS (3j) Loss ENS</del>		<del>(3a) Upgrade While S/D (3b) RPS Activation (except) (3c) CSF Activation (3d) Safe S/D Capability (3e) M/R Capability (3f) Controlled Rad Release (3g) Accident Mitigation (3h) Air Release &gt; 2X Ann B (3i) Liqu Release &gt; 2X Ann B (3j) Offsite Medical</del>
<b>OTHER (10CFR50.55(e))</b>		<del>(4) Lost Emergency Assessment</del>		<del>(4) Offsite Notification</del>

## DESCRIPTION

During a Nuclear Assessment, TVA has identified various types of conduit deficiencies which include the following: loose flex conduits, no conduit ID, minimum bend radius violations, inadequate support for marinite board, various support deficiencies (shanked out bolts, proper torque cannot be achieved, no IDs, etc.), and separation violations. TVA has identified sixty-nine cables having various safety functions which are impacted by one or more of these deficiencies. Certain of these deficiencies would obviously not result in an adverse impact to plant safety in specific applications. However, based on the large number of safety related cables involved and the various other types of deficiencies identified it can be concluded that these conditions could represent an impact to the safe operation of the plant and would, therefore, represent a significant safety hazard.

Reference: Construction Deficiency Report (CDR) 95-03 - Significant Corrective Action Report  
WBSCA950003

Include External effects, vibration, &amp; their mitigating health, safety, effec. to envir. control, operat. limits &amp; beyond crit.

NOTIFICATIONS IN RESIDENT	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	WILL BE ANYTHING OTHER THAN UNINTENDED?	YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>
STATEMENT	Did ALL SYSTEMS FUNCTION AS REQUIRED?			YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>
LOCAL	<b>N/A</b>			YES <input type="checkbox"/>	NO <input checked="" type="checkbox"/>
OTHER GOV AGENCIES	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	MODE OF OPERATION	ESTIMATE FOR REACTOR DATE	ADDITIONAL INFO ON BACK
MEDIA/CAUSE RELEASE	YES <input checked="" type="checkbox"/>	NO <input type="checkbox"/>	<b>N/A</b>	<b>N/A</b>	<b>N/A</b>

9503220283 950317  
PDR ADDCK 05000390  
PDR  
S