TENNESSEE VALLEY AUTHORITY
CHATTANOOGA, TENNESSEE 37401
400 Chestnut Street Tower II

January 31, 1983

U.S. Nuclear Regulatory Commission
Region II
Attn: Mr. James P. O'Reilly, Regional Administrator
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - NRC-OIE REGION II INSPECTION REPORT 50-390/82-20 AND 50-391/82-20 - SUPPLEMENTAL RESPONSE TO DEVIATIONS 390,391/82-20-01

The subject inspection report cited TVA with four deviations. Our responses were submitted December 16, 1982. In our report, TVA committed to complete the corrective actions as specified for the subject deviations by January 31, 1983. The date of January 31, 1983 will not be met. Replacement dampers do not work properly so TVA is requesting vendor inspection as they are still under warranty. Also, continuing reinspection has shown that three more dampers need to be replaced. The corrective action on this matter will be completed by March 31, 1983.

If you have any questions, please get in touch with R. H. Shell at FTS 858-2688.

To the best of my knowledge, I declare the statements contained herein to be complete and true.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager
Nuclear Licensing

cc: Mr. Richard C. DeYoung, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

8306100239 830131
PDR ADOCK 05000390
Q PDR

IE01 1/0

An Equal Opportunity Employer