

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

June 17, 1983

Director of Nuclear Reactor Regulation  
Attention: Ms. E. Adensam, Chief  
Licensing Branch No. 4  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Dear Ms. Adensam:

In the Matter of the Application of ) Docket Nos. 50-390  
Tennessee Valley Authority ) 50-391

Reference: Letter from E. G. Adensam, NRC, to H. G. Parris dated  
March 25, 1983

In response to the referenced letter, we do not believe that adding  $T_{cold}$  or  $T_{avg}$  instrumentation in the auxiliary control room (ACR) adds any safety benefits in shutting down the plant from the ACR. We have performed a startup test on Sequoyah unit 1 (and will on Watts Bar unit 1) which demonstrated that the plant was safely cooled down from the ACR.

Item 1 in the enclosure to the referenced letter acknowledges that, during natural circulation conditions, the saturation temperature corresponding to the secondary side steam generator pressure,  $T_{sat}$ , will approximate  $T_{cold}$  but further suggests that "the converse cannot be assumed" due to the inherent lag in temperature response between the primary and secondary systems.

While a lag in temperature response exists between the primary and secondary systems, the interruption of natural circulation can be detected with the existing instrumentation in the ACR. A loss of natural circulation in one loop will result in an increased delta-T between  $T_{hot}$  and  $T_{sat}$  in the other loops.

Section III.L.2.d of Appendix R to 10 CFR 50 states that the process monitoring function shall be capable of providing direct readings of the process variables necessary to perform and control a plant cooldown. Since it has been demonstrated at Sequoyah that a safe, controlled cooldown can be performed without the use of  $T_{cold}$  indication, we believe the existing ACR instrumentation meets these requirements of Appendix R and can perform the functional requirements set forth in Appendix R.

Item 3 in the enclosure to the referenced letter recommends that  $T_{cold}$  indication, in conjunction with RCS pressure indication, be used to provide a direct indication relative to the plant's pressure/temperature limits as they pertain to pressurized thermal shock considerations and the low temperature overpressure protection as outlined in Appendix G of 10 CFR 50.

8306230178 830617  
PDR ADDOCK 05000390  
F PDR

13002  
1/0

U.S. Nuclear Regulatory Commission

June 17, 1983

Since pressurized thermal shock considerations are unique to accident situations, the ACR was not designed to mitigate accidents caused by pressurized thermal shock. This concern is addressed in section III.L.6 of Appendix R which states that "shutdown systems installed to ensure postfire shutdown capability need not be designed to meet category I criteria, single failure criteria or other design basis accident criteria."

During a reactor coolant system cooldown from the ACR, the steam generator pressure will be adjusted to the desired corresponding  $T_{cold}$  temperature using the steam generator PORV controller. The saturation temperature,  $T_{sat}$ , is the coolest possible temperature that could be encountered during RCS cooldown. This fact was reflected in the results of the ACR cooldown test performed at Sequoyah where  $T_{cold}$  was observed to be slightly higher than  $T_{sat}$  but tracking was done with  $T_{sat}$  at all times during the plant cooldown. The use of  $T_{sat}$  as a conservative indication of  $T_{cold}$  ensures that plant cooldown will occur at a controlled rate and the Appendix G limits will not be exceeded.

In addition,  $T_{avg}$  would be of no value in the ACR because, for the instrument to function properly, the forced flow from the reactor coolant pumps is necessary.

Therefore, since  $T_{cold}$  or  $T_{avg}$  is not needed for the operator to verify natural circulation, set a reactor cooldown rate, or any other Appendix R function, we believe that adding  $T_{cold}$  or  $T_{avg}$  indication in the ACR would be of no value and would constitute an unnecessary expense.

We believe the ACR instrumentation meets all requirements of Appendix R and can perform all functional requirements set forth in Appendix R.

If you have any questions concerning this matter, please get in touch with D. P. Ormsby at FTS 858-2682.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L. M. Mills, Manager  
Nuclear Licensing

Sworn to and subscribed before me  
this 17th day of June 1983

Phulette N. White  
Notary Public  
My Commission Expires 9-5-84

ccl: See page 3

U.S. Nuclear Regulatory Commission

June 17, 1983

cc: U.S. Nuclear Regulatory Commission  
Region II  
Attn: Mr. James P. O'Reilly, Regional Administrator  
101 Marietta Street, NW, Suite 2900  
Atlanta, Georgia 30303