

DMB

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

OCT 15 1986 OCT 17 9:44

WBRD-50-390/86-25
WBRD-50-391/86-21

U.S. Nuclear Regulatory Commission
Region II
Attention: Dr. J. Nelson Grace, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Dear Dr. Grace:

WATTS BAR NUCLEAR PLANT UNITS 1 AND 2 - NON-QUALITY ASSURANCE DATA FOR CABLE WEIGHTS AND OUTSIDE DIAMETERS USED IN CALCULATIONS - WBRD-50-390/86-25, WBRD-50-391/86-21 - SCHEDULE CHANGE FOR FINAL REPORT

The subject deficiency was initially reported to NRC-Region II Inspector Bob Carroll on January 1, 1986 in accordance with 10 CFR 50.55(e) as NCRs WBN EEB 8589 and EEB 8590. Interim reports were submitted on February 20 and June 20, 1986. A final report on this deficiency cannot be provided at this time. Higher priority work for Sequoyah has delayed completion of the deficiency evaluation. The verified cable weight and outside diameters must be entered into the computer data base and actual cable tray fill evaluated so that this condition, adverse to quality (CAQ), can be dispositioned. The final report on this deficiency, based on the CAQ disposition, will be submitted on or about January 20, 1987.

If there are any questions, please get in touch with J. A. McDonald at (615) 365-8527.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

R. Gridley
R. Gridley, Director
Nuclear Safety and Licensing

cc: Mr. James Taylor, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. G. G. Zech
Director, TVA Projects
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Records Center
Institute of Nuclear Power Operations
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

B610280117 861015
PDR ADOCK 05000390
S PDR

U.S. NRC - REGION II
OFFICIAL COPY

10/10