



HOSE STA. #44 ATE BSMT

SOUTH HOSE STA. #45 ATE 1<sup>st</sup> FLOOR

NORTH HOSE STA. #46 ATE 1<sup>st</sup> FLOOR

WEST HOSE STA. #47 ATE 1<sup>st</sup> FLOOR

SOUTH HOSE STA. #48 ATE 2<sup>nd</sup> FLOOR

NORTH HOSE STA. #49 ATE 2<sup>nd</sup> FLOOR

WEST HOSE STA. #50 ATE 2<sup>nd</sup> FLOOR

SOUTH HOSE STA. #51 ATE 3<sup>rd</sup> FLOOR

NORTH HOSE STA. #52 ATE 3<sup>rd</sup> FLOOR

WEST HOSE STA. #53 ATE 3<sup>rd</sup> FLOOR

DETAIL "3"

- NOTES:**
1. MANUAL FIRE HOSE STATIONS ARE ALSO SUPPLIED BY THE SERVICE WATER SYSTEM AS SHOWN ON DWG. OPER M-202
  2. HOSE HOUSES #1 AND 13 ARE SUPPLIED BY POTABLE WATER SYSTEM AS SHOWN ON DWG. OPER M-209.
  3. ALL ITEMS ARE Q.A. TYPE 2 EXCEPT AS NOTED.

- LR NOTES:**
1. THESE VALVES WITH 'SW' SYSTEM DESIGNATORS IN THEIR EQUIPMENT NUMBERS HAVE BEEN ASSIGNED TO (08/FP) FIRE PROTECTION SYSTEM FOR LR PURPOSES.
  2. PIPING, VALVES AND SPRINKLER HEADS ARE IN LR SCOPE, BUT NOT SHOWN ON DRAWING.
  3. AUTO BALL DRIPS ARE INCLUDED IN THE COMPONENT GROUP VALUES.

**LICENSE RENEWAL DRAWING LEGEND**

- 08/FP FIRE PROTECTION
- 02/SW SERVICE WATER
- 27B/MUP SERVICE WATER PRETREATMENT

IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)

IN SCOPE FOR LR PER 10CFR 54.4 (a) (3)

DOMINION ENERGY KEWAUNEE, INC.  
KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING  
FIRE PROTECTION SYSTEM

HYBRID CADD	APPROVED	DRAWN	DWG. NO.	REV.
	REVIEWED	SCALE	LRM-208-1	0
REFERENCED PER MASTER DRAWING				REV
OPERM-208-1				A

REV 'M' PER LAST UPDATE