


- LR NOTES:**
1. POSITIONERS ARE CONSIDERED PART OF THE ACTUATORS WHICH ARE TREATED AS "ACTIVE" COMPONENTS AND THEREFORE DO NOT REQUIRE AGING MANAGEMENT REVIEW.
  2. ACTUATORS ARE DESIGNATED BY A "CV" IN THE EQUIPMENT NUMBER.
  3. THE INSTRUMENT AIR TUBING HAS BEEN CONSERVATIVELY INCLUDED IN SCOPE UP TO THE AIR-OPERATED VALVES AND DAMPERS SHOWN ON THIS DRAWING. REFER TO THE APPLICABLE LR DRAWING FOR THE SYSTEMS IN WHICH THE VALVES AND DAMPERS ARE LOCATED, TO DETERMINE WHICH ONES ARE INCLUDED IN SCOPE.
  4. THE PANELS (INCLUDING THE INTERNAL COMPONENTS) ON THIS DRAWING HAVE BEEN CONSERVATIVELY INCLUDED IN LR SCOPE. THEY HAVE NOT BEEN HIGHLIGHTED BECAUSE THEY ARE BEING HANDLED AS A STRUCTURAL COMMODITY.
  5. INCLUDES INSTRUMENTS TUBING, VALVES AND REGULATORS, ETC. FOR TSC PNEUMATIC CONTROL EQUIPMENT THAT IS NOT SHOWN ON A LR DRAWING.

- NOTES:**
1. ALL INSTRUMENT AIR COMPONENTS PROVIDE A QA-2 BOUNDARY UNLESS NOTED. THE COMPONENTS SUPPLIED WITH INSTRUMENT AIR ALONG WITH THEIR ASSOCIATED SOLENOID VALVES MAY PERFORM A QA-1 FUNCTION.
  2. FIVE DIGIT FILTER/REGULATORS NUMBERED 36014 THROUGH 36088 ARE QA 1.
  3. QA TYPING TRANSITION IS AT ACTUATOR TRIP VALVE

**LICENSE RENEWAL LEGEND**

<span style="color: blue;">—</span>	01/AS STATION AND INSTRUMENT AIR
<span style="color: orange;">—</span>	10/0GM DIESEL GENERATOR,
<span style="color: green;">—</span>	51/GS MISCELLANEOUS GAS



DOMINION ENERGY KEWAUNEE, INC.  
KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING  
STATION & INSTRUMENT AIR SYSTEM

APPROVED	DRAWN	DATE	REV.
CADD	JSW	10/07/80	0
REVIEWED	SCALE	LRM-213-2	

REFERENCED PER MASTER DRAWING	REV.
OPERM-213-2	N

REV "N" PER LAST UPDATE