



- LR NOTES:**
- ACTUATORS ARE DESIGNATED BY A 'CV' IN THE EQUIPMENT NUMBER AND ARE 'ACTIVE' COMPONENTS. THEREFORE ACTUATORS DO NOT REQUIRE AGING MANAGEMENT REVIEW.
  - THE ANALYTICAL INSTRUMENTATION PANEL IS IN LR SCOPE BECAUSE IT SUPPORTS INTERNAL FLUID-CONTAINING COMPONENTS THAT HAVE BEEN INCLUDED IN SCOPE FOR SPATIAL CONSIDERATIONS. SEE LRM-219. THE PANEL HAS NOT BEEN HIGHLIGHTED BECAUSE IT IS BEING HANDLED AS A STRUCTURAL COMMODITY. THE INSTRUMENT AIR LINES TO THE PANEL ARE NOT REQUIRED TO SUPPORT OPERATION OF THE PLANT.
  - THE INSTRUMENT AIR TUBING HAS BEEN CONSERVATIVELY INCLUDED IN SCOPE UP TO THE AIR-OPERATED VALVES AND DAMPERS SHOWN ON THIS DRAWING. REFER TO THE APPLICABLE LR DRAWING FOR THE SYSTEMS IN WHICH THE VALVES AND DAMPERS ARE LOCATED, TO DETERMINE WHICH ONES ARE INCLUDED IN SCOPE.

**LICENSE RENEWAL DRAWING LEGEND**

- 01/AS STATION AND INSTRUMENT AIR
- 10/DGM DIESEL GENERATOR.
- IN SCOPE FOR LR PER 10CFR 54.4 (a) (1)
- IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)

**DOMINION ENERGY KEWAUNEE, INC.**  
**KEWAUNEE POWER STATION**

**LICENSE RENEWAL DRAWING**  
**STATION & INSTRUMENT AIR SYSTEM**

APPROVED	DRAWN	DATE	REV.
CADD	JSW	10/07/00	0
REVIEWED	SCALE	LRM-213-3	

OPERM-213-3