



- LR NOTES:
- HG-6 AUTOMATICALLY CLOSES TO PREVENT BLOWING DOWN THE HYDROGEN SUPPLY STORAGE CYLINDER IN THE EVENT OF A DOWNSTREAM LINE RUPTURE. CLOSURE WILL HELP PREVENT AN EXPLOSION/FIRE HAZARD. VALVE IS IN SCOPE BUT DOES NOT REQUIRE AGING MANAGEMENT REVIEW SINCE THE ISOLATION IS AN ACTIVE FUNCTION. LEAKAGE THROUGH THE VALVE BODY WILL NOT CONTRIBUTE TO A FIRE HAZARD IN THE BUILDING SINCE THE VALVE IS LOCATED OUTSIDE.
 - THE "NG" VALVES ARE ASSIGNED TO THE MISCELLANEOUS GAS SYSTEM.
 - COMPONENTS ARE ASSIGNED TO SYSTEM 32B/WD-(G) GASEOUS WASTE PROCESSING AND DISCHARGE.

LICENSE RENEWAL DRAWING LEGEND

	51/GS MISCELLANEOUS GAS
	05A/FW FEEDWATER
	12/BS BLEED STEAM
	22/HS HEATING STEAM
	32A/WD-(L) LIQUID WASTE PROCESSING AND DISCHARGE
	32B/WD-(G) GASEOUS WASTE PROCESSING AND DISCHARGE
	33/SI SAFETY INJECTION
	35/CVC CHEMICAL & VOLUME CONTROL
	36/RC REACTOR COOLANT

IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)

IN SCOPE FOR LR PER 10CFR 54.4 (a) (3)

ANCHOR LOCATION

PROpane STORAGE STATION
2-200LB CAPACITY PROpane CYLINDERS

X-K02646-18

LEGEND

- WESTINGHOUSE INSTRUMENT NUMBER
- P.S. & E.CO. INSTRUMENT NUMBER
- *-DENOTES EQUIPMENT FURNISHED BY WESTINGHOUSE CORP USING WESTINGHOUSE INSTR. SYMBOLS.

NOTE: ROOT VALVE NUMBERS WILL NOT BE SHOWN ON THIS DRAWING THE OPERATION VALVE NUMBER CONTAINS THE SYSTEM DESIGNATOR FOLLOWED BY THE INSTRUMENT NUMBER (I.E., SW-11007)

NOTE 1: SECURITY SHUT-OFF VALVE LOCKED OPEN. SEE KAPS 1309-1312 FOR DETAIL ON ACCEPTABILITY OF LOCKING OPEN VALVES. SEE ALSO 0TH001861 AND 0TH001864.

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING
MISCELLANEOUS GAS SYSTEMS

APPROVED	DRAWN	DATE	REV.
REVIEWED	SCALE	LRM-216	0