



LEGEND

* VALVES WITH ASTERISK SHALL BE LOCKED

INDICATES NORMALLY CLOSED

NON-SV ZONE | SV ZONE

- NOTES:**
- CHECK VALVES SUPPLIED WITH MANUAL OPERATOR.
 - ROOT VALVE NUMBERS WILL NOT BE SHOWN ON THIS DRAWING. THE OPERATION VALVE NUMBER CONTAINS THE SYSTEM DESIGNATOR FOLLOWED BY THE INSTRUMENT NUMBER (I.E., SW-11007).
 - VALVES SHALL NOT BE CLOSED WITH PLANT AT HOT SHUTDOWN OR ABOVE WITHOUT AN ENGINEERING EVALUATION OF GL 96-06 IMPACT (REF. CALC. C11483).
 - THESE VALVES, ALTHOUGH THEY ARE NOT CREDITED AS CONTAINMENT ISOLATION VALVES, RECEIVE A CONTAINMENT ISOLATION SIGNAL.

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING
INTERNAL CONTAINMENT SPRAY SYSTEM

APPROVED	DRAWN	DWG. NO.	REV.
HYBRID CADD	JSW	LRM-217	0
REVIEWED	SCALE		

LR NOTES:

1. THE COMPONENTS WITH A 'CI' (CHEMICAL INJECTION SYSTEM DESIGNATOR IN THE EQUIPMENT NUMBER HAVE BEEN ASSIGNED TO THE CONTAINMENT VESSEL INTERNAL SPRAY SYSTEM FOR LR PURPOSES.

LICENSE RENEWAL DRAWING LEGEND

- 23/ICS CONTAINMENT VESSEL INTERNAL SPRAY
- 31/CC COMPONENT COOLING
- 32A/WD-(L) LIQUID WASTE PROCESSING AND DISCHARGE
- 33/SI SAFETY INJECTION
- 34/RHR RESIDUAL HEAT REMOVAL

IN SCOPE FOR LR PER 18CFR 54.4 (a) (2)

IN SCOPE FOR LR PER 18CFR 54.4 (a) (1) 18CFR 54.4 (a) (3)

REFERENCED PER MASTER DRAWING: OPERM-217

REV. AP

REV. AP*