



LR NOTES:
 1. FOR LR PURPOSES SOME COMPONENTS WITH A "MD(R)" OR "WD" SYSTEM DESIGNATOR IN THEIR EQUIPMENT NUMBERS, HAVE BEEN ASSIGNED TO SYSTEM 30/MDS IN ORDER TO MAINTAIN CONSISTENCY WITH SYSTEM DESCRIPTIONS AND M-RULE DOCUMENTATION.

LEGEND:

 F.O. - DENOTES FAIL OPEN
 F.C. - DENOTES FAIL CLOSED
 T(2) - DENOTES CONTAINMENT ISOLATION SIGNAL GROUP 2 POST ACCIDENT RELEASE CONTROL SYSTEMS

NOTES:
 1. VALVES FAIL WITH FLOW TO WASTE GAS DISPOSAL SYSTEM. VALVE PORT A, B & C IDENTIFICATION FOR INSTALLATION.
 2. INSTALL SOLENOID VALVE IN DIRECTION OF FLOW.
 3. VALVE SHALL NOT BE CLOSED WITH PLANT AT HOT SHUTDOWN OR ABOVE WITHOUT AN ENGINEERING EVALUATION OF GL 96-06 IMPACT (REF. CALC. C11483).

DOMINION ENERGY KEWAUNEE, INC.
 KEWAUNEE POWER STATION
 LICENSE RENEWAL DRAWING
 REACTOR PLANT MISC VENTS, DRAINS
 AND SUMP PUMP PIPING

APPROVED	DRAWN	OWG. NO.	REV.
REVIEWED	SCALE	LRM-539	0

LICENSE RENEWAL DRAWING LEGEND

	30/MDS MISCELLANEOUS DRAINS AND SUMPS
	32A/WD-LI LIQUID WASTE PROCESSING AND DISCHARGE
	32B/WD-GI GASEOUS WASTE PROCESSING AND DISCHARGE
	35/CVC CHEMICAL & VOLUME CONTROL

IN SCOPE FOR LR PER 10CFR 54.4 (b) (2)
 IN SCOPE FOR LR PER 10CFR 54.4 (b) (3)

REFERENCED PER MASTER DRAWING	REV
OPERM-539	0

REV '0' PER LAST UPDATE