



- LR NOTES:
1. OA-1 VALVES WITH 'MG' DESIGNATORS ARE ASSIGNED TO FIRE PROTECTION SYSTEM FOR LR PURPOSES, SINCE THEY PERFORM A PRESSURE BOUNDARY FUNCTION FOR CO2 STORAGE TANK.
  2. CO2 DISCHARGE PIPING, VALVES AND NOZZLES IN RECORD STORAGE ROOM, RELAY ROOM, TURBINE GENERATOR BEARINGS, TURBINE GENERATOR HEAD ENCLOSURE, TELEPHONE EQUIPMENT ROOM, TURBINE GENERATOR BEARING HOUSING DISCHARGE NOZZLES AND DIESEL GENERATOR AREAS 1A AND 1B ARE IN LR SCOPE BUT NOT SHOWN ON THIS DRAWING.
  3. VENT HOSE REEL BLEEDER LINE UP TO THE HYDROGEN AND PURGING VENT STACK IS IN LR SCOPE BUT NOT SHOWN ON THIS DRAWING.
  4. THIS COMPONENT IS AN ORDERIZER.

NOTE:  
ROOT VALVE NUMBERS WILL NOT BE SHOWN ON THIS DRAWING. THE OPERATION VALVE NUMBER CONTAINS THE SYSTEM DESIGNATOR FOLLOWED BY THE INSTRUMENT NUMBER (I.E. SW-11007)

**LICENSE RENEWAL DRAWING LEGEND**

- 08/FP FIRE PROTECTION
- 22/HS HEATING STEAM
- 51/GS MISCELLANEOUS GAS

IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)

IN SCOPE FOR LR PER 10CFR 54.4 (a) (3)

DOMINION ENERGY KEWAUNEE, INC.  
KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING  
CO2 FIRE PROTECTION SYSTEM

APPROVED	DRAWN	DWG. NO.	REV.
REVIEWED	SCALE	LRM-384	0

HYBRID CADD

REFERENCED PER MASTER DRAWING: OPERM-384

REV 'Q' PER LAST UPDATE