



- NOTES
- 1 ALL ITEMS ON TYPE 2 EXCEPT AS NOTED
 - 2 ROOT VALVE NUMBERS WILL NOT BE SHOWN ON THIS DRAWING THE OPERATION VALVE NUMBER CONTAINS THE SYSTEM DESIGNATOR FOLLOWED BY THE INSTRUMENT NUMBER (IE SW 11027)
 - 3 THE PRESSURE READING AT PI-11258 IS 40 ±2 PSIG WHEN THE PRESSURE REDUCING VALVE IS SET AT 38 ±2 PSIG DUE TO ELEVATION HEAD.
 - 4 MIXER INTERNALS REMOVED.

- LR NOTES:
1. THE COMPONENTS ARE LOCATED IN THE TURBINE BUILDING BASEMENT EAST/SOUTHEAST SIDE, THERE ARE NO SAFETY RELATED COMPONENTS LOCATED IN THIS AREA.
 2. THE COMPONENTS ARE LOCATED IN THE AUXILIARY BUILDING BASEMENT SOUTH SIDE, THERE ARE NO SAFETY RELATED COMPONENTS LOCATED IN THIS AREA.
 3. THE COMPONENTS ARE LOCATED BEHIND THE WASTE NEUTRALIZATION TANK LOCATED AT THE SOUTHEAST CORNER OF THE AUXILIARY BUILDING BASEMENT, THERE ARE NO SAFETY RELATED COMPONENTS LOCATED IN THIS AREA.

LICENSE RENEWAL DRAWING LEGEND

- 278/MUP SERVICE WATER PRE-TREATMENT
- 02/SW SERVICE WATER
- 30/MDS MISCELLANEOUS DRAINS AND SUMPS

IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)

IN SCOPE FOR LR PER 10CFR 54.4 (a) (3)

DOMINION ENERGY KEWAUNEE, INC. KEWAUNEE POWER STATION			
LICENSE RENEWAL DRAWING SERVICE WATER PRE-TREATMENT SYS			
APPROVED	DRAWN	DATE	REV.
REVIEWED	SCALE	LRM-394	0
HYBRID CADD		OPERM-394	REV 'BW' PER LAST UPDATE