



BASEMENT FIRST FLOOR

- NOTE:
1. ALL FIRE DAMPERS (FD) ARE OA TYPE 2. ALL OTHER ITEMS ARE OA TYPE 3, UNLESS OTHERWISE NOTED.
 2. NOT ALL FUSIBLE LINK FIRE DAMPERS ARE SHOWN ON THIS FLOW DIAGRAM. SEE M-510 FOR A COMPLETE LISTING OF FIRE DAMPERS.
 3. FOR INTEGRATED LOGIC DIAGRAM SEE E2994 THRU E2996, E3040 & E3041

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION
LICENSE RENEWAL DRAWING
TECHNICAL SUPPORT CENTER
HEATING VENTILATION & AIR COND.

APPROVED	DRAWN	DATE	REV.
HYBRID CADD	JSW	10/26/00	0
REVIEWED	SCALE	LRM-501	

LICENSE RENEWAL DRAWING LEGEND

- 67/TCV TECHNICAL SUPPORT CENTER VENTILATION
- 10/ODM DIESEL GENERATOR, MECHANICAL

IN SCOPE FOR LR PER 18CFR 54.4 (a) (2)

IN SCOPE FOR LR PER 18CFR 54.4 (a) (3)

OPERM-501

REV. Y

REV. Y PER LAST UPDATE

- LR NOTES:
1. ALL FIRE DAMPER HOUSINGS ARE IN LR SCOPE.
 2. THESE LOUVERS ARE INCLUDED IN LR SCOPE AND ARE COVERED IN CIVIL EVALUATIONS FOR THE TECHNICAL SUPPORT CENTER.