



- LR NOTES:
1. THE COMPONENTS WITH A 'CI' (CHEMICAL INJECTION SYSTEM DESIGNATOR IN THE EQUIPMENT NUMBERS HAVE BEEN ASSIGNED TO THE 102/SW SERVICE WATER SYSTEM FOR LR PURPOSES.
  2. THE COMPONENTS ARE LOCATED IN BASEMENT OF THE TURBINE BUILDING TO THE EAST SIDE OF THE CONDENSER. THERE ARE NO SAFETY RELATED COMPONENTS LOCATED IN THIS AREA.
  3. THE COMPONENTS ARE LOCATED IN BASEMENT OF THE TURBINE BUILDING TO THE SOUTH EAST CORNER OF THE MAIN CONDENSER AND ARE SEPARATED FROM SAFETY RELATED COMPONENTS BY MAJOR PLANT COMPONENTS.
  4. THE COMPONENTS NORMALLY DO NOT CONTAIN FLUID AND ARE AT ATMOSPHERIC PRESSURE.
  5. THE TANK IS A PORTABLE UNIT.
  6. THE TANK IS MAINTAINED AT ATMOSPHERIC PRESSURE. THERE ARE NO SAFETY RELATED COMPONENTS WITHIN THE COLLAPSE ENVELOPE OF THE TANK.
  7. SERVICE WATER ACTI-BROM EQUIPMENT PROVIDED, BUT NOT HOOKED UP.

DOMINION ENERGY KEWAUNEE, INC.  
KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING  
CHLORINATION SYSTEM

LICENSE RENEWAL DRAWING LEGEND	
	Ø2/SW SERVICE WATER
	IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)
	IN SCOPE FOR LR PER 10CFR 54.4 (a) (3)

APPROVED	DRAWN	DWG. NO.	REV.
CADD	JSW	LRM-1274	0
REVIEWED	SCALE		