



- NOTES:**
- ELBOW FLOW METER.
 - TCV-130 SHOWN SOLID ON CHEMICAL & VOLUME CONTROL SYSTEM, OPERXK-100-36.
 - TEMPORARY STRAINER WAS PLACED IN THE SPOOL PIECE DURING INITIAL FLUSHING OPERATIONS. STRAINER WAS REMOVED BEFORE PLANT START-UP. CAPPED LINE IS CONNECTED TO PRESSURE GAUGE DURING INITIAL FLUSHING.
 - ALL PIPING (P. S. & E.) QUALITY ASSURANCE TYPE 1.
 - QUALITY ASSURANCE CODES BY P. S. & E.
 - R-17 CONNECTION SHOWN ON DWG. M-761.
 - MOTOR OPERATORS & CONTROL BY P. S. & E.
 - LIMIT STOP INSTALLED PER DCR 3482.

LR NOTES:

- R-17 IS Q3 AND IS NOT A PRESSURE BOUNDARY. IT IS IN A WELL.

LICENSE RENEWAL DRAWING LEGEND

	31/CC COMPONENT COOLING
	02/SW SERVICE WATER
	27A/MUP MAKE-UP AND DEMINERALIZED WATER
	32A/WD-(L) LIQUID WASTE PROCESSING AND DISCHARGE
	34/RHR RESIDUAL HEAT REMOVAL
	35/CVC CHEMICAL & VOLUME CONTROL
	37/PS PRIMARY SAMPLING

IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)

IN SCOPE FOR LR PER 10CFR 54.4 (a) (3)

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING
COMPONENT COOLING SYSTEM

APPROVED	DRAWN	DWG. NO.	REV.
CADD	JSW	LRXK-100-19	0
REVIEWED	SCALE		

REFERENCED PER MASTER DRAWING: OPERXK-100-19

REV 'AL' PER LAST UPDATE