



- NOTES:
- TEMPORARY STRAINER IS PLACED IN THE SPOOL PIECE DURING INITIAL FLUSHING OPERATIONS. STRAINER MUST BE REMOVED BEFORE PLANT START-UP. CAPPED LINE IS CONNECTED TO PRESSURE GAUGE DURING INITIAL FLUSHING.
 - LEGEND:
S - SAFETY INJECTION ACTUATION SIGNAL
 - ALL PIPING THIS SHEET IS P.S.&E. QUALITY ASSURANCE CODE TYPE 1 UNLESS OTHERWISE NOTED.
 - MINIFLOW ORIFICE SUPPLIED BY PUMP VENDOR.
- LEGEND
-
- SEE M758 SERIES FOR ADDITIONAL INSTRUMENTS ON MAJOR COMPONENTS.
 - ROOT VALVE NUMBERS WILL NOT BE SHOWN ON THIS DRAWING. THE OPERATION VALVE NUMBER CONTAINS THE SYSTEM DESIGNATOR FOLLOWED BY THE INSTRUMENT NUMBER (I.E., SV-11007).
 - DCR 2920 RENUMBERED VALVES, RHR-300A BECAME RHR-299A & RHR-300B BECAME RHR-299B.
 - VALVE SHALL NOT BE CLOSED WITH PLANT AT HOT SHUTDOWN OR ABOVE WITHOUT AN ENGINEERING EVALUATION OF CL 36-06 IMPACT (REF. CALC. C11483).

LICENSE RENEWAL DRAWING LEGEND

- 33/SI SAFETY INJECTION
- 21/SFP SPENT FUEL POOL COOLING
- 23/ICS CONTAINMENT VESSEL INTERNAL SPRAY
- 31/CC COMPONENT COOLING
- 32A/WD-LI LIQUID WASTE PROCESSING AND DISCHARGE
- 34/RHR RESIDUAL HEAT REMOVAL
- 35/CVC CHEMICAL & VOLUME CONTROL

IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)

IN SCOPE FOR LR PER 10CFR 54.4 (a) (3)

DOMINION ENERGY KEWAUNEE, INC.
KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING
SAFETY INJECTION SYSTEM

APPROVED	DRAWN	DATE	REV.
	JSW	02/14/00	0
REVIEWED	SCALE	LRXK-100-29	
			AD

REV 'AD' PER LAST UPDATE