



LR NOTES:
 1. VALVE DW-152 IS ASSIGNED TO SYSTEM 35/CVC CHEMICAL & VOLUME CONTROL FOR LR PURPOSES.

- NOTES:
- 3/4 PIPE 3/8 TUBE INSERT
 - *QUALITY ASSURANCE CODES BY P. S. & E.
 - FOR CONT. OF ALL REFERENCES TO DH (DRAIN HEADER) SEE A350.
 - CONTROL VALVE MODULATES OPEN/CLOSE TO MAINTAIN DOWNSTREAM PRESSURE OF 5 PSI.
 - FILTER HOUSINGS INSTALLED BACKWARDS PER DCR 1638 FOR COALESCING PURPOSES.

LICENSE RENEWAL DRAWING LEGEND

	35/CVC CHEMICAL & VOLUME CONTROL
	27A/MUP MAKE-UP AND DEMINERALIZED WATER
	32A/WD-LI LIQUID WASTE PROCESSING AND DISCHARGE
	32B/WD-IGI GASEOUS WASTE PROCESSING AND DISCHARGE
	51/GS MISCELLANEOUS GAS

IN SCOPE FOR LR PER 18CFR 54.4 (a) (2)
 IN SCOPE FOR LR PER 18CFR 54.4 (a) (3)

ANCHOR LOCATION

DOMINION ENERGY KEWAUNEE, INC.
 KEWAUNEE POWER STATION

LICENSE RENEWAL DRAWING
 CHEMICAL & VOLUME CONTROL SYS.

HYBRID CADD

APPROVED	DRAWN	DWG. NO.	REV.
REVIEWED	SCALE	LRXK-100-37	0

REFERENCED PER MASTER DRAWING	REV
OPERXK-100-37	AF