



NOTES:

1. LINES HEAT TRACED BY OTHERS.
2. ALL LINES MARKED * ARE CLASS 151R, THIS IS A DESIGNATION ONLY, NO ADDITIONAL INSPECTION HAS BEEN PERFORMED ON THIS PIPING. ALL OTHER PIPE IS CLASS 151.
3. SYSTEM LOGIC DEALING WITH SOLENOID VALVES CAN BE FOUND ON THE APPROPRIATE ELECTRICAL OR PNEUMATIC DIAGRAMS.
4. T.P. INDICATES "TERMINAL POINT"
5. SOLENOID VALVE ACTION (P)

	AIR SUPPLY	VALVE ACTION (P)
ENERGIZED	ON	OPEN
DEENERGIZED	ON	CLOSED
ENERGIZED	OFF	OPEN
DEENERGIZED	OFF	CLOSED

*"FAIL OPEN" REFERS TO AIR FAILURE ONLY (NOT ELECTRICAL FAILURE)
6. BLOCKED PORT ON SOLENOID INDICATES NORMAL MODE OF OPERATION.
7. ROOT VALVE NUMBERS WILL NOT BE SHOWN ON THIS DRAWING. THE OPERATION VALVE NUMBER CONTAINING THE SYSTEM DESIGNATOR FOLLOWED BY THE INSTRUMENT NUMBER (I.E., SW-11007)

This document is the property of, and contains proprietary information used by the staff through the Department of Energy Services, Kewaunee Electric Company and is loaned to you under a confidential relationship and subject to the following understanding: neither you nor your employees are permitted to publish, copy, reproduce, transmit or disseminate the information contained in this document or any information derived therefrom without the express written permission of the Department of Energy Services.

LR NOTES:

1. THE DIAPHRAGM SEAL IS PART OF THE PRESSURE INDICATOR MODULE, TYPICAL TO THIS DRAWING.

LICENSE RENEWAL DRAWING LEGEND

	35/CVC CHEMICAL & VOLUME CONTROL
	02/SW SERVICE WATER
	22/HS HEATING
	27A/MUP MAKE-UP AND DEMINERALIZED WATER
	31/CC COMPONENT COOLING
	32A/WD-LL LIQUID WASTE PROCESSING AND DISCHARGE
	51/GS MISCELLANEOUS GAS

IN SCOPE FOR LR PER 10CFR 54.4 (a) (2)
 IN SCOPE FOR LR PER 10CFR 54.4 (a) (3)

DOMINION ENERGY KEWAUNEE, INC.
 KEWAUNEE POWER STATION
 LICENSE RENEWAL DRAWING
 15 GPM BORIC ACID EVAP.
 & GAS STRIPPER

APPROVED	DRAWN	DWG. NO.	REV.
HYBRID CADD	JSW	LRXK-100-400	0

REVIEWED	SCALE	REV
		11R