



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 2100
ATLANTA, GEORGIA 30303

TIC

In Reply Refer To:

RII:JPO
54-438, 50-439
50-259, 50-260
50-296, 50-518
50-519, 50-520
50-521, 50-553
50-554, 50-327
50-328, 50-390
50-391, 50-566
50-567

SEP 26 1979

Tennessee Valley Authority
Attn: H. G. Parris
Manager of Power
500A Chestnut Street Tower II
Chattanooga, Tennessee 37401

Gentlemen:

The enclosed Information Notice provides information with regard to failures of lube oil coolers for emergency diesel generators.

Sincerely,

James P. O'Reilly
Director

Enclosures:

1. Information Notice 79-23
2. List of IR Information Notices Issued in the Last Six Months

1095 346

7910040 155

Tennessee Valley Authority

-2-

cc w/encl:
A. M. Qualls
Plant Superintendent
Post Office Box 2000
Mollywood, Alabama 35752

W. R. Bahnke, Project Manager
Post Office Box 2000
Mollywood, Alabama 35752

J. F. Cox
400 Commerce Street
W10C131 C
Knoxville, Tennessee 37902

D. L. Terrill
Project Engineer
400 Chestnut Street Tower II
Chattanooga, Tennessee 37401

H. L. Abercrombie
Plant Superintendent
Post Office Box 2000
Decatur, Alabama 35602

D. E. McCloud
Project Engineer
400 Chestnut Street Tower II
Chattanooga, Tennessee 37401

R. T. Hatchote, Project Manager
Post Office Box 2000
Hartsville, Tennessee 37074

J. E. Wills, Project Engineer
400 Chestnut Street Tower II
Chattanooga, Tennessee 37401

W. P. Keileghan, Project Manager
Post Office Box 2000
Surgoinsville, Tennessee 37873

G. G. Stack, Project Manager
Post Office Box 2000
Daisy, Tennessee 37319

cc w/encl: (Continued on Page 3)

1095 347

SEP 26 1979

Tennessee Valley Authority

-3-

cc w/encl: (Continued from Page 2)
J. H. Ballentine
Plant Superintendent
Post Office Box 2000
Daisy, Tennessee 37319

D. L. Lambert, Project Engineer
400 Chestnut Street Tower II
Chattanooga, Tennessee 37401

J. F. Groves, Plant Superintendent
Post Office Box 2000
Spring City, Tennessee 37381

T. J. Northern, Jr., Project Manager
Post Office Box 2000
Spring City, Tennessee 37381

M. H. Price, Project Manager
Post Office Box 2000
Iuka, Mississippi 38852

1095 348

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

September 26, 1979

IE Information Notice No. 79-23

EMERGENCY DIESEL GENERATOR LUBE OIL COOLERS

Within a two week time span (August 27 to September 11, 1979), the tube sheets failed in the Arkansas Nuclear One (ANO) Unit 1 lube oil coolers for both of the Unit 1 Emergency Diesel Generators. The introduction of water into the diesel lube oil system resulted in trips of both diesels during surveillance testing. The diesels were not considered capable of sustained operation.

Investigation by the licensee has indicated cracks around the outer periphery of the tube sheets. The exact failure mode has not been assessed; however, the licensee has replaced the Emergency Diesel lube oil coolers for both diesels with a cooler of different design. The original lube oil coolers had tube sheets which were one-eighth (1/8) inch in thickness and the tubes were soldered in place. Epoxy was also used as a sealer on the tube (water side) of the lube oil cooler. The new coolers have one-half (1/2) inch tube sheets and the tubes are rolled.

The ANO, Unit 1 Emergency Diesel Generators were purchased in 1970 and were manufactured by the Electromotive Division of General Motors Corporation. The lube oil coolers (Model Number D-191700) were manufactured by Young Radiator Corporation.

This information is provided as an early notification of a possible significant matter. It is expected that recipients will review the information for possible applicability to their facilities. No specific action or response is requested at this time. If further NRC evaluations so indicate, an IE Circular or Bulletin will be issued to recommend or request specific licensee actions. If you have questions regarding this matter, please contact the Director of the appropriate NRC Regional Office.

1095 347

DUPLICATE DOCUMENT

Entire document previously entered
into system under:

ANO 7908220121

No. of pages: 3