

**ATTACHMENT (2)**

---

**MARKUP OF TECHNICAL SPECIFICATION PAGES**

---

TABLE OF CONTENTS

3.5.4	Refueling Water Tank (RWT) .....	3.5.4-1
3.5.5	<del>Trisodium Phosphate (TSP)</del> .....	3.5.5-1
3.6	CONTAINMENT SYSTEMS..... <i>Sodium Tetraborate (STB)</i>	3.6.1-1
3.6.1	Containment .....	3.6.1-1
3.6.2	Containment Air Locks .....	3.6.2-1
3.6.3	Containment Isolation Valves .....	3.6.3-1
3.6.4	Containment Pressure .....	3.6.4-1
3.6.5	Containment Air Temperature .....	3.6.5-1
3.6.6	Containment Spray and Cooling Systems .....	3.6.6-1
3.6.7	Deleted	
3.6.8	Iodine Removal System (IRS) .....	3.6.8-1
3.7	PLANT SYSTEMS.....	3.7.1-1
3.7.1	Main Steam Safety Valves (MSSVs) .....	3.7.1-1
3.7.2	Main Steam Isolation Valves (MSIVs) .....	3.7.2-1
3.7.3	Auxiliary Feedwater (AFW) System .....	3.7.3-1
3.7.4	Condensate Storage Tank (CST) .....	3.7.4-1
3.7.5	Component Cooling (CC) System .....	3.7.5-1
3.7.6	Service Water (SRW) System .....	3.7.6-1
3.7.7	Saltwater (SW) System .....	3.7.7-1
3.7.8	Control Room Emergency Ventilation System (CREVS) ..	3.7.8-1
3.7.9	Control Room Emergency Temperature System (CRETS) ..	3.7.9-1
3.7.10	Emergency Core Cooling System (ECCS) Pump Room Exhaust Filtration System (PREFS) .....	3.7.10-1
3.7.11	Spent Fuel Pool Exhaust Ventilation System (SFPEVS) .....	3.7.11-1
3.7.12	Penetration Room Exhaust Ventilation System (PREVS) .....	3.7.12-1
3.7.13	Spent Fuel Pool (SFP) Water Level .....	3.7.13-1
3.7.14	Secondary Specific Activity .....	3.7.14-1
3.7.15	Main Feedwater Isolation Valves (MFIVs) .....	3.7.15-1
3.7.16	Spent Fuel Pool (SFP) Boron Concentration .....	3.7.16-1
3.7.17	Spent Fuel Pool (SFP) Storage .....	3.7.17-1
3.8	ELECTRICAL POWER SYSTEMS.....	3.8.1-1
3.8.1	AC Sources—Operating .....	3.8.1-1
3.8.2	AC Sources—Shutdown .....	3.8.2-1
3.8.3	Diesel Fuel Oil .....	3.8.3-1
3.8.4	DC Sources—Operating .....	3.8.4-1
3.8.5	DC Sources—Shutdown .....	3.8.5-1
3.8.6	Battery Cell Parameters .....	3.8.6-1

3.5 EMERGENCY CORE COOLING SYSTEM (ECCS)

3.5.5 ~~Trisodium Phosphate (TSP)~~ Sodium Tetraborate (STB)

LC0 3.5.5 The ~~TSP~~ baskets shall contain  $\geq 289.3 \text{ ft}^3$  of ~~active TSP~~.

13,750 lbm  
STB

APPLICABILITY: MODES 1, 2, 3, and 4.

ACTIONS

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>STB</p> <p>A. <del>TSP</del> not within limits.</p>	<p>A.1 Restore <del>TSP</del> to within limits.</p> <p>STB</p>	72 hours
<p>B. Required Action and associated Action Completion Time not met.</p>	<p>B.1 Be in MODE 3.</p>	6 hours
	<p><u>AND</u></p> <p>B.2 Be in MODE 5.</p>	36 hours

SURVEILLANCE REQUIREMENTS

SURVEILLANCE	FREQUENCY
<p>STB</p> <p>SR 3.5.5.1 Verify the <del>TSP</del> baskets contain <math>\geq 289.3 \text{ ft}^3</math> of granular <del>TSP dodecahydrate</del>.</p> <p>equivalent weight sodium tetraborate decahydrate</p> <p>13,750 lbm</p>	24 months
<p>STB</p> <p>SR 3.5.5.2 Verify that a sample from the <del>TSP</del> baskets provides adequate pH adjustment of water borated to be representative of a post-loss-of-coolant accident sump condition.</p>	24 months