

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA TENNESSEE 37401
5N 157B Lookout Place

DATE: January 30, 1986

WBRD-50-391/85-12

U.S. Nuclear Regulatory Commission
Region II
Attention: Dr. J. Nelson Grace, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Dear Dr. Grace:

WATTS BAR NUCLEAR PLANT UNIT 2 - HYDROGEN COLLECTOR PIPING COULD BE
OVERSTRESSED - WBRD-50-391/85-12 - SUPPLEMENTAL FINAL REPORT

The subject deficiency was initially reported to NRC OIE Inspector
D. M. Verrelli on February 14, 1985 in accordance with 10 CFR 50.55(e) as NCR
WBN MEB 8506. Our final report was submitted on March 19, 1985. A
supplemental report was submitted on April 18, 1985. The corrective
action required in our supplemental final report on February 14, 1985
has been met.

The completion of the hydrogen collector piping hanger rework has been delayed
due to the need to remove various conduits in order to do the rework.

The corrective action on this matter will be completed by unit 2 fuel load.

If there are any questions, please get in touch with R. H. Shell at
FTS 858-2688.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

R. Gridley
by *ell*

R. L. Gridley
Manager of Operations

cc: Mr. James Taylor, Director
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, D.C. 20545

Records Center
Institute of Nuclear Power Opera.
1100 Circle 75 Parkway, Suite 1500
Atlanta, Georgia 30339

8602200663 860131
PDR ADOCK 05000391
S PDR

40

EE 27