Report No.: SIR-07-132-NPS Revision No.: 1 Project No.: VY-16Q File No.: VY- 16Q-404 December 2007

Summary Report of Plant-Specific Environmental Fatigue Analyses for the Vermont Yankee Nuclear Power Station

> *Prepared for:* Entergy Nuclear Operations. Inc. *(Contract Order No. 10150394)*

Prepared by: Structural Integrity Associates, Inc. Centennial, CO

Prepared by:

T. J. Herkmann P.E.

Reviewed by:

V. L. Stevens, P.E.

T. J. **Hertmann P.E.**

Approved by:

DOCKETED USNRC

August 12, **2008** (11:00am)

OFFICE OF SECRETARY **RULEMAKINGS AND ADJUDICATIONS STAFF**

mplate telly-028

Date: 12/15/2007

Date: 12/15/2007

Date: 12/15/2007

 $DS-0.3$

REVISION CONTROL **SHEET**

Document Number: SIR-07-132-NPS

Title: Summary Report of Plant-Specific Environmental Fatigue Analyses for the Vermont Yankee Nuclear Power Station

Client: Entergy Nuclear Operations, Inc.

SI Project Number: VY-16Q

Table of Contents

SIR-07-132-NPS, Rev. 1

iii **V** *Structural Integrity Associates, Inc.*

LIST OF **TABLES**

Table Title Page

r *Structural Integrity Associates, Inc.*

1.0 INTRODUCTION

This report provides the results of plant-specific environmental fatigue calculations for the Vermont Yankee Nuclear Power Station (VYNPS). These calculations are performed to satisfy Nuclear Regulatory Commission (NRC) requirements for Entergy Nuclear Vermont Yankee's (ENVY's) License Renewal Application for VYNPS, submitted to the NRC in 2006.

Generic Safety Issue (GSI) 166 [1], later renumbered as GSI-190 [2], was identified by the NRC staff because of concerns about the effects of reactor water environments on fatigue life during the period of extended operation [3]. GSI-190 was closed in December 1999, based on a memorandum from NRC-RES to NRC-NRR [4]. Timing of issue closure required the first two license renewal applicants - Baltimore Gas & Electric Company for the Calvert Cliffs Nuclear Power Plant and Duke Energy for the Oconee Nuclear Station - to address GSI-190 in their applications prior to issue closure. Each of the applicants developed responses to the NRC staff without the benefit of information from GSI-190 closure. Subsequent license renewal applicants have had the benefit of this information that could be used to guide the resolution of the fatigue design basis and time limited aging analyses (TLAA) issues.

This report addresses VYNPS reactor water environmental effects on the fatigue life of selected fatigue-sensitive reactor coolant system (RCS) components, in accordance with the resolution of GSI- 190, as required by Chapter X, "Time Limited Aging Analyses Evaluation of Aging Management Programs Under lOCFR54.21(c)(1)(iii), Section X.Ml "Metal Fatigue of Reactor Coolant Pressure Boundary", of the Generic Aging Lessons Learned (GALL) Report [5]. Consistent with the requirements of the GALL report, the method chosen for this environmentally-assisted fatigue (EAF) evaluation is based on evaluation of the locations identified in NUREG/CR-6260 [6] and the NRC-accepted EAF relationships generated from laboratory data, as documented in References [7] and [8].

SIR-07-132-NPS, Rev. 1 1-1 **C** *Structural Integrity Associates, Inc.*

2.0 **BACKGROUND**

As a part of the NRC's Fatigue Action Plan [3], incorporation of environmental fatigue effects originally involved a reduced set of fatigue design curves, such as those proposed by Argonne National Laboratory (ANL) in NUREG/CR-5999 [9]. As a part of the effort to close GSI-166 (later GSI- 190) for operating nuclear power plants during the current 40-year licensing term, Idaho National Engineering Laboratory (INEL) evaluated fatigue-sensitive component locations at plants designed by all four U. S. nuclear steam supply system (NSSS) vendors. The ANL fatigue curves were used by INEL to recalculate the cumulative usage factors (CUFs) for fatiguesensitive component locations in early and late vintage Combustion Engineering (CE) pressurized water reactors (PWRs), early and late vintage Westinghouse PWRs, early and late vintage General Electric (GE) boiling water reactors (BWRs), and Babcock & Wilcox Company (B&W) PWRs. The results of the INEL calculations were published in NUREG/CR-6260 [6]. The **INEL** calculations took advantage of conservatisms present in governing ASME Code fatigue calculations, including the numbers of actual plant transients relative to the numbers of design-basis transients, but did not recalculate stress ranges based on actual plant transient profiles. The BWR calculations, especially the early-vintage GE BWR calculations, are directly relevant to VYNPS.

The fatigue-sensitive component locations chosen for the older-vintage GE BWR plant were: (1) the reactor vessel shell and lower head, (2) the reactor vessel feedwater nozzle, (3) the reactor recirculation piping (including the reactor inlet and outlet nozzles), (4) the core spray line reactor vessel nozzle and associated Class 1 piping, (5) the residual heat removal (RHR) return line Class 1 piping, and (6) the feedwater line Class 1 piping. For the recirculation, RHR, and feedwater piping locations, INEL performed representative design-basis fatigue calculations. This is because no CUF calculations had originally been performed since the piping systems for the selected BWR plant were initially designed and analyzed in accordance with the criteria of USAS B31.1-1967 [10].

4) Structural Integrity Associates, Inc.

The six RCS component locations described above are evaluated for EAF effects for VYNPS in this report through separate plant-specific analyses of nine VY component locations (with report section numbers indicated): the reactor pressure vessel (RPV) shell and lower head (3.1); the RPV shell at the shroud support junction (3.1) ; the feedwater nozzle (3.2) ; the recirculation / residual heat removal Class 1 piping (3.3.1 and 3.5); the recirculation inlet nozzle forging (3.3.2); the recirculation inlet nozzle safe end (3.3.2); the recirculation outlet nozzle forging (3.3.3); the core spray nozzle, safe end, and Class 1 piping (3.4); and the feedwater Class 1 piping (3.6).

The calculations reported in NUREG/CR-6260 were based on the interim reduced fatigue design curves given in NUREG/CR-5999 [9]. Such an approach penalizes the component location fatigue analysis unnecessarily, because research has shown that a combination of environmental conditions is required before reactor water environmental effects become pronounced. The strain rate must be sufficiently low and the strain range must be sufficiently high to cause continuing rupture of the passivation layer that protects the exposed surface area. Temperature, dissolved oxygen content, metal sulfur content, and water flow rate are additional variables to be considered. In order to take these parameters into consideration, EPRI and GE jointly developed a method, called the F_{en} approach [11], which permits reactor water environmental effects to be applied selectively, as justified by parameter combinations.

In 1999, the NRC staff raised a number of issues relative to the use of the EPRI/GE methodology in various industry applications. Those issues, coupled with more recent laboratory fatigue data in simulated LWR reactor water environments generated by ANL for carbon and low-alloy steels and stainless steels, resulted in a revised F_{en} methodology, as published in NUREG/CR-6583 [7] for carbon and low alloy steels, and NUREG/CR-5704 [8] for stainless steels. The methodology documented in these reports was used to evaluate environmental effects for VYNPS components, as described in Section 3.0 of this report.

SIR-07-132-NPS, Rev. 1 **2-2 1 2-2 Structural Integrity Associates, Inc.**

3.0 ENVIRONMENTAL FATIGUE CALCULATIONS

Section 2.0 identifies the locations evaluated in NUREG/CR-6260 for the older vintage GE plant, which corresponds to VYNPS. NUREG/CR-6260 provided an assessment of these six selected component locations with respect to environmental fatigue using the older reduced environmental fatigue curves. Potential reactor water environmental effects are evaluated using the updated Fen methodology on a plant-specific basis in this subsection, in order to address the associated effects on fatigue as required by the GALL Report [5].

For each of the components identified in Section 2.0, environmental fatigue calculations were performed. The details of these calculations are documented in the Reference [12, 17, 18, 21, 22 and 24] calculations. The calculations were carried out using the appropriate methodology contained in NUREG/CR-6583 for carbon/low alloy steel material, and in NUREG/CR-5704 for stainless steel material. This methodology is as follows:

Note that the above expressions have been corrected as summarized in Reference [23].

SIR-07-132-NPS, Rev. 1 3-1 **Structural Integrity Associates**, Inc.

For Types 304 and 316 Stainless Steel [8]: $F_{en} = \exp (0.935 - T^* \dot{\epsilon}^* O^*)$

where: F_{en} = fatigue life correction factor $T =$ fluid service temperature ($^{\circ}C$) T^* = 0 for $T < 200^{\circ}C$ $= 1$ for $T \ge 200$ ^oC $\dot{\epsilon}$ * $=$ 0 for strain rate, $\dot{\epsilon}$ > 0.4%/sec **=** $\ln(\frac{\varepsilon}{0.4})$ for $0.0004 \leq \frac{\varepsilon}{2} \leq 0.4\%$ /sec $=$ $\ln(0.0004/0.4)$ for $\dot{\epsilon}$ < 0.0004%/sec **0*** = 0.260 for dissolved oxygen, **DO<** 0.05 parts per million (ppm) $= 0.172$ for DO ≥ 0.05 ppm

Bounding F_{en} values are determined or, where necessary, computed for each load pair in a detailed fatigue calculation. The environmental fatigue is then determined as $U_{env} = (U)$ (F_{en}), where U is the original fatigue usage, and U_{env} is the EAF usage factor.

INFORMATION REDACTED

Since implementation of HWC in 2003, VYNPS's availability has exceeded 98.5% and the objective for future HWC system availability is a minimum of 99% [12]. With these considerations, the overall availability for HWC since implementation at VYNPS until the end of the 60-year operating period was estimated at 98.5%.

SIR-07-132-NPS, Rev. 1 3-2 **Structural Integrity Associates**, Inc.

This Page Contains Reference to Vendor Proprietary Information *(such information is marked with a "bar" in the right-hand margin)*

Some nozzles, (e.g., recirculation outlet nozzle) have three materials: a Ni-Cr-Fe dissimilar metal weld (DMW), a low alloy steel forging, and a stainless steel safe end. To ensure the maximum CUF considering environmental effects was identified, locations in both the safe end and nozzle forging were selected. This selection produces bounding environmental fatigue results for the entire nozzle assembly for the following reasons:

- The highest thermal stresses from the finite-element model (FEM) analysis occur in the stainless steel safe end. Stainless steel **Fen** multipliers at VYNPS are significantly higher than Ni-Cr-Fe multipliers (F_{en} values are 2.55 or higher for stainless steel [12] vs. a constant value of 1.49 for Ni-Cr-Fe [11]). Therefore, evaluation of the safe end bounds the Ni-Cr-Fe weld material.
- The highest pressure stresses from the FEM analysis occur in the low alloy steel nozzle forging. Low alloy steel F_{en} multipliers at VYNPS are higher than Ni-Cr-Fe multipliers (F_{en} values are 2.45 or higher for low alloy steel [12] vs. a constant value of 1.49 for Ni--Cr-Fe **[11]).** Therefore, evaluation of the nozzle forging bounds the Ni-Cr-Fe weld material.

The number of cycles for forty years was adjusted based on the number of cycles actually experienced by the plant, projected out to 60 years of operation [14]. In addition, VYNPS has implemented extended power uprate (EPU). These effects have been incorporated into the evaluations documented in this report. With the use of this information, the CUF values documented in this report are applicable for 60 years of operation.

The environmental fatigue calculations are shown in Tables 3-1 through 3-9 and summarized in Table 3-10. Component-specific details are provided in the subsections that follow.

3.1 Reactor Vessel Shell and Lower Head

The environmental fatigue calculations for the reactor vessel shell and lower head location are shown in Table 3-1. The limiting CUF value reported in the VY LRA for the RPV shell/bottom SIR-07-132-NPS, Rev. 1 3-3 **3-3 Structural Integrity** Associates, Inc.

head location corresponds to a point located on the outside surface of the RPV bottom head at the junction with the support skirt. Therefore, this location is not exposed to the reactor coolant, and EAF effects do not apply. Based on this, evaluation of the limiting location along the inside surface of the RPV bottom head was performed.

The calculations shown in Table 3-1 are for the RPV lower head at the area with the highest alternating stress, which represents the limiting RPV bottom head location [12]. Reference [*15]* is the governing stress report for this low alloy steel location. The design fatigue calculation for the limiting RPV lower head location is reproduced in Table 3-1. The effects of EPU as well as conservative cycle counts for 60 years of plant operation are incorporated in this table. The final results in Table 3-1 show an EAF adjusted CUF of 0.0809 for 60 years, which is acceptable (i.e., less than the allowable value of 1.0).

The calculations shown in Table 3-2 are for the RPV shell at the RPV shell junction to the shroud support plate, which represents the limiting RPV shell location exposed to the reactor coolant [12]. Reference [16] is the governing stress report for this low alloy steel location. The design fatigue calculation for the limiting RPV shell location is reproduced in Table 3-2, which considers the effects of EPU and conservative cycle counts were used for 60 years of plant operation. The final results in Table 3-2 show an EAF adjusted CUF of 0.7364 for 60 years, which is acceptable (i.e., less than the allowable value of 1.0).

3.2 Reactor Vessel Feedwater Nozzle

The environmental fatigue calculations for the reactor vessel feedwater nozzle location are summarized in Table 3-3. The calculations summarized in Table 3-3 show both the blend radius, which represents the limiting feedwater nozzle location, and the safe end. Reference [17] contains the governing fatigue calculation for this location. Upper RPV region chemistry was assumed for the feedwater nozzle blend radius location, since this location is exposed to the reactor water chemistry in this region, whereas feedwater line chemistry was assumed for the safe end location.

SIR-07-132-NPS, Rev. 1 3-4 **Structural Integrity** Associates, Inc.

The governing fatigue calculation for the limiting feedwater nozzle locations includes the effects of EPU and cycle counts for 60 years of operation obtained from Attachment 1 of Reference [I4]. The blend radius cumulative usage factor (CUF) from system cycling is 0.0636 for 60 years. The safe end CUF is 0.1471 for 60 years. Although the carbon steel safe end has a higher CUF prior to considering environmental effects, the environmental multiplier from Table 3-3 results in a higher CUF at the low alloy steel blend radius. For the safe end location, the EAF adjusted. CUF is 0.2560 for 60 years. For the blend radius location, EAF adjusted CUF is 0.6392 for 60 years, which is acceptable (i.e., less than the allowable value of 1.0).

3.3 Reactor Recirculation Piping (Including the Reactor Inlet and Outlet Nozzles)

Three locations were identified for the reactor recirculation piping in NUREG/CR-6260: the reactor vessel nozzle (includes both the inlet and outlet nozzles), and the recirculation piping. The evaluations for each of these components are described in the following subsections.

3.3.1 Reactor Recirculation Piping

Two locations (both stainless steel) were identified for VY for the reactor recirculation/RHR piping that correspond to the equivalent locations to those identified in NUREG/CR-6260: the RHR return tee connection to the recirculation piping, and the valve to pipe weld at the RHR isolation valve. Reference [18] contains the governing fatigue calculations for these locations. These analyses determined the limiting location to be at the RHR return tee.

The environmental fatigue calculations for the limiting recirculation/RHR piping location is summarized in Table 3-4, which includes the effects of EPU and cycle counts for 60 years of plant operation.

A review of the shutdown cooling mode of operation since the time of recirculation piping replacement in 1986 was performed by VYNPS, and the number of cycles per loop was / conservatively estimated to be'150 through Year 60 [14]. Based on this, the cycle counts for the SIR-07-132-NPS, Rev. 1 3-5 **3-5** *Structural Integrity Associates, Inc.*

Recirculation piping were reduced by a factor of 150/300 (50%) for all transients with the exception of transients that have fewer than 10 transient cycles. To ensure this cycle reduction adequately considered the potential impact on the RHR piping, the full number of transient cycles listed in Attachment 1 of Reference [14] was initially applied to the PIPESTRESS model and the highest CUF for the RHR piping was lower than the value obtained for the recirculation piping with reduced cycles.

Due to replacement of the recirculation piping, HWC conditions exist for 39% of the time, and NWC conditions exist for 61% of the time. This is based on 17.5 years of operation with NWC between March 1986 when the piping was replaced and November 2003 when HWC was implemented, and 46 years of operation from March 1986 to the end of the period of extended operation in March 2032. Using the bounding EAF multipliers (8.36 for HWC and 15.35 for NWC) [12], the overall multiplier is 12.62. Applying this to the 60-Year CUF of 0.0590 results in a total environmentally assisted CUF of 0.7446.

3.3.2 Reactor Recirculation Inlet Nozzle

References *[15,* 19 and 20] are the applicable stress reports for this location. An evaluation was. performed for both the inlet nozzle forging (low alloy steel) and the safe end (stainless steel).

The environmental fatigue calculations for the recirculation inlet nozzle forging location are shown in Table 3-5. The governing fatigue calculation for the recirculation inlet nozzle location is reproduced in Table 3-5 [12], which includes the effects of EPU and cycle counts for **60** years of plant operation from Attachment 1 of Reference [14]. The final results show an EAF adjusted CUF of 0.5034 for 60 years, which is acceptable (i.e., less than the allowable value of 1.0).

The environmental fatigue calculations for the recirculation inlet nozzle safe end location are shown in Table 3-6. The governing fatigue calculation for the recirculation inlet nozzle location is reproduced in Table 3-6 [12], which includes the effects of EPU and cycle counts for 60 years

SIR-07-132-NPS, Rev. 1 3-6

William *Structural Integrity Associates, Inc.*

of plant operation from Attachment 1 of Reference [14]. The final results show an EAF adjusted CUF of 0.0199 for 60 years, which is acceptable (i.e., less than the allowable value of 1.0).

3.3.3 Reactor Recirculation Outlet Nozzle

The recirculation outlet nozzle was evaluated for environmental fatigue effects. Reference [24] is the fatigue calculation for this location. An evaluation was performed for both the outlet nozzle safe end (stainless steel) and the nozzle inner corner blend radius (low alloy steel). The results for the limiting nozzle forging location are reported here.

The environmental fatigue calculations for the limiting recirculation outlet nozzle forging blend radius location are shown in Table 3-7 [24], which includes the effects of EPU and cycle counts for 60 years of plant operation from Attachment 1 of Reference [14]. The final results in Table 3-7 show an EAF adjusted CUF of 0.0836 for 6Q years, which is acceptable (i.e., less than the allowable value of 1.0).

3.4 Core Spray Line Reactor Vessel Nozzle and Associated Class 1 Piping

Locations that were evaluated in NUREG/CR-6260 included the reactor vessel nozzle blend radius (low alloy steel), the reactor vessel nozzle safe end (Alloy 600) and the core spray piping (stainless steel).

Reference [21] is the applicable fatigue calculation for these locations, which shows the nozzle limiting location to be the blend radius. The design fatigue calculations for the limiting location at the core spray nozzle, safe end, and piping are summarized in Table 3-8 [21], which include the effects of EPU and cycle counts for 60 years of plant operation from Attachment 1 of Reference [14]. The cumulative fatigue usage, prior to considering environmental effects for the blend radius, is 0.0166. Factoring in the environmental multiplier from Table 3-8 [12], the EAF adjusted CUF is 0.1668 for 60 years, which is acceptable (i.e., less than the. allowable value of 1.0).

SIR-07-132-NPS, Rev. 1 **3-7** *Structural* Integrity *Associates, Inc.*

3.5 RHR Return Line Class **1** Piping

The environmental fatigue calculations for the RHR return line Class 1 piping are covered by the calculations in Subsection 3.3.1 above.

3.6 Feedwater Line Class **1** Piping

The environmental fatigue calculation for the limiting feedwater Class 1 piping location (carbon steel) is summarized in Table 3-9. The calculations shown in Table 3-9 are for the limiting feedwater Class 1 piping location. Per Reference [22], the limiting total fatigue usage for the analyzed feedwater/high pressure coolant injection (HPCI) piping system occurs on the riser to the RPV feedwater nozzle N4B. The limiting fatigue usage value for the feedwater Class 1 piping location is 0.1661, which includes the effects of EPU and cycle counts for 60 years of plant operation from Attachment 1 of Reference [14]. The final results in Table 3-9 show the EAF adjusted CUF of 0.2890 for 60 years, which is acceptable (i.e., less than the allowable value of 1.0).

3.7 Summary of Results

The results of the calculations contained in Tables 3-1 through 3-9 are summarized in Table 3-10.

It is noteworthy that the CUF results presented in this section include uniformly applied environmental effects without consideration of threshold criteria that might indicate an absence of conditions that would lead to environmental fatigue effects. Furthermore, conservative values were applied for temperature, strain rate and metal sulfur content in calculating environmental multipliers. Therefore, the environmental adjustments to the CUF results are considered to be conservative.

 \bar{C} Structural Integrity Associates, Inc.

Table 3-1. Environmental Fatigue Evaluation for the Reactor Vessel Shell

Component: RPV Shell/Bottom Head
R-6260 CUF: 0.032 (for reference only) NUREG/CR-6260 CUF: 0.032 *(for reference only)* Reference: NUREG/CR-6260, p. 5-102
Report CUF: 0.0057 (for Point 14, Stress Report CUF: 0.0057 (for *Point 14,* see *below)* Material: Low Alloy Steel *(Material = A-533* Gr B)

Design Basis CUF Calculation for 40 years: $E_{\text{fatigue curve}}/E_{\text{analysis}} =$ Power Uprate = K, *=* m *=* $n=$ $S_m =$ 1.149 1.0067 1.000 2.0 0.2 26,700 *Conservatively used minimum E of 26.1 from Section* S2 *Appendix of RPV Stress Report.* =(549 - *100)* 1(546 - *100)* per *4.4.* l.b *of 26A6019,* Rev. **I** *stress concentration factor NB-3228.5 of ASME* Code, *Section Il/ NB-3228.5 of ASME Code, Section III* psi *(ASME* Code, *Section II, Part* 0) PL+PB+Q(see *Note I) K, (see Note* 2) Salt (see *Note 3)* n (see Note *4)* N (see Note *5)* **U** 44,526 1.00 25,762 200 35,300 0.0057 **I** Total, **U40** *=* 0.0057 Notes: **1.** P_L + P_B +Q is obtained for Point 14 from p. A52 of VYC-378, Rev. 0.

2. K. computed in accordance with NB-3228.5 of ASME Code, Section I11.

3. S_{alt} = 0.5 * K_e * K_t * E_{latique curve/E_{analysis} * Power Uprate * (P_L+P_B+Q).
4. n for 40 years is the number of Heatup-Cooldown cycles, per p. B8 of VYC-378, Rev. 0.}

5. *N obtained fnrm Figure* **1-9.1** *of Appendix i of ASME Code, Section I111*

6. n for 60 years is the projected number of Heatup-Cooldown cycles.

Revised CUF Calculation for 60 Years:

Environmental CUF Calculation for 60 Years:

 \mathbb{R}^2

SIR-07-132-NPS, Rev. 1 **3-9**

C *Structural Integrity Associates, Inc.*

Table 3-2. Environmental Fatigue Evaluation for the Reactor Vessel Shell at

Shroud Support

n. P_L +P_B +Q is computed for Point 9 based on the $[(H_H - H_t)_{E$ ₂₀₀ $t + (H_H - H_t)_{E$ ₂₀₀ $t + (H_H - H_t)_{E}$ and *I* stress intensity.

2. K. computed in accordance with NB-3228.5 of *ASME* Code, *Section* ttt

 $3.$ $S_{\text{alt}} = 0.5$ $^{*}K_{\text{e}}$ $^{*}E_{\text{fating}}$ *curve* $/E_{\text{analysis}}$ $^{*}Power$ Uprate $^{*}I$ $(K, H_H - H_r)$ $_{Event}$ * $(K, H_H - H_r)$ $_{Event2}$ I .

4. *n* for *40 years is the number of cycles as follows per p.* S3-99e *and S3-99f of the RPV* Stress *Report:*

Revised **CUF** Calculation for 60 Years:

Environmental CUF Calculation for 60 Years:

Maximum $F_{en\text{-HWC}}$ Multiplier for HWC Conditions = 5.39

Maximum F_{en-NWC} Multiplier for NWC Conditions = 13.17

 \sim

U **...-6 0** = **U⁶ 0** x *Fn.sewc* X **0.53 + U60** X Fn.Hewc X 0.47 = 0.7364 Overall Multiplier = $U_{env-60}/U_{60} =$ 9.51

SIR-07-132-NPS, Rev. 1 **3-10**

V *Structural* Integrity *Associates, Inc.*

 $\ddot{}$

Table 3-3. Environmental Fatigue Evaluation for the Reactor Vessel Feedwater Nozzle Forging Blend Radius

Notes: 1. An Fen Multiplier was used for each respective component with the following conditions: + 47% HWC conditions and 53% NWC conditions

2. Results using updated ASME Code fatigue calculations and actual cycles accumulated to-date and projected to 60 years.

SIR-07-132-NPS, Rev. 1 3-11 **Structural Integrity Associates**, Inc.

Table 3-4. Environmental Fatigue Evaluation for the Recirculation/RHR Piping Tee

Notes: $1.$ An F_{en} multiplier was used for each respective component with the following conditions:

+ 39% HWC conditions and 61% NWC conditions

2. Results using updated ASME Code fatigue calculations and actual cycles accumulated to-date and projected to 60 years.

SIR-07-132-NPS, Rev. 1 3-12

AV Structural Integrity Associates, Inc.

Table 3-5. Environmental Fatigue Evaluation for the Reactor Recirculation Inlet Nozzle Forging

Component: Recirculation Inlet Nozzle Forging
R-6260 CUF: 0.310 (for referent NUREG/CR-6260 CUF: 0.310 *(for reference only)* Reference: NUREG/CR-6260, p. 5-105 Stress Report CUF: 0.0433 *(updated for Point 12,* see *below)* Material: Low Alloy Steel *(Material = A-508 Cl. I/ per p. I-S8-4 of CBON Stress Report Section* **S8)** Design Basis **CUF** Calculation for 40 years: $E_{\text{fatigue curve}}/E_{\text{analysis}} = 1.1278$ *= 30.0/26.6 (per p. I-S8-24 of CBIN Stress Report Section S8 and ASME Code fatigue curve)* $\ddot{}$ Power Uprate = 1.0067
 $K_t = 1.660$ *1(549-* t00)/((546- *100) per 4.4.l.b of 26A6019, Rev.* **I** 1.660 *stress concentration factor (p. A270 of VYC-378, Rev. 0)* $m = 2.0$ *NB-3228.5 of ASME Code, Section Ili* $n = 0.2$ NS-3228.5 *of ASME Code, Section IfI* $S_m = 26,700$ psi *(ASME Code, Section It, Part D)* - PL+PB+Q *(see Note 1)* Skin Stress (see *Note 2)* K, *(see Note* **3)** Saet (see *Note 4)* n (see *Note* **5)** N (see *Note 6)* U 43,110 15,145 1.00 49,224 200 4,614 0.0433 $Total, U_{40} = 0.0433$ *Notes: 1.* P_L + P_B +Q is obtained for Point 12 from p. A270 of VYC-378, Rev. 0. *2. Skin Stress is obtained for Point 12 from p. A270 of VYC-378. Rev. 0. 3. K, computed in accordance with NB-3228.5 of ASME Code. Section* lIt. *4.* S_{ab} = 0.5 * K_a * E_{halyob} $_{cuvb}$ / $E_{analysis}$ * Power Uprate * $[(P_L + P_B + Q) K_t +$ Skin Stress]. 5. *n for 40 years is the number of Heatup-Cooldown cycles, per p. B28 of VYC-378, Rev.* **0.** *6. N obtained from Figure* 1-9.1 *of Appendix / of ASME Code, Section bl.* 7. *n for 60 years is the projected number of Heatup-Coo/down cycles.* • Revised **CUF** Calculation for 60 Years: PL+PB+Q (see *Note 1)* Skin Stress *(see Note 2)* Ke *(see Note* **3)** Salt (see *Note 4)* n *(see Note 5)* N *(see Note 7)* U 43,110 15,145 1.00 49,224 300 4,614 0.0650 $Total, U_{60} = 0.0650$ Environmental CUF Calculation for 60 Years: Maximum F_{en-HWC} Multiplier for HWC Conditions = 2.45 Maximum F_{en-NWC} Multiplier for NWC Conditions = 12.43 **Unv60 = Ueo** x **Fa,.NWC X 0.53 + U6o** x FnHwc X 0.47 **=** 0.5034 Overall Multiplier = $U_{\text{env-60}}/U_{\text{60}} = 7.74$

SIR-07-132-NPS, Rev. 1 **3-13**

V *Structural Integrity Associates, Inc.*

Table 3-6. Environmental Fatigue Evaluation for Reactor Recirculation Inlet Nozzle Safe End

SIR-07-132-NPS, Rev. 1 3-14

C *Structural Integrity Associates, Inc.*

Table 3-7. Environmental Fatigue Evaluation for Recirculation Outlet Nozzle Forging

Notes: 1. An F_{en} multiplier was used for each respective component with the following conditions:

+ 47% HWC conditions and 53% NWC conditions

2. Results using updated ASME Code fatigue calculations and actual cycles accumulated to-date and projected to 60 years.

SIR-07-132-NPS, Rev. 1 **3-15**

1 *Structural Integrity Associates, Inc.*

Table 3-8. Environmental Fatigue Evaluation for Core Spray Reactor Vessel Nozzle Forging Blend Radius, Safe End, and Piping

Notes: 1. An Fen Multiplier was used for each respective component with the following conditions: + 47% HWC conditions and 53% NWC conditions

2. Results using updated ASME Code fatigue calculations and actual cycles accumulated to-date and projected to 60 years.

SIR-07-132-NPS, Rev. 1 3-16 **Structural Integrity** Associates, Inc.

Table 3-9. Environmental Fatigue Evaluation for the Feedwater Line Class 1 Piping

Notes: 1. An F_{en}multiplier was used for each respective component with the following conditions:

+ 47% HWC conditions and 53% NWC conditions

2. Results using updated ASME Code fatigue calculations and actual cycles accumulated to-date and projected to 60 years.

SIR-07-132-NPS, Rev. 1 **3-17**

Structural Integrity Associates, Inc.

Table 3-10. Summary of Environmental Fatigue Calculations for VYNPS

Notes: 1. Updated 40-year **CUF** calculation based on recent ASME Code methodology and design basis cycles.

2. **CUF** results using updated ASME Code methodology and actual cycles accumulated to-date and projected to 60 years.

3. An F_{en} multiplier was used for each respective component with the following conditions:

+ 47% HWC conditions and 53% NWC conditions

4. 40 year values were not calculated for these locations

5. Only the highest **CUF** from Table 3-8 is shown

V Structural Integrity Associates, Inc.

4.0 SUMMARY **AND CONCLUSIONS**

i

The results of Tables 3-1 through 3-9, as summarized in Table 3-10, demonstrate that the fatigue usage factor, including environmental effects, remains within the allowable value of 1.0 for 60 years of operation for the following component locations:

- **V-**Reactor vessel shell, bottom head and shroud support
- **Vt-**Reactor vessel feedwater nozzle
- **V/** Reactor recirculation piping (including the reactor inlet and outlet nozzles)
- **V** Core spray line reactor vessel nozzle and associated Class 1 piping
- **Vt-**Feedwater line Class 1 piping

Therefore, the environmental fatigue assessment results for all of the NUREG/CR-6260 locations associated with the older vintage BWR plant are acceptable for 60 years of operation for VYNPS.

SIR-07-132-NPS, Rev. 1 4-1

Structural Integrity Associates, Inc.

5.0 REFERENCES

- 1. U. S. Nuclear Regulatory Commission, Generic Safety Issue 166, "Adequacy of Fatigue Life of Metal Components."
- 2. U. S. Nuclear Regulatory Commission, Generic Safety Issue 190, "Fatigue Evaluation of Metal Components for 60-Year Plant Life."
- 3. SECY-95-245, "Completion of the Fatigue Action Plan," James M. Taylor, Executive Director for Operations, U. S. Nuclear Regulatory Commission, Washington, DC, September 25, 1995.
- 4. Memorandum, Ashok C. Thadani, Director, Office of Nuclear Regulatory Research, to William D. Travers, Executive Director for Operations, Closeout of Generic Safety Issue 190, "Fatigue Evaluation of Metal Components for 60 Year Plant Life," U. S. Nuclear Regulatory Commission, Washington, DC, December 26, 1999.
- 5. NUREG-1801, Revision 1, "Generic Aging Lessons Learned (GALL) Report," U.S. Nuclear Regulatory Commission, September 2005.
- 6. NUREG/CR-6260 (INEL-95/0045), "Application of NUREG/CR-5999 Interim Fatigue Curves to Selected Nuclear Power Plant Components," March 1995.
- 7. NUREG/CR-6583 (ANL-97/18), "Effects of LWR Coolant Environments on Fatigue Design Curves of Carbon and Low-Alloy Steels," March 1998.
- 8. NUREG/CR-5704 (ANL-98/31), "Effects of LWR Coolant Environments on Fatigue Design Curves of Austenitic Stainless Steels," April 1999.
- 9. NUREG/CR-5999 (ANL-93/3), "Interim Fatigue Design Curves for Carbon, Low-Alloy, and Austenitic Stainless Steels in LWR Environments," April 1993.
- 10. USAS B31.1 1967, USA Standard Code for Pressure Piping, "Power Piping," American Society of Mechanical Engineers, New York.
- 11. EPRI Report No. TR-105759, "An Environmental Factor Approach to Account for Reactor Water Effects in Light Water Reactor Pressure Vessel and Piping Fatigue Evaluations," December 1995.
- 12. Structural Integrity Associates Calculation No. VY-16Q-303, Revision 0, " Environmental Fatigue Evaluation of Reactor Recirculation Inlet Nozzle and Vessel Shell/Bottom Head."

 $SIR-07-132-NPS, Rev. 1$ 5-1

 \sum *Structural Integrity Associates, Inc.*

13. INFORMATION REDACTED

- 14. Entergy Design Input Record (DIR) Rev. 1, EC No. 1773, Rev. 0, "Environmental Fatigue Analysis for Vermont Yankee Nuclear Power Station," 7/26/07, SI File No. VY-16Q-209.
- *15.* VY Calculation No. VYC-378, Revision 0, "Vermont Yankee Reactor Cyclic Limits for Transient Events," 10/16/85, SI File No. VY-05Q-21 1.
- 16. Chicago Bridge & Iron RPV Stress Report, Section **S3,** Revision 4, "Stress Analysis, Shroud Support, Vermont Yankee Reactor Vessel, CB&I Contract 9-6201," 2/3/70, SI File No. VY-16Q-203.
- 17. Structural Integrity Associates Calculation No. VY-16Q-302, Revision 0, "Fatigue Analysis of Feedwater Nozzle."
- 18. Structural Integrity Associates Calculation No. VY-16Q-307, Revision 0, "Recirculation Class 1 Piping Fatigue and EAF Analysis."
- 19. CB&I RPV Stress Report, Section **S8,** Revision 4, "Stress Analysis, Recirculation Inlet Nozzle, Vermont Yankee Reactor Vessel, CB&I Contract 9-6201," 2/3/70, SI File No. VY-16Q-203.
- 20. GE Nuclear Energy Certified Stress Report No. 23A4292, Revision 0, "Reactor Vessel Recirculation Inlet Safe End Nozzle," January 21, 1985, SI File No. VY-16Q-203.
- 21. Structural Integrity Associates Calculation No. VY- 16Q-310, Revision 1, "Fatigue Analysis of Core Spray Nozzle."
- 22. Structural Integrity Associates Calculation No. VY-16Q-311, Revision 0, "Feedwater Class 1 Piping Fatigue Analysis."
- 23. EPRI/BWRVIP Memo. No. 2005-271, "Potential Error in Existing Fatigue Reactor Water Environmental Effects Analyses," July 1, 2005
- 24. Structural Integrity Associates Calculation No. VY-16Q-306, Revision 0, "Fatigue Analysis of Recirculation Outlet Nozzle."

SIR-07-132-NPS, Rev. **1 5-2** *Structural Integrity Associates, Inc.*

This Page Contains Reference to Vendor Proprietary Information *(such information is marked with a "bar" in the right-hand margin)*