PMHarrisCOL PEmails

From: Tanya Simms
Sent: Wednesday, September 10, 2008 2:52 PM
To: 'robert.kitchen@pgnmail.com'; 'david.waters@pgnmail.com'; 'tillie.wilkins@pgnmail.com'
Cc: Manny Comar; PMHarrisCOL PEmails
Subject: Draft RAI 1235 Related SRP Section 7.5 for Harris Units 2 and 3
Attachments: Harris draft RAI 1235.pdf

To All,

Attached is Draft RAI 1235 related to SRP Section 7.5 for Harris Units 2 and 3. If no response is heard by close of business September 15, 2008, the final RAI will be issued.

Tanya Simms
Project Manager
New Reactor Licensing
U.S. Nuclear Regulatory Commission
11555 Rockville Pike
Rockville, Maryland 20852-2738
301-415-1387
tanya.simms@nrc.gov

Hearing Identifier: ShearonHarris_COL_Public
Email Number: 62

Mail Envelope Properties (C4A4C9A16294FB4CBA5A36312D05FFAC0ABBC7F80B)

Subject: Draft RAI 1235 Related SRP Section 7.5 for Harris Units 2 and 3
Sent Date: 9/10/2008 2:51:47 PM
Received Date: 9/10/2008 2:51:49 PM
From: Tanya Simms

Created By: Tanya.Simms@nrc.gov

Recipients:
"Manny Comar" <Manny.Comar@nrc.gov>
Tracking Status: None
"PMHarrisCOL PEmails" <PMHarrisCOL.PEmails@nrc.gov>
Tracking Status: None
"'robert.kitchen@pgnmail.com'" <robert.kitchen@pgnmail.com>
Tracking Status: None
"'david.waters@pgnmail.com'" <david.waters@pgnmail.com>
Tracking Status: None
"'tillie.wilkins@pgnmail.com'" <tillie.wilkins@pgnmail.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	**Size**	**Date & Time**
MESSAGE	457	9/10/2008 2:51:49 PM
Harris draft RAI 1235.pdf	14254	

Options
Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 1235 Revision 0
Shearon Harris
Progress Energy Carolinas, Inc.
Docket No. 52-022 and 52-023
SRP Section: 07.05 - Information Systems Important to Safety
Application Section: Chapter 7.5

QUESTION from Instrumentation, Controls and Electrical Engineering 1 (ICE1)

07.05-***

Tables 7.5-1 and 7.5-8 of the AP1000 Design Control Document (DCD), Revision 16, Post-Accident Monitoring System, contain variables to monitor the meteorological parameters and environs radiation and radioactivity. These variables are defined as site specific. Define these variables in compliance with Regulatory Guide 1.97, Revision 3, as committed to in the combined license application, or justify an alternative approach.

Table 7.5-1 (Sheet 12 of 12) of the AP1000 DCD, Revision 16, identifies meteorological parameters as site specific. Additionally, Table 7.5-8 of the AP1000 DCD identifies "meteorology" and "boundary environs radiation and radioactivity" as site specific variables. However, the staff has not found where the combined license application addresses the parameters/variables. Explain where these variables are found.