

## 18.0 LOADING COMBINATION:

18.1. WEIGHT ( $\frac{1}{2}$  HORIZONTAL HOSE)

SOCKET ADAPTOR = .477 LB

FERRULE = .057 LB

HOSE & BRAIDS  $(1.133 + .638) \cdot 5 = .885$  LBFLUID IN HOSE  $(.727) \cdot 5 = .364$  LB

---

 $\frac{1}{2}$  DEAD WEIGHT = 1.783 LB

## 18.2. ACCIDENT FORCE:

## 18.2.1. DUE TO INERTIA:

$$F = W \times g$$

$$(a) F_x = (\text{HORIZ. HOSE} + \text{FITTINGS} + \frac{1}{2} \text{ VERT. HOSE}) \times g^*$$

$$= [(1.783 + 1.249) + .30 + \frac{1}{2} (2.37)] \times (8.6 \cos 30^\circ)$$

$$= 4.517 \quad (7.44')$$

$$= 33.6 \text{ LB}$$

REF. PARA 18.1, 17.12.4.

$$(b) F_z = (\frac{1}{2} \text{ HORIZ. HOSE}) \times g^*$$

$$= (1.783) \times (8.6 \sin 30^\circ)$$

$$= 7.66 \text{ LB}$$

$$(c) F_y = (1.783) (1.24) = 2.21 \text{ LB}$$

\* NOTE: AT ELEVATION 754 FT. AZIMUTH 300 DEG.  
"g" PEAK VALUE (ACCIDENT RESPONSE CONDITION)





### 18.5. VIBRATION FORCES

#### 18.5.1. DUE TO INERTIA

$$F = W \times g$$

$$(a) F_x = (\text{HORIZ. HOSE} + \text{FITTINGS} + \frac{1}{2} \text{VERT. HOSE}) \times g$$

$$= 4.517 (.5g's)$$

$$= 2.258 \text{ LB}$$

$$(b) F_y = F_z = 2.011 (.5g's)$$

$$= 1.005 \text{ LB}$$

### 18.6. TOTAL FORCE

#### 18.6.1. IN X-DIRECTION

$$F_x = \text{ACCIDENT AND SEISMIC FORCE DUE TO INERTIA \& MOVEMENT) + VIBRATION}$$

$$= (33.6 + 42.24 + 4.8) + 2.258$$

$$= 82.89 \text{ LB}$$

SPECIFICATION ALLOWABLE

$$P_x = .01 G_y A$$

$$= .01 (30,000) [.7854 (1.315^2 - 1.049^2)]$$

$$= 148.16 \text{ LB}$$

$$P_x > F_x$$

DESIGN IS ADEQUATE

METAL *Rollins* CORPORATION

20677 KNAPP STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER

J. Shen

REFERENCE NUMBER

CR 683

PH-77754

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

106

### 18.6.2. IN Y-DIRECTION:

$$F_y = \text{INSTALLATION MISALIGNMENT FORCE} + \\ \text{ACCIDENT \& SEISMIC FORCE DUE TO MOVEMENT} \\ + \text{VIBRATION}$$

$$= 2.84 + (2.21 + 1.1 + 1.84) + 1.005$$

$$= 8.995 \text{ LBS}$$

REF. PARA 16.11.3, 18.4.2

SPECIFICATION ALLOWABLE

$$P_y = .016yA$$

$$= 148.16 \text{ LB}$$

$$P_y > F_y$$

DESIGN IS ADEQUATE

### 18.6.3. IN Z-DIRECTION

$$F_z = \text{DEAD WEIGHT} + (\text{ACCIDENT AND SEISMIC FORCE} \\ \text{DUE TO INERTIA \& MOVEMENT}) + \text{VIBRATION}$$

$$= 1.783 + (7.66 + 9.62 + 4.21) + 1.005$$

$$= 24.278 \text{ LB}$$

REF. PARA 18.0.18.2.1.(b)

SPECIFICATION ALLOWABLE 18.3.1(b), 18.4.3.18.5.L(b)

$$P_z = .016yA$$

$$= 148.16 \text{ LB}$$

$$P_z > F_z$$

DESIGN IS ADEQUATE

## 18.7. DYNAMIC MOMENT

## MOMENT ARMS:

$$\text{SOCKET ADAPTORS } .477 \text{ LB} \times .695 \text{ IN} = .33 \text{ IN-LB}$$

$$\text{FERRULE } .057 \text{ LB} \times 2.015 \text{ IN} = .115 \text{ IN-LB}$$

$$\text{HOSE \& BRAIDS } .885 \text{ LB} \times 6.296 \text{ IN} = 5.57 \text{ IN-LB}$$

$$\text{FLUID IN HOSE } .364 \text{ LB} \times 1.39 \text{ IN} = .505 \text{ IN-LB}$$

---


$$\text{TOTAL} = 6.52 \text{ IN-LB}$$

## 18.7.1. ACCIDENT MOMENT:

## 18.7.1.1. DUE TO INERTIA:

$$\begin{aligned} \text{(a) } M_z &= 6.52 (8.6 \sin 30^\circ) \\ &= 28.03 \text{ IN-LB} \end{aligned}$$

REF. PARA. 18.7.

$$\text{(b) } M_y = 6.52 (1.24) = 8.804 \text{ IN-LB}$$

## 18.7.2. SEISMIC MOMENT (SSE)

## 18.7.2.1. DUE TO INERTIA:

$$\begin{aligned} \text{(a) } M_z &= 6.52 (10.8 \sin 30^\circ) \\ &= 35.208 \text{ IN-LB} \end{aligned}$$

PARA. 18.7.

$$\text{(b) } M_y = 6.52 (1.62) = 4.042 \text{ IN-LB}$$

## 18.7.3. MOMENT AT SOCKET ADAPTOR

HOSE FORCE  $\times$  L (HOSE END TO SOCKET ADAPTOR)

$$18.7.3.1. M_y = F_y (L)$$

$$= 1.84 (1.39)$$

$$= 2.557 \text{ IN-LB}$$

REF. PARA. 18.4.2.

METAL *Roller* CORPORATION

20877 KNAPP STREET  
CHATEWORTH, CALIFORNIA 91311

ENGINEER

J. Jhon

REFERENCE NUMBER

CR 683

PIN-77714

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

108

$$\begin{aligned} 18.7.3.2. \quad M_z &= F_z (L) \\ &= 4.21 (1.39) \\ &= 5.85 \text{ IN-LB} \end{aligned}$$

REF. PARA. 18.4.3.

### 18.7.4. TOTAL MOMENT

#### 18.7.4.1. IN Y-DIRECTION

$M_y$  = TOTAL DEFLECTION MOMENT (INCL. INSTALLATION & SEISMIC & ACCIDENT DUE TO MOVEMENT & INERTIA

$$= [ 83.69 + (2.84) (1.39) + 1.0 ] + 8.804 + 9.042$$

$$= 109.76 \text{ IN-LB} \quad \begin{array}{l} * \text{ ADDITIONAL DEFLECTION} \\ \text{MOMENT DUE TO SEISMIC} \end{array}$$

REF. PARA 16.11.4, 16.11.3

SPECIFICATION ALLOWABLE 16.7.3.1.

$$M_{by} = .0707 G_y Z$$

$$= .0707 (30,000) (.133)$$

$$= 282.09 \text{ IN-LB}$$

$$M_{by} > M_y$$

DESIGN IS ADEQUATE

WHERE

$$Z = \frac{I}{c}$$

$$= .098 \frac{D^4 - d^4}{D}$$

$$= .098 \frac{1.315^4 - 1.049^4}{1.315}$$

$$= .133$$

18.7.4.2. IN  $\delta$ -DIRECTION

$$M_{\delta} = \text{DEAD WEIGHT} + \text{SEISMIC AND ACCIDENT DUE TO INERTIA \& MOVEMENT}$$

$$= 6.52 + [28.03 + 35.208 + (\text{DEFLECTION MOMENT} + \text{MOMENT AT SOCKET ADAPTOR})]$$

$$= 6.52 + [28.03 + 35.208 + (123.93 + 5.85)]$$

$$= 199.538 \text{ IN-LB}$$

REF. PARA. 18.7. 18.7. 1.1.  
 18.7.2.1. 18.7. 3.2.

DEFLECTION MOMENT IN  $\delta$ -DIRECTION

$$F = (K_{\delta}) \delta$$

$$= (5.54') (1.76)$$

$$= 4.21 \text{ LB}$$

$f^k$  = LENGTH RATIOS

REF. 16.11.2.15.1.15.1.1.

$$M = (F) (L) (F/2) / 2$$

$$= (4.21) (19.625) (3.0) / 2$$

$$= 123.93 \text{ IN-LB}$$

SPECIFICATION ALLOWABLE

$$M_{\delta} = .0707 \delta$$

$$= 282.09 \text{ IN-LB}$$

$$M_{\delta} > M_{\delta}$$

DESIGN IS ADEQUATE

METAL *Elbow* CORPORATION

2017 KNAPP STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER

F. J. JEN

REFERENCE NUMBER

CR 683 P/N-77754

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

110

### 18.8. TORSIONAL MOMENT

$$M_x = F_y (L)$$

$$= [f^* y K_o] (L)$$

$$= [(1.487) (.65) (6.99)] (1.5)$$

$$= 3.08 \text{ (IN-LB)}$$

L = ELBOW RADIUS

= 1.5 IN.

f\* = LENGTH RATIO

REF. 15.1.1, 15.1, 17.11.2

### SPECIFICATION ALLOWABLE

$$M_{ex} = .1 \frac{6yJ}{R_o}$$

$$= .1 \frac{(30,000) .174}{1.315 / 2}$$

$$= 794 \text{ IN-LB}$$

$$J = \frac{\pi}{32} (d_o^4 - d_i^4)$$

$$= \frac{\pi}{32} (1.315^4 - 1.049^4)$$

$$= .174$$

$$M_{ex} > M_x$$

DESIGN IS ADEQUATE

19.0 MOTION AT CENTER DUE TO RESPONSE FROM  
 ACCIDENT & SEISMIC CONDITION:

19.0.1. UNDER ACCIDENT CONDITION:

19.0.1.1. ASSUMPTIONS

A. SEISMIC INPUT OF  $\sqrt{(8.6 \sin 30^\circ)^2 + 1.24^2}$

B. AMPLIFICATION FACTOR IS DERIVED FROM  
 RESULTS OF TEST DATA AND IS CONSIDERED  
 CONSERVATIVE.

FREQUENCY <sup>*</sup>	INPUT	AMPLIFICATION	OUTPUT	DISPLACEMENT	EXCURSION
HZ	g		g	INCHES	INCHES
30.5	4.475	4	17.9	.376	± .188

19.0.1.2.

EQUIVALENT AXIAL MOTION

$$e = \frac{3 D_p \Delta}{(.5 N) (1.5 L)}$$

$$= \frac{3 (1.145) (\pm .188)}{(76) (19.812)} = \pm .00086$$

$$S_5 = \frac{E_b t_p^2 e}{2 W^3 C_f}$$

$$= \frac{(29 \times 10^6) (0.019)^2 (\pm .00086)}{2 (.165)^3 (1.50)} = \pm 668 \text{ PSI}$$

$$S_6 = \frac{5 E_b t_p e}{3 W^2 C_d}$$

$$= \frac{5 (29 \times 10^6) (0.019) (\pm .00086)}{3 (.165)^2 (1.56)} = \pm 18595 \text{ PSI}$$

\* NOTE: IT IS WORST frequency. SEE 16.12.6 PAGE 83



## 14.0.2. UNDER SEISMIC CONDITION

## 19.0.2.1 ASSUMPTIONS

A. SEISMIC INPUT OF  $\sqrt{(10.8 \sin 30)^2 + (6.2)^2}$ 

<u>FREQUENCY</u>	<u>INPUT</u>	<u>AMPLIFICATION</u>	<u>OUTPUT</u>	<u>DISPLACEMENT</u>	<u>EXCUR.</u>
Hz	g		g	IN.	IN.
30.5	5.435	4	21.74	.457	±.228

## 19.0.2.2.

EQUIVALENT AXIAL MOTION

$$e = \frac{3 D_p \Delta}{(1.5N)(1.5L)}$$

$$= \frac{3 (1.145)(2.228)}{(76)(19.812)} = \pm .000104$$

$$S_5 = \frac{E_b t_p^2 e}{2 W^3 C_f}$$

$$= \frac{(29 \times 10^6)(.019)^2}{2(1.165)^3(1.50)} (\pm .000104) = \pm 807 \text{ PSI}$$

$$S_6 = \frac{5 E_b t_p e}{3 W^3 C_f}$$

$$= \frac{5(29 \times 10^6)(.019)}{3(1.165)^3(1.56)} (\pm .000104) = \pm 22487 \text{ PSI}$$



METAL *Palms* CORPORATION  
28877 KNAPP STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER

F. J. Kim

REFERENCE NUMBER

CR 683

P/N 77714

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

113

19.0.3. CYCLE LIFE (ACCIDENT + SSE)

$$S_T = .7(S_3 + S_4) + (S_5 + S_6) \text{ ACCIDENT} + (S_7 + S_8) \text{ SSE}$$

$$= .7(4570 + 29424) + (1336 + 37190) + (1614 + 44974)$$

$$= 108909 \text{ PSI}$$

$$N_c = \left( \frac{186000}{S_T - 54000} \right)^{3.4}$$

$$N_c = \text{MORE THAN } 69 \times 10^5 \text{ CYCLES}$$

SPECIFICATION ALLOWABLE = 500 CYCLES

DESIGN IS ADEQUATE

## 20.0 LOADING:

## 20.0.1. SUSTAINED LOAD. (NC-3652.1)

$$S_{SL} = \frac{PD_0^*}{4t_n} + \frac{.75 i M_A}{Z} \leq 1.0 S_R$$

WHERE:  $M_A$  = MOMENT DUE TO DEFLECT HOSE +  
MOMENT DUE TO DEAD WEIGHT

NOTE: IN OPERATION, MOMENT TO DEFLECT WILL  
APPROACH TO ZERO, FOR CONSERVATIVE,  
FULL VALUE USED.

$$= \frac{1025 (1.315)}{4 (1.133)} + \frac{.75 (1.8) [\sqrt{(83.69 + 3.95)^2 + (6.52)^2}]}{\pi (1.591)^2 (1.133)}$$

$$= 2532 \text{ PSI} + 813 \text{ PSI}$$

$$= 3.345 \text{ ksi} < 18.7 \text{ ksi}$$

REF. PARA 18.11.4, 18.7.

## 20.0.2 OCCASIONAL LOAD. (NC-3652.2)

$$S_{OL} = \frac{PD_0^*}{4t_n} + \frac{.75 i (M_A + M_B)}{Z} \leq 1.2 S_R \text{ (NC-3652.2)}$$

$$= \frac{1025 (1.315)}{4 (1.133)} + \frac{.75 (1.8) [\sqrt{109.76^2 + 199.54^2}]}{\pi (1.591)^2 (1.133)}$$

$$= 2532 \text{ PSI} + 2106 \text{ PSI}$$

$$= 4.638 \text{ ksi} < 18.7 \text{ ksi}$$

REF. PARA 18.7.4.1, 18.7.4.2

\* CALCULATION WAS BASED ON ATTACHED SCH. 40 PIPE (1")  
IN THE FIELD.

METAL *Belmont* CORPORATION

2007 KNAPP STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER

J. Allen

REFERENCE NUMBER

CR683 PIN 7774

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

115

## 21.0. PIPING:

### 21.0.1. ADAPTORS (PIN 77)

#### 21.0.1.1. BELLOWS END:

$$O.D. = 1.31 \pm .03 \text{ IN.}$$

$$I.D. = 1.02 \begin{matrix} +.005 \\ -.000 \end{matrix}$$

$$t_{\text{MIN.}} = .1575 \text{ IN}$$

$$t_{\text{REQD}} = \frac{PD}{2(S + PY)} + A \quad (\text{NC-3641.1})$$

$$= \frac{1025 (1.31)}{2 (18700 + 1025(.4))}$$

$$= .035 \text{ IN.}$$

$$t_{\text{MIN.}} > t_{\text{REQD}}$$

ADEQUATE

#### 21.0.1.2. WELD END

$$O.D. = 1.31 \pm .03 \text{ IN.}$$

$$I.D. = 1.092 \begin{matrix} +.005 \\ -.000 \end{matrix} \text{ IN}$$

$$t_{\text{MIN.}} = .109 \text{ IN.}$$

$$t_{\text{REQD}} = \frac{PD}{2(S + PY)} + A$$

$$= \frac{1025 (1.31)}{2 (18700 + 1025(.4))}$$

$$= .035 \text{ IN.}$$

$$t_{\text{MIN.}} > t_{\text{REQD}}$$

ADEQUATE

METAL *B. Lines* CORPORATION  
20977 KNAPP STREET  
CHATSORTH, CALIFORNIA 91311

ENGINEER

F. J. Jhon

REFERENCE NUMBER

CR 6 P 3 P/N 77754

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

116

21.0.2. ELBOW PER SA312, 346 TP 304 (22PS SCH. 10)

$$O.D. = 1.315 \text{ IN.}$$

$$I.D. = 1.097$$

$$t = .109 \text{ IN. NOM.}$$

$$= .095 \text{ IN. MIN.}$$

$$t_{\text{READ}} = \frac{PD}{2(S + Py)} + A \quad (\text{NC-3641.1})$$
$$= \frac{1025 (1.31)}{2(18700 + 1025(1.4))}$$

$$= .035 \text{ IN.}$$

$$t_{\text{MIN.}} > t_{\text{READ}}$$

21.0.3. PIPING (CIRCUMFERENTIAL) WELD

$$t = \frac{PR}{2S + .4P} \quad (\text{NC-3324.3})$$

$$= \frac{1025 (.5485)}{2(18700) + .4(1025)}$$

$$= .0148 \text{ IN.}$$



METAL *Bellows* CORPORATION

20077 KNAPP STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER

J. Shen

REFERENCE NUMBER

CR 683 PIN 77752

DATE

4-11-80



CUSTOMER

TVA

PAGE OF

117


22.0 MOTION CORRECTION FOR COMPUTER USE:




22.1. MOTIONS

$$\begin{aligned} \Delta &= .059 \frac{L}{\sqrt{D}} \\ &= .059 \frac{12.125}{\sqrt{.75}} \\ &= .826 \end{aligned}$$

THERMAL  
INSTALLATION



SSE



OBE

22.1.1. TOTAL LENGTH & LENGTH RATIOS:

TOTAL LENGTH :  $12.125 + 18.125 = 30.25$  IN

LENGTH RATIOS :  $\frac{12.125}{30.25} = .401$

AND

LENGTH RATIOS :  $\frac{18.125}{30.25} = .599$

22.1.2. MOTION FOR HORIZONTAL HOSE:

(a) THERMAL =  $(.826) \cdot .401 = .331$  IN.

(b) SEISMIC OBE =  $\sqrt{y^2 + [.401(z + A)]^2}$   
=  $\sqrt{.085^2 + [.401(.075 + .826)]^2}$   
= .371 IN.

(c) SEISMIC SSE =  $\sqrt{y^2 + [.401(z + A)]^2}$   
=  $\sqrt{.17^2 + [.401(.15 + .826)]^2}$   
= .426 IN.

22.1.3. MOTION FOR VERTICAL HOSE:

(a) THERMAL =  $(.826) \cdot .599 = .495$  IN.

(b) SEISMIC OBE =  $\sqrt{x^2 + [.599(z + A)]^2}$   
=  $\sqrt{.425^2 + [.599(.075 + .826)]^2}$   
= .686 IN.

(c) SEISMIC SSE =  $\sqrt{x^2 + [.599(z + A)]^2}$   
=  $\sqrt{.85^2 + [.599(.15 + .826)]^2}$   
= 1.03 IN.

METAL *Bellows* CORPORATION

28877 KNAPP STREET  
CHATSORTH, CALIFORNIA 91311

ENGINEER

*J. Shen*

REFERENCE NUMBER

CR 683 PN 77752

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

119

22.1.4. MOTION FOR VIBRATION:

$$g = (.0511) f^2 D \quad f = 15 \text{ Hz}$$

$$.5 = (.0511) (15^2) D$$

$$D = .043 \text{ IN. (FOR WORST CONDITION)}$$

22.1.4.1. HORIZONTAL HOSE:

$$\begin{aligned} \text{DISPLACEMENT} &= \sqrt{.043^2 + [.401(.043 + .826)]^2} \\ &= .35 \text{ IN.} \end{aligned}$$

1.4.2. VERTICAL HOSE:

$$\begin{aligned} \text{DISPLACEMENT} &= \sqrt{.043^2 + [.599(.043 + .826)]^2} \\ &= .52 \text{ IN.} \end{aligned}$$

## 23.0 REFERENCES

23.0.1 TVA BOK A2-826892

HORIZ. HOSE 47W450-1001/1002 (FEN.NO.X-39B-1/-0)

23.0.2 METAL BELLOWS CORP DRAWING

77752

23.0.3 ASME BOILER AND PRESSURE VESSEL CODE, SECTION III  
SUBSECTION NC CLASS 2 COMPONENTS23.0.4 STANDARDS OF THE EXPANSION JOINT MANUFACTURERS  
ASSOCIATION (EJMA) FOURTH EDITION23.0.5 ASSESSMENT OF FLEXIBLE LINE FOR FLOW INDUCED  
VIBRATION - GEORGE C. MARSHAL SPACE FLIGHT CENTER  
REPORT NUMBER 20M02540.



## DESIGN CONDITIONS

GF683  
PAGE 121

OPERATING PRESSURE	3 PSIG
DESIGN PRESSURE	150 PSIG
OPERATING TEMPERATURE	100 F
DESIGN TEMPERATURE	150 F
ROOM TEMPERATURE PROOF PRESSURE	225 PSIG
BURST PRESSURE	600 PSIG
FLOW RATE, NITROGEN	0 LB/SEC
LINE SIZE	0.8 INCHES
MOTIONS	
THERMAL OFFSET, DT	0.331 INCHES
CYCLE LIFE	10000 CYCLES
VIBRATION OFFSET DV	0.350 INCHES AT 15 HZ
ALLOWABLE LOADS	
FORCE	N/A LBS
MOMENT	N/A IN-LBS

23.2 HOSE DATA

23.2.1	BASIC TUBE, OD	0.750 INCHES
	OUTSIDE DIA. OD	1.040 INCHES
	INSIDE DIA, D	0.735 INCHES
	MEAN DIA, DP	0.887 INCHES
	THICKNESS, T	0.016 INCHES
	SPAN, W	0.152 INCHES
	PITCH, Q	0.125 INCHES
	LENGTH, L	12.125 INCHES
	NO OF CONVOLUTIONS, N	97

23.3 PERFORMANCE CONSTANTS

$$TP = T(D) \text{EXP}.5 / (DP) \text{EXP}.5 \quad (\text{MATERIAL THINNING})$$

$$TP = 0.015 \text{ INCHES}$$

$$Q/2W = 0.41$$

$$Q/2.2(DP(TP)) \text{EXP}.5 = 0.49$$

23.3.1 FROM FIGURE 38, EJMA STANDARDS

$$CF = 0.71$$

23.3.2 FROM FIGURE 39, EJMA STANDARDS

$$CF = 1.52$$

23.3.3 FROM FIGURE 40, EJMA STANDARDS

$$CD = 1.59$$



23.4 PERFORMANCE EQUATIONS

CR663  
PAGE 123

23.4.1 BELLOWS TANGENT CIRCUMFERENTIAL PRESSURE STRESS

$$S1 = (P)(D)(EB)/2((TC)(EC) + (N)(T)(ES))$$

$$S1 = 353 \text{ PSI}$$

CODE ALLOWABLE = 18500 PSI

23.4.2 BELLOWS CIRCUMFERENTIAL MEMBRANE PRESSURE STRESS

$$S2 = (P)(DP)/2N(TP)(.571 + 2W/Q)$$

$$S2 = 1518 \text{ PSI}$$

CODE ALLOWABLE = 18550 PSI

23.4.3 BELLOWS MERIDIONAL PRESSURE STRESS

$$S3 = (P)(W)/2N(TP)$$

$$S3 = 785 \text{ PSI}$$

23.4.4 BELLOWS MERIDIONAL PRESSURE BENDING STRESS

$$S4 = (P)(CP)(W/TP)EXP2/2N$$

$$S4 = 5852 \text{ PSI}$$

23.5 EQUIVALENT AXIAL MOTION DUE TO OFFSET

CR683  
PAGE 124

$$ET = 3DP(DT)/N(L) \quad (\text{THERMAL})$$

$$ET = 0.0007493 \text{ INCHES}$$

$$EOBE = 3DP(DOBE)/N(L) \quad (\text{SEISMIC-OBE})$$

$$EOBE = 0.0008399 \text{ INCHES}$$

$$ESSE = 3DP(DSSE)/N(L) \quad (\text{SEISMIC-SSE})$$

$$ESSE = 0.0009644 \text{ INCHES}$$

$$EV = 3DP(DV)/N(L) \quad (\text{VIBRATION})$$

$$EV = 0.0007923 \text{ INCHES}$$

23.6 BELLOWS MERIDIONAL MEMBRANE DEFLECTION STRESS

$$S5 = EB(TP)EXP2(ET)/2(W)EXP3(CF) \quad (\text{THERMAL})$$

$$S5 = 440 \text{ PSI}$$

$$S5 = EB(TP)EXP2(EOBE)/2(W)EXP3(CF) \quad (\text{SEISMIC-OBE})$$

$$S5 = 494 \text{ PSI}$$

$$S5 = EB(TP)EXP2(ESSE)/2(W)EXP3(CF) \quad (\text{SEISMIC-SSE})$$

$$S5 = 567 \text{ PSI}$$

$$S5 = EB(TP)EXP2(EV)/2(W)EXP3(CF) \quad (\text{VIBRATION})$$

$$S5 = 466 \text{ PSI}$$

23.7 BELLOWS MERIDIONAL DEFLECTION STRESS

$$S6 = 5EB(TP)(ET)/3(W)EXP2(CD) \quad (\text{THERMAL})$$

$$S6 = 14790 \text{ PSI}$$

$$S6 = 5EB(TP)(EOBE)/3(W)EXP2(CD) \quad (\text{SEISMIC-OBE})$$

$$S6 = 16578 \text{ PSI}$$

$$S6 = 5EB(TP)(ESSE)/3(W)EXP2(CD) \quad (\text{SEISMIC-SSE})$$

$$S6 = 19035 \text{ PSI}$$

$$S6 = 5EB(TP)(EV)/3(W)EXP2(CD) \quad (\text{VIBRATION})$$

$$S6 = 15639 \text{ PSI}$$



25.8 TOTAL CYCLIC STRESS

CR683  
PAGE 125

$$ST = (S3+S4)+(S5+S6) \quad (\text{THERMAL})^*$$

$$ST = 21869 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{SEISMIC-OBE})^{**}$$

$$ST = 21719 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{SEISMIC-SSE})^{**}$$

$$ST = 24249 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{VIBRATION})$$

$$ST = 20752 \text{ PSI}$$

\* MODIFIED FATIGUE ANALYSIS BASED ON CYCLING PRESSURE.

\*\* EJMA FATIGUE ANALYSIS BASED ON CONSTANT PRESSURE.

23.9 CALCULATED LIFE

$$NC = ((C)(TF)/(ST-B)) \text{EXP} 3.4$$

$$NC = \text{MORE THAN } 1.0 \text{EXP } 8 \text{ CYCLES} \quad (\text{THERMAL})$$

$$\text{REQUIRED LIFE} = 10000 \text{ CYCLES}$$

$$NC = \text{MORE THAN } 1.0 \text{EXP } 8 \text{ CYCLES} \quad (\text{SEISMIC-OBE})$$

$$\text{REQUIRED LIFE} = 500 \text{ CYCLES}$$

$$NC = \text{MORE THAN } 1.0 \text{EXP } 8 \text{ CYCLES} \quad (\text{SEISMIC-SSE})$$

$$\text{REQUIRED LIFE} = 500 \text{ CYCLES}$$

$$NC = \text{MORE THAN } 1.0 \text{EXP } 8 \text{ CYCLES} \quad (\text{VIBRATION})$$

23.10

BRAID ANALYSIS

CP683  
PAGE 126

WIRE DIA, D= .0120 INCHES

NUMBER OF WIRES PER BUNDLE, N= 6

NUMBER OF BUNDLES, B= 36

ANGLE FROM HOSE AXIS, X=43 DEGREES

HEIGHT PER FOOT, BW= 0.162 LBS

23.10.1

END LOAD DUE TO PRESSURE

$$F = .7854(DP)EXP2(P)$$

$$F = 92.79 \text{ LBS}$$

23.10.2

BRAID AREA, TOTAL

$$A = .7854(D)EXP2(N)(B)$$

$$A = 0.033 \text{ SQ INCHES}$$

23.10.3

BRAID STRESS

$$ST = F/ACOSX$$

$$ST = 3894 \text{ PSI}$$

ALLOWABLE STRESS = 18550 PSI

23.11

SPRING RATES

23.11.1

AXIAL SPRING RATE

$$KA = 1.7(NP)(EB)(DP)(TP)EXP3/N(CF)(W)EXP3$$

$$KA = 266.48 \text{ LB/IN}$$

23.11.2

OFFSET SPRING RATE

$$KO = 1.5(DP)EXP2(KA)(F1)/(L)EXP2$$

$$KO = 5.69 \text{ LB/IN}$$

23.11.3

THERMAL DEFLECTION FORCES

$$F = (KO)(DT)$$

$$F = 1.95 \text{ LB}$$

MAXIMUM ALLOWABLE = N/A LBS



23.13.2.3 BELLOWS SPRING RATE

FROM PARA 23.11.1

KA= 266.48 LB/IN

23.13.2.4 ELEMENTAL SPRING RATE

KE= 2NC(KA)

KE= 51697.02 LB/IN

23.13.3 FREQUENCY RANGE (FLEX HOSE)

23.13.3.1 IN-PHASE LONGITUDINAL

FR1= (2KE/(MM+MF1))EXP.5/2(3.1416)

FR1= 20010.8 HZ

23.13.3.2 OUT-PHASE LONGITUDINAL

FR2= (2KE/(MM+MF2))EXP.5/2(3.1416)

FR2= 19860.7 HZ

23.13.3.3 FIRST BENDING MODE

FR1= (8KE/MM+MF2))EXP.5/2(3.1416)

FR1= 39721.5 HZ

23.13.4 VORTEX SHEDDING VELOCITY

23.13.4.1 PITCH (LAMDA)= 0.125 INCHES

CONVOLUTION WIDTH (SIGMA)= 0.078 INCHES

LAMDA/SIGMA= 1.592

FROM FIGURE 1

UPPER STROUHAL NUMBER, SU= .37921

LOWER STROUHAL NUMBER, SL= .16314

23.13.4.2 FOR FR1

VU= FR1(SIGMA)/SU

VU= 4142. FT/SEC

VL= FR1(SIGMA)/SL

VL= 9629. FT/SEC

23.13.4.3 FOR FR2

CP683  
PAGE 130

$$VU = FR2(SIGMA)/SU$$

$$VU = 4111. FT/SEC$$

$$VL = FR2(SIGMA)/SL$$

$$VL = 5557. FT/SEC$$

23.13.4.4 FOR FB1

$$VU = FB1(SIGMA)/SU$$

$$VU = 8223. FT/SEC$$

$$VL = FB1(SIGMA)/SL$$

$$VL = 19113. FT/SEC$$

NO OVERLAP OCCURS BETWEEN THE BELLOWS HOSE FLOW AND THE  
VORTEX SHEDDING RANGE THEREFORE NO ADDITIONAL ANALYSIS  
IS REQUIRED ON HOSE ASSEMBLY FOR INDUCED VIBRATION

23.14 PRESSURE DROP

$$23.14.1 \text{ LOSS} = (\text{FRICTION FACTOR}) \cdot (L) \cdot (\text{DENSITY}) \cdot (V) \cdot \text{EX}^2 \cdot (2.46)$$

$$\text{LOSS} = .000E+00 \text{ PSI/FT}$$



24.0 REFERENCES

24.0.1 TVA 80K-826892

VEHT. HOSE 47W 450-1001/1002 (PEN.NO. X-39B-I/-C)

24.0.2 METAL BELLOWS CORP DRAWING

77752.

24.0.3 ASME BOILER AND PRESSURE VESSEL CODE, SECTION III  
SUBSECTION NC CLASS 2 COMPONENTS

24.0.4 STANDARDS OF THE EXPANSION JOINT MANUFACTURERS  
ASSOCIATION (EJMA) FOURTH EDITION

24.0.5 ASSESSMENT OF FLEXIBLE LINE FOR FLOW INDUCED  
VIBRATION - GEORGE C. MARSHAL SPACE FLIGHT CENTER  
REPORT NUMBER 20M02540.

14.1

DESIGN CONDITIONS

CP683  
PAGE 132

OPERATING PRESSURE	3 PSIG
DESIGN PRESSURE	150 PSIG
OPERATING TEMPERATURE	100 F
DESIGN TEMPERATURE	150 F
ROOM TEMPERATURE PROOF PRESSURE	225 PSIG
BURST PRESSURE	600 PSIG
FLOW RATE, NITROGEN	0 LB/SEC
LINE SIZE	0.8 INCHES
MOTIONS	
THERMAL OFFSET, DT	0.495 INCHES
CYCLE LIFE	10000 CYCLES
VIBRATION OFFSET DV	0.520 INCHES AT 15 HZ
ALLOWABLE LOADS	
FORCE	N/A LBS
MOMENT	N/A IN-LBS



24.2 HOSE DATA

24.2.1	BASIC TUBE, OD	0.750 INCHES
	OUTSIDE DIA, OD	1.040 INCHES
	INSIDE DIA, D	0.735 INCHES
	MEAN DIA, DP	0.697 INCHES
	THICKNESS, T	0.016 INCHES
	SPAN, W	0.152 INCHES
	PITCH, Q	0.125 INCHES
	LENGTH, L	18.125 INCHES
	NO OF CONVOLUTIONS, N	145

24.3 PERFORMANCE CONSTANTS

$$TP = T(D)EXP.5 / (DP)EXP.5 \quad (\text{MATERIAL THINNING})$$

$$TP = 0.015 \text{ INCHES}$$

$$Q/2W = 0.41$$

$$Q/2.2(DP(TP))EXP.5 = 0.49$$

24.3.1 FROM FIGURE 38, EJMA STANDARDS

$$CF = 0.71$$

24.3.2 FROM FIGURE 39, EJMA STANDARDS

$$CF = 1.52$$

24.3.3 FROM FIGURE 40, EJMA STANDARDS

$$CF = 1.59$$

24.4 PERFORMANCE EQUATIONS

CR683  
PAGE 134

24.4.1 BELLOWS TANGENT CIRCUMFERENTIAL PRESSURE STRESS

$$S1 = (P)(D)(EB)/2((TD)(LD) + (N)(T)(EB))$$

$$S1 = 353 \text{ PSI}$$

CODE ALLOWABLE = 16550 PSI

24.4.2 BELLOWS CIRCUMFERENTIAL MEMBRANE PRESSURE STRESS

$$S2 = (P)(DP)/2N(TP)(.571 + 2W/D)$$

$$S2 = 1518 \text{ PSI}$$

CODE ALLOWABLE = 18550 PSI

24.4.3 BELLOWS MERIDIONAL PRESSURE STRESS

$$S3 = (P)(W)/2N(TP)$$

$$S3 = 785 \text{ PSI}$$

24.4.4 BELLOWS MERIDIONAL PRESSURE BENDING STRESS

$$S4 = (P)(CP)(W/TP)EXP2/2N$$

$$S4 = 5852 \text{ PSI}$$



24.5 EQUIVALENT AXIAL MOTION DUE TO OFFSET

CR603  
PAGE 135

$$ET = 3DP(DT)/N(L) \quad (\text{THERMAL})$$

$$ET = 0.0005015 \text{ INCHES}$$

$$EOBE = 3DP(DOBE)/N(L) \quad (\text{SEISMIC-OBE})$$

$$EOBE = 0.0006950 \text{ INCHES}$$

$$ESSE = 3DP(DSSE)/N(L) \quad (\text{SEISMIC-SSE})$$

$$ESSE = 0.0010435 \text{ INCHES}$$

$$EV = 3DP(DV)/N(L) \quad (\text{VIBRATION})$$

$$EV = 0.0005268 \text{ INCHES}$$

24.6 BELLOWS MERIDIONAL MEMBRANE DEFLECTION STRESS

$$S5 = EB(TP)EXP2(ET)/2(W)EXP3(CF) \quad (\text{THERMAL})$$

$$S5 = 295 \text{ PSI}$$

$$S5 = EB(TP)EXP2(EOBE)/2(W)EXP3(CF) \quad (\text{SEISMIC-OBE})$$

$$S5 = 402 \text{ PSI}$$

$$S5 = EB(TP)EXP2(ESSE)/2(W)EXP3(CF) \quad (\text{SEISMIC-SSE})$$

$$S5 = 613 \text{ PSI}$$

$$S5 = EB(TP)EXP2(EV)/2(W)EXP3(CF) \quad (\text{VIBRATION})$$

$$S5 = 309 \text{ PSI}$$

24.7 BELLOWS MERIDIONAL DEFLECTION STRESS

$$S6 = 5EB(TP)(ET)/3(W)EXP2(CD) \quad (\text{THERMAL})$$

$$S6 = 9898 \text{ PSI}$$

$$S6 = 5EB(TP)(EOBE)/3(W)EXP2(CD) \quad (\text{SEISMIC-OBE})$$

$$S6 = 13718 \text{ PSI}$$

$$S6 = 5EB(TP)(ESSE)/3(W)EXP2(CD) \quad (\text{SEISMIC-SSE})$$

$$S6 = 20597 \text{ PSI}$$

$$S6 = 5EB(TP)(EV)/3(W)EXP2(CD) \quad (\text{VIBRATION})$$

$$S6 = 10398 \text{ PSI}$$

24.8

TOTAL CYCLIC STRESS

CR603  
PAGE 136

$$ST = (S3+S4)+(S5+S6) \quad (\text{THERMAL})^*$$

$$ST = 16831 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{SEISMIC-OBE})^{**}$$

$$ST = 18773 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{SEISMIC-SSE})^{**}$$

$$ST = 25857 \text{ PSI}$$

$$ST = .7(S3+S4)+(S5+S6) \quad (\text{VIBRATION})$$

$$ST = 15355 \text{ PSI}$$

\* MODIFIED EJMA FATIGUE ANALYSIS BASED ON CYCLING PRESSURE.

\*\* EJMA FATIGUE ANALYSIS BASED ON CONSTANT PRESSURE.

24.9

CALCULATED LIFE

$$NC = (C)(TF)/(ST-B)^{EXP3.4}$$

$$NC = \text{MORE THAN } 1.0 \times 10^8 \text{ CYCLES} \quad (\text{THERMAL})$$

$$\text{REQUIRED LIFE} = 10000 \text{ CYCLES}$$

$$NC = \text{MORE THAN } 1.0 \times 10^8 \text{ CYCLES} \quad (\text{SEISMIC-OBE})$$

$$\text{REQUIRED LIFE} = 500 \text{ CYCLES}$$

$$NC = \text{MORE THAN } 1.0 \times 10^8 \text{ CYCLES} \quad (\text{SEISMIC-SSE})$$

$$\text{REQUIRED LIFE} = 500 \text{ CYCLES}$$

$$NC = \text{MORE THAN } 1.0 \times 10^8 \text{ CYCLES} \quad (\text{VIBRATION})$$



24.10 BRAID ANALYSIS

CP683  
PAGE 137

PIPE DIA, D= .6120 INCHES

NUMBER OF WIRES PER BUNDLE, N= 8

NUMBER OF BUNDLES, B= 36

ANGLE FROM HOSE AXIS, X=43 DEGREES

WEIGHT PER FOOT, BW= 0.162 LBS

24.10.1 END LOAD DUE TO PRESSURE

$$F = .7854(DP)EXP2(P)$$

$$F = 92.79 \text{ LBS}$$

24.10.2 BRAID AREA, TOTAL

$$A = .7854(D)EXP2(N)(B)$$

$$A = 0.033 \text{ SQ INCHES}$$

24.10.3 BRAID STRESS

$$ST = F/ACOSX$$

$$ST = 3894 \text{ PSI}$$

ALLOWABLE STRESS = 18550 PSI

24.11 SPRING RATES

24.11.1 AXIAL SPRING RATE

$$KA = 1.7(NP)(EB)(DP)(TF)EXP3/N(CF)(W)EXP3$$

$$KA = 178.27 \text{ LB/IN}$$

24.11.2 OFFSET SPRING RATE

$$KO = 1.5(DP)EXP2(KA)(F1)/(L)EXP2$$

$$KO = 1.76 \text{ LB/IN}$$

24.11.3 THERMAL DEFLECTION FORCES

$$F = (KO)(DT)$$

$$F = 0.87 \text{ LB}$$

MAXIMUM ALLOWABLE = N/A LBS

24.11.4 REFLECTION MOMENTS

$$M = (F)(L)(F2)/2$$

$$M = 21.75 \text{ IN-LB}$$

$$\text{MAXIMUM ALLOWABLE} = 11/4 \text{ IN-LB}$$

24.17 NATURAL FREQUENCIES

24.12.1 WEIGHT OF HOSE

$$W1 = ((OD-D)N+.57(L))3.1416D(T)(.3)$$

$$W1 = 0.607 \text{ LBS}$$

24.12.2 WEIGHT OF FLUID

$$W2 = .7851(DP)EXP2(L)(.000628)$$

$$W2 = .704E-02 \text{ LBS}$$

24.12.3 WEIGHT OF BRAID

$$W3 = (BW)(L)/12$$

$$W3 = 0.254 \text{ LBS}$$

24.12.4 TOTAL WEIGHT

$$W = W1+W2+W3$$

$$W = 0.87 \text{ LBS}$$

24.12.5 AXIAL VIBRATION (PARALLEL TO AXIS)

$$F = 9.61(KA/W)EXP.5(F3) \quad (\text{FIRST NODE})$$

$$F = 211.2 \text{ HZ}$$

$$F = 19.6(KA/W)EXP.5(F3) \quad (\text{SECOND NODE})$$

$$F = 422.4 \text{ HZ}$$

$$F = 29.2(KA/W)EXP.5(F3) \quad (\text{THIRD NODE})$$

$$F = 633.6 \text{ HZ}$$

$$F = 38.6(KA/W)EXP.5(F3) \quad (\text{FOURTH NODE})$$

$$F = 844.8 \text{ HZ}$$



24.12.6 LATERAL VIBRATION

$F = 24.8(DP/L)(KA/W)EXP.5(KVL)$  (FIRST MODE)

$F = 26.1 \text{ HZ}$

$F = 46.2(DP/L)(KA/W)EXP.5(KVL)$  (SECOND MODE)

$F = 71.9 \text{ HZ}$

$F = 133(DP/L)(KA/W)EXP.5(KVL)$  (THIRD MODE)

$F = 140.2 \text{ HZ}$

$F = 221(DP/L)(KA/W)EXP.5(KVL)$  (FOURTH MODE)

$F = 233.0 \text{ HZ}$

24.13 FLOW INDUCED VIBRATION

24.13.1 FLOW VELOCITY

24.13.1.1 SYSTEM FLOW

$Q = FR / 60 \text{ LB/CUFT/60 SEC/MIN}$

$Q = 0.000 \text{ CUFT/SEC}$

24.13.1.2 FLOW AREA

$A = .7054(D)EXP2$

$A = 0.0029 \text{ SQFT}$

24.13.1.3 FLOW VELOCITY

$V = Q/A$

$V = 0.00 \text{ FT/SEC}$

24.13.2 METAL MASS

$MM = .3DF(T)3.1416(3.1416A+H-2A)(.00256)$

$MM = .0000065 \text{ LB-(SEC)EXP2/(IN)EXP4}$

24.13.2.2 FLUID MASS

$MF1 = .000628DF(H)(3.1416)(.00256)/2((2H-T)(NF))$

$MF1 = .161E-07 \text{ LB-(SEC)EXP2/(IN)EXP4}$

$MF2 = .000628DF(H)EXP3(3.1416)/2DF(L)$

$MF2 = .115E-06 \text{ LB-(SEC)EXP2/(IN)EXP4}$

24.13.2.3 FELLOWS SPRING RATE

FROM PARA 24.11.1

KE = 175.27 LB/IN

24.13.2.4 ELEMENTAL SPRING RATE

KE = 2ND(KA)

KE = 51697.04 LB/IN

24.13.3 FREQUENCY RANGE (FLEX HOSE)

24.13.3.1 IN-PHASE LONGITUDINAL

$FR1 = (2KE / (NM + MF1)) \text{EXP. } 5/2(3.1416)$

FR1 = 20010.8 HZ

24.13.3.2 OUT-PHASE LONGITUDINAL

$FR2 = (2KE / (NM + MF2)) \text{EXP. } 5/2(3.1416)$

FR2 = 19860.7 HZ

24.13.3.3 FIRST BENDING MODE

$BF1 = (SKE / (NM + MF2)) \text{EXP. } 5/2(3.1416)$

BF1 = 39721.5 HZ

24.13.4 ORTEX SHEDDING VELOCITY

24.13.4.1 PITCH (LAMBDA) = 0.125 INCHES

REVOLUTION WIDTH (SIGMA) = 0.078 INCHES

LAMBDA/SIGMA = 1.592

FROM FIGURE 1

UPPER STRONGAL NUMBER, SU = .37921

LOWER STRONGAL NUMBER, SL = .16314

24.13.4.2 FOR FR1

$VL = FR1(SIGMA) / SU$

VL = 4142. FT/SEC

$VL = FR1(SIGMA) / SL$

VL = 9629. FT/SEC



24.13.4.3 FOR FR2

CP683  
PAGE 141

$$VU = FR2(SIGMA)/SU$$

$$VU = 4111. FT/SEC$$

$$VL = FR2(SIGMA)/SL$$

$$VL = 9557. FT/SEC$$

24.13.4.4 FOR FB1

$$VU = FB1(SIGMA)/SU$$

$$VU = 8223. FT/SEC$$

$$VL = FB1(SIGMA)/SL$$

$$VL = 19113. FT/SEC$$

NO OVERLAP OCCURS BETWEEN THE BELLOWS HOSE FLOW AND THE  
VORTEX SHEDDING RANGE THEREFORE NO ADDITIONAL ANALYSIS  
IS REQUIRED ON HOSE ASSEMBLY FOR INDUCED VIBRATION

24.14 PRESSURE DROP

24.14.1 LOSS= (FRICTION FACTOR)(L)(DENSITY)(V)EXP2/2D(G)

LOSS= .000E+00 PSI/FT

25.0 LOADING COMBINATION:

25.1. WEIGHT (1/2 HORIZONTAL HOSE)

- SOCKET ADAPTOR = .24 LB
- FERRULE = .05 LB
- HOSE & BRAIDS (.405 + .17) .5 = .288 LB
- FLUID IN HOSE (.00471) .5 = .002 LB

1/2 DEAD WEIGHT = .58 LB

25.2. ACCIDENT FORCE:

25.2.1. DUE TO INERTIA:

$F = W \times g$

(a)  $F_x = (\text{HORIZ. HOSE} + \text{FITTINGS} + \frac{1}{2} \text{ VERT. HOSE}) \times g^*$   
 $= [ (.58 + .3) + .15 + \frac{1}{2} (.87) ] \times (2.52 \cos 15^\circ)$   
 $= (1.465) (2.43)$   
 $= 3.56 \text{ LB}$

REF. PARA 25.1, 23/12.4.

(b)  $F_z = (\frac{1}{2} \text{ HORIZ. HOSE}) \times g^*$   
 $= (.58) \times (2.52 \sin 15^\circ)$   
 $= .378 \text{ LB}$

(c)  $F_y = (.58) \cdot (.29) = .17 \text{ LB}$

\* NOTE: AT ELEVATION 716.5 AZIMUTH 285 DEG.  
 "g" PEAK VALUE (ACCIDENT RESPONSE CONDITION)



## 25.3. SEISMIC FORCES : (SSE)

## 25.3.1. DUE TO INERTIA

$$F = W \times g$$

$$(a) F_x = (\text{HORIZ. HOSE} + \text{FITTINGS} + \frac{1}{2} \text{ VERT. HOSE}) \times g^*$$

$$= (1.465) (2.4 \cos 15^\circ)$$

$$= 3.396 \text{ LB}$$

$$(b) F_z = (\frac{1}{2} \text{ HORIZ. HOSE}) \times g^*$$

$$= (.58) (2.4 \sin 15^\circ)$$

$$= .36 \text{ LB.}$$

$$(c) F_y = (.58) (1.6) = .35 \text{ LB}$$

\* NOTE: AT ELEVATION 716.5 FT, AZIMUTH 285 DEG.  
"g" AT PEAK VALUE (CONSERVATIVE VALUE)

## 25.4. DUE TO MOVEMENT

(ACCIDENT AND SEISMIC FORCE)

$$25.4.1. F_x = K_0 x$$

$$= 1.76 (.85)$$

$$= 1.49 \text{ LB}$$

REF. PARA 24.11.2, 22.1

$$25.4.2. F_y = K_0 y$$

$$= 5.89 (.17)$$

$$= 1 \text{ LB}$$

f\* = LENGTH RATIOS  
22.1.1.

REF. PARA 23.11.2, 22.1

$$25.4.3 F_z = K_0 z f^*$$

$$= 5.89 (.15) (.901) = .354 \text{ LB}$$

REF. PARA 23.11.2  
22.1.

## 25.5. VIBRATION FORCES

### 25.5.1. DUE TO INERTIA

$$F = W \times g$$

$$\begin{aligned} (a) \quad F_x &= (\text{HORIZ. HOSE} + \text{FITTINGS} + \frac{1}{2} \text{ VERT. HOSE}) \times g \\ &= 1.465 \text{ (.5g's)} \\ &= .73 \text{ LB} \end{aligned}$$

$$\begin{aligned} (b) \quad F_y = F_z &= .58 \text{ (.5g's)} \\ &= .29 \text{ LB} \end{aligned}$$

## 25.6. TOTAL FORCE

### 25.6.1. IN X-DIRECTION

$$\begin{aligned} F_x &= (\text{ACCIDENT AND SEISMIC FORCE DUE TO} \\ &\quad \text{INERTIA \& MOVEMENT}) + \text{VIBRATION} \\ &= (3.56 + 3.396 + 1.49) + .73 \\ &= 9.176 \text{ LB} \end{aligned}$$

### SPECIFICATION ALLOWABLE

$$\begin{aligned} P_x &= .016, A \\ &= .01 (30,000) [ .7854 (1.05^2 - .924^2) ] \\ &= 99.8 \text{ LB} \end{aligned}$$

$$P_x > F_x$$

DESIGN IS ADEQUATE



## 25.6.2. IN Z-DIRECTION:

$$F_z = \text{INSTALLATION MISALIGNMENT FORCE} + \\ \text{ACCIDENT \& SEISMIC FORCE DUE TO MOVEMENT} \\ + \text{VIBRATION}$$

$$= 1.95 + (.378 + .36 + .354i) + .29$$

$$= 3.332 \text{ LBS}$$

REF. PARA 23.11.3, 25.4.2

SPECIFICATION ALLOWABLE

$$P_z = .016yA$$

$$= 99.8 \text{ LB}$$

$$P_z > F_z$$

DESIGN IS ADEQUATE

## 25.6.3. IN Y-DIRECTION

$$F_y = \text{DEAD WEIGHT} + (\text{ACCIDENT AND SEISMIC FORCE} \\ \text{DUE TO INERTIA \& MOVEMENT}) + \text{VIBRATION}$$

$$= .58 + (.17 + .35 + 1) + .29$$

$$= 2.39 \text{ LB}$$

REF. PARA 25.0.25.2.1(b)

SPECIFICATION ALLOWABLE 25.3.1(b), 25.4.3.25.1(b)

$$P_y = .016yA$$

$$= 99.8 \text{ LB}$$

$$P_y > F_y$$

DESIGN IS ADEQUATE

## 25.7. DYNAMIC MOMENT

## MOMENT ARMS:

SOCKET ADAPTORS .24 LB x .56 IN = .134 IN-LB

FERRULE .05 LB x 1.78 IN. = .089 IN-LB

HOSE & BRAIDS .288 LB x 4.18 IN. = 1.2 IN-LB

FLUID IN HOSE .002 LB x 1.15 IN. = .002 IN-LB

---

TOTAL = 1.425 IN-LB

## 25.7.1. ACCIDENT MOMENT:

## 25.7.1.1. DUE TO INERTIA:

$$M_z = 1.425 (2.52 \sin 15^\circ)$$

$$= .929 \text{ IN-LB}$$

REF. PARA 25.7.

$$M_y = 1.425 (.29) = .413 \text{ IN-LB}$$

## 25.7.2. SEISMIC MOMENT (SSE)

## 25.7.2.1. DUE TO INERTIA:

$$M_z = 1.425 (2.4 \sin 15^\circ)$$

$$= .885 \text{ IN-LB}$$

PARA 25.7.

$$M_y = (1.425) (.69's) = .985 \text{ LB}$$

## 25.7.3. MOMENT AT SOCKET ADAPTOR

HOSE FORCE x L (HOSE END TO SOCKET ADAPTOR)

$$25.7.3.1. M_y = F_y (L)$$

$$= 1 (1.15)$$

$$= 1.15 \text{ IN-LB}$$

REF. PARA. 25, 4.2.

METAL *Rollers* CORPORATION20517 KIAPP STREET  
CHATSWOORTH, CALIFORNIA 91311

ENGINEER

J. *Shen*

REFERENCE NUMBER

CR 683

PIN-77752

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

147

$$\begin{aligned}
 25.7.3.2. \quad M_z &= F_z (L) \\
 &= .378 (1.15) \\
 &= .434 \text{ IN-LB}
 \end{aligned}$$

REF. PARA. 25.4.3.

## 25.7.4. TOTAL MOMENT

25.7.4.1. IN  $z$ -DIRECTION

$$\begin{aligned}
 M_z &= \text{TOTAL DEFLECTION MOMENT (INCL. INSTALLATION)} \\
 &\quad \text{\& SEISMIC} \\
 &\quad \text{+ SEISMIC \& ACCIDENT DUE TO MOVEMENT \&} \\
 &\quad \text{INERTIA} \\
 &= [32.5 + (1.95)(1.15) + 5^*] + .929 + .885 \\
 &= 41.55 \text{ IN-LB} \quad \begin{array}{l} * \text{ ADDITIONAL DEFLECTION} \\ \text{MOMENT DUE TO SEISMIC} \end{array} \\
 &\quad \text{REF. PARA. 23.11.4, 23.11.3}
 \end{aligned}$$

SPECIFICATION ALLOWABLE

$$\begin{aligned}
 M_{bz} &= .0707 G_y z \\
 &= .0707 (30,000) (.0704) \\
 &= 149.3 \text{ IN-LB}
 \end{aligned}$$

$$M_{bz} > M_z$$

DESIGN IS ADEQUATE

WHERE

$$\begin{aligned}
 z &= \frac{I}{c} \\
 &= .098 \frac{D^4 - d^4}{D} \\
 &= .098 \frac{1.05^4 - .824^4}{1.05} \\
 &= .0704
 \end{aligned}$$



## 25.7.4.2. IN Y-DIRECTION

$M_y =$  DEAD WEIGHT + SEISMIC AND ACCIDENT  
DUE TO INERTIA & MOVEMENT

$$= 1.425 + [ .413 + .855 + (\text{DEFLECTION MOMENT} \\ + \text{MOMENT AT SOCKET ADAPTOR}) ]$$

$$= 1.425 + [ .413 + .855 + (14.67 + 1.15) ]$$

$$= 18.51 \text{ IN-LB}$$

REF. PARA. 25.7. 25.7. 1.1.  
25.7.2.1. 25.7. 3.2.

## DEFLECTION MOMENT IN Z-DIRECTION

$$F = (k_o) y$$

$$= (5.89) (.15)$$

$$= .88 \text{ LB}$$

$f^R =$  LENGTH RATIOS

REF. 23.11.2. 22.1.22.1.1.

$$M = (F) (L) (F 2) / 2$$

$$= (.88) (12.125) (2.75) / 2$$

$$= 14.67 \text{ IN-LB}$$

## SPECIFICATION ALLOWABLE

$$M_{bz} = .07076 y z$$

$$= 149.3 \text{ IN-LB}$$

$$M_{bz} > M_y$$

DESIGN IS ADEQUATE

## 25.8 TORSIONAL MOMENT

$$M_x = F_y (L)$$

$$= [f^* \cdot K_o] (L)$$

$$= [(1.599) (1.15) (1.76)] (1.125)$$

$$= .178 \text{ (IN-LB)}$$

L = ELBOW RADIUS

= 1.125 IN.

f\* = LENGTH RATIO

REF. 22 I. 1.22.1, 24.11.2

## SPECIFICATION ALLOWABLE

$$M_{Lx} = .1 \frac{6yJ}{R_o}$$

$$= .1 \frac{(30,000) .074}{1.05 / 2}$$

$$= 422.8 \text{ IN-LB}$$

$$J = \frac{\pi}{32} (d_o^4 - d_i^4)$$

$$= \frac{\pi}{32} (1.05^4 - .824^4)$$

$$= .074$$

$$M_{Lx} > M_x$$

DESIGN IS ADEQUATE



- 26.0 MOTION AT CENTER DUE TO RESPONSE FROM  
 ACCIDENT & SEISMIC CONDITION:  
 26.0.1. UNDER ACCIDENT CONDITION:  
 26.0.1.1. ASSUMPTIONS

A. SEISMIC INPUT OF  $\sqrt{(2.52 \sin 15^\circ)^2 + .29^2}$

B. AMPLIFICATION FACTOR IS DERIVED FROM  
 RESULTS OF TEST DATA AND IS CONSIDERED  
 CONSERVATIVE.

FREQUENCY <sup>*</sup>	INPUT	AMPLIFICATION	OUTPUT	DISPLACEMENT	EXCURSION
HZ	g		g	INCHES	INCHES
58.4	.713	4	2.852	.016	±.008

26.0.1.2.

EQUIVALENT AXIAL MOTION

$$e = \frac{3 D_p \Delta}{(.5 N) (1.56)}$$

$$= \frac{3 (.887) (\pm .008)}{(485) (6.06)} = \pm .000072$$

$$S_5 = \frac{E_b t_p^2 e}{2 W^3 C_f}$$

$$= \frac{(29 \times 10^6) (1.015)^2 (\pm .000072)}{2 (.152)^3 (1.52)} = \pm 44 \text{ PSI}$$

$$S_6 = \frac{5 E_b t_p e}{3 W^2 C_d}$$

$$= \frac{5 (29 \times 10^6) (1.015) (\pm .000072)}{3 (.152)^2 (1.59)} = \pm 1421 \text{ PSI}$$

\* NOTE: IT IS WORST FREQUENCY. SEE 23.12.6 PAGE

YAL *Bohling* CORPORATION  
17 KNAPP STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER  
F. J. Hen  
DATE  
4-11-80

REFERENCE NUMBER  
CR 683  
CUSTOMER  
TVA

P/N 77712  
PAGE OF  
152

26. 0.3. CYCLE LIFE (ACCIDENT + SSE)

$$\begin{aligned} S_T &= .7(S_3 + S_4) + (S_5 + S_6) \text{ ACCIDENT} + (S_5 + S_6) \text{ SSE} \\ &= .7(785 + 5852) + (88 + 2842) + (108 + 3512) \\ &= 11,195 \text{ PSI} \end{aligned}$$

$$N_c = \left( \frac{1,860,000}{S_T - 54,000} \right)^{3.4}$$

SINCE  $54,000 > S_T$

$N_c = \text{INFINITE CYCLES}$

SPECIFICATION ALLOWABLE = 500 CYCLES

DESIGN IS ADEQUATE

METAL ~~PIPE~~ CORPORATION

20277 KNAPP STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER

F. Abu

REFERENCE NUMBER

CR 683

P/N 77712

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

153

## 27.0 LOADING

### 27.0.1. SUSTAINED LOAD. (NC-3652.1)

$$S_{SL} = \frac{PD_0^*}{4t_n} + \frac{.75 i M_A}{Z} \leq 1.0 S_R$$

WHERE:  $M_A$  = MOMENT DUE TO DEFLECT HOSE +  
MOMENT DUE TO DEAD WEIGHT

NOTE: IN OPERATION, MOMENT TO DEFLECT WILL  
APPROACH TO ZERO, FOR CONSERVATIVE,  
FULL VALUE USED.

$$= \frac{150(1.05)}{4(1.113)} + \frac{.75(1.8) \left[ \sqrt{(32.5 + 2.24)^2} + 1.425^2 \right]}{\pi(1.468)^2(1.113)}$$

$$= 348 \text{ PSI} + 603 \text{ PSI}$$

$$= .951 \text{ ksi} < 18.55 \text{ ksi}$$

REF. PARA. 11.4. .7.

### 27.0.2 OCCASIONAL LOAD (NC-3652.2)

$$S_{OL} = \frac{PD_0^*}{4t_n} + \frac{.75 i (M_A + M_B)}{Z} \leq 1.2 S_R \text{ (NC-3652.2)}$$

$$= \frac{150(1.05)}{4(1.113)} + \frac{.75(1.8) \left[ \sqrt{41.55^2 + 18.51^2} \right]}{\pi(1.468)^2(1.113)}$$

$$= 348.4 \text{ PSI} + 789.7 \text{ PSI}$$

$$= 1.138 \text{ ksi} < 18.55 \text{ ksi}$$

REF. PARA. 23.7.4.1, 23.7.4.2

\* CALCULATION WAS BASED ON ATTACHED SCH. 40 PIPE ( $\frac{3}{4}$ "  
IN THE FIELD.



METAL *Bellevue* CORPORATION  
20977 KNIGHT STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER  
F. Allen  
DATE  
4-11-80

REFERENCE NUMBER  
CR.683 P/N 77742  
CUSTOMER  
TVA  
PAGE OF  
154

## 28.0. PIPING:

### 28.0.1 ADAPTORS (P/N 77209)

#### 28.0.1.1 BELLOWS END:

$$O.D. = 1.05 \pm .03 \text{ IN.}$$

$$I.D. = .77 \begin{matrix} +.005 \\ -.000 \end{matrix} \text{ IN.}$$

$$t_{\text{MIN.}} = .122 \text{ IN}$$

$$\begin{aligned} t_{\text{REQD}} &= \frac{PD}{2(S + PY)} + A \quad (\text{NC-3641.1}) \\ &= \frac{150(1.05)}{2(18550 + 150(.4))} \\ &= .004 \text{ IN.} \end{aligned}$$

$$t_{\text{MIN.}} > t_{\text{REQD}}$$

ADEQUATE

#### 28.0.1.2 WELD END

$$O.D. = 1.05 \pm .03 \text{ IN.}$$

$$I.D. = .884 \begin{matrix} +.005 \\ -.000 \end{matrix} \text{ IN}$$

$$t_{\text{MIN.}} = .083 \text{ IN.}$$

$$\begin{aligned} t_{\text{REQD}} &= \frac{PD}{2(S + PY)} + A \\ &= \frac{150(1.05)}{2(18550 + 160(.4))} \\ &= .004 \text{ IN.} \end{aligned}$$

$$t_{\text{MIN.}} > t_{\text{REQD}}$$

ADEQUATE

METAL FABRICATING CORPORATION

20977 ALVARO STREET  
CHATSWORTH, CALIFORNIA 91311

ENGINEER

F. Allen

REFERENCE NUMBER

CR 683 P/N 77752

DATE

4-11-80

CUSTOMER

TVA

PAGE OF

155

28.0.2. ELBOW PER SA 312, 376 TP 304 (3/4" IPS SCH. 10)

$$O.D. = 1.05$$

$$I.D. = .82$$

$$t = .065 \text{ IN. NOM.}$$

$$= .057 \text{ IN. MIN.}$$

$$t_{REQD} = \frac{PD}{2(S + Py)} + A \quad (NC-3641.1)$$

$$= \frac{150(1.05)}{2(18550 + 150(.4))}$$

$$= .004 \text{ IN.}$$

$$t_{MIN.} > t_{REQD}$$

28.0.3. PIPING (CIRCUMFERENTIAL) WELD

$$t = \frac{PR}{2S + .4P} \quad (NC-3324.3)$$

$$= \frac{150(.4)}{2(18550) + .4(150)}$$

$$= .0016 \text{ IN.}$$