

September 4, 2008

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Stop P1-137
Washington, DC 20555-0001

ULNRC-05537



Ladies and Gentlemen:

**DOCKET NUMBER 50-483
CALLAWAY PLANT UNIT 1
UNION ELECTRIC CO.
FACILITY OPERATING LICENSE NPF-30
CALLAWAY PLANT ERDS DATA POINT LIBRARY REVISIONS**

- Ref: 1) 10 CFR 50, Appendix E.VI.3.a
2) NUREG – 1934, Revision 1

This correspondence is submitted in accordance with 10CFR50 Appendix E section VI.3.a, which requires any hardware and software changes that affect the transmitted data points identified in the ERDS Data Point Library be submitted to the NRC within 30 days after the changes are completed. Please find attached a revision for the Callaway Plant's ERDS Data Point Library reference file. These changes reflect changes made to Callaway's plant process computer on August 20, 2008.

Please contact Mr. Lewis Beaty, Computer Systems (573) 676-8632 for any questions.

This letter does not contain new commitments.

Sincerely,


D. W. Neterer 4430
FDR Plant Director

Sub 12015

LSB/nls

Enclosure (68 pages)

A026
NR

ULNRC-05537
September 4, 2008
Page 2

cc: Mr. Elmo E. Collins, Jr.
Regional Administrator
U.S. Nuclear Regulatory Commission
Region IV
612 E. Lamar Blvd., Suite 400
Arlington, TX 76011-4125

Senior Resident Inspector
Callaway Resident Office
U.S. Nuclear Regulatory Commission
8201 NRC Road
Steedman, MO 65077

Mr. Mohan C. Thadani (2 copies)
Licensing Project Manager, Callaway Plant
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop O-8G14
Washington, DC 20555-2738

Index and send hardcopy to QA File A160.0761

Hardcopy:

Certrec Corporation
4200 South Hulen, Suite 422
Fort Worth, TX 76109
(Certrec receives ALL attachments as long as they are non-safeguards and may be publicly disclosed.)

**Electronic distribution for the following can be made via Other Situations
ULNRC Distribution:**

A. C. Heflin
F. M. Diya
T. E. Herrmann
L. H. Graessle
S. A. Maglio
S. L. Gallagher
L. M. Belsky (NSRB)
T. B. Elwood
Ms. Diane M. Hooper (WCNOC)
Mr. Dennis Buschbaum (TXU)
Mr. Scott Bauer (Palo Verde)
Mr. Stan Ketelsen (PG&E)
Mr. Scott Head (STP)
Mr. John O'Neill (Pillsbury Winthrop Shaw Pittman LLP)
Missouri Public Service Commission

Enclosure
to ULNRC-05537

NRC EMERGENCY RESPONSE DATA SYSTEM
DATA POINT LIBRARY
J-26060A Rev. 5

| <u>REV .</u> | <u>AFFECTED PAGES</u> |
|--------------|---|
| 0 | NEW DOCUMENT |
| 1 | Page 2 & 9 change SEN0701 units from PCM to % |
| 2 | Change Section 2 pages 46, 48, 53-56, and 62 to revise system descriptions. Reference RFR 15126, SCR5929, 6247-6251. |
| 3 | Bulk issue for changes to Section 2 pages 15, 16, 17, 18, 44, 48, 53, 54, 55, 56. Reference MP 00-1008A, 00-1013A, SCR 6342, 6388-6391, 7595-7598, 7737, 7739-7742, 7744, 7864-7867. |
| 4 | Bulk issue for changes to pages 4, 62-66. Reference MP 04-1020, SCR 8258, 8259 8261, 8262, 8183, 8185, 8187, 8189 & 8324. |
| 5 | Bulk issue for changes to Section 1 pages 2-4 and Section 2 pages 6-9, 11-13, 19-41, 44-46, 48, 50, 51, 57-60, 64-66. Reference MP 07-0025. |

Enclosure
to ULNRC-05537

NRC EMERGENCY RESPONSE DATA SYSTEM
DATA POINT LIBRARY
J-26060A Rev. 5
TABLE OF CONTENTS

| <u>Section</u> | <u>Title</u> | <u>Page Number</u> |
|----------------|-------------------------------------|--------------------|
| 1 | Critical Safety Function Parameters | 1 |
| 2 | ERDS Data Point Library | 5 |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

SECTION 1

CRITICAL SAFETY FUNCTION PARAMETERS

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

CRITICAL SAFETY FUNCTION PARAMETERS

| PARAMETER | PARAMETER DESCRIPTION | UNITS | COMPUTER POINT |
|--------------------|---|--------|----------------|
| REACTIVITY CONTROL | | | |
| NI POWER RNG | Nuclear Instruments, Power Range | % | SPDSS102 |
| NI INTER RNG | Nuclear Instruments, Intermediate Range | AMPS | REU0640 |
| NI SOURC RNG | Nuclear Instruments, Source Range | CPS | SPDSS286 |
| NL | Post Accident Wide Range | PCM | SEN0701 |
| NL | Post Accident Source Range | CPS | SEN0702 |
| CORE COOLING | | | |
| REAC VES LEV | Reactor Vessel Water Level | % | REU0523 |
| TEMP CORE EX | Highest Temperature at the Core Exit | F | RJUITC08 |
| SUB MARGIN | Saturation Temperature-Highest CET | F | SPDSC252 |
| CORE FLOW | Total Reactor Coolant Flow | % | REU0487 |
| STEAM GENERATORS | | | |
| SG LEVEL 1/A | Steam Generator 1 (or A) Water Level | % | REL0404A |
| SG LEVEL 2/B | Steam Generator 2 (or B) Water Level | % | REL0424A |
| SG LEVEL 3/C | Steam Generator 3 (or C) Water Level | % | REL0444A |
| SG LEVEL 4/D | Steam Generator 4 (or D) Water Level | % | REL0464A |
| SG PRESS 1/A | Steam Generator 1 (or A) Pressure | PSIG | SPDSH263 |
| SG PRESS 2/B | Steam Generator 2 (or B) Pressure | PSIG | SPDSH264 |
| SG PRESS 3/C | Steam Generator 3 (or C) Pressure | PSIG | SPDSH265 |
| SG PRESS 4/D | Steam Generator 4 (or D) Pressure | PSIG | SPDSH266 |
| MN FD FL 1/A | Stm Gen 1 (or A) Main Feedwater Flow | KLB/HR | SPDSH005 |
| MN FD FL 2/B | Stm Gen 2 (or B) Main Feedwater Flow | KLB/HR | SPDSH007 |
| MN FD FL 3/C | Stm Gen 3 (or C) Main Feedwater Flow | KLB/HR | SPDSH008 |
| MN FD FL 4/D | Stm Gen 4 (or D) Main Feedwater Flow | KLB/HR | SPDSH250 |
| AX FD FL 1/A | Stm Gen 1 (or A) Auxiliary FW Flow | KLB/HR | ALF0702 |
| AX FD FL 2/B | Stm Gen 2 (or B) Auxiliary FW Flow | KLB/HR | ALF0703 |
| AX FD FL 3/C | Stm Gen 3 (or C) Auxiliary FW Flow | KLB/HR | ALF0704 |
| AX FD FL 4/D | Stm Gen 4 (or D) Auxiliary FW Flow | KLB/HR | ALF0701 |
| HL TEMP 1/A | Stm Gen 1 (or A) Inlet Temperature | F | RET0419A |
| HL TEMP 2/B | Stm Gen 2 (or B) Inlet Temperature | F | RET0439A |
| HL TEMP 3/C | Stm Gen 3 (or C) Inlet Temperature | F | RET0459A |
| HL TEMP 4/D | Stm Gen 4 (or D) Inlet Temperature | F | RET0479A |
| CL TEMP 1/A | Stm Gen 1 (or A) Outlet Temperature | F | RET0406A |
| CL TEMP 2/B | Stm Gen 2 (or B) Outlet Temperature | F | RET0426A |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

CRITICAL SAFETY FUNCTION PARAMETERS

| | | | |
|-------------|-------------------------------------|---|----------|
| CL TEMP 3/C | Stm Gen 3 (or C) Outlet Temperature | F | RET0446A |
| CL TEMP 4/D | Stm Gen 4 (or D) Outlet Temperature | F | RET0466A |

| PARAMETER | PARAMETER DESCRIPTION | UNITS | COMPUTER POINT |
|-----------|-----------------------|-------|----------------|
|-----------|-----------------------|-------|----------------|

RCS INTEGRITY

| | | | |
|--------------|--|--------|----------|
| RCS PRESSURE | Reactor Coolant System Pressure | PSIG | SPDSP252 |
| PRZR LEVEL | Primary System Pressurizer Level | % | REU0483 |
| RCS CHG/MU | Primary System Charging or Makeup Flow | GPM | REU0503 |
| HP SI FLOW | High Pressure Safety Injection Flow | GPM | REU0502 |
| LP SI FLOW | Low Pressure Safety Injection Flow | GPM | REU0501 |
| CTMNT SMP NR | Containment Sump Narrow Range Level | INCHES | LFL0702 |
| CTMNT SMP WR | Containment Sump Wide Range Level | INCHES | LFL0701 |

RADIOACTIVITY CONTROL

| | | | |
|--------------|-------------------------------------|--------|----------|
| EFF GAS RAD | Radioactivity of Released Gasses | UCI/ML | GTR0021B |
| EFF GAS RAD | Radioactivity of Released Gasses | UCI/ML | GHR0010B |
| EFF GAS RAD | Radioactivity of Released Gasses | MR/HR | FCR0385 |
| EFF LIQ RAD | Radioactivity of Released Liquids | UCI/ML | HBR0018 |
| COND A/E RAD | Condenser Air Ejector Radioactivity | UCI/ML | GER0092 |
| CNMNT RAD | Radiation Level in the Containment | R/HR | SPDSC254 |
| RCS LTDN RAD | Rad Level of the RCS Letdown Line | UCI/ML | SJR0001 |

| | | | |
|-------------|---------------------------------------|--|--|
| MAIN SL 1/A | Stm Gen 1 (or A) Steam Line Rad Level | | |
| MAIN SL 2/B | Stm Gen 2 (or B) Steam Line Rad Level | | |
| MAIN SL 3/C | Stm Gen 3 (or C) Steam Line Rad Level | | |
| MAIN SL 4/D | Stm Gen 4 (or D) Steam Line Rad Level | | |

| | | | |
|----|-------------------------------|-------|---------|
| NL | Stm Line A PORV Disch Rad Mon | MR/HR | ABR0111 |
| NL | Stm Line B PORV Disch Rad Mon | MR/HR | ABR0112 |
| NL | Stm Line C PORV Disch Rad Mon | MR/HR | ABR0113 |
| NL | Stm Line D PORV Disch Rad Mon | MR/HR | ABR0114 |

| | | | |
|--------------|-------------------------------------|--------|---------|
| SG BD RAD 1A | Stm Gen 1 (or A) Blowdown Rad Level | UCI/ML | BMR0025 |
| SG BD RAD 2B | Stm Gen 2 (or B) Blowdown Rad Level | | |
| SG BD RAD 3C | Stm Gen 3 (or C) Blowdown Rad Level | | |
| SG BD RAD 4D | Stm Gen 4 (or D) Blowdown Rad Level | | |

CONTAINMENT CONDITIONS

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

CRITICAL SAFETY FUNCTION PARAMETERS

| | | | |
|-------------|------------------------------------|------|----------|
| CTMNT PRESS | Containment Pressure | PSIG | SPDSC253 |
| CTMNT TEMP | Containment Temperature | F | GNT0701 |
| H2 CONC | Containment Hydrogen Concentration | % | SPDSCH2A |

| PARAMETER | PARAMETER DESCRIPTION | UNITS | COMPUTER POINT |
|-----------|-----------------------|-------|----------------|
|-----------|-----------------------|-------|----------------|

MISCELLANEOUS PARAMETERS

| | | | |
|------------|------------------------------------|-------|----------|
| BWST LEVEL | Borated Water Storage Tank Level | % | REU0511 |
| WIND SPEED | Wind Speed at the Reactor Site | MPH | RDS5010A |
| WIND SPEED | Wind Speed at the Reactor Site | MPH | RDS5060A |
| WIND DIR | Wind Direction at the Reactor Site | DEGFR | RDZ5010A |
| WIND DIR | Wind Direction at the Reactor Site | DEGFR | RDZ5060A |
| STAB CLASS | Air Stability at the Reactor Site | STABI | RDU0701A |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

SECTION 2

ERDS DATA POINT LIBRARY

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: NI POWER RNG
Point ID: SPDSS102
Plant Spec Point Desc: POWER RANGE LEVEL AVG
Generic/Cond Desc: NUCLEAR INSTR POWER RANGE
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: EACH 1% EQUALS APROX. 12 MW
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.200E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 4
How Processed: AVERAGE
Sensor Locations: REACTOR CAVITY
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: NI INTER RNG
Point ID: REU0640
Plant Spec Point Desc: AVERAGE INTERMEDIATE RANGE Q
Generic/Cond Desc: NUCLEAR INSTR INTERMEDIATE RANGE
Analog/Digital: A
Engr Units/Dig States: AMPS
Engr Units Conversion: N/A
Minimum Instr Range: 1.000E-11
Maximum Instr Range: 1.000E-03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 2
How Processed: AVERAGE
Sensor Locations: REACTOR CAVITY
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: NI SOURC RNG
Point ID: SPDSS286
Plant Spec Point Desc: SOURCE RANGE POWER LEVEL AVG
Generic/Cond Desc: NUCLEAR INSTR SOURCE RANGE
Analog/Digital: A
Engr Units/Dig States: CPS
Engr Units Conversion: N/A
Minimum Instr Range: 2.500E-01
Maximum Instr Range: 1.000E+06
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 2
How Processed: AVERAGE
Sensor Locations: REACTOR CAVITY
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: 1E-10 AMPS
NI Detector Power Supply
Turn-on Power Level: >1E-10 AMPS
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: NL
Point ID: SEN0701
Plant Spec Point Desc: POST ACCIDENT WIDE RANGE
Generic/Cond Desc: POST ACCIDENT WIDE RANGE
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: PERCENT * E-03
Minimum Instr Range: 1.000E-08
Maximum Instr Range: 2.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 2
How Processed: AVERAGE
Sensor Locations: REACTOR CAVITY
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|----------------------------|
| Date: | 10/01/91 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | NL |
| Point ID: | SEN0702 |
| Plant Spec Point Desc: | POST ACCIDENT SOURCE RANGE |
| Generic/Cond Desc: | POST ACCIDENT SOURCE RANGE |
| Analog/Digital: | A |
| Engr Units/Dig States: | CPS |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 1.000E-01 |
| Maximum Instr Range: | 1.000E+05 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 2 |
| How Processed: | AVERAGE |
| Sensor Locations: | REACTOR CAVITY |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: REAC VES LEV
Point ID: REU0523
Plant Spec Point Desc: RX VESSEL WR A/B LEVEL AVG
Generic/Cond Desc: REACTOR VESSEL WATER LEVEL
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: TOTAL INSIDE FLUID HEIGHT 494.9 INCHES
Minimum Instr Range: -2.500E+00
Maximum Instr Range: 1.250E+02
Zero Point Reference: COMPLX
Reference Point Notes: BOTTOM OF VESSEL
PROC or SENS: P
Number of Sensors: 2
How Processed: AVERAGE
Sensor Locations: REACTOR VESSEL
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: WET
Unique System Desc: USES DIFFERENTIAL PRESSURE ACROSS THE
VESSEL TO DETERMINE VESSEL LEVEL OR
RELATIVE VOID CONTENT OF THE CIRCULATING
PRIMARY COOLANT SYSTEM FLUID.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|---------------------------|
| Date: | 8/29/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | TEMP CORE EX |
| Point ID: | RJUITC08 |
| Plant Spec Point Desc: | HOTTEST NON BAD TC 1MA |
| Generic/Cond Desc: | HIGHEST TEMP AT CORE EXIT |
| Analog/Digital: | A |
| Engr Units/Dig States: | F |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 2.300E+03 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 50 |
| How Processed: | MAXIMUM |
| Sensor Locations: | REACTOR VESSEL |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|---|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | SUB MARGIN |
| Point ID: | SPDSC252 |
| Plant Spec Point Desc: | RCS COOLANT SUBCOOLING |
| Generic/Cond Desc: | SATURATION TEMP - HIGHEST CET |
| Analog/Digital: | A |
| Engr Units/Dig States: | F |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | -2.000E+02 |
| Maximum Instr Range: | 2.000E+03 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 4 |
| How Processed: | AVERAGE OF LOWEST VALUE FROM EACH TRAIN |
| Sensor Locations: | REACTOR VESSEL |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/01/91
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: CORE FLOW
Point ID: REU0487
Plant Spec Point Desc: REACTOR COOLANT LOOP AVE FLOW
Generic/Cond Desc: TOTAL REACTOR COOLANT FLOW
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: EACH 1% EQUALS APROX. 1.394E+06 LB/HR
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.200E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 12
How Processed: AVERAGE
Sensor Locations: CROSSOVER LEG
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/31/2005
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG LEVEL 1/A
Point ID: REL0404A
Plant Spec Point Desc: SG A WR LEVEL
Generic/Cond Desc: STEAM GEN A WATER LEVEL
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: 100% = 586.9 INCHES
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.000E+02
Zero Point Reference: TUBSHT
Reference Point Notes: 13 INCHES ABOVE TUBE SHEET
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: STEAM GENERATOR A
Alarm/Trip Set Points: HIHI/HI /LO /LOLO
97 /92 /NA /NA (Plant mode 1-3)
97 /92 /87 /NA (Plant mode 4)
NA /NA /87 /NA (Plant mode 5-6)

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: WET
Unique System Desc: 73.3% IS TOP OF HIGHEST TUBE.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/31/2005
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG LEVEL 2/B
Point ID: REL0424A
Plant Spec Point Desc: SG B WR LEVEL
Generic/Cond Desc: STEAM GEN B WATER LEVEL
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: 100% = 586.9 INCHES
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.000E+02
Zero Point Reference: TUBSHT
Reference Point Notes: 13 INCHES ABOVE TUBE SHEET
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: STEAM GENERATOR B
Alarm/Trip Set Points: HIHI/HI /LO /LOLO
97 /92 /NA /NA (Plant mode 1-3)
97 /92 /87 /NA (Plant mode 4)
NA /NA /87 /NA (Plant mode 5-6)

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: WET
Unique System Desc: 73.3% IS TOP OF HIGHEST TUBE.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/31/2005
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG LEVEL 3/C
Point ID: REL0444A
Plant Spec Point Desc: SG C WR LEVEL
Generic/Cond Desc: STEAM GEN C WATER LEVEL
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: 100% = 586.9 INCHES
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.000E+02
Zero Point Reference: TUBSHT
Reference Point Notes: 13 INCHES ABOVE TUBE SHEET
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: STEAM GENERATOR C
Alarm/Trip Set Points
HIHI/HI /LO /LOLO
97 /92 /NA /NA (Plant mode 1-3)
97 /92 /87 /NA (Plant mode 4)
NA /NA /87 /NA (Plant mode 5-6)

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: WET
Unique System Desc: 73.3% IS TOP OF HIGHEST TUBE.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/31/2005
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG LEVEL 4/D
Point ID: REL0464A
Plant Spec Point Desc: SG D WR LEVEL
Generic/Cond Desc: STEAM GEN D WATER LEVEL
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: 100% = 586.9 INCHES
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.000E+02
Zero Point Reference: TUBSHT
Reference Point Notes: 13 INCHES ABOVE TUBE SHEET
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: STEAM GENERATOR D
Alarm/Trip Set Points: HIHI/HI /LO /LOLO
97 /92 /NA /NA (Plant mode 1-3)
97 /92 /87 /NA (Plant mode 4)
NA /NA /87 /NA (Plant mode 5-6)

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: 73.3% IS TOP OF HIGHEST TUBE.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG PRESS 1/A
Point ID: SPDSH263
Plant Spec Point Desc: SG A AVG PRESSURE
Generic/Cond Desc: STEAM GENERATOR A PRESSURE
Analog/Digital: A
Engr Units/Dig States: PSIG
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.300E+03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 3
How Processed: AVERAGE
Sensor Locations: SECONDARY SIDE DOWNSTREAM SG A
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG PRESS 2/B
Point ID: SPDSH264
Plant Spec Point Desc: SG B AVG PRESSURE
Generic/Cond Desc: STEAM GENERATOR B PRESSURE
Analog/Digital: A
Engr Units/Dig States: PSIG
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.300E+03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 3
How Processed: AVERAGE
Sensor Locations: SECONDARY SIDE DOWNSTREAM SG B
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG PRESS 3/B
Point ID: SPDSH265
Plant Spec Point Desc: SG C AVG PRESSURE
Generic/Cond Desc: STEAM GENERATOR C PRESSURE
Analog/Digital: A
Engr Units/Dig States: PSIG
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.300E+03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 3
How Processed: AVERAGE
Sensor Locations: SECONDARY SIDE DOWNSTREAM SG C
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG PRESS 4/D
Point ID: SPDSH266
Plant Spec Point Desc: SG D AVG PRESSURE
Generic/Cond Desc: STEAM GENERATOR D PRESSURE
Analog/Digital: A
Engr Units/Dig States: PSIG
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.300E+03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 3
How Processed: AVERAGE
Sensor Locations: SECONDARY SIDE DOWNSTREAM SG D
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: MN FD FL 1/A
Point ID: SPDSH005
Plant Spec Point Desc: SG A MAIN FEEDWATER FLOW
Generic/Cond Desc: STM GEN A MAIN FEEDWATER FLOW
Analog/Digital: A
Engr Units/Dig States: KLB/HR
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 5.000E+03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 2
How Processed: AVERAGE
Sensor Locations: FROM FEEDWATER SYSTEM UPSTREAM SG A
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: MN FD FL 2/B
Point ID: SPDSH007
Plant Spec Point Desc: SG B MAIN FEEDWATER FLOW
Generic/Cond Desc: STM GEN B MAIN FEEDWATER FLOW
Analog/Digital: A
Engr Units/Dig States: KLB/HR
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 5.000E+03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 2
How Processed: AVERAGE
Sensor Locations: FROM FEEDWATER SYSTEM UPSTREAM SG B
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: MN FD FL 3/C
Point ID: SPDSH008
Plant Spec Point Desc: SG C MAIN FEEDWATER FLOW
Generic/Cond Desc: STM GEN C MAIN FEEDWATER FLOW
Analog/Digital: A
Engr Units/Dig States: KLB/HR
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 5.000E+03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 2
How Processed: AVERAGE
Sensor Locations: FROM FEEDWATER SYSTEM UPSTREAM SG C
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: MN FD FL 4/D
Point ID: SPDSH250
Plant Spec Point Desc: SG D MAIN FEEDWATER FLOW
Generic/Cond Desc: STM GEN D MAIN FEEDWATER FLOW
Analog/Digital: A
Engr Units/Dig States: KLB/HR
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 5.000E+03
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 2
How Processed: AVERAGE
Sensor Locations: FROM FEEDWATER SYSTEM UPSTREAM SG D
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: AX FD FL 1/A
Point ID: ALF0702
Plant Spec Point Desc: AFW TO SG A FLOW
Generic/Cond Desc: STM GEN A AUXILIARY FW FLOW
Analog/Digital: A
Engr Units/Dig States: KLB/HR
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 2.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: FROM AUX FEEDWATER SYSTEM UPSTREAM SG A
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: AX FD FL 2/B
Point ID: ALF0703
Plant Spec Point Desc: AFW TO SG B FLOW
Generic/Cond Desc: STM GEN B AUXILIARY FW FLOW
Analog/Digital: A
Engr Units/Dig States: KLB/HR
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 2.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: FROM AUX FEEDWATER SYSTEM UPSTREAM SG B
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: AX FD FL 3/C
Point ID: ALF0704
Plant Spec Point Desc: AFW TO SG C FLOW
Generic/Cond Desc: STM GEN C AUXILIARY FW FLOW
Analog/Digital: A
Engr Units/Dig States: KLB/HR
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 2.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: FROM AUX FEEDWATER SYSTEM UPSTREAM SG C
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 8/29/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: AX FD FL 4/D
Point ID: ALF0701
Plant Spec Point Desc: AFW TO SG D FLOW
Generic/Cond Desc: STM GEN D AUXILIARY FW FLOW
Analog/Digital: A
Engr Units/Dig States: KLB/HR
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 2.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: FROM AUX FEEDWATER SYSTEM UPSTREAM SG D
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: HL TEMP 1/A
Point ID: RET0419A
Plant Spec Point Desc: RCS LOOP A WR HOT LEG TEMP
Generic/Cond Desc: STM GEN A INLET TEMPERATURE
Analog/Digital: A
Engr Units/Dig States: F
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 7.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: LOOP 1 HOT LEG
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: HL TEMP 2/B
Point ID: RET0439A
Plant Spec Point Desc: RCS LOOP B WR HOT LEG TEMP
Generic/Cond Desc: STM GEN B INLET TEMPERATURE
Analog/Digital: A
Engr Units/Dig States: F
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 7.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: LOOP 2 HOT LEG
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: HL TEMP 3/C
Point ID: RET0459A
Plant Spec Point Desc: RCS LOOP C WR HOT LEG TEMP
Generic/Cond Desc: STM GEN C INLET TEMPERATURE
Analog/Digital: A
Engr Units/Dig States: F
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 7.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: LOOP 3 HOT LEG
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: HL TEMP 4/D
Point ID: RET0479A
Plant Spec Point Desc: RCS LOOP D WR HOT LEG TEMP
Generic/Cond Desc: STM GEN D INLET TEMPERATURE
Analog/Digital: A
Engr Units/Dig States: F
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 7.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: LOOP 4 HOT LEG
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: CL TEMP 1/A
Point ID: RET0406A
Plant Spec Point Desc: RCS LOOP A WR COLD LEG TEMP
Generic/Cond Desc: STM GEN A OUTLET TEMPERATURE
Analog/Digital: A
Engr Units/Dig States: F
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 7.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: LOOP 1 COLD LEG
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537.

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: CL TEMP 2/B
Point ID: RET0426A
Plant Spec Point Desc: RCS LOOP B WR COLD LEG TEMP
Generic/Cond Desc: STM GEN B OUTLET TEMPERATURE
Analog/Digital: A
Engr Units/Dig States: F
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 7.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: LOOP 2 COLD LEG
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: CL TEMP 3/C
Point ID: RET0446A
Plant Spec Point Desc: RCS LOOP C WR COLD LEG TEMP
Generic/Cond Desc: STM GEN C OUTLET TEMPERATURE
Analog/Digital: A
Engr Units/Dig States: F
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 7.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: LOOP 3 COLD LEG
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|------------------------------|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | CL TEMP 4/D |
| Point ID: | RET0466A |
| Plant Spec Point Desc: | RCS LOOP D WR COLD LEG TEMP |
| Generic/Cond Desc: | STM GEN D OUTLET TEMPERATURE |
| Analog/Digital: | A |
| Engr Units/Dig States: | F |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 7.000E+02 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | S |
| Number of Sensors: | 1 |
| How Processed: | N/A |
| Sensor Locations: | LOOP 4 COLD LEG |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|---------------------------------|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | RCS WR AVG PRESSURE |
| Point ID: | SPDSP252 |
| Plant Spec Point Desc: | RCS WR AVG PRESSURE |
| Generic/Cond Desc: | REACTOR COOLANT SYSTEM PRESSURE |
| Analog/Digital: | A |
| Engr Units/Dig States: | PSIG |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 3.000E+03 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 2 |
| How Processed: | AVERAGE |
| Sensor Locations: | TUBING FROM REACTOR VESSEL |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | Y |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 08/29/08
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: PRZR LEVEL
Point ID: REU0483
Plant Spec Point Desc: PZR LEVEL 1/2/3 AVG
Generic/Cond Desc: PRIMARY SYSTEM PRESSURIZER LEVEL
Analog/Digital: A
Engr Units/Dig States: %
Engr Units Conversion: 100% = 555 INCHES
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.000E+02
Zero Point Reference: COMPLX
Reference Point Notes: 40 INCHES ABOVE PRESSURIZER BOTTOM
PROC or SENS: P
Number of Sensors: 3
How Processed: AVERAGE
Sensor Locations: PRESSURIZER
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: Y
Level Reference Leg: WET
Unique System Desc: PRESSURIZER VOLUME IS 1800 CUBIC
FEET. HEATER TOPS AT 17.5% LEVEL.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|---------------------------------------|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | RCS CHG/MU |
| Point ID: | REU0503 |
| Plant Spec Point Desc: | CHG PUMP SI FLOW |
| Generic/Cond Desc: | PRI SYS CHARGING OR MAKEUP FLOW |
| Analog/Digital: | A |
| Engr Units/Dig States: | GPM |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 1.140E+03 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 2 |
| How Processed: | SUM |
| Sensor Locations: | UPSTREAM OF CENTRIFUGAL CHARGING PUMP |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | Y |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|--------------------------------|
| Date: | 10/01/91 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | HP SI FLOW |
| Point ID: | REU0502 |
| Plant Spec Point Desc: | SI PUMP DISCHARGE FLOW |
| Generic/Cond Desc: | HI PRESS SAFETY INJECTION FLOW |
| Analog/Digital: | A |
| Engr Units/Dig States: | GPM |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 1.600E+03 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 2 |
| How Processed: | SUM |
| Sensor Locations: | DOWNSTREAM SI PUMPS |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | Y |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|--------------------------------|
| Date: | 10/01/91 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | LP SI FLOW |
| Point ID: | REU0501 |
| Plant Spec Point Desc: | RHR FLOW |
| Generic/Cond Desc: | LO PRESS SAFETY INJECTION FLOW |
| Analog/Digital: | A |
| Engr Units/Dig States: | GPM |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 1.450E+04 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 3 |
| How Processed: | SUM |
| Sensor Locations: | DOWNSTREAM RHR PUMPS |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | Y |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|----------------------------------|
| Date: | 8/29/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | CTMNT SMP NR |
| Point ID: | LFL0702 |
| Plant Spec Point Desc: | CTMT NORMAL SUMP NR LEVEL |
| Generic/Cond Desc: | CONTAINMENT SMP NARROW RANGE LVL |
| Analog/Digital: | A |
| Engr Units/Dig States: | IN |
| Engr Units Conversion: | 9.77 GAL/INCH |
| Minimum Instr Range: | 1.175E+01 |
| Maximum Instr Range: | 2.575E+01 |
| Zero Point Reference: | TNKBOT |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 2 |
| How Processed: | MAXIMUM |
| Sensor Locations: | CONTAINMENT NORMAL SUMPS |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | Y |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|--------------------------------|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | CTMNT SMP WR |
| Point ID: | LFL0701 |
| Plant Spec Point Desc: | CTMT NORMAL SUMP WR LEVEL |
| Generic/Cond Desc: | CONTAINMENT SMP WIDE RANGE LVL |
| Analog/Digital: | A |
| Engr Units/Dig States: | IN |
| Engr Units Conversion: | 41.6 GAL/INCH |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 1.560E+02 |
| Zero Point Reference: | TNKBOT |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 2 |
| How Processed: | MAXIMUM |
| Sensor Locations: | CONTAINMENT NORMAL SUMPS |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | Y |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: EFF GAS RAD
Point ID: GTR0021B
Plant Spec Point Desc: UNIT VENT GAS RAD MON
Generic/Cond Desc: RADIOACTIVITY OF RELEASED GASSES
Analog/Digital: A
Engr Units/Dig States: UCI/ML
Engr Units Conversion: N/A
Minimum Instr Range: 1.000E-07
Maximum Instr Range: 1.000E+05
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: UNIT VENT DWNSTRM LAST PNT OF RAD ENTRY
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: UNIT VENT NOMINAL FLOW RATES (CFM)
16500 MN STM ENCLOSURE BLD EXHAUST
32000 FULL SPEED AUX/FUEL BLD EXHAUST
12000 SLOW SPEED
6300 ACCESS CONTROL
1000 COND AIR REMOVAL FILTRATION
20000 CONT. SHUTDOWN PURGE EXHAUST
4000 CONT. MINIPURGE EXHAUST
9000 FUEL BLD EMERG EXHAUST
ALERT/HIGH ALARMS PER ODCM ON RMS RM-11.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 04/09/92
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: EFFS GAS RAD
Point ID: GHR0010B
Plant Spec Point Desc: RADWASTE VENT GAS RAD MON
Generic/Cond Desc: RADIOACTIVITY OF RELEASED GASSES
Analog/Digital: A
Engr Units/Dig States: UCI/ML
Engr Units Conversion: 2.039E+10 ML/HR
Minimum Instr Range: 1.000E-07
Maximum Instr Range: 1.000E+05
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: DOWNSTREAM OF EXHAUST FILTER AND FANS
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MONITORS GASEOUS RADIOACTIVITY IN
THE EFFLUENT RADWASTE BUILDING DUCT.
ISOLATES WASTE GAS DECAY TANK
DISCHARGE LINE ON HIGH ALARM.
FLOW IS 12000 SCFM.
ALERT/HIGH ALARMS PER ODCM ON RMS
RM-11.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: EFFS GAS RAD
Point ID: FCR0385
Plant Spec Point Desc: AFW PUMP TURBINE DISCH RAD MON
Generic/Cond Desc: RADIOACTIVITY OF RELEASES GASSES
Analog/Digital: A
Engr Units/Dig States: MR/HR
Engr Units Conversion: N/A
Minimum Instr Range: 1.000E-02
Maximum Instr Range: 1.000E+05
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: VIEWS PLUME FROM TURBINE EXHAUST
Alarm/Trip Set Points: HIHI / HI /LO /LOLO
8.50E2 /1.5E2 /NA /NA

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MULTIPLY VALUE BY 5.51E-02 TO CONVERT
UNITS TO UCI/ML. THIS CONVERSION FACTOR
TAKES INTO CONSIDERATION PLUME SIZE AND
DISTANCE FACTORS.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 04/09/92
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: EFF LIQ. RAD
Point ID: HBR0018
Plant Spec Point Desc: RADWASTE LIQUID DIS RAD MON
Generic/Cond Desc: RADIOACTIVITY OF RELEASED LIQUID
Analog/Digital: A
Engr Units/Dig States: UCI/ML
Engr Units Conversion: MAX 2.082E+06 ML/MIN
Minimum Instr Range: 1.000E-07
Maximum Instr Range: 9.990E-02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: UPSTREAM OF DISCHARGE VALVE
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: HIGH RADIOACTIVITY ALARM CLOSES THE
LIQUID RADWASTE SYSTEM DISCHARGE
VALVE.
FLOW IS 0-550 GPM.
ALERT/HIGH ALARMS PER ODCM ON RMS
RM-11.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: COND A/E RAD
Point ID: GER0092
Plant Spec Point Desc: CONDENSER DISCHARGE RAD MONITOR
Generic/Cond Desc: CONDESER AIR EJECTOR RAD
Analog/Digital: A
Engr Units/Dig States: UCI/ML
Engr Units Conversion: 1.699E+09 ML/HR
Minimum Instr Range: 1.000E-07
Maximum Instr Range: 1.000E-02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: UPSTREAM OF COND AIR REMOVAL SYS
FILTERS
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: THIS MONITOR CLOSES STEAM GENERATOR
BLOWDOWN ISOLATION VALVE ON HIGH
ALARMS. DISCHARGES THROUGH UNIT
VENT.
FLOW IS 1000 SCFM.
ALERT/HIGH = 2.0E-06/2.0E-05 UCI/ML
ON RMS RM-11.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|------------------------------------|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | CNTMNT RAD |
| Point ID: | SPDSC254 |
| Plant Spec Point Desc: | CTMT HI RNG AREA RAD MON |
| Generic/Cond Desc: | RADIATION LEVEL IN CONTAINMENT |
| Analog/Digital: | A |
| Engr Units/Dig States: | R/HR |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 1.000E-01 |
| Maximum Instr Range: | 1.000E+08 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 2 |
| How Processed: | MAXIMUM |
| Sensor Locations: | INSIDE SURFACE OF CONTAINMENT WALL |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|---|
| Date: | 04/09/92 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | RCS LTDN RAD |
| Point ID: | SJR0001 |
| Plant Spec Point Desc: | CVCS LETDOWN RAD MON |
| Generic/Cond Desc: | RAD LVL OF RCS LETDOWN LINE |
| Analog/Digital: | A |
| Engr Units/Dig States: | UCI/ML |
| Engr Units Conversion: | MAX 640 ML/MIN |
| Minimum Instr Range: | 1.000E-03 |
| Maximum Instr Range: | 1.700E+03 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | S |
| Number of Sensors: | 1 |
| How Processed: | N/A |
| Sensor Locations: | UPSTREAM OF CVCS LETDOWN DEMINERALIZERS |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | VARIABLE ALERT/HIGH ALARMS ON RMS RM-11. MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/31/2005
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: NL
Point ID: ABR0111
Plant Spec Point Desc: STM LINE A PORV DISCH RAD MON
Generic/Cond Desc: STM LINE A PORV DISCH RAD MON
Analog/Digital: A
Engr Units/Dig States: MR/HR
Engr Units Conversion: N/A
Minimum Instr Range: 1.000E-02
Maximum Instr Range: 1.000E+05
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: VIEWS PLUME FROM SG A PORV
Alarm/Trip Set Points: HIHI /HI/LO/LOLO
1.46E2/27/NA/NA

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MULTIPLY VALUE BY 4.06E-02 TO CONVERT
UNITS TO UCI/ML. THIS CONVERSION
FACTOR TAKES INTO CONSIDERATION PLUME
SIZE AND DISTANCE FACTORS.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/31/2005
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: N/A
Point ID: ABR0112
Plant Spec Point Desc: STM LINE B PORV DISCH RAD MON
Generic/Cond Desc: STM LINE B PORV DISCH RAD MON
Analog/Digital: A
Engr Units/Dig States: MR/HR
Engr Units Conversion: N/A
Minimum Instr Range: 1.000E-02
Maximum Instr Range: 1.000E+05
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: VIEWS PLUME FROM SG B PORV
Alarm/Trip Set Points: HIHI /HI/LO/LOLO
1.46E2/27/NA/NA

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MULTIPLY VALUE BY 4.06E-02 TO CONVERT
UNITS TO UCI/ML. THIS CONVERSION
FACTOR TAKES INTO CONSIDERATION PLUME
SIZE AND DISTANCE FACTORS.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/31/2005
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: NL
Point ID: ABR0113
Plant Spec Point Desc: STM LINE C PORV DISCH RAD MON
Generic/Cond Desc: STM LINE C PORV DISCH RAD MON
Analog/Digital: A
Engr Units/Dig States: MR/HR
Engr Units Conversion: N/A
Minimum Instr Range: 1.000E-02
Maximum Instr Range: 1.000E+05
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: VIEWS PLUME FROM SG C PORV
Alarm/Trip Set Points: HIHI /HI/LO/LOLO
1.46E2/27/NA/NA

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MULTIPLY VALUE BY 4.06E-02 TO CONVERT
UNITS TO UCI/ML. THIS CONVERSION
FACTOR TAKES INTO CONSIDERATION PLUME
SIZE AND DISTANCE FACTORS.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/31/2005
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: NL
Point ID: ABR0114
Plant Spec Point Desc: STM LINE D PORV DISCH RAD MON
Generic/Cond Desc: STM LINE D PORV DISCH RAD MON
Analog/Digital: A
Engr Units/Dig States: MR/HR
Engr Units Conversion: N/A
Minimum Instr Range: 1.000E-02
Maximum Instr Range: 1.000E+05
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: VIEWS PLUME FROM SG D PORV
Alarm/Trip Set Points: HIHI /HI/LO/LOLO
1.46E2/27/NA/NA

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MULTIPLY VALUE BY 4.06E-02 TO CONVERT
UNITS TO UCI/ML. THIS CONVERSION
FACTOR TAKES INTO CONSIDERATION PLUME
SIZE AND DISTANCE FACTORS.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: SG BD RAD 1A
Point ID: BMR0025
Plant Spec Point Desc: SG BLOWDOWN PROCESS RAD MON
Generic/Cond Desc: STM GEN BLOWDOWN RADIATION LEVEL
Analog/Digital: A
Engr Units/Dig States: UCI/ML
Engr Units Conversion: MAX 640 ML/MIN
Minimum Instr Range: 1.000E-07
Maximum Instr Range: 1.000E-02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: DOWNSTREAM OF SAMPLE SYS HEAT EXCHANGER
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: MONITOR CLOSES STEAM GENERATOR
BLOWDOWN ISOLATION TO PREVENT THE
DISCHARGE OF RADIOACTIVE FLUID AND TO
LIMIT RADIOACTIVE CONTAMINATION OF
THE BLOWDOWN DEMINERALIZERS.
MONITORS DOWNSTREAM COMB OF 4 LOOPS.
RMS RM-11 ALERT/HIGH ALARMS =
1.0E-05/1.0E-04 UCI/ML.
MAY FAIL HIGH.

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|----------------------------------|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | CTMNT PRESS |
| Point ID: | SPDSC253 |
| Plant Spec Point Desc: | CTMT AVG PRESSURE |
| Generic/Cond Desc: | CONTAINMENT PRESSURE |
| Analog/Digital: | A |
| Engr Units/Dig States: | PSIG |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 6.900E+01 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 3 |
| How Processed: | AVERAGE |
| Sensor Locations: | CONTAINMENT BLDG 2026' ELEVATION |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | Y |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|----------------------------------|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | CTMNT TEMP |
| Point ID: | GNT0701 |
| Plant Spec Point Desc: | CTMT TEMP AVG |
| Generic/Cond Desc: | CONTAINMENT TEMPERATURE |
| Analog/Digital: | A |
| Engr Units/Dig States: | F |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 4.000E+02 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 4 |
| How Processed: | AVERAGE |
| Sensor Locations: | CONTAINMENT BLDG 2047' ELEVATION |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|---|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | H2 CONC |
| Point ID: | SPDSCH2A |
| Plant Spec Point Desc: | CTMT H2 AVG |
| Generic/Cond Desc: | CONTAINMENT HYDROGEN CONC |
| Analog/Digital: | A |
| Engr Units/Dig States: | % |
| Engr Units Conversion: | CONTAINMENT VOLUME = 2.5E+06 CUBIC FEET |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 1.000E+01 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | P |
| Number of Sensors: | 2 |
| How Processed: | AVERAGE |
| Sensor Locations: | CONTAINMENT BLDG 2047' ELEVATION |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|----------------------------------|
| Date: | 04/09/92 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | BWST LEVEL |
| Point ID: | REU0511 |
| Plant Spec Point Desc: | RWST LEVEL |
| Generic/Cond Desc: | BORATED WATER STORAGE TANK LEVEL |
| Analog/Digital: | A |
| Engr Units/Dig States: | % |
| Engr Units Conversion: | 100% = 419445 GALLONS |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 1.000E+02 |
| Zero Point Reference: | COMPLX |
| Reference Point Notes: | 0% = 18722 GALLONS |
| PROC or SENS: | P |
| Number of Sensors: | 4 |
| How Processed: | AVERAGE |
| Sensor Locations: | REFUELING WATER STORAGE TANK |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | Y |
| Level Reference Leg: | WET |
| Unique System Desc: | MAY FAIL HIGH. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 10/08/2007
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: WIND SPEED
Point ID: RDS5010A
Plant Spec Point Desc: MET TWR 10M A WIND SPEED
Generic/Cond Desc: WIND SPEED AT REACTOR SITE
Analog/Digital: A
Engr Units/Dig States: MPH
Engr Units Conversion: N/A
Minimum Instr Range: 0.000E+00
Maximum Instr Range: 1.000E+02
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: S
Number of Sensors: 1
How Processed: N/A
Sensor Locations: MET TOWER AT 10 METERS ELEVATION
Alarm/Trip Set Points: HIHI/HI/LO/LOLO
40 /NA/NA/NA

NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc:

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|----------------------------------|
| Date: | 10/08/2007 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | WIND SPEED |
| Point ID: | RDS5060A |
| Plant Spec Point Desc: | MET TOWER 60M A WIND SPEED |
| Generic/Cond Desc: | WIND SPEED AT REACTOR SITE |
| Analog/Digital: | A |
| Engr Units/Dig States: | MPH |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 1.000E+02 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | S |
| Number of Sensors: | 1 |
| How Processed: | N/A |
| Sensor Locations: | MET TOWER AT 60 METERS ELEVATION |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|--|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | WIND DIR |
| Point ID: | RDZ5010A |
| Plant Spec Point Desc: | MET TOWER 10M A WIND DIRECTION |
| Generic/Cond Desc: | WIND DIRECTION AT REACTOR SITE |
| Analog/Digital: | A |
| Engr Units/Dig States: | DEG |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 3.600E+02 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | S |
| Number of Sensors: | 1 |
| How Processed: | N/A |
| Sensor Locations: | MET TOWER AT 10 METERS ELEVATION |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MEASURED IN THE "FROM" DIRECTION. 0 DEG = NORTH. MAY FAIL IN ANY MODE. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

| | |
|--|--|
| Date: | 7/21/2008 |
| Reactor Unit: | CW1 |
| Data Feeder: | N/A |
| NRC ERDS Parameter: | WIND DIR |
| Point ID: | RDZ5060A |
| Plant Spec Point Desc: | MET TOWER 60M A WIND DIRECTION |
| Generic/Cond Desc: | WIND DIRECTION AT REACTOR SITE |
| Analog/Digital: | A |
| Engr Units/Dig States: | DEG |
| Engr Units Conversion: | N/A |
| Minimum Instr Range: | 0.000E+00 |
| Maximum Instr Range: | 3.600E+02 |
| Zero Point Reference: | N/A |
| Reference Point Notes: | N/A |
| PROC or SENS: | S |
| Number of Sensors: | 1 |
| How Processed: | N/A |
| Sensor Locations: | MET TOWER AT 60 METERS ELEVATION |
| Alarm/Trip Set Points: | N/A |
| NI Detector Power Supply Cut-off Power Level: | N/A |
| NI Detector Power Supply Turn-on Power Level: | N/A |
| Instrument Failure Mode: | LOW |
| Temperature Compensation For DP Transmitters: | N/A |
| Level Reference Leg: | N/A |
| Unique System Desc: | MEASURED IN THE "FROM" DIRECTION. 0 DEG = NORTH. MAY FAIL IN ANY MODE. |

Enclosure
to ULNRC-05537

J-26060A
Rev. 5

DATA POINT LIBRARY REFERENCE FILE

Date: 7/21/2008
Reactor Unit: CW1
Data Feeder: N/A
NRC ERDS Parameter: STAB CLASS
Point ID: RDU0701A
Plant Spec Point Desc: MET TWR A STABILITY (1-7=A-G)
Generic/Cond Desc: AIR STABILITY AT REACTOR SITE
Analog/Digital: A
Engr Units/Dig States:
Engr Units Conversion: N/A
Minimum Instr Range: 1.000E+00
Maximum Instr Range: 7.000E+00
Zero Point Reference: N/A
Reference Point Notes: N/A
PROC or SENS: P
Number of Sensors: 7
How Processed: N/A
Sensor Locations: MET TOWER
Alarm/Trip Set Points: N/A
NI Detector Power Supply
Cut-off Power Level: N/A
NI Detector Power Supply
Turn-on Power Level: N/A
Instrument Failure Mode: LOW
Temperature Compensation
For DP Transmitters: N/A
Level Reference Leg: N/A
Unique System Desc: STABILITY PRIMARILY BASED ON RATE OF
VERTICAL TEMPERATURE CHANGE. IF NOT
VALIDATED GOOD, STABILITY IS BASED ON
STANDARD DEVIATION OF WIND DIRECTION
WHEN WIND SPEEDS ARE ABOVE 1 M/S.

- 1 = EXTREMELY UNSTABLE
- 2 = MODERATELY UNSTABLE
- 3 = SLIGHTLY UNSTABLE
- 4 = NEUTRAL
- 5 = SLIGHTLY STABLE
- 6 = MODERATELY STABLE
- 7 = EXTREMELY STABLE