

Rancho Seco
Final Status Survey Summary Report
June 24, 2008
Decon Room +0' AB Room 134
Survey Unit F8131231

Prepared By: Gin L. Brown Date: 6/24/2008
FSS Engineer

Reviewed By: Robert F. Decker Date: 7/3/08
Lead FSS Engineer

Approved By: S. P. [Signature] Date: 7-28-08
Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8131231, Decon Room +0' AB Room 134

Survey Unit Description:

Operating History: The reinforced concrete structure contained the RadWaste processing and supporting systems. The building contained six main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure. One report documented contamination of the auxiliary building roof. The roof was later replaced.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements on the -47' elevation showed a mean gross activity level of 320,071 dpm/100 cm² and a maximum value of 5,720,000 dpm/100 cm². Direct measurements on the -29' elevation showed a mean gross activity level of 544,756 dpm/100 cm² and a maximum value of 11,370,000 dpm/100 cm². Direct measurements on the -20' elevation showed a mean gross activity level of 247,831 dpm/100 cm² and a maximum value of 10,080,000 dpm/100 cm². Direct measurements on the grade elevation showed a mean gross activity level of 373,758 dpm/100 cm² and a maximum value of 5,800,000 dpm/100 cm². Direct measurements on the +20' elevation showed a mean gross activity level of 85,408 dpm/100 cm² and a maximum value of 1,900,000 dpm/100 cm². Direct measurements on the +40' elevation showed a mean gross activity level of 3,288 dpm/100 cm² and a maximum value of 24,781 dpm/100 cm². Direct measurements on the building exterior, including the mezzanine roof, showed a mean gross activity level of 1,897 dpm/100 cm² and a maximum value of 2,990 dpm/100 cm². (The roof had been replaced prior to the classification survey.) Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the interior of the auxiliary building was determined to be a Class 1, 2 area and the exterior was a Class 2,3.

HSA Events: HSA Report pg. 63.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 260 m² were scanned for 100% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Table 1. Survey Unit Design Parameters

Survey Design Parameter	Value	Comment
Survey Area:	F813	Decon Room +0' AB Room 134
Survey Unit:	1231	Structure Surface
Class:	1	LTP Table 5-4
SU Area (m²):	260	
Evaluator:	Erin L. Brown	
DCGL (dpm/100 cm²):	43000	Gross Activity DCGL
Area Factor:	3.6	Class 1
Design DCGL_{mc} (dpm/100 cm²):	155071	Class 1
LBGR (dpm/100 cm²):	21500	Default = 50% DCGL
Design Sigma (dpm/100 cm²):	6935	
Type I Error:	0.05	
Type II Error:	0.05	
Predominant Nuclide:	Cs-137	
Sample Area (m²):	6.8	Class 1
Scan Area (m²):	260	
Scan Coverage (%):	100%	Class 1
Z_{1-α}:	1.645	
Z_{1-β}:	1.645	
Sign P:	0.99865	
Calculated Relative Shift:	3.1	
Relative Shift Used:	3	Uses 3.0 if Relative Shift is >3
N-Value:	11	
Design N-Value + 20%:	14	NUREG-1575 Table 5-5
Design Min Samples N:	38	Class 1
Grid Spacing L:	2.6	Class 1

Survey Results:

A total of 38 direct measurements were made in F8131231. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Scan activity ranged from 1727 to 13001 dpm/100 cm², based on a surveyor efficiency of 0.5 and no background subtracted. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Table 2. Direct Measurement Results

Measurement ID	Gross Activity (dpm/100 cm ²)
F8131231-C0001BD	2403
F8131231-C0002BD	2513
F8131231-C0003BD	2392
F8131231-C0004BD	2668
F8131231-C0005BD	2337
F8131231-C0006BD	2612
F8131231-C0007BD	3020
F8131231-C0008BD	2315
F8131231-C0009BD	2172
F8131231-C0010BD	3252
F8131231-C0011BD	3042
F8131231-C0012BD	3296
F8131231-C0013BD	2304
F8131231-C0014BD	2756
F8131231-C0015BD	2767
F8131231-C0016BD	3252
F8131231-C0017BD	2712
F8131231-C0018BD	2910
F8131231-C0019BD	3042
F8131231-C0020BD	2116
F8131231-C0021BD	2568
F8131231-C0022BD	2910
F8131231-C0023BD	3131
F8131231-C0024BD	2811
F8131231-C0025BD	3031
F8131231-C0026BD	2756
F8131231-C0027BD	1885
F8131231-C0028BD	5556
F8131231-C0029BD	2767
F8131231-C0030BD	2381
F8131231-C0031BD	2943
F8131231-C0032BD	2778
F8131231-C0033BD	2712
F8131231-C0034BD	2976
F8131231-C0035BD	3053
F8131231-C0036BD	2910

F8131231-C0037BD	2855
F8131231-C0038BD	2877
Mean:	2810
Median:	2772
Standard Deviation:	566
Range:	1885 - 5556

Table 3. Removable Surface Activity Results

Measurement ID	Surface Beta Activity (dpm/100 cm ²)
F8131231C0001SM	-0.95
F8131231C0002SM	-3.53
F8131231C0003SM	-4.82
F8131231C0004SM	1.64
F8131231C0005SM	-2.24
F8131231C0006SM	-3.53
F8131231C0007SM	-3.53
F8131231C0008SM	-3.53
F8131231C0009SM	-3.53
F8131231C0010SM	-0.95
F8131231C0011SM	-0.95
F8131231C0012SM	-3.53
F8131231C0013SM	-0.95
F8131231C0014SM	-3.53
F8131231C0015SM	-3.53
F8131231C0016SM	-4.82
F8131231C0017SM	-3.53
F8131231C0018SM	-2.24
F8131231C0019SM	-2.24
F8131231C0020SM	-3.53
F8131231C0021SM	0.34
F8131231C0022SM	-3.53
F8131231C0023SM	-3.53
F8131231C0024SM	-0.95
F8131231C0025SM	-2.24
F8131231C0026SM	-4.82
F8131231C0027SM	-3.53
F8131231C0028SM	-3.53
F8131231C0029SM	0.34
F8131231C0030SM	-3.53
F8131231C0031SM	-2.24
F8131231C0032SM	-4.82
F8131231C0033SM	-6.11
F8131231C0034SM	-3.53
F8131231C0035SM	-4.82
F8131231C0036SM	-0.95
Mean:	-2.81
Median:	-3.53
Standard Deviation:	1.7
Range:	-6.11 to 1.64

Survey Unit Data Assessment:

The survey design required 38 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Table 4. Data Assessment Results

Survey Results Parameter	Value	Comment
Material Background Used (dpm/100 cm ²):	N/A	Average Ambient BKG = 0
Ambient Background Used (dpm/100 cm ²):	N/A	
Actual Direct Measurements (N):	38	
Median (dpm/100 cm ²):	2772	
Mean (dpm/100 cm ²):	2810	
Direct Measurement Standard Deviation (dpm/100 cm ²):	566	Based on samples and backgrounds.
Total Standard Deviation (dpm/100 cm ²):	566	
Maximum (dpm/100 cm ²):	5556	
Material Type:	N/A	
Sign Test Final N Value:	38	
S+ Value:	38	Background Subtract Not Applied
Critical Value:	24	
Sufficient Samples Collected:	Yes	
Maximum Value < DCGL:	Yes	
Median Value < DCGL:	Yes	
Mean Value < DCGL:	Yes	Class 1
Maximum Value < DCGL_{mc}:	Yes	
Total Standard Deviation <= Sigma:	Yes	
Pass the Sign Test?	Yes	
Reject the Null Hypothesis?	Yes	
Does the Survey Unit Pass All Criteria?	Yes	

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 1 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 1 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8131231 meets the release criteria of 10CFR20.1402.


Attachment 1


Maps



June 24, 2008

Survey Unit F8131231









Scale Feet

1" = 1'-0"

Scale Meters



SMUD



SACRAMENTO MUNICIPAL
UTILITY DISTRICT

AUXILIARY BUILDING EL. 0'-0"
ROOM 134 BETA DIRECT/LOOSE
SURFACE MEASUREMENT LOCATIONS
F8131231-M2

DATE: 01/03/00


SHEET 3 OF 4

TC HILL



Scale Feet
1" = 1'-0"

Scale Meters



SMUD



SACRAMENTO MUNICIPAL
UTILITY DISTRICT

AUXILIARY BUILDING EL. 0'-0"
ROOM 134 BETA DIRECT/LOOSE
SURFACE MEASUREMENT LOCATIONS
F8131231-M2

PLD 310000.00

SHEET 4 OF 4

TC HILL






AUXILIARY BUILDING EL. 0'-0"
ROOM 134 BETA SCAN
MEASUREMENT LOCATIONS
F8131231-M3

CLD: 313000.00

SHEET 1 OF 3

TC HILL





Scale Feet

1" = 1'-0"

Scale Meters



SMUD

SACRAMENTO MUNICIPAL
UTILITY DISTRICT

AUXILIARY BUILDING EL. 0'-0"


ROOM 134 BETA SCAN
MEASUREMENT LOCATIONS


F8131231-M3

LC: 31000000

SHEET 3 OF 3

TC HILL





Attachment 2

Instrumentation

June 24, 2008

Survey Unit F8131231

Table 2-1. Survey Unit Instrumentation

Instrument Model; Serial No.	Detector Model; Serial No.	MDC Static (dpm/100 cm²)	MDC Scan (dpm/100 cm²)
M2350; 180733	43-98B; 148638	N/A	2520
M2350; 180733	43-94B; 148620	N/A	2800
M2350; 203486	43-68B; 190476	912	2176
M2350; 189089	43-68B; 161406	912	2176
M2350; 203486	43-68B; 161400	912	217+
M2350; 175834	43-116-1B; 190642	N/A	6854
M2350; 203486	43-116-1B; 190173	N/A	6854
Tennelec; 0401171	N/A	5.9 dpm α , 11.7 dpm β	N/A

The MDC noted for the detector model 43-98B is for the 4" diameter piping and for the detector model 43-94B is for the 2" diameter piping which are the most conservative.

Table 2-2. Investigation Criteria and DCGL

Parameter	Value (dpm/100 cm²)
Investigation Criteria - Direct	154800
Investigation Criteria – Scan	154800
DCGL _W	43000
DCGL _{EMC}	154800

Attachment 3

Investigation

June 24, 2008

Survey Unit F8131231

(none required)

Attachment 4

Data Assessment

June 24, 2008

Survey Unit F8131231

