Rancho Seco

Final Status Survey Summary Report

July 7, 2008

Electrical Penetration Room 209, 20' Auxiliary Building, Floor and Lower Walls

Survey Unit F8131381

Prepared By

Date:

FSS Engineer

10/08 **Reviewed By:** Date: Lead FSS Engineer -28-08 Approved By: Date: Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8131381, Electrical Penetration Room 209, 20' Auxiliary Building, Floor and Lower Walls

Survey Unit Description:

Operating History: The reinforced concrete structure contained the RadWaste processing and supporting systems. The building contained six main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure. One report documented contamination of the auxiliary building roof. The roof was later replaced.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements on the -47' elevation showed a mean gross activity level of 320,071 dpm/100 cm² and a maximum value of $5,720,000 \text{ dpm}/100 \text{ cm}^2$. Direct measurements on the -29' elevation showed a mean gross activity level of 544,756 dpm/100 cm² and a maximum value of 11,370,000 dpm/100 cm². Direct measurements on the -20' elevation showed a mean gross activity level of 247,831 dpm/100 cm² and a maximum value of 10,080,000 dpm/100 cm². Direct measurements on the grade elevation showed a mean gross activity level of 373,758 dpm/100 cm² and a maximum value of 5,800,000 dpm/100 cm². Direct measurements on the +20' elevation showed a mean gross activity level of $85,408 \text{ dpm}/100 \text{ cm}^2$ and a maximum value of $1,900,000 \text{ dpm}/100 \text{ cm}^2$. Direct measurements on the +40' elevation showed a mean gross activity level of 3,288 dpm/100 cm² and a maximum value of 24,781 dpm/100 cm². Direct measurements on the building exterior, including the mezzanine roof, showed a mean gross activity level of 1,897 dpm/100 cm² and a maximum value of $2.990 \text{ dpm}/100 \text{ cm}^2$. (The roof had been replaced prior to the classification survey.) Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the interior of the auxiliary building was determined to be a Class 1, 2 area and the exterior was a Class 2,3. The Electrical Penetration Room 209 floor and lower walls were determined to be a Class 1.

HSA Events: HSA Report pg. 63.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 184 m² were scanned for 100% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

| Survey Design Parameter | Value | · Comment |
|---|---------------|-------------------------------|
| Survey Area: | F813 | Electrical Penetration Room |
| | | 209, 20' Auxiliary Building, |
| | | Floor and Lower Walls |
| Survey Unit: | 1381 | Structure Surface |
| Class: | 1 | LTP Table 5-4 |
| SU Area (m ²): | 184 | |
| Evaluator: | Michael Stein | |
| DCGL (dpm/100 cm ²): | 43000 | Gross Activity DCGL |
| Area Factor: | 3.6 | Class 1 |
| Design DCGLemc | 154800 | Class 1 |
| (dpm/100 cm ²): | | |
| LBGR (dpm/100 cm ²): | 21500 | Default = 50% DCGL |
| Design Sigma (dpm/100 cm ²): | 5461 | |
| Type I Error: | 0.05 | |
| Type II Error: | 0.05 | |
| Predominant Nuclide: | Cs-137 | |
| Sample Area (m ²): | 6.8 | Class I |
| Scan Area (m ²): | 184 | |
| Scan Coverage (%): | 100% | Class 1 |
| $Z_{1-\alpha}$: | 1.645 | |
| $Z_{1-\beta}$: | 1.645 | |
| Sign P: | 0.99865 | |
| Calculated Relative Shift: | 3.9 | |
| Relative Shift Used: | . 3 | Uses 3.0 if Relative Shift is |
| NY XY X | 11 | >3 |
| N-Value: | | NUDEC 1575 Table 5.5 |
| Design IN-Value + 20%: | 14 | NUKEG-15/5 Table 5-5 |
| Design Min Samples N: | 27 | |
| Grid Spacing L: | 2.6 | Class I |

Table 1. Survey Unit Design Parameters

Survey Results:

A total of 34 direct measurements were made in F8131381. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the beta scan measurements indicated areas of elevated activity. Beta scan activity ranged from 1,620 to 66,383 dpm/100 cm², based on a surveyor efficiency of 0.5 and no background subtracted. None of the gamma scan measurements detected activity due to plant operations. Scan measurement locations for both beta and gamma emissions are identified in Attachment 1 of this report. Samples for removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

| Measurement ID | Gross Activity (dpm/100 cm²) |
|------------------|---------------------------------|
| F8131381-C0001BD | 2594 |
| F8131381-C0002BD | 2132 |
| F8131381-C0003BD | 1774 |
| F8131381-C0004BD | 2531 |
| F8131381-C0005BD | 4757 |
| F8131381-C0006BD | 1795 |
| F8131381-C0007BD | 2007 |
| F8131381-C0008BD | 1670 |
| F8131381-C0009BD | 2148 |
| F8131381-C0010BD | 1873 |
| F8131381-C0011BD | 1743 |
| F8131381-C0012BD | 1696 |
| F8131381-C0013BD | 1520 |
| F8131381-C0014BD | 1551 |
| F8131381-C0015BD | 1359 |
| F8131381-C0016BD | 1442 |
| F8131381-C0017BD | 1541 |
| F8131381-C0018BD | . 1494 |
| F8131381-C0019BD | 1520 |
| F8131381-C0020BD | · 1131 |
| F8131381-C0021BD | 1535 |
| F8131381-C0022BD | 1499 |
| F8131381-C0023BD | 1494 |
| F8131381-C0024BD | 1380 |
| F8131381-C0025BD | 908 |
| F8131381-C0026BD | 1037 |
| F8131381-C0027BD | 986 |
| F8131381-C0028BD | 1063 |
| F8131381-C0029BD | 1769 |
| F8131381-C0030BD | 2308 |
| F8131381-C0031BD | 1390 |
| F8131381-C0032BD | 846 |
| F8131381-C0033BD | 840 |
| F8131381-C0034BD | 716 |
| Mean: | 1648 |

Table 2. Direct Measurement Results

FSS Summary Report

| Median: | 1528 |
|---------------------|----------------|
| Standard Deviation: | . 719 |
| Range: | 716 - 4757 |

| Measurement ID | Surface Beta Activity (dpm/100 cm²) |
|--------------------|--|
| F8131381C0001SM | -2.24 |
| F8131381C0002SM | 8.09 |
| F8131381C0003SM | 0.34 |
| F8131381C0004SM | 6.8 |
| F8131381C0005SM | 9.38 |
| F8131381C0006SM | 2.93 |
| F8131381C0007SM | 4.22 |
| F8131381C0008SM | -0.95 |
| F8131381C0009SM | 5.51 |
| F8131381C0010SM | 2.93 |
| F8131381C0011SM | 5.51 |
| F8131381C0012SM | 5.51 |
| F8131381C0013SM | 1.64 |
| F8131381C0014SM | -0.95 |
| F8131381C0015SM | 2.93 |
| F8131381C0016SM | 0.34 |
| F8131381C0017SM | 2.93 |
| F8131381C0018SM | 0.34 |
| F8131381C0019SM | 2.93 |
| F8131381C0020SM | -0.95 |
| F8131381C0021SM | -0.95 |
| F8131381C00225W | -0.95 |
| F0131301CUU235IVI | -2.24 |
| F0131301CUU245IVI | 4.22 |
| F0131301C00255W | -3.33 |
| F0131301C00205W | -2.24 |
| E9424294C0029SM | 1.04 |
| F0131301000205W | 2.93 |
| E8131381C00295W | 4.22 |
| F8131381C0031SM | 0.34 |
| F8131381C0032SM | 5.51 |
| E8131381C0032SM | _0.95 |
| E8131381C0034SM | -0.55 |
| Mean | 2 13 |
| Median | 2.13 |
| Standard Deviation | 3 23 |
| Range: | -3.53 to 9.38 |

Table 3. Removable Surface Activity Results

Survey Unit Data Assessment:

The survey design required 27 direct measurements for the Sign Test. In actuality, 34 direct measurements were obtained. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

| Survey Results Parameter | Value | Comment |
|--|-------|---------------------------|
| Material Background Used (dpm/100 cm ²): | N/A | |
| Ambient Background Used (dpm/100 cm ²): | N/A | Average Ambient $BKG = 0$ |
| Actual Direct Measurements (N): | -34 | |
| Median $(dpm/100 cm^2)$: | 1528 | |
| Mean $(dpm/100 cm^2)$: | 1648 | |
| Direct Measurement Standard Deviation | 719 | |
| $(dpm/100 cm^2)$: | - | |
| Total Standard Deviation (dpm/100 cm ²): | 719 | Based on samples and |
| | | backgrounds. |
| Maximum (dpm/100 cm ²): | 4757 | ç |
| Material Type: | N/A | Background Subtract Not |
| | | Applied |
| Sign Test Final N Value: | 34 | |
| S+ Value: | 34 | |
| Critical Value: | 22 | |
| Sufficient Samples Collected: | Yes | |
| Maximum Value < DCGL: | Yes | |
| Median Value < DCGL: | Yes | |
| Mean Value < DCGL: | Yes | |
| Maximum Value < DCGLemc: | Yes | Class 1 |
| Total Standard Deviation <= Sigma: | Yes | |
| Pass the Sign Test? | Yes | |
| Reject the Null Hypothesis? | Yes | |
| Does the Survey Unit Pass All Criteria? | Yes | |

Table 4. Data Assessment Results

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 1 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 1 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8131381 meets the release criteria of 10CFR20.1402.

Attachment 1

Maps

July 7, 2008

Survey Unit F8131381



Page 2 of 15

Att. 1 Maps



Page 3 of 15

Att. 1 Maps



Page 4 of 15

Att. 1 Maps



Page 5 of 15

Att. 1 Maps



.

Att. 1 Maps

F8131381

Page 6 of 15



Att. 1 Maps



Page 8 of 15

Att. 1 Maps



Att. 1 Maps

Page 9 of 15



Page 10 of 15

Att. 1 Maps



Page 11 of 15

Att. 1 Maps



Att. 1 Maps



Page 13 of 15

Att. 1 Maps



Page 14 of 15

Att. 1 Maps

F8131381

31



Page 15 of 15

Att. 1 Maps

Attachment 2

Instrumentation

July 7, 2008

Survey Unit F8131381

| Instrument Model; Serial No. | Detector Model; Serial No. | MDC Static (dpm/100 cm ²) | MDC Scan (dpm/100 cm²) |
|---------------------------------|-------------------------------|--|---------------------------|
| M2350; 180733 | 43-98B; 148638 | 930 | 1680 |
| M2350; 180733 | 43-94B; 148620 | 350 | 610 , |
| M2350; 193715 | 43-68B; 160703 | 433 | 1033 |
| M2350; 193715 | 43-68B; 148630 | 433 | 1033 |
| M2350; 193700 | 43-116-1B; 216072 | 796 | 3258 |
| M2350; 193715 | 43-116-1B; 190643 | 491 β Juncture | 739 β Juncture |
| M2350; 180733 | 43-111B; 148641 | 1230 | 2230 |
| Tennelec; 0401171 | N/A | 5.9 dpm α, 11.7 dpm β | N/A |
| InSpector 1000 | 10054579 | N/A | 462 Cs-137 470 Co-60 |

Table 2-1. Survey Unit Instrumentation

The scan and static MDC's provided represent the most conservative MDC values for the survey conducted.

| Parameter | Value (dpm/100 cm ²) | |
|---------------------------------|-------------------------------------|--|
| Investigation Criteria - Direct | 154800 | |
| Investigation Criteria – Scan | 154800 | |
| DCGL _W | 43000 | |
| DCGL _{EMC} | 154800 | |

Attachment 3

Investigation

July 7, 2008

Survey Unit F8131381

(none required)

Attachment 4

Data Assessment

July 7, 2008

Survey Unit F8131381



Page 2 of 4

Att. 4 Data Assessment

Page 3 of 4

Att. 4 Data Assessment



3804

1648

-507

000

C0033BD C0034BD



Page 4 of 4

Att. 4 Data Assessment