Rancho Seco

Final Status Survey Summary Report

July 14, 2008

Electrical Penetration Room 209, 20' Auxiliary Building, Upper Walls and Ceiling

Survey Unit F8131382

Prepared By:

14/2008 Date: 1/

FSS Engineer

Reviewed By: Date: 10/08

Lead FSS Engineer

-28-08 Approved By: Date:

Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8131382, Electrical Penetration Room 209, 20' Auxiliary Building, Upper Walls and Ceiling

Survey Unit Description:

Operating History: The reinforced concrete structure contained the RadWaste processing and supporting systems. The building contained six main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure. One report documented contamination of the auxiliary building roof. The roof was later replaced.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements on the -47' elevation showed a mean gross activity level of 320,071 dpm/100 cm² and a maximum value of 5,720,000 dpm/100 cm². Direct measurements on the -29' elevation showed a mean gross activity level of 544,756 dpm/100 cm² and a maximum value of 11.370.000 dpm/100 cm². Direct measurements on the -20' elevation showed a mean gross activity level of 247,831 dpm/100 cm² and a maximum value of 10,080,000 dpm/100 cm². Direct measurements on the grade elevation showed a mean gross activity level of 373,758 dpm/100 cm² and a maximum value of 5,800,000 dpm/100 cm². Direct measurements on the +20' elevation showed a mean gross activity level of $85,408 \text{ dpm}/100 \text{ cm}^2$ and a maximum value of 1,900,000 dpm/100 cm². Direct measurements on the +40' elevation showed a mean gross activity level of 3,288 dpm/100 cm² and a maximum value of 24,781 dpm/100 cm². Direct measurements on the building exterior, including the mezzanine roof, showed a mean gross activity level of 1,897 dpm/100 cm² and a maximum value of 2,990 dpm/100 cm². (The roof had been replaced prior to the classification survey.) Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the interior of the auxiliary building was determined to be a Class 1, 2 area and the exterior was a Class 2,3. The Electrical Penetration Room 209 upper walls and ceiling were determined to be a Class 1.

HSA Events: HSA Report pg. 63.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 312 m² were scanned for 100% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Survey Design Parameter	Value	Comment
Survey Area:	F813	Electrical Penetration Room
		209, 20' Auxiliary Building,
		Upper Walls and Ceiling
Survey Unit:	1382	Structure Surface
Class:	· 1	LTP Table 5-4
SU Area (m ²):	312	· · ·
Evaluator:	Michael Stein	
DCGL (dpm/100 cm ²):	43000	Gross Activity DCGL
Area Factor:	3.6	Class 1
Design DCGLemc	154800	Class 1
(dpm/100 cm ²):		
LBGR (dpm/100 cm ²):	21500	Default = 50% DCGL
Design Sigma (dpm/100 cm ²):	5461	
Type I Error:	0.05	
Type II Error:	0.05	
Predominant Nuclide:	Cs-137	
Sample Area (m ²):	6.9	Class 1
Scan Area (m ²):	312	
Scan Coverage (%):	100%	Class 1
$Z_{1-\alpha}:$	1.645	
$Z_{1-\beta}:$	1.645	
Sign P:	0.99865	
Calculated Relative Shift:	3.9	
Relative Shift Used:	3	Uses 3.0 if Relative Shift is
		>3
N-Value:	11	
Design N-Value $+ 20\%$:	14	NUKEG-15/5 Table 5-5
Design Min Samples N:	45	
Grid Spacing L:	2.6	Class 1

Table 1. Survey Unit Design Parameters

Survey Results:

A total of 63 direct measurements were made in F8131382. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the beta scan measurements indicated areas of elevated activity. Beta scan activity ranged from 1,563 to 45,196 dpm/100 cm², based on a surveyor efficiency of 0.5 and no background subtracted. None of the gamma scan measurements detected activity due to plant operations. Scan measurement locations for both beta and gamma emissions are identified in Attachment 1 of this report. Samples for removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Measurement ID	Gross Activity (dpm/100 cm²)
F8131382-C0001BD	. 2225
F8131382-C0002BD	2168
F8131382-C0003BD	1961
F8131382-C0004BD	. 2075
F8131382-C0005BD	1956
F8131382-C0006BD	1852
F8131382-C0007BD	1753
F8131382-C0008BD	` 2028
F8131382-C0009BD	1899
F8131382-C0010BD	1888
F8131382-C0011BD	1826
F8131382-C0012BD	1530
F8131382-C0013BD	1478
F8131382-C0014BD	1525
F8131382-C0015BD	1587
F8131382-C0016BD	1406
F8131382-C0017BD	1478
F8131382-C0018BD	1323
F8131382-C0019BD	. 1473
F8131382-C0020BD	1395
F8131382-C0021BD	• 1432
F8131382-C0022BD	1665
F8131382-C0023BD	1442
F8131382-C0024BD	1452
F8131382-C0025BD	1/90
F8131382-C0026BD	• 1592
F8131382-C002/BD	1001
F8131382-C0028BD	1130
F8131382-C0029BD	1426
F8131382-C0030BD	1205
F8131382-C0031BD	1450
F0131302-CUU32BD	1402
F0131302-00033BD	1004
F0131302-60034BD E9131392 C0035BD	1404
LO191907-00032DD	1304

Table 2. Direct Measurement Results

Page 4 of 10

FSS Summary Report

F8131382-C0036BD	1421
F8131382-C0037BD	J665
F8131382-C0038BD	1437
F8131382-C0039BD	1551
F8131382-C0040BD	1629
F8131382-C0041BD	1416
F8131382-C0042BD	1546
F8131382-C0043BD	1509
F8131382-C0044BD	1541
F8131382-C0045BD	1613
F8131382-C0046BD	2448
F8131382-C0047BD	2495
F8131382-C0048BD	4710
F8131382-C0049BD	2122
F8131382-C0050BD	2303
F8131382-C0051BD	1442
F8131382-C0052BD	1442
F8131382-C0053BD	1292
F8131382-C0054BD	1323
F8131382-C0055BD	1406
F8131382-C0056BD	1229
F8131382-C0057BD	1369
F8131382-C0058BD	1338
F8131382-C0059BD	1712
F8131382-C0060BD	1509
F8131382-C0061BD	1618
F8131382-C0062BD	1556
F8131382-C0063BD	1447
Mean:	1666
Median:	1525
Standard Deviation:	489
Range:	1136 - 4710

FSS Summary Report

Measurement ID	Surface Beta Activity (dpm/100 cm²)
F8131382C0001SM	-3.53
F8131382C0002SM	-3.53
F8131382C0003SM	-3.53
F8131382C0004SM	-3.53
F8131382C0005SM	-2.24
F8131382C0006SM	-0.95
F8131382C0007SM	-0.95
F8131382C0008SM	-3.53
F8131382C0009SM	0.34
F8131382C0010SM	-2.24
F8131382C0011SM	-3.53
F8131382C0012SM	-2.24
F8131382C0013SM	-2.24
F8131382C0014SM	-0.95
F8131382C0015SM	2.93
F8131382C0016SM	-0.95
F8131382C0017SM	0.95
F8131382C0018SM	-0.95
F8131382C0019SM	0.34
F8131382C0020SM	1.64
F8131382C0021SM	-3.53
F8131382C0022SM	-6.11
F8131382C0023SM	-3.53
F8131382C0024SM	0.34
F8131382C0025SM	-2.24
F8131382C0026SM	-4.82
F8131382C0027SM	1.64
F8131382C00285W	4.22
F0131302C00295W	-2.24
F0131302C00305W	-4.02
E8131382C00315W	-2.24
E8131382C0032SM	-2.24
F8131382C00335M	-2.24
F8131382C0035SM	-0.00
E8131382C0036SM	-2.24
E8131382C0037SM	-0.00
E8131382C0038SM	-0.00
F8131382C0039SM	-2.24
F8131382C0040SM	-4.02
F8131382C0041SM	-0.00
F8131382C0042SM	0.34
F8131382C0043SM	-2 24
F8131382C0044SM	-3.53
F8131382C0045SM	-0.95
F8131382C0046SM	19.72
F8131382C0047SM	11.97
F8131382C0048SM	36.5
F8131382C0049SM	-0.95
F8131382C0050SM	-0.95

Table 3. Removable Surface Activity Results

Page 6 of 10

FSS Summary Report

F8131382C0051SM	-0.95
F8131382C0052SM	-4.82
F8131382C0053SM	0.34
F8131382C0054SM	-0.95
F8131382C0055SM	-2.24
F8131382C0056SM	-4.82
F8131382C0057SM	-3.53
F8131382C0058SM	4.22
F8131382C0059SM	-0.95
F8131382C0060SM	-2.24
F8131382C0061SM	-4.82
F8131382C0062SM	-3.53
F8131382C0063SM	-4.82
Mean:	-0.6
Median:	-2.24
Standard Deviation:	6.16
Range:	-6.11 to 36.5

FSS Summary Report

Survey Unit Data Assessment:

The survey design required 45 direct measurements for the Sign Test. In actuality, 63 direct measurements were obtained. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

FSS Summary Report

Survey Results Parameter	Value	Comment
Material Background Used (dpm/100 cm ²):	N/A	
Ambient Background Used (dpm/100 cm ²):	N/A	Average Ambient BKG = 0
Actual Direct Measurements (N):	63	-
Median (dpm/100 cm ²):	1525	
Mean (dpm/100 cm ²):	1666	
Direct Measurement Standard Deviation	489	
(dpm/100 cm ²):	·	
Total Standard Deviation (dpm/100 cm ²):	489	Based on samples and backgrounds.
Maximum $(dpm/100 cm^2)$:	4710	C
Material Type:	N/A	Background Subtract Not
		Applied
Sign Test Final N Value:	63	
S+ Value:	63	
Critical Value:	- 38	
Sufficient Samples Collected:	Yes	
Maximum Value < DCGL:	Yes	
Median Value < DCGL:	Yes	
Mean Value < DCGL:	Yes	
Maximum Value < DCGLemc:	Yes	Class 1
Total Standard Deviation <= Sigma:	Yes	
Pass the Sign Test?	Yes	· · ·
Reject the Null Hypothesis?	Yes	
Does the Survey Unit Pass All Criteria?	Yes	

Table 4. Data Assessment Results

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 1 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 1 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8131382 meets the release criteria of 10CFR20.1402.

Attachment 1

Maps

July 14, 2008

Survey Unit F8131382

. .



Page 2 of 24

Att. 1 Maps



Page 3 of 24

Att. 1 Maps



Page 4 of 24

Att. 1 Maps



Page 5 of 24

Att. 1 Maps



Page 6 of 24

Att. 1 Maps



Att. 1 Maps



Page 8 of 24

Att. 1 Maps



F8131382

Att. 1 Maps



Page 10 of 24

Att. 1 Maps



Page 11 of 24

Att. 1 Maps



Page 12 of 24

Att. 1 Maps



Page 13 of 24

Att. 1 Maps



Page 14 of 24



Page 15 of 24

Att. 1 Maps



Page 16 of 24

Att. 1 Maps



F8131382

Page 17 of 24

Att. 1 Maps

Page 19 of 24

Att. 1 Maps

Page 20 of 24

Att. 1 Maps

Page 21 of 24

Att. 1 Maps

Page 22 of 24

Att. 1 Maps

_

Att. 1 Maps

Attachment 2

Instrumentation

July 14, 2008

Survey Unit F8131382

Instrument	Detector	Detector MDC Static	
Model; Serial No.	Model; Serial No.	(dpm/100 cm ²)	(dpm/100 cm ²)
M2350; 142514	43-98B; 148639	930	1680
M2350; 180733	43-98B; 148638	930	1680
M2350; 180733	43-94B; 148620	350	610
M2350; 175834	43-68B; 190482	433	1033
M2350; 193700	43-68B; 190294	433	1033
M2350; 142509	43-68B; 160699	433	1033
M2350; 175834	43-68B; 148634	433	1033
M2350; 149789	43-68B; 148633	433	1033
M2350; 149789	43-116-1B; 256006	796	3258
M2350; 175834	43-116-1B; 190642	796	3258
M2350; 180733	43-111B; 148641	2290	4160
Tennelec; 0401171	N/A	5.9 dpm α, 11.7 dpm β	N/A
InSpector 1000	03069793	N/A	4830 Cs-137 5350 Co-60

Table 2-1. Survey Unit Instrumentation

The scan and static MDC's provided represent the most conservative MDC values for the survey conducted.

Table 2	2-2.	Investigati	on Criteria	and	DCGL
---------	------	-------------	-------------	-----	------

Parameter	Value (dpm/100 cm²)	
Investigation Criteria - Direct	154800	
Investigation Criteria – Scan	154800	
DCGLw	43000	
DCGL _{EMC}	154800	

Attachment 3

Investigation

July 14, 2008

Survey Unit F8131382

(none required)

Attachment 4

Data Assessment

July 14, 2008

Survey Unit F8131382

Page 2 of 4

Att. 4 Data Assessment

Page 3 of 4

Att. 4 Data Assessment

Page 4 of 4

Att. 4 Data Assessment