



Rancho Seco
Final Status Survey Summary Report

May 30, 2008

AB +40' Radiochemistry Lab (room 320 – lower)

Survey Unit F8131791

Prepared By: Dan A. Tallman  **Date:** May 30, 2008
FSS Engineer

Reviewed By:  **Date:** 5/30/08
Lead FSS Engineer

Approved By:  **Date:** 7-29-08
Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8131791, AB +40' Radiochemistry Lab (room 320) lower

Survey Unit Description:

Operating History: The Auxiliary Building is a reinforced concrete structure that contained the RadWaste processing and supporting systems. The building contained six main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements on the +40' elevation showed a mean gross activity level of 3,288 dpm/100 cm² and a maximum value of 24,781 dpm/100 cm². Based on the classification procedure (DSIP-0020) and levels of gross activity reported, Survey Unit 8131791 (Room 320's lower walls and floor) within the interior of the auxiliary building was determined to be a Class 2 area.

HSA Events: HSA Report pg. 63.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 15 m² were scanned for approximately 25% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Table 1. Survey Unit Design Parameters

Survey Design Parameter	Value	Comment
Survey Area:	F813	AB +40' Radiochemistry Lab (room 320) lower Structure Surface
Survey Unit:	1791	LTP Table 5-4
Class:	2	
SU Area (m²):	59	
Evaluator:	D.A.Tallman	
DCGL (dpm/100 cm²):	43000	Gross Activity DCGL
Area Factor:	N/A	Class 2
Design DCGL_{mc} (dpm/100 cm²):	N/A	Class 2
LBGR (dpm/100 cm²):	21500	Default = 50% DCGL
Design Sigma (dpm/100 cm²):	3627	
Type I Error:	0.05	
Type II Error:	0.05	
Predominant Nuclide:	Cs-137	
Sample Area (m²):	4.2	Class 2
Scan Area (m²):	15	
Scan Coverage (%):	25%	Class 2
Z_{1-α} :	1.645	
Z_{1-β} :	1.645	
Sign P:	0.99865	
Calculated Relative Shift:	6	
Relative Shift Used:	3	Uses 3.0 if Relative Shift is >3
N-Value:	11	
Design N-Value + 20%:	14	NUREG-1575 Table 5-5
Design Min Samples N:	14	Class 2
Grid Spacing L:	2.0	Class 2

Survey Results:

A total of 15 direct measurements were made in F8131791. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. None of the scan measurements indicated areas of elevated activity. Scan activity ranged from 2010 to 2956 dpm/100 cm², based on a surveyor efficiency of 0.5 and no background subtracted. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Table 2. Direct Measurement Results

Measurement ID	Gross Activity (dpm/100 cm ²)
F8131791-C0001BD	1349
F8131791-C0002BD	1618
F8131791-C0003BD	1437
F8131791-C0004BD	1577
F8131791-C0005BD	1333
F8131791-C0006BD	1587
F8131791-C0007BD	1380
F8131791-C0008BD	1203
F8131791-C0009BD	1043
F8131791-C0010BD	1136
F8131791-C0011BD	975
F8131791-C0012BD	1089
F8131791-C0013BD	1271
F8131791-C0014BD	1157
F8131791-C0015BD	1089
Mean:	1283
Median:	1271
Standard Deviation:	208
Range:	975 - 1618

Table 3. Removable Surface Activity Results

Measurement ID	Surface Beta Activity (dpm/100 cm²)
F8131791C0008SM	-3.53
F8131791C0001SM	-3.53
F8131791C0002SM	-2.24
F8131791C0003SM	-3.53
F8131791C0004SM	-0.95
F8131791C0005SM	-4.82
F8131791C0006SM	-2.24
F8131791C0007SM	2.93
F8131791C0008SM	-4.82
F8131791C0009SM	0.34
F8131791C0010SM	-4.82
F8131791C0011SM	-2.24
F8131791C0012SM	-4.82
F8131791C0013SM	-2.24
F8131791C0014SM	-0.95
F8131791C0015SM	6.8
Mean:	-1.92
Median:	-2.24
Standard Deviation:	3.15
Range:	-4.82 to 6.8

Survey Unit Data Assessment:

The survey design required 15 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Table 4. Data Assessment Results

Survey Results Parameter	Value	Comment
Material Background Used (dpm/100 cm ²):	N/A	Average Ambient BKG = 0
Ambient Background Used (dpm/100 cm ²):	N/A	
Actual Direct Measurements (N):	15	
Median (dpm/100 cm ²):	1271	
Mean (dpm/100 cm ²):	1283	
Direct Measurement Standard Deviation (dpm/100 cm ²):	208	Based on samples and backgrounds.
Total Standard Deviation (dpm/100 cm ²):	208	
Maximum (dpm/100 cm ²):	1618	
Material Type:	N/A	Background Subtract Not Applied
Sign Test Final N Value:	15	
S+ Value:	15	
Critical Value:	11	
Sufficient Samples Collected:	Yes	
Maximum Value < DCGL:	Yes	Class 2
Median Value < DCGL:	Yes	
Mean Value < DCGL:	Yes	
Maximum Value < DCGL_{emc}:	N/A	
Total Standard Deviation <= Sigma:	Yes	
Pass the Sign Test?	Yes	
Reject the Null Hypothesis?	Yes	
Does the Survey Unit Pass All Criteria?	Yes	

Survey Unit Investigations and Results:

No investigations were required for either direct or scan measurements and no investigation results are reported.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 2 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. No potential areas of elevated activity were detected.

Conclusion:

The FSS of this survey unit was properly designed as a Class 2 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. No investigations were required.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.


It is concluded that survey unit F8131791 meets the release criteria of 10CFR20.1402.

Attachment 1





Maps

May 30, 2008


Survey Unit F8131791







DEVELOPED VIEW
SHOWER INTERIOR



SMUD


SACRAMENTO MUNICIPAL
UTILITY DISTRICT


AUXILIARY BUILDING EL. 40'-0"
ROOM 320 FLOOR & LOWER WALLS
BETA DIRECT/REMOVABLE ACTIVITY
MEASUREMENT LOCATIONS
F8131791-M2

FILE: 813000.05a


SHEET 2 of 3

RC RAYMOND








ELEVATION LOOKING EAST
AT COL. P



DEVELOPED VIEW
SHOWER INTERIOR



DEVELOPED VIEW
SHOWER EXTERIOR



ELEVATION LOOKING WEST
EAST OF COL. LINE N



SMUD


SACRAMENTO MUNICIPAL
UTILITY DISTRICT

AUXILIARY BUILDING EL. 40'-0"
ROOM 320 FLOOR & LOWER WALLS
BETA SCAN
MEASUREMENT LOCATIONS
F8131791-M3

FILE: 813000.05a

SHEET 1 of 2

RC RAYMOND



Attachment 2

Instrumentation

May 30, 2008

Survey Unit F8131791

Table 2-1. Survey Unit Instrumentation

Instrument Model; Serial No.	Detector Model; Serial No.	MDC Static (dpm/100 cm²)	MDC Scan (dpm/100 cm²)
M2350; 203486	43-68B; 190476	433	1033
Tennelec; 0401171	N/A	6 dpm α , 12 dpm β	N/A

Table 2-2. Investigation Criteria and DCGL

Parameter	Value (dpm/100 cm²)
Investigation Criteria - Direct	43000
Investigation Criteria – Scan	43000
DCGL _w	43000
DCGL _{EMC}	N/A

Attachment 3

Investigation

May 30, 2008

Survey Unit F8131791

(none required)

Attachment 4

Data Assessment

May 30, 2008

Survey Unit F8131791

