




Rancho Seco
Final Status Survey Summary Report
(Rev.1)
June 16, 2008
RC Drain Tank (V-600) Room (lowers)
Survey Unit F8130051

Prepared By: Dan A. Tallman  Date: June 16, 2008
FSS Engineer

Reviewed By: R. H. Decker  Date: 7/31/08
Lead FSS Engineer

Approved By: E. J.  Date: 8-5-08
Dismantlement Superintendent, Radiological

FINAL STATUS SURVEY SUMMARY REPORT

Survey Unit:

F8130051, RC Drain Tank (V-600) Room (lowers)

Survey Unit Description:

Operating History: The Auxiliary Building was a reinforced concrete structure which contained the RadWaste processing and supporting systems. The building contained six main elevations. Residual radioactive material was known to be present on all levels of the interior of the building. Operating records and the HSA document several events with the potential for a release of radioactivity inside this structure.

Site Characterization: Direct measurements were made of each of the interior elevation surfaces as well as the exterior surfaces of the structure. These measurements confirmed the presence of plant-derived radionuclides. Direct measurements on the -47' elevation showed a mean gross activity level of 320,071 dpm/100 cm² and a maximum value of 5,720,000 dpm/100 cm². Based on the classification procedure (DSIP-0020) and levels of gross activity reported, the Reactor Coolant Drain Tank (V-600) room within the interior of the auxiliary building was determined to be a Class 1 survey unit.

HSA Events: HSA Report pg. 63.

Survey Unit Design Information:

The Survey Unit Design Parameters are presented in Table 1 below. The survey unit and measurement locations are depicted on the maps in Attachment 1. Direct measurement locations were determined using a random-start, fixed grid pattern and 141 m² were scanned for 100% coverage. Samples of removable contamination were collected at each direct measurement location. The instrumentation used for the survey along with the MDC values are listed in Tables 2-1 and 2-2 in Attachment 2.

Table 1. Survey Unit Design Parameters

| Survey Design Parameter | Value | Comment |
|---|--------------|----------------------------------|
| Survey Area: | F813 | RC Drain Tank (V-600) |
| Survey Unit: | 0051 | Room (lowers) |
| Class: | 1 | Structure Surface |
| SU Area (m²): | 141 | LTP Table 5-4 |
| Evaluator: | D.A.Tallman | |
| DCGL (dpm/100 cm²): | 43000 | Gross Activity DCGL |
| Area Factor: | 3.6 | Class 1 |
| Design DCGL_{mc} (dpm/100 cm²): | 156520 | Class 1 |
| LBGR (dpm/100 cm²): | 21500 | Default = 50% DCGL |
| Design Sigma (dpm/100 cm²): | 9976 | |
| Type I Error: | 0.05 | |
| Type II Error: | 0.05 | |
| Predominant Nuclide: | Cs-137 | |
| Sample Area (m²): | 6.7 | Class 1 |
| Scan Area (m²): | 141 | |
| Scan Coverage (%): | 100% | Class 1 |
| Z_{1-α}: | 1.645 | |
| Z_{1-β}: | 1.645 | |
| Sign P: | 0.97725 | |
| Calculated Relative Shift: | 2.1 | |
| Relative Shift Used: | 2.1 | Uses 3.0 if Relative Shift is >3 |
| N-Value: | 12 | |
| Design N-Value + 20%: | 15 | NUREG-1575 Table 5-5 |
| Design Min Samples N: | 21 | Class 1 |
| Grid Spacing L: | 2.5 | Class 1 |

Survey Results:

A total of 26 direct measurements were made in F8130051. The results including mean, median, standard deviation and range are shown in Table 2. All direct measurements were less than the DCGL. Multiple scan measurements indicated areas of elevated activity. Scan activity ranged from 1922 to 189618 dpm/100 cm², based on a surveyor efficiency of 0.5 and no background subtracted. Samples for removable surface activity were all less than 10% of the DCGL as shown in Table 3. Removable surface activity samples were counted for alpha activity and none was detected at the MDC shown in Table 2-1 of Attachment 2.

Table 2. Direct Measurement Results

| Measurement ID | Gross Activity (dpm/100 cm ²) |
|---------------------|--|
| F8130051-C0001BD | 2422 |
| F8130051-C0002BD | 2148 |
| F8130051-C0003BD | 1982 |
| F8130051-C0004BD | 1707 |
| F8130051-C0005BD | 1644 |
| F8130051-C0006BD | 1971 |
| F8130051-C0007BD | 27664 |
| F8130051-C0008BD | 2324 |
| F8130051-C0009BD | 1608 |
| F8130051-C0010BD | 1790 |
| F8130051-C0011BD | 1733 |
| F8130051-C0012BD | 1769 |
| F8130051-C0013BD | 1779 |
| F8130051-C0014BD | 1940 |
| F8130051-C0015BD | 7221 |
| F8130051-C0016BD | 2293 |
| F8130051-C0017BD | 2013 |
| F8130051-C0018BD | 4565 |
| F8130051-C0019BD | 2760 |
| F8130051-C0020BD | 5493 |
| F8130051-C0021BD | 3138 |
| F8130051-C0022BD | 2557 |
| F8130051-C0023BD | 2028 |
| F8130051-C0024BD | 2314 |
| F8130051-C0025BD | 2843 |
| F8130051-C0026BD | 2848 |
| Mean: | 3560 |
| Median: | 2220 |
| Standard Deviation: | 5084 |
| Range: | 1608 - 27664 |

Table 3. Removable Surface Activity Results

| Measurement ID | Surface Beta Activity (dpm/100 cm²) |
|-----------------------|---|
| F8130051C0001SM | 11.97 |
| F8130051C0002SM | 4.22 |
| F8130051C0003SM | 1.64 |
| F8130051C0004SM | 9.38 |
| F8130051C0005SM | 4.22 |
| F8130051C0006SM | 2.93 |
| F8130051C0007SM | -2.24 |
| F8130051C0008SM | 32.63 |
| F8130051C0009SM | 8.09 |
| F8130051C0010SM | 4.22 |
| F8130051C0011SM | 126.91 |
| F8130051C0012SM | 11.97 |
| F8130051C0013SM | 14.55 |
| F8130051C0014SM | 70.08 |
| F8130051C0015SM | -0.95 |
| F8130051C0016SM | 4.22 |
| F8130051C0017SM | -0.95 |
| F8130051C0018SM | 17.13 |
| F8130051C0019SM | 28.76 |
| F8130051C0020SM | 21.01 |
| F8130051C0021SM | 2.93 |
| F8130051C0022SM | 1.64 |
| F8130051C0023SM | 48.13 |
| F8130051C0024SM | 32.63 |
| F8130051C0025SM | 10.68 |
| F8130051C0026SM | 1.64 |
| Mean: | 17.98 |
| Median: | 8.74 |
| Standard Deviation: | 27.92 |
| Range: | -2.24 to 126.91 |

Survey Unit Data Assessment:

The survey design required 26 direct measurements for the Sign Test. The critical value and the results of the Sign Test are presented in Table 4. The sample mean and median values were less than the DCGL. The sample standard deviation was less than the design standard deviation so no additional samples were required.

Table 4. Data Assessment Results

| Survey Results Parameter | Value | Comment |
|---|--------------|--------------------------------------|
| Material Background Used (dpm/100 cm ²): | N/A | Average Ambient BKG = 0 |
| Ambient Background Used (dpm/100 cm ²): | N/A | |
| Actual Direct Measurements (N): | 26 | |
| Median (dpm/100 cm ²): | 2220 | |
| Mean (dpm/100 cm ²): | 3560 | |
| Direct Measurement Standard Deviation (dpm/100 cm ²): | 5084 | Based on samples and backgrounds. |
| Total Standard Deviation (dpm/100 cm ²): | 5084 | |
| Maximum (dpm/100 cm ²): | 27664 | |
| Material Type: | N/A | Background Subtract Not Applied |
| Sign Test Final N Value: | 26 | |
| S+ Value: | 26 | |
| Critical Value: | 17 | |
| Sufficient Samples Collected: | Yes | |
| Maximum Value < DCGL: | Yes | Class 1 |
| Median Value < DCGL: | Yes | |
| Mean Value < DCGL: | Yes | |
| Maximum Value < DCGL_{mc}: | Yes | |
| Total Standard Deviation <= Sigma: | Yes | |
| Pass the Sign Test? | Yes | |
| Reject the Null Hypothesis? | Yes | |
| Does the Survey Unit Pass All Criteria? | Yes | |

Survey Unit Investigations and Results:

Six (6) investigations (scan grids 019, 143, 145, Junctures 02, & 42, and Penetration 02) were required for the scan measurements and the results are reported in Attachment 3. The EMC unity rule was not exceeded as shown in Table 3-1.

During routine surveillance surveys utilizing the 44-10 NaI detector, discovery was made in grids 14, 33, 36, 51, 61, and 71. The results of this discovery are detailed in Revision 1 to Attachment 3. The EMC unity rule was not exceeded as shown in Revision 1 to Table 3-1.

ALARA Statement:

As stated in Chapter 4 of the LTP, as long as the residual activity within the survey unit is less than the DCGL (i.e. the survey unit average activity is less than the DCGL and the EMC criterion has been met), the ALARA criterion has been met.

Changes in Initial Survey Unit Assumptions:

The survey unit was designed as a Class 1 structure survey and the sample results are consistent with that classification. The variability of the survey results was less than the characterization data used for survey design. Potential areas of elevated activity were detected and evaluated as shown in Attachment 3 demonstrating that the EMC criterion was met.

Conclusion:

The FSS of this survey unit was properly designed as a Class 1 survey based on Table 5-4 of the LTP. The required number of direct measurements was made and the scan coverage met the requirement of Table 5-6 of the LTP. No direct measurements exceeded the DCGL of 43000 dpm/100 cm² and none of the removable surface activity measurements exceeded 10% of the DCGL. The required investigations were performed.

The direct measurement data support rejection of the null hypothesis, providing high confidence that the survey unit satisfied the release criteria and that the data quality objectives were met.

It is concluded that survey unit F8130051 meets the release criteria of 10CFR20.1402.

Attachment 2

(Rev. 1)

Instrumentation

June 16, 2008

Survey Unit F8130051

Table 2-1. Survey Unit Instrumentation

| Instrument Model; Serial No. | Detector Model; Serial No. | MDC Static (dpm/100 cm²) | MDC Scan (dpm/100 cm²) |
|-------------------------------------|-----------------------------------|--|--|
| M2350; 203481 | 43-68B; 161405 | 433 | 1033 |
| M2350; 142507 | 43-68B; 160781 | | |
| M2350; 193715 | 43-68B; 160703 | | |
| M2350; 149789 | 43-116-1B; 256006 | 796 | 3258 |
| M2350; 193715 | 43-116-1B; 190643 | | |
| M2350; 149789 | 43-116-1B; 256006 | 491 ¹ | 1060 ¹ |
| M2350; 193715 | 43-116-1B; 190643 | | |
| M2350; 203482 | 44-10; 211672 | NA | 18720 |
| M2350; 203486 | 44-10; 171995 | | |
| Tennelec; 0401171 | N/A | 6 dpm α , 12 dpm β | N/A |

¹ 43-116-1B – Juncture Scan - concrete

Table 2-2. Investigation Criteria and DCGL

| Parameter | Value (dpm/100 cm²) |
|---------------------------------|---------------------------------------|
| Investigation Criteria - Direct | 156520 |
| Investigation Criteria – Scan | 43000 ^{1, 2} |
| DCGL _w | 43000 |
| DCGL _{EMC} | 156520 |

¹ Scan Investigation Level set at DCGL_w

² Scan Investigation Level for routine 44-10 surveillance scan set at 20,000 cpm

Attachment 3

(Rev. 1)

Investigation

June 16, 2008

Survey Unit F8130051

Table 3-1 Survey Unit Investigation

| <i>Grid</i> | <i>Investigation Level (cpm)</i> | <i>Initial Value (cpm)</i> | <i>Investigation Result (cpm)</i> | <i>Elevated Area (m²)</i> | <i>Area Factor</i> | <i>DCGL_{emc}</i> | <i>Investigation Result (dpm/100cm²)</i> | <i>DCGL_{emc} Unity Fraction</i> |
|---|----------------------------------|----------------------------|-----------------------------------|--------------------------------------|--------------------|---------------------------|---|--|
| Grid 19 | 1990* | 2154 | 1723 | NA | NA | NA | NA | 0 |
| Grid 145 | 5840 | 25848 | 13262 | 0.22 | 60.95 | 2,620,881 | 153,584 | 0.056 |
| Grid 143 | 5840 | 13468 | 5919 | 0.04 | 326 | 14,022,374 | 68547 | 0.005 |
| J-42 | 4260 | 4529 | 5515 | 0.02 | 649 | 27,913,730 | 63868 | 0.002 |
| J-02 | 1990* | 3031 | 2498 | NA | NA | NA | NA | 0 |
| P-02 | 1990* | 2013 | 2013 | 0.4 | 34.65 | 1,489,303 | 43380 | 0.025 |
| G14 | 20000 | 44000 | 44000 | 0.02 | 559.7 | 24,067,100 | 1,707,808 | 0.071 |
| G33 | 20000 | 37000 | 37000 | 0.05 | 280.9 | 12,079,990 | 1,436,111 | 0.119 |
| G36 | 20000 | 35000 | 35000 | 0.01 | 1294.1 | 55,646,300 | 1,358,483 | 0.024 |
| G51 | 20000 | 30000 | 30000 | 0.01 | 1294.1 | 55,646,300 | 1,164,414 | 0.021 |
| G61 | 20000 | 48000 | 48000 | 0.01 | 1294.1 | 55,646,300 | 1,863,063 | 0.034 |
| G71 | 20000 | 37000 | 37000 | 0.01 | 1294.1 | 55,646,300 | 1,436,111 | 0.026 |
| Investigation Level as documented within the survey instructions = 1100 cpm above background. Subsequent to survey performance, the IL was revised to the 1990 value based on the scan speed coefficient modification (0.42 vs. 0.76) | | | | | | | | |
| During routine surveillance surveys using the 44-10 (NaI), discovery was made within grids 14, 33, 36, 51, 61, & 71. | | | | | | | | |
| Survey Unit Remainder | | | | | | DCGL = 43,000 | SU Mean = 6194 | 0.144 |
| EMC Unity Sum | | | | | | | | 0.526 |