

PMBelCOL PEmails

From: Ravindra Joshi
Sent: Thursday, June 05, 2008 11:32 AM
To: BelCol Resource
Subject: FW: Draft RAI related to SRP section 11.2 (FSAR Section 11.2), Liquid Waste Management System-- Bellefonte Units 3 and 4
Attachments: RAI 330.doc

From: Ravindra Joshi
Sent: Thursday, June 05, 2008 11:32 AM
To: Ray, Phillip M; Eddie R Grant
Cc: Joshua Wilson; Peter Wilson
Subject: Draft RAI related to SRP section 11.2 (FSAR Section 11.2), Liquid Waste Management System-- Bellefonte Units 3 and 4

Attached is the Draft RAI related to SRP Section 11.2 (FSAR Section 11.2). Please let me know if you want to discuss the RAI before it is made official.

Ravi Joshi
Chapter PM
US NRC
301-415-6191

Hearing Identifier: Bellefonte_COL_Public_EX
Email Number: 706

Mail Envelope Properties (CEEA97CC21430049B821E684512F6E5E8525DEFAF1)

Subject: FW: Draft RAI related to SRP section 11.2 (FSAR Section 11.2), Liquid Waste Management System-- Bellefonte Units 3 and 4

Sent Date: 6/5/2008 11:31:57 AM

Received Date: 6/5/2008 11:32:01 AM

From: Ravindra Joshi

Created By: Ravindra.Joshi@nrc.gov

Recipients:

"BelCol Resource" <BelCol.Resource@nrc.gov>

Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	483	6/5/2008 11:32:01 AM
RAI 330.doc	27130	

Options

Priority: Standard

Return Notification: No

Reply Requested: No

Sensitivity: Normal

Expiration Date:

Recipients Received:

Request for Additional Information No. 330

Bellefonte Units 3 and 4
TVA
Docket No. 52-014 and 52-015
SRP Section: 11.02 - Liquid Waste Management System
Application Section: 11.2

QUESTION from Balance of Plant Branch 2 (SBPB)

11.02-***

In FSAR Section 11.2.1.2.5.2, TVA addresses COL Information Item 11.2-1 by providing the description of the conformance of the mobile or temporary equipment to the guidance of Regulatory Guide 1.143. The conformance discussion is limited to the codes and standards listed in Table 1 and Position C.1.1.2 of Regulatory Guide 1.143. Please clarify the extent to which the mobile or temporary equipment meets the remaining applicable guidance of Regulatory Guide 1.143; please revise FSAR Section 11.2 to include this information, or justify its exclusion.