

PMBeCOL PEmails

From: Manny Comar
Sent: Monday, July 21, 2008 5:19 PM
To: bobhirman@live.com; erg-xl@cox.net; pmray@tva.gov
Cc: Joseph Sebrosky; Juan Peralta; Milton Concepcion; ravi.joshi@nrc.gov; BelCol Resource
Attachments: RAI 713_bellfonte.doc

To All,

Attached is the Draft RAI 713 related to SRP Section: 14.02 - Initial Plant Test Program for Bellefonte
Units 3 and 4

Please let me know if you would like to discuss the RAI before it is made official.

Thanks

Manny Comar
Senior Project Manager
NRO/DNRL/NWE1
Nuclear Regulatory Commission
301-415-3863
<mailto:manny.comar@nrc.gov>

Hearing Identifier: Bellefonte_COL_Public_EX
Email Number: 730

Mail Envelope Properties (3AF7DEF82ADA8944AD8247B7ED7FD65169793EBD04)

Subject:
Sent Date: 7/21/2008 5:18:43 PM
Received Date: 7/21/2008 5:18:45 PM
From: Manny Comar

Created By: Manny.Comar@nrc.gov

Recipients:

"Joseph Sebrosky" <Joseph.Sebrosky@nrc.gov>
Tracking Status: None
"Juan Peralta" <Juan.Peralta@nrc.gov>
Tracking Status: None
"Milton Concepcion" <Milton.Concepcion@nrc.gov>
Tracking Status: None
"ravi.joshi@nrc.gov" <ravi.joshi@nrc.gov>
Tracking Status: None
"BelCol Resource" <BelCol.Resource@nrc.gov>
Tracking Status: None
"bobhirman@live.com" <bobhirman@live.com>
Tracking Status: None
"erg-xl@cox.net" <erg-xl@cox.net>
Tracking Status: None
"pmray@tva.gov" <pmray@tva.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

| Files | Size | Date & Time |
|-----------------------|-------------|------------------------|
| MESSAGE | 395 | 7/21/2008 5:18:45 PM |
| RAI 713_bellfonte.doc | 28666 | |

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 713

Bellefonte Units 3 and 4
TVA

Docket No. 52-014 and 52-015

SRP Section: 14.02 - Initial Plant Test Program - Design Certification and New License Applicants
Application Section: 14.2

QUESTIONS: Quality and Vendor Branch 1 (CQVB)

14.02-***

Section C.I.14.2.4 of RG 1.206 states that the COL applicant should describe the methods and identify provisions to ensure that retesting that is required for modifications or maintenance remains in compliance with ITAAC commitments. Explain how Section 14.2.3.2 of the Bellefonte COL application includes provisions to ensure that retesting required for modifications or maintenance remains in compliance with ITAAC commitments, when applicable; alternatively, explain why this is not necessary. Revise Subsection 14.2.3.2 as appropriate.

14.02-***

Section C.I.14.2.11 of RG 1.206 states that the COL applicant should identify and cross-reference each test (or portion thereof) required to be completed before initial fuel loading designed to satisfy the requirements for completing ITAAC. Explain how Section 14.2 of the Bellefonte COL FSAR includes provisions to ensure that required tests to be completed before initial fuel loading to satisfy ITAAC are adequately identified; alternatively, explain why this is not necessary. Revise Section 14.2 as appropriate.