

Facility: <u>ANO-1</u>		Date of Examination: <u>9-8-2008</u>
Examination Level: RO <input checked="" type="checkbox"/> SRO <input type="checkbox"/>		Operating Test Number: <u>2008-1</u>

Administrative Topic (see Note)	Type Code*	Describe activity to be performed
Conduct of Operations A1.        2.1.29 (Imp 4.1)	N/R	Knowledge of how to conduct system lineups, such as valves, breakers, switches, etc. A1JPM-RO-LINE1
Conduct of Operations A2.        2.1.19 (Imp 3.9)	N/S	Ability to use plant computers to evaluate system or component status. A1JPM-RO-PMS3
Equipment Control A3.        2.2.12 (Imp 3.7)	D/R	Knowledge of surveillance procedures. A1JPM-RO-SURV3
Radiation Control A4.        2.3.4 (Imp 3.2)	M/R	Knowledge of radiation exposure limits under normal or emergency conditions. A1JPM-RO-DOSE-SVY2
Emergency Procedures/Plan A5.	N/A	N/A

NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.

\* Type Codes & Criteria:

(C)ontrol room, (S)imulator, or Class(R)oom  
 (D)irect from bank ( $\leq 3$  for ROs;  $\leq 4$  for SROs & RO retakes)  
 (N)ew or (M)odified from bank ( $\geq 1$ )  
 (P)revious 2 exams ( $\leq 1$ ; randomly selected)

Facility: <u>ANO-1</u>		Date of Examination: <u>9-8-2008</u>
Examination Level: RO <input type="checkbox"/> SRO <input checked="" type="checkbox"/>		Operating Test Number: <u>2008-1</u>

Administrative Topic (see Note)	Type Code*	Describe activity to be performed
Conduct of Operations A5.        2.1.23 (Imp 4.3)	D/R	Ability to perform specific system and integrated plant procedures during all modes of plant operation. A1JPM-SRO-HTBAL1
Conduct of Operations A6.        2.1.34 (Imp 3.5)	M/R	Knowledge of primary and secondary plant chemistry limits. A1JPM-SRO-CHEM1
Equipment Control A7.        2.2.12 (Imp 4.1)	D/R	Knowledge of surveillance procedures. A1JPM-SRO-SURV4
Radiation Control A4.        2.3.4 (Imp 3.7)	N/R	Knowledge of radiation exposure limits under normal or emergency conditions. A1JPM-SRO-DOSE-SVY2
Emergency Procedures/Plan A8.        2.4.41 (Imp 4.6)	N/S	Knowledge of the Emergency Action Level thresholds and classification A1JPM-SRO-EAL11

NOTE: All items (5 total) are required for SROs. RO applicants require only 4 items unless they are retaking only the administrative topics, when all 5 are required.

\* Type Codes & Criteria:

(C)ontrol room, (S)imulator, or Class(R)oom  
 (D)irect from bank (≤ 3 for ROs; ≤ 4 for SROs & RO retakes)  
 (N)ew or (M)odified from bank (≥ 1)  
 (P)revious 2 exams (≤ 1; randomly selected)

---

## A1. Conduct of Operations

N/R

K/A 2.1.29

Knowledge of how to conduct system lineups, such as valves, breakers, switches etc.

A1JPM-RO-LINE1

## ADMINISTRATIVE JOB PERFORMANCE MEASURE

A1JPM-RO-LINE1

Page 1 of 4

UNIT: 1 REVISION # 1 DATE: 8/19/2008TUOI NUMBER: A1JPM-RO-LINE1SYSTEM: A.1 – Conduct of OperationsTASK: Perform a Partial Valve Line-up on C-28A Instrument Air CompressorJTA: ANO-RO-ADMIN-NORM-182KA VALUE RO 4.1 SRO 4.0 KA REFERENCE: 2.1.29APPROVED FOR ADMINISTRATION TO: RO X SRO \_\_\_\_\_TASK LOCATION: INSIDE CR: \_\_\_\_\_ OUTSIDE CR: \_\_\_\_\_ BOTH: X

SUGGESTED TESTING ENVIRONMENT AND METHOD (PERFORM OR SIMULATE):

PLANT SITE: \_\_\_\_\_ SIMULATOR: \_\_\_\_\_ CLASSROOM: PERFORMPOSITION EVALUTED: RO X SRO \_\_\_\_\_ACTUAL TESTING ENVIRONMENT: PLANT SITE: \_\_\_\_\_ SIMULATOR: \_\_\_\_\_ CLASSROOM: XACTUAL TESTING METHOD: SIMULATE: \_\_\_\_\_ PERFORM: XAPPROXIMATE COMPLETION TIME IN MINUTES: 15 MINUTESREFERENCES: 1015.001 Conduct of Operations

EXAMINEE'S NAME: \_\_\_\_\_ SSN: \_\_\_\_\_

EVALUATOR'S NAME: \_\_\_\_\_

THE EXAMINEE'S PERFORMANCE WAS EVALUATED AGAINST THE STANDARDS CONTAINED IN THIS JPM AND IS DETERMINED TO BE:

SATISFACTORY: \_\_\_\_\_ UNSATISFACTORY: \_\_\_\_\_

PERFORMANCE CHECKLIST COMMENTS: \_\_\_\_\_

START TIME: \_\_\_\_\_ STOP TIME: \_\_\_\_\_ TOTAL TIME: \_\_\_\_\_

SIGNED:  DATE: 8-19-08

SIGNATURE INDICATES THIS JPM HAS BEEN COMPARTED TO ITS APPLICABLE PROCEDURE BY A QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.



**THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:**

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:** It is desired to align the C-28A Instrument Air Compressor within the tagout boundary following compressor replacement. The tagout isolation boundary valves are: IA-790A – Closed; CS-150A – Closed.

**TASK STANDARD:** The examinee has correctly identified valves internal to the tagout boundary and their correct positions.

IA-1057 – Closed; CS-151A – Open; CV-1000A – Closed.

**TASK PERFORMANCE AIDS:** Copy of partially completed 1015.001E, 1015.001G, and 1015.001 step 6.2.3 P&IDs M-218 Sheets 1 through 5.


**INITIATING CUE:**

The CRS requests that you complete 1015.001G for a partial valve lineup for the C-28A Instrument Air Compressor within the tagout boundary per 1015.001 step 6.2.3 B.

**CRITICAL ELEMENTS (C):** 1

(C)	PERFORMANCE CHECKLIST	STANDARDS	N/A	SAT	UNSAT
<b>NOTE: Provide examinee with a copy of partially completed 1015.001E, form 1015.001G, and copy of 1015.001 step 6.2.3.</b>					
(C)	1. List component number, description (optional), and required position from applicable attachment.	Examinee will need to locate PID for C28A instrument air compressor, Attachment A of 1106.015 Condensate Transfer system page 4 of 10 Turbine building Basement (By Condensate Pumps) section and Attachment A of 1104.024 Instrument Air System page 3 of 6 C-28 Area. To determine the following valves and their positions: <b>IA-1057A – Closed</b> <b>CS-151A – Open</b> <b>CS-1000A - Closed</b>			
	2. N/A any lines and blanks not used.	Draw a line through blank lines on form 1015.001G and N/A besides line or N/A each blank line			
	3. Enter reason for partial lineup, e.g., post maintenance test, tagout number, etc.	Should copy the reason from form 1015.001E			
	4. If NOT obvious from components and reason listed, <u>THEN</u> describe lineup, e.g., list major components, boundaries, or list components, boundaries, or list components excluded, etc.	Should not have to perform this step			
	5. Obtain SRO signature, indicating approval of appropriateness and scope of the partial lineup.	When examinee says he will give the form to SRO for approval <b>Inform examinee JPM is complete</b>			

**END**



KEY

E-DOC TITLE:

## PARTIAL SYSTEM LINEUP SHEET

E-DOC NO.

1015.001G

CHANGE NO.

055-00-0

System: Instrument Air C28-A Air CompressorPage 1 of 1

Reason for partial lineup, e.g. post maintenance test, clearance no., etc.

Describe lineup if needed, e.g., list major components, boundaries, or list components excluded, etc.:

Align system within tagout boundary due to compressor replacement. Tag Out boundary valves are IA 790A IA compressor C-28A Outlet Isolation, and CS 150A Condensate to IA compressor C-28A

Partial lineup approval: \_\_\_\_\_

SRO Signature

Date: \_\_\_\_\_

Component	Description (optional)	Required Position	Checked Initial	SRO Initial*
IA 1057A	C-28A Water Condensate Drain	Closed		
CS 151A	C-28A Condensate supply Isolation	Open		
CS 1000A	F-49A water drain	Closed		

\*SRO Initial signifies review.

Lineup Performed By: \_\_\_\_\_

Signature

Initial

Date

~ KEY ~

PROC./WORK PLAN NO. <b>1106.015</b>	PROCEDURE/WORK PLAN TITLE: <b>CONDENSATE TRANSFER SYSTEM</b>	PAGE: <b>14 of 21</b> CHANGE: <b>016</b>
--	---	---

ATTACHMENT A

Page 4 of 10

VALVE NUMBER	TAG ✓	OPEN	CLOSED	DESCRIPTION
<b>TURBINE BUILDING BASEMENT (BY CONDENSATE PUMPS)</b>				
CS-1088			X	Vent on Line From Cond Pump Disch To Cond Transfer HDR
CS-1089			X	Drain on Line from Cond Pump Disch to Cond Transfer HDR
CS-150A		X		Condensate to IA Compressor C-28A
<del>CS-151A</del>		X		<del>C-28A Condensate Supply Isol</del>
CS-150B		X		Condensate to IA Compressor C-28B
CS-151B		X		C-28B Condensate Supply Isol
CS-150C			X	Future Connection
<del>CS-1000A</del>			X	<del>F-49A Water Drain</del>
CS-1000B			X	F-49B Water Drain
<b>SECONDARY SAMPLE ROOM</b>				
CS-292		X		Cond Transfer To Secondary Sample Room Isol
CS-321		X		Cond Transfer Flush Isol to Secondary Sample Sys
CS-320		(1)	(1)	Cond Transfer Flush Throttle For S/G (Future) Sample CAT COL A
<b>COMPUTER ROOM (BY VUC-5A)</b>				
CS-330			X	Cond Transfer to Computer Rm Unit Clr VUC-5C Drain
CS-329		X		Cond Transfer to Computer Rm Unit Clr VUC-5C Filter F-55 Outlet
CS-328		X		Cond Transfer to Computer Rm Unit Clr VUC-5C Filter F-55 Inlet

Note 1: Throttled per Chemistry's request to facilitate T-41 DI water sample.

KEY

PROC./WORK PLAN NO. <b>1104.024</b>	PROCEDURE/WORK PLAN TITLE: <b>INSTRUMENT AIR SYSTEM</b>	PAGE: <b>34 of 67</b> CHANGE: <b>031</b>
--	--	---

ATTACHMENT A

Page 3 of 6

VALVE NUMBER	TAG ✓	OPEN	CLOSED	DESCRIPTION
IA-16		X		IA Hdr to Intake Structure and Majority of Turbine Bldg (South of IA Dryer)
IA-19		X		IA Hdr Isol (IA Compr Rm South of IA Dryers)
IA-18		X		IA Hdr Isol to Aux Bldg (South of IA Dryers)
IA-17		X		IA Hdr Isol (South IA Dryers)
IA-92		X		IA Root Isol to T-86, CV-2888, P-7A/B Recirc and IA Hdr Press Instruments
IA-155		X		IA Hdr Isol to P-7A/B EFWPs Comb Recirc (South of IA Dryers)
IA-483		X		IA Isol to P-7A/B EFWPs Comb Recirc (South of IA Dryer)
IA-5408		X		IA Isol to PS-5408 (South of IA Dryers)
IA-5409		X		IA Isol to PS/PT-5409 (South of IA Dryers)
<b>C-28 AREA</b>				
IA-790A		X		IA Compressor C-28A Outlet Isol
IA-790B		X		IA Compressor C-28B Outlet Isol
IA-790C			X	Future Connection
IA-1057A			X	C-28A Water Condensate Drain
IA-1057B			X	C-28B Water Condensate Drain
IA-811		X		IA Receiver T-52/T-39A Cross-Tie at T-52
IA-805		X		IA Receiver T-52 Drain Trap Vent Isol
IA-796		X		IA Receiver T-52 Drain Isol
IA-1055			X	IA Receiver T-52 Drain Trap Bypass
IA-791		X		IA Filter F-32 Inlet Isol
IA-792			X	IA Filter F-32 Bypass
IA-793		X		IA Filter F-32 Outlet Isol
IA-5400C		X		PDI-5400 Upstream Isol
IA-5400D		X		PDI-5400 Downstream Isol

KEY

**JPM INITIAL TASK CONDITIONS:**

- C28A instrument Air compressor has been replaced it is still tagged out. Maintenance requests compressor to be properly aligned within the tag out boundaries.

**INITIATING CUE:**

- The CRS requests that you complete 1015.001G for a partial valve lineup for the C-28A Instrument Air Compressor within the tagout boundary per 1015.001 step 6.2.3 B.

ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE

TITLE: **CONDUCT OF OPERATIONS**

DOCUMENT NO.  
**1015.001**

CHANGE NO.  
**066**

SET #

WORK PLAN EXP. DATE  
**N/A**

SAFETY-RELATED  
☒ YES ☐ NO

IPTE  
☐ YES ☒ NO

TEMP MOD  
☒ YES ☐ NO

LEVEL OF USE  
☐ CONTINUOUS  
☐ REFERENCE  
☒ INFORMATIONAL

PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO

When you see these **TRAPS**

Get these **TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

VERIFIED BY

DATE

TIME

_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

FORM TITLE:

**VERIFICATION COVER SHEET**

FORM NO.  
**1000.006A**

CHANGE NO.  
**054**



PROC./WORK PLAN NO. 1015.001	PROCEDURE/WORK PLAN TITLE: <b>CONDUCT OF OPERATIONS</b>	PAGE: 26 of 218 CHANGE: 066
---------------------------------	--	--------------------------------

## 6.2 Performing Valve Alignments

6.2.1 Obtain the latest revision of the lineup.

6.2.2 Ensure Lineup Cover Sheet (E-DOC 1015.001E) and at least one Lineup Exception Sheet (E-DOC 1015.001F) maintained.

### **NOTE**

If performance of a lineup check on a non-safety related system poses a safety concern, an ALARA concern, requires the building of scaffolding, or removal of access cover, etc., then the SRO may choose to NOT perform lineup check on that component. This constitutes a partial alignment.

6.2.3 IF a partial valve lineup to be performed,  
THEN perform either of the sub-steps below:

A. Use a Lineup Cover Sheet (E-DOC 1015.001E) and tailor existing lineup as follows:

- Designate "partial lineup" on lineup cover sheet.
- Enter reason for partial lineup, e.g., 1R21, tagout number, etc.
- Describe lineup, e.g., list major components, boundaries, or list components excluded, etc.
- IF including only pages of lineup that are needed, THEN so state on the lineup cover sheet, e.g., "Only pages 25 and 26 of 158".
- For valves in the body of the lineup, or on the pages included, that do NOT require checking, mark N/A and obtain SRO initial.
- Obtain SRO signature, indicating approval of appropriateness and scope of the partial lineup.

B. Use Partial System Lineup Sheet (E-DOC 1015.001G) as follows:

- List component number, description (optional), and required position from applicable attachment.
- N/A any lines and blanks NOT used.
- Enter reason for partial lineup, e.g., post maintenance test, tagout number, etc.
- IF NOT obvious from components and reason listed, THEN describe lineup, e.g., list major components, boundaries, or list components excluded, etc.
- Obtain SRO signature, indicating approval of appropriateness and scope of the partial lineup.

6.2.4 Conduct lineup per Attachment A.3 of this procedure.

6.2.5 Deliver completed lineup to an SRO for review.

E-DOC TITLE:

LINEUP COVER SHEET


E-DOC NO.  
1015.001ECHANGE NO.  
055-00-0

Page 1 of 1

System: Instrument Air C28-A Air CompressorProcedure: 1104.024 and 1106.015 Attachment No. AComplete Lineup ☐ or Partial Lineup ☒

If applicable, reason for partial lineup, e.g. 1R21, clearance no., etc. Describe lineup, e.g., list major components, boundaries, or list components excluded, etc.:

Align system within tagout boundary due to compressor replacement. Tag Out boundary valves are IA 790A IA compressor C-28A Outlet Isolation, and CS 150A Condensate to IA compressor C-28A

If applicable,  
partial lineup approval:
  
SRO Signature
Date: 9/10/2008

Lineup Performed by:

_____ Signature	_____ Initial	_____ Date
_____ Signature	_____ Initial	_____ Date
_____ Signature	_____ Initial	_____ Date
_____ Signature	_____ Initial	_____ Date
_____ Signature	_____ Initial	_____ Date
_____ Signature	_____ Initial	_____ Date
_____ Signature	_____ Initial	_____ Date
_____ Signature	_____ Initial	_____ Date

This system lineup has been completed per the requirements of Attachment A.3 of this procedure and reviewed per the requirements of SRO Review of Lineups section of this procedure.

\_\_\_\_\_  
SRO Signature\_\_\_\_\_  
Date

E-DOC TITLE:

PARTIAL SYSTEM LINEUP SHEET

E-DOC NO.  
1015.001GCHANGE NO.  
055-00-0

System: \_\_\_\_\_

Page \_\_\_\_ of \_\_\_\_

Reason for partial lineup, e.g. post maintenance test, clearance no., etc.

Describe lineup if needed, e.g., list major components, boundaries, or list components excluded, etc.:

\_\_\_\_\_

\_\_\_\_\_

Partial lineup approval: \_\_\_\_\_ Date: \_\_\_\_\_

SRO Signature

Component	Description (optional)	Required Position	Checked Initial	SRO Initial*

\*SRO Initial signifies review.


Lineup Performed By:

 \_\_\_\_\_ / \_\_\_\_\_  
 Signature Initial Date

 \_\_\_\_\_ / \_\_\_\_\_  
 Signature Initial Date

SRO Review: \_\_\_\_\_ Date \_\_\_\_\_





38	AS-BUILT I.D.N. 88-292	PROPOSED REVISION	DATE	BY	APP'D	REVISION
40	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
42	AS-BUILT I.D. 2940	AS-BUILT I.D. 2940	DATE	BY	APP'D	REVISION
44	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
46	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
48	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
50	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
52	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
54	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
56	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
58	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
60	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
62	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
64	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
66	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
68	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
70	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
72	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
74	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
76	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
78	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
80	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
82	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
84	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
86	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
88	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
90	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
92	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
94	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
96	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
98	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION
100	AS-BUILT I.D. 8868	AS-BUILT I.D. 8868	DATE	BY	APP'D	REVISION

ARKANSAS NUCLEAR ONE  
RUSSELLVILLE, ARKANSAS

INSTRUMENT & SERVICE AIR

PIPING & INSTRUMENT DIAGRAM

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR


INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR


INSTRUMENT & SERVICE AIR

INSTRUMENT & SERVICE AIR

# INTAKE STRUCTURE AND YARD AREAS



ARKANSAS NUCLEAR ONE RUSSELLVILLE, ARKANSAS			
PIPING & INSTRUMENT DIAGRAM INSTRUMENT & SERVICE AIR			
NO.	DESCRIPTION	DATE	BY
73	AS-BUILT, DYN 85-2548		
74	AS-BUILT, DYN 85-2548		
75	AS-BUILT, DYN 85-2548		
76	AS-BUILT, DYN 85-2548		
77	AS-BUILT, DYN 85-2548		
78	AS-BUILT, DYN 85-2548		
79	AS-BUILT, DYN 85-2548		
80	AS-BUILT, DYN 85-2548		
81	AS-BUILT, DYN 85-2548		
82	AS-BUILT, DYN 85-2548		
83	AS-BUILT, DYN 85-2548		
84	AS-BUILT, DYN 85-2548		
85	AS-BUILT, DYN 85-2548		
86	AS-BUILT, DYN 85-2548		
87	AS-BUILT, DYN 85-2548		
88	AS-BUILT, DYN 85-2548		
89	AS-BUILT, DYN 85-2548		
90	AS-BUILT, DYN 85-2548		
91	AS-BUILT, DYN 85-2548		
92	AS-BUILT, DYN 85-2548		
93	AS-BUILT, DYN 85-2548		
94	AS-BUILT, DYN 85-2548		
95	AS-BUILT, DYN 85-2548		
96	AS-BUILT, DYN 85-2548		
97	AS-BUILT, DYN 85-2548		
98	AS-BUILT, DYN 85-2548		
99	AS-BUILT, DYN 85-2548		
100	AS-BUILT, DYN 85-2548		



- NOTES:
1. FOR GENERAL NOTES SEE M-208-001.
  2. AIR FOR PNEUMATIC TOOLS - 80% GPM GALLON MINUTE.
  3. AIR FOR PNEUMATIC TOOLS - 80% GPM GALLON MINUTE.
  4. AIR FOR PNEUMATIC TOOLS - 80% GPM GALLON MINUTE.
  5. AIR FOR PNEUMATIC TOOLS - 80% GPM GALLON MINUTE.
  6. AIR FOR PNEUMATIC TOOLS - 80% GPM GALLON MINUTE.
  7. AIR FOR PNEUMATIC TOOLS - 80% GPM GALLON MINUTE.

REVISION		DATE		BY	
1	AS-BUILT	1968-05-10	1968-05-10	1	1
2	AS-BUILT	1968-05-10	1968-05-10	1	1
3	AS-BUILT	1968-05-10	1968-05-10	1	1
4	AS-BUILT	1968-05-10	1968-05-10	1	1
5	AS-BUILT	1968-05-10	1968-05-10	1	1
6	AS-BUILT	1968-05-10	1968-05-10	1	1
7	AS-BUILT	1968-05-10	1968-05-10	1	1
8	AS-BUILT	1968-05-10	1968-05-10	1	1
9	AS-BUILT	1968-05-10	1968-05-10	1	1
10	AS-BUILT	1968-05-10	1968-05-10	1	1
11	AS-BUILT	1968-05-10	1968-05-10	1	1
12	AS-BUILT	1968-05-10	1968-05-10	1	1
13	AS-BUILT	1968-05-10	1968-05-10	1	1
14	AS-BUILT	1968-05-10	1968-05-10	1	1
15	AS-BUILT	1968-05-10	1968-05-10	1	1
16	AS-BUILT	1968-05-10	1968-05-10	1	1
17	AS-BUILT	1968-05-10	1968-05-10	1	1
18	AS-BUILT	1968-05-10	1968-05-10	1	1
19	AS-BUILT	1968-05-10	1968-05-10	1	1
20	AS-BUILT	1968-05-10	1968-05-10	1	1
21	AS-BUILT	1968-05-10	1968-05-10	1	1
22	AS-BUILT	1968-05-10	1968-05-10	1	1
23	AS-BUILT	1968-05-10	1968-05-10	1	1
24	AS-BUILT	1968-05-10	1968-05-10	1	1
25	AS-BUILT	1968-05-10	1968-05-10	1	1
26	AS-BUILT	1968-05-10	1968-05-10	1	1
27	AS-BUILT	1968-05-10	1968-05-10	1	1
28	AS-BUILT	1968-05-10	1968-05-10	1	1
29	AS-BUILT	1968-05-10	1968-05-10	1	1
30	AS-BUILT	1968-05-10	1968-05-10	1	1
31	AS-BUILT	1968-05-10	1968-05-10	1	1
32	AS-BUILT	1968-05-10	1968-05-10	1	1
33	AS-BUILT	1968-05-10	1968-05-10	1	1
34	AS-BUILT	1968-05-10	1968-05-10	1	1
35	AS-BUILT	1968-05-10	1968-05-10	1	1
36	AS-BUILT	1968-05-10	1968-05-10	1	1
37	AS-BUILT	1968-05-10	1968-05-10	1	1
38	AS-BUILT	1968-05-10	1968-05-10	1	1
39	AS-BUILT	1968-05-10	1968-05-10	1	1
40	AS-BUILT	1968-05-10	1968-05-10	1	1
41	AS-BUILT	1968-05-10	1968-05-10	1	1
42	AS-BUILT	1968-05-10	1968-05-10	1	1
43	AS-BUILT	1968-05-10	1968-05-10	1	1
44	AS-BUILT	1968-05-10	1968-05-10	1	1
45	AS-BUILT	1968-05-10	1968-05-10	1	1
46	AS-BUILT	1968-05-10	1968-05-10	1	1
47	AS-BUILT	1968-05-10	1968-05-10	1	1
48	AS-BUILT	1968-05-10	1968-05-10	1	1
49	AS-BUILT	1968-05-10	1968-05-10	1	1
50	AS-BUILT	1968-05-10	1968-05-10	1	1
51	AS-BUILT	1968-05-10	1968-05-10	1	1
52	AS-BUILT	1968-05-10	1968-05-10	1	1
53	AS-BUILT	1968-05-10	1968-05-10	1	1
54	AS-BUILT	1968-05-10	1968-05-10	1	1
55	AS-BUILT	1968-05-10	1968-05-10	1	1
56	AS-BUILT	1968-05-10	1968-05-10	1	1
57	AS-BUILT	1968-05-10	1968-05-10	1	1
58	AS-BUILT	1968-05-10	1968-05-10	1	1
59	AS-BUILT	1968-05-10	1968-05-10	1	1
60	AS-BUILT	1968-05-10	1968-05-10	1	1
61	AS-BUILT	1968-05-10	1968-05-10	1	1
62	AS-BUILT	1968-05-10	1968-05-10	1	1
63	AS-BUILT	1968-05-10	1968-05-10	1	1
64	AS-BUILT	1968-05-10	1968-05-10	1	1
65	AS-BUILT	1968-05-10	1968-05-10	1	1
66	AS-BUILT	1968-05-10	1968-05-10	1	1
67	AS-BUILT	1968-05-10	1968-05-10	1	1
68	AS-BUILT	1968-05-10	1968-05-10	1	1
69	AS-BUILT	1968-05-10	1968-05-10	1	1
70	AS-BUILT	1968-05-10	1968-05-10	1	1
71	AS-BUILT	1968-05-10	1968-05-10	1	1
72	AS-BUILT	1968-05-10	1968-05-10	1	1
73	AS-BUILT	1968-05-10	1968-05-10	1	1
74	AS-BUILT	1968-05-10	1968-05-10	1	1
75	AS-BUILT	1968-05-10	1968-05-10	1	1
76	AS-BUILT	1968-05-10	1968-05-10	1	1
77	AS-BUILT	1968-05-10	1968-05-10	1	1
78	AS-BUILT	1968-05-10	1968-05-10	1	1
79	AS-BUILT	1968-05-10	1968-05-10	1	1
80	AS-BUILT	1968-05-10	1968-05-10	1	1
81	AS-BUILT	1968-05-10	1968-05-10	1	1
82	AS-BUILT	1968-05-10	1968-05-10	1	1
83	AS-BUILT	1968-05-10	1968-05-10	1	1
84	AS-BUILT	1968-05-10	1968-05-10	1	1
85	AS-BUILT	1968-05-10	1968-05-10	1	1
86	AS-BUILT	1968-05-10	1968-05-10	1	1
87	AS-BUILT	1968-05-10	1968-05-10	1	1
88	AS-BUILT	1968-05-10	1968-05-10	1	1
89	AS-BUILT	1968-05-10	1968-05-10	1	1
90	AS-BUILT	1968-05-10	1968-05-10	1	1
91	AS-BUILT	1968-05-10	1968-05-10	1	1
92	AS-BUILT	1968-05-10	1968-05-10	1	1
93	AS-BUILT	1968-05-10	1968-05-10	1	1
94	AS-BUILT	1968-05-10	1968-05-10	1	1
95	AS-BUILT	1968-05-10	1968-05-10	1	1
96	AS-BUILT	1968-05-10	1968-05-10	1	1
97	AS-BUILT	1968-05-10	1968-05-10	1	1
98	AS-BUILT	1968-05-10	1968-05-10	1	1
99	AS-BUILT	1968-05-10	1968-05-10	1	1
100	AS-BUILT	1968-05-10	1968-05-10	1	1





---

## A2. Conduct of Operations

N/S

K/A 2.1.19

Ability to use plant computers to  
evaluate system or component  
status.

A1JPM-RO-PMS3

UNIT: 1 REV # 1 DATE: \_\_\_\_\_

TUOI NUMBER: A1JPM-RO-PMS3

SYSTEM/DUTY AREA: ADMINISTRATIVE TOPIC – CONDUCT OF OPERATIONS

TASK: OPERATE THE PLANT COMPUTER

JTA#: ANO1-RO-PMS-NORM-7

KA VALUE RO: 3.9 SRO: 3.8 KA REFERENCE: 2.1.19

APPROVED FOR ADMINISTRATION TO: RO: X SRO: \_\_\_\_\_

TASK LOCATION: INSIDE CR: X OUTSIDE CR: \_\_\_\_\_ BOTH: \_\_\_\_\_

SUGGESTED TESTING ENVIRONMENT AND METHOD (PERFORM OR SIMULATE):

PLANT SITE: \_\_\_\_\_ SIMULATOR: PERFORM LAB: \_\_\_\_\_

POSITION EVALUATED: RO: X SRO: \_\_\_\_\_

ACTUAL TESTING ENVIRONMENT: SIMULATOR: X PLANT SITE: \_\_\_\_\_ LAB: \_\_\_\_\_

TESTING METHOD: SIMULATE: \_\_\_\_\_ PERFORM: X

APPROXIMATE COMPLETION TIME IN MINUTES: 5 MINUTES

REFERENCE(S): 1105.010

EXAMINEE'S NAME: \_\_\_\_\_ SSN \_\_\_\_\_ - \_\_\_\_\_ - \_\_\_\_\_

EVALUATOR'S NAME: \_\_\_\_\_

THE EXAMINEE'S PERFORMANCE WAS EVALUATED AGAINST THE STANDARDS  
CONTAINED IN THIS JPM AND IS DETERMINED TO BE:

SATISFACTORY: \_\_\_\_\_ UNSATISFACTORY: \_\_\_\_\_

PERFORMANCE CHECKLIST COMMENTS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_ Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time

SIGNED \_\_\_\_\_ DATE: \_\_\_\_\_

SIGNATURE INDICATES THIS JPM HAS BEEN COMPARED TO ITS APPLICABLE PROCEDURE BY A  
QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.

---

**THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:**

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:** The plant is at 100% power operations.

---

**TASK STANDARD:** The examinee has determined CRD rod 2 of group 2 motor temperature alarm on PMS was  
Disabled point T1G09 and placed it back into service

---

---

**TASK PERFORMANCE AIDS:** 1105.010, Plant Monitoring System

---

**NOTE:** 1105.010 covers the operation of the Plant Monitoring System, but the exact manipulations are within the skill of the craft. Therefore, use of procedure in hand is not required.

**Simulator setup:** verify the following points are disabled CRD motor temperature alarms disabled T1D10, T1F06, T1G09, T1H14, T1K11, and T1M05

**INITIATING CUE:**

The CRS directs you to verify all Group 2 rods motor temperature alarms are enabled on PMS per step 21.2.4 of 1105.010 Plant Computer Operation procedure

(C)	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UNSAT
(C)	1. Type in turn on code PDFA <enter>	Typed in turn on code PDFA <enter> on the keyboard	_____	_____	_____
(C)	2. <enter>	Report printed	_____	_____	_____
(C)	3. Should review print out.	Found several CRD motor temperature alarms disabled T1D10, T1F06, T1G09, T1H14, T1K11, and T1M05	_____	_____	_____
(C)	4. Reference Exhibit A of 1105.009 CRD system operating procedure.	Found from print point (T1G09) is disabled. Used Exhibit A as a reference to find that it is group 2 rod 2.	_____	_____	_____
(C)	5. Type in turn on code RPTA <enter>	Typed in turn on code RPTA <enter> on the keyboard	_____	_____	_____
(C)	6. Depress F2	Depressed F2 on the keyboard	_____	_____	_____
(C)	7. Type in desired point press enter	Typed in desired point T1G09 on the keyboard	_____	_____	_____

EXAMINER NOTE: The following steps are verifying the alarm was restored

	8. Type in turn on code PDFA <enter>	Typed in turn on code PDFA <enter> on the keyboard	_____	_____	_____
	9. <enter>	Report printed	_____	_____	_____
	10. Should review print out.	Point T1G09 not listed in report	_____	_____	_____

EXAMINER NOTE: ***Once he verifies T1G09 is now restored the JPM is complete if he states he would update the ESL notebook tell him it is updated .***

**END**

---

## **EXAMINEE'S COPY**

### **JPM INITIAL TASK CONDITIONS:**

The plant is at 100% power operations.

### **INITIATING CUE:**

The CRS directs you to verify all Group 2 rods motor temperature alarms are enabled on PMS per step 21.2.4 of 1105.010 Plant Computer Operation procedure.

# ENTERGY OPERATIONS INCORPORATED ARKANSAS NUCLEAR ONE

**TITLE: PLANT COMPUTER OPERATION**

**DOCUMENT NO.**  
**1105.010**

**CHANGE NO.**  
**014**

**WORK PLAN EXP. DATE**  
**N/A**

**TC EXP. DATE**  
**N/A**

**SET #**

**SAFETY-RELATED**  
☒ **YES**    ☐ **NO**

**IPTE**  
☐ **YES**    ☒ **NO**

**TEMP ALT**  
☐ **YES**    ☒ **NO**

**PROGRAMMATIC EXCLUSION PER EN-LI-100**  
☐ **YES**    ☒ **NO**

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.**  
**1000.006A**

**CHANGE NO.**  
**052-00-0**

PROC./WORK PLAN NO. <b>1105.010</b>	PROCEDURE/WORK PLAN TITLE: <b>PLANT COMPUTER OPERATION</b>	PAGE: <b>18 of 18</b> CHANGE: <b>014</b>
--	---	---

**NOTE**

TOC DDFA will display all computer points which are currently disabled from alarming. TOC PDFA (Points Disabled From Alarm report) shows the points with quality code DALM.

21.0 DISABLING/RESTORING COMPUTER POINTS FROM ALARM

21.1 Disabling Computer Points from Alarming

- 21.1.1 Obtain CRS/SM permission to disable point(s).
- 21.1.2 Type in Turn on Code DPFA, <enter>.
- 21.1.3 Depress F2.
- 21.1.4 Type in desired point <enter>.
- 21.1.5 Press Y and <enter> to save changes.
- 21.1.6 Print Points Disabled From Alarm report as follows:
  - A. Type in Turn on Code PDFA, <enter>.
  - B. <enter> (to send to print queue).
  - C. Update the PDFA report maintained in Control Room (normally in ESL Notebook).
- 21.1.7 Verify WR/WO submitted for repair/restoration of the disabled point(s) AND include words to effect to restore computer point alarm.

21.2 Restoring Computer Points from Alarming

- 21.2.1 Type in Turn on Code RPTA <enter>.
- 21.2.2 Depress F2.
- 21.2.3 Type in desired point <enter>.
- 21.2.4 Print Points Disabled From Alarm report as follows:
  - A. Type in Turn on Code PDFA, <enter>.
  - B. <enter> (to send to print queue)
  - C. Update the PDFA report maintained in Control Room (normally in ESL Notebook).





EXHIBIT A  
1105.009

Page 2 of 2

## CONTROL ROD LOCATION AND INSTRUMENT CROSS REFERENCE

Revised 5/5/05

GROUP	ROD	RX CORE GRID LOC.	C77 API AMP LOC.	RPI AMP (1)	PLANT/SPDS COMPUTER PI SIGNAL	PI SIGNAL FUSE	PLANT COMPUTER ROD TEMP	RX HEAD NOZZLE NUMBER
5	1	C-9	A12	12	Z1C09	F-12	T1C09	39
5	2	E-11	A13	13	Z1E11	F-13	T1E11	27
5	3	G-13	A11	11	Z1G13	F-11	T1G13	40
5	4	K-13	A4	4	Z1K13	F-4	T1K13	41
5	5	M-11	B3	21	Z1M11	F-21	T1M11	28
5	6	O-9	B2	20	Z1O09	F-20	T1O09	42
5	7	O-7	C12	48	Z1O07	F-48	T1O07	43
5	8	M-5	D4	58	Z1M05	F-58	T1M05	29
5	9	K-3	D3	57	Z1K03	F-57	T1K03	44
5	10	G-3	C13	49	Z1G03	F-49	T1G03	45
5	11	E-5	C3	39	Z1E05	F-39	T1E05	26
5	12	C-7	C2	38	Z1C07	F-38	T1C07	38
6	1	B-8	A15	15	Z1B08	F-15	T1B08	58
6	2	F-10	B6	24	Z1F10	F-24	T1F10	11
6	3	H-14	A7	7	Z1H14	F-7	T1H14	59
6	4	L-10	B16	34	Z1L10	F-34	T1L10	12
6	5	P-8	C15	51	Z1P08	F-51	T1P08	60
6	6	L-6	D6	60	Z1L06	F-60	T1L06	13
6	7	H-2	C16	52	Z1H02	F-52	T1H02	61
6	8	F-6	C6	42	Z1F06	F-42	T1F06	10
7	1	D-8	A17	17	Z1D08	F-17	T1D08	22
7	2	D-12	A16	16	Z1D12	F-16	T1D12	47
7	3	H-12	B10	28	Z1H12	F-28	T1H12	23
7	4	N-12	B7	25	Z1N12	F-25	T1N12	48
7	5	N-8	B17	35	Z1N08	F-35	T1N08	24
7	6	N-4	D7	61	Z1N04	F-61	T1N04	49
7	7	H-4	C18	54	Z1H04	F-54	T1H04	25
7	8	D-4	C7	43	Z1D04	F-43	T1D04	46
8	1	D-10	D14	68	Z1D10 (2)	F-68	T1D10	31
8	2	F-12	D13	67	Z1F12 (2)	F-67	T1F12	32
8	3	L-12	D12	66	Z1L12 (2)	F-66	T1L12	33
8	4	N-10	D11	65	Z1N10 (2)	F-65	T1N10	34
8	5	N-6	D10	64	Z1N06 (2)	F-64	T1N06	35
8	6	L-4	D9	63	Z1L04 (2)	F-63	T1L04	36
8	7	F-4	D8	62	Z1F04 (2)	F-62	T1F04	37
8	8	D-6	D15	69	Z1D06 (2)	F-69	T1D06	30

- (1) RPI amp number is also the transfer switch number. PASSPORT identifies a CRDM by its RPI amp/transfer switch number, i.e., Group 1 Rod 1 is CRDM-10
- (2) Group 8 available on Plant Computer only.

---

## A3. Equipment Control

D/R

K/A 2.2.12

Knowledge of surveillance  
procedures.

A1JPM-RO-SURV3

## ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-RO-SURV3

Page 1 of 4

UNIT: 1 REV # 4 DATE: \_\_\_\_\_

TUOI NUMBER: A1JPM-RO-SURV3

SYSTEM/DUTY AREA: ADMINISTRATIVE TOPIC – EQUIPMENT CONTROL

TASK: PERFORM SURVEILLANCE TESTS

JTA#: ANO-RO-ADMIN-NORM-23

KA VALUE RO: 3.7 SRO: 4.1 KA REFERENCE: 2.2.12

APPROVED FOR ADMINISTRATION TO: RO: X SRO: \_\_\_\_\_

TASK LOCATION: INSIDE CR: \_\_\_\_\_ OUTSIDE CR: X BOTH: \_\_\_\_\_

SUGGESTED TESTING ENVIRONMENT AND METHOD (PERFORM OR SIMULATE):

PLANT SITE: \_\_\_\_\_ SIMULATOR: \_\_\_\_\_ LAB: PERFORM

POSITION EVALUATED: RO: X SRO: \_\_\_\_\_

ACTUAL TESTING ENVIRONMENT: SIMULATOR: \_\_\_\_\_ PLANT SITE: \_\_\_\_\_ LAB: X

TESTING METHOD: SIMULATE: \_\_\_\_\_ PERFORM: X

APPROXIMATE COMPLETION TIME IN MINUTES: 10 MINUTES

REFERENCE(S): 1104.036, Emergency Diesel Generator Operation

EXAMINEE'S NAME: \_\_\_\_\_ SSN \_\_\_\_\_ - \_\_\_\_\_ - \_\_\_\_\_

EVALUATOR'S NAME: \_\_\_\_\_

THE EXAMINEE'S PERFORMANCE WAS EVALUATED AGAINST THE STANDARDS  
CONTAINED IN THIS JPM AND IS DETERMINED TO BE:

SATISFACTORY: \_\_\_\_\_ UNSATISFACTORY: \_\_\_\_\_

PERFORMANCE CHECKLIST COMMENTS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_ Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time

SIGNED \_\_\_\_\_ DATE: \_\_\_\_\_

SIGNATURE INDICATES THIS JPM HAS BEEN COMPARED TO ITS APPLICABLE PROCEDURE BY A  
QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.

---

## ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-RO-SURV3

Page 2 of 4

### THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:** A surveillance test of DG1 Fuel Transfer Pump P-16A is in progress.

Data gathering of Supplement 5 of 1104.036 up to step 2.6 is completed.

---

**TASK STANDARD:** The examinee calculates pump flow rate correctly on Supplement 5 of 1104.036 and  
determines the data is below the minimum in the acceptance criteria.

---

**TASK PERFORMANCE AIDS:** 1104.036, Supplement 5, completed to step 2.6.

---

---

# ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-RO-SURV3

Page 3 of 4

## INITIATING CUE:

The CRS directs you to perform steps 2.7, and 3.1, of 1104.036, Supplement 5, "DG1 Fuel Transfer Pump (P-16A) Capacity Test" and determine if P-16A data is within the Limiting Range for Operability.

Stop Watch used to time P-16A elapsed time indicates 9 minutes and 40.8 seconds.

CRITICAL ELEMENTS (C) 2, 3, 4

(C)	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UNSAT
	1. Review 1104.036, Supplement 5.	Examinee reviewed 1104.036, Supplement 5.	—	—	—
(C)	2. Calculate pump flow rate.	Examinee correctly calculated pump flow rate.  Per note, 41.36 seconds equals .68 minutes.  $(200 - 105) / 9.68 = 9.81 \text{ gpm}$	—	—	—
(C)	3 Record flow rate in Section 3.0.	Examinee recorded flow rate in Section 3.0.	—	—	—
(C)	4 Evaluate flow rate, compare to "LIMITING RANGE FOR OPERABILITY" value.	Examinee circled "NO" in column titled "IS DATA WITHIN LIMITING RANGE".	—	—	—
	5. Upon declaring the pump inoperable, the examinee may discuss the required procedural actions.	Examinee may discuss declaring pump inoperable, notifying SM, writing a Condition Report, initiating corrective action, and referring to Tech Specs.	—	—	—
<p style="text-align: center;"><b>NOTE:</b>  <i>The SM or CRS will consult Tech Specs to determine operability, it is the RO's responsibility to report the inoperability of P-16A only. Diesel operability will be determined by the SM/CRS.</i></p>					

END

**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

**TITLE: EMERGENCY DIESEL GENERATOR  
OPERATION**

**DOCUMENT NO.**  
1104.036

**CHANGE NO.**  
048

**WORK PLAN EXP. DATE**  
N/A

**SET #**

**SAFETY-RELATED**  
☒ YES ☐ NO

**IPTE**  
☐ YES ☒ NO

**TEMP MOD**  
☐ YES ☒ NO

**LEVEL OF USE**  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL

**PROGRAMMATIC EXCLUSION PER EN-LI-100**  
☐ YES ☒ NO

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.**  
1000.006A

**CHANGE NO.**  
054

KEY

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>169 of 271</b> CHANGE: <b>048</b>
--	---	---

SUPPLEMENT 5

Page 1 of 4

DG1 FUEL TRANSFER PUMP (P-16A) CAPACITY TEST

This test demonstrates operability of P-16A and components and partially satisfies TS 5.5.8 (ANO IST program requirements). Steps are provided for measuring P-16A capacity using the timed fill rate of the associated DG skid tank.

1.0 INITIAL CONDITIONS

1.1 Check the purpose of this test:

- ☐ A. Regularly scheduled 24-month test.
- ☒ B. Operability test following significant maintenance (describe maintenance performed in section 4.0).
- ☐ C. Other (describe in section 4.0).

~~1.2~~ In Mode 5 or Mode 6 or DG1 is inoperable

**NOTE**

Day tank level may be lowered by draining fuel oil or securing transfer pumps while engine is running.

~~1.3~~ DG1 day tank level has been lowered to ~100 gallons.

~~1.4~~ Stop watch available. (Cal Due Date 10-08-08)

~~1.4.1~~ Record stopwatch M&TE number in section 3.0.

~~1.5~~ DG1 is idle.

~~1.6~~ IF ANY loads on MCC B55 and B56 are required to be operable, THEN verify MCC B55 and B56 powered from bus B6.

2.0 TEST METHOD

~~2.1~~ Verify DG1 Fuel Transfer Pump P-16A HS (HS-5211) on C107 in OFF.

~~2.2~~ Verify DG1 Engine Control Selector switch (HS-5234) on C107 in MAINT.

~~2.3~~ Record DG1 day tank level (should be ~100 gallons) at DG1 Fuel Oil Day Tank T-30A Level (LG-5218).

105 gallons

KEY

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>170 of 271</b> CHANGE: <b>048</b>
--	---	---

SUPPLEMENT 5

Page 2 of 4

**CAUTION**

Manual operation of Fuel Transfer Pump can cause day tank to overflow.

- ~~2.3~~ Start P-16A by placing (HS-5211) on C107 in MANUAL.
- ~~2.4.1~~ Start the stopwatch when day tank T-30A level begins to rise.
- ~~2.5~~ Continue manual transfer until day tank level reaches ~200 gallons.
- ~~2.5.1~~ Monitor level continuously. ←
- ~~2.6~~ WHEN level is ~200 gallons,  
THEN perform the following:
  - ~~2.6.1~~ Stop the watch.
  - ~~2.6.2~~ Record actual T-30A level 200 gallons.
  - ~~2.6.3~~ Stop P-16A using (HS-5211).

**NOTE**

Round fractions of a second to seconds and divide seconds by 60 to obtain fraction of minute (i.e.--15.02 seconds should be rounded to 15.0 seconds. 15/60=.25 minutes).

- ~~2.7~~ Calculate average flow rate by dividing tank level change  
( 95 gals) by elapsed time for fill ( 9.68 minutes).  
P-16A flow rate = 9.81 GPM.
- 2.7.1 Record in section 3.0.
- 2.8 Place P-16A HS (HS-5211) in AUTO.
- 2.9 Return DG1 Engine Control selector switch (HS-5234) on C107 to REMOTE.
- 2.10 Acknowledge or reset all local alarms.
- 2.11 Power MCC B55 and B56 as required by ES Electrical System Operation (1107.002).

KEY



PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>171 of 271</b> CHANGE: <b>048</b>
--	---	---

SUPPLEMENT 5

Page 3 of 4

3.0 ACCEPTANCE CRITERIA

3.1

Record values observed during P-16A testing AND compare with "Limiting Range For Operability."

TEST QUANTITY	INSTRUMENT	MEASURED VALUES	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? (CIRCLE YES OR NO)
P-16A flow	M&TE # <u>SW-007</u>	<u>9.81</u> GPM	≥10 GPM	YES <u>NO</u>

3.2 IF "NO" is circled in above table,  
THEN perform the following:

- Declare P-16A inoperable.
- Notify SM.
- Verify a Condition Report initiated.
- Initiate corrective action.
- Reference Tech Spec for applicable Conditions and Required Actions.

Performed by \_\_\_\_\_ Operator Date/Time \_\_\_\_\_

Review all calculations AND verify correct.

Reviewed and verified by (SRO) \_\_\_\_\_ Date \_\_\_\_\_

KEY

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>172 of 271</b> CHANGE: <b>048</b>
--	---	---

SUPPLEMENT 5

Page 4 of 4

4.0 SHIFT MANAGER REVIEW AND ANALYSIS

(circle one)

4.1 Do all measured values recorded in the Acceptance Criteria section fall within the specified LIMITING RANGE FOR OPERABILITY? YES NO

4.2 IF answer to 4.1 is "NO",  
THEN describe action taken below.

*This supplement is being performed to document operability of P16-A following complete rebuild under WO# 00017524*

4.3 Has this equipment been proven operable per the ACCEPTANCE CRITERIA? YES NO

4.4 Have all the administrative requirements of this test been satisfied (i.e., all initial blocks initialed or N/A'd, all data entered, cal due dates listed, applicable signature spaces signed, etc.)? YES NO

SHIFT MANAGER \_\_\_\_\_ DATE \_\_\_\_\_

*KEY*

**EXAMINEE'S COPY****JPM INITIAL TASK CONDITIONS:**

- A surveillance test of DG1 Fuel Transfer Pump P-16A is in progress.
- Supplement 5 of 1104.036 through step 2.6 is completed.

**INITIATING CUE:**

The CRS directs you to perform steps 2.7, and 3.1, of 1104.036, Supplement 5, "DG1 Fuel Transfer Pump (P-16A) Capacity Test" and determine if P-16A data is within the Limiting Range for Operability.

Stop Watch used to time P-16A elapsed time indicates 9 minutes and 40.8 seconds.

**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>  SET #	DOCUMENT NO. 1104.036	CHANGE NO. 048
	WORK PLAN EXP. DATE N/A	
	SAFETY-RELATED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	IPTE <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
	TEMP MOD <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	LEVEL OF USE <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> REFERENCE <input type="checkbox"/> INFORMATIONAL
	PROGRAMMATIC EXCLUSION PER EN-LI-100 <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	

When you see these **TRAPS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Get these **TOOLS**

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

VERIFIED BY	DATE	TIME
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
FORM TITLE: <b>VERIFICATION COVER SHEET</b>	FORM NO. 1000.006A	CHANGE NO. 054

*RO Handout for Examinee*

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>7 of 271</b> CHANGE: <b>048</b>
--	---	---

## 5.0 LIMITS AND PRECAUTIONS

- 5.1 If AC Lube Oil Soak Back Pump has not operated continuously, no planned fast start should be made (immediate acceleration to 900 RPM) unless the following are verified:
  - 5.1.1 For DG1, if 90 minutes have elapsed since P-106A-2 ran, then verify the following:
    - DG1 Main LO Upstream Supply Sightglass (SG-5270B) indicates full.
    - E-197A Lube Oil Cooler Oil Return Sightglass (SG-5270C) indicates full.
    - DG1 Lube Oil HX Outlet Temp (TI-5270) indicates >85°F.
      - A. If TI-5270 indicates ≤85°F, refer to L&P 5.2.
  - 5.1.2 For DG2, if 45 minutes have elapsed since P-106B-2 ran, then verify the following:
    - DG2 Main LO Upstream Supply Sightglass (SG-5271B) indicates full.
    - E-197B Lube Oil Cooler Oil Return Sightglass (SG-5271C) indicates full.
    - DG2 Lube Oil HX Outlet Temp (TI-5271) indicates >85°F.
      - A. If TI-5271 indicates ≤85°F, refer to L&P 5.2.
- 5.2 If DG1/DG2 Lube Oil HX Outlet Temp (TI-5270, TI-5271) indicates ≤85°F, then DG must not operate and affected DG engine control selector should be placed in MAINT, and DG declared unavailable and inoperable.
- 5.3 Any visible tubing vibrations during DG surveillances, or, water, air, or oil leaks are to be promptly reported. Elevated leaks may allow oil system to draw in air when shut down, draining pipes.
- 5.4 Diesel run time unloaded or at low load (<75%) should be minimized in order to prevent carbon fouling (improper combustion) and excessive turbocharger gear train wear.
- 5.5 During periods of known off-site electrical grid disturbances, neither diesel should be paralleled to the grid. This will prevent a loss of the diesel generator from protective relay actuation such as overload or reverse power.
- 5.6 When both diesel generators are in operation, do not tie them to the grid simultaneously. One DG shall be dedicated only to its ES bus. Otherwise a single grid electrical fault may cause a loss of both emergency diesel generators.
- 5.7 Governor booster pump tubing should be inspected for leaks during diesel run to prevent loss of governor-control oil pressure.

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>8 of 271</b> CHANGE: <b>048</b>
--	---	---

- 5.8 The Shift Manager (SM) shall be notified of any oil spill that has the potential of reaching Lake Dardanelle.
- 5.9 Do not attempt diesel generator restarts until engine has stopped (0 RPM) .
- 5.10 Either the AC or DC soak back pump (P-106A-3 or P-106A-1 for DG1, P-106B-3 or P-106B-1 for DG2) must be operational before operating the diesel and must continue to operate a minimum of 30 minutes after the diesel is shutdown to cool the turbocharger bearings.
- 5.11 In parallel operation, maximum allowed reactive load is 1200 KVAR out and 500 KVAR in at full load.
- 5.12 Maximum current: 450 amps. Do not exceed except in emergency.
- 5.13 Maximum ambient temp for diesel operation is 122°F. Verify ventilation fans operate to maintain ambient temp < maximum allowed.
- 5.14 Maximum engine outlet water temperature is 205°F.
- 5.15 Minimum oil pressure is 26 psig when diesel is operating at 900 RPM.
- 5.16 Except for automatic starts and tests when opposite train components are inoperable, do not operate the diesel until all cylinders are cleared of water.
- 5.17 Do not operate the diesel unless service water is available for cooling.
- 5.18 The following values are given to help determine when diesel temperatures have stabilized, and are not intended to limit operation.
  - Scavenging Pump Disc. Temp. - 190°F - 195°F
  - Water Pump Suction Temp. - 155°F - 160°F
  - Water Leaving Engine Temp. - 165°F - 175°F
- 5.19 The fuel oil filter bypass sightglass (farthest from the engine) should be empty in normal operation, if fuel oil is in this sightglass, the fuel oil filter should be changed.
- 5.20 The return fuel sightglass (nearer the engine) passes returning fuel from the injectors to the day tank. This sightglass should normally be full. Air bubbles in this sightglass with the fuel priming pump running and the engine stopped indicates air entering the suction of the pump. Bubbles appearing only when engine is running indicates leaky valves in fuel injectors. Little or no fuel in the sightglass indicates insufficient fuel to the engine.
- 5.21 To maintain the seven day requirement for one diesel, either procure additional fuel to allow both diesels to continue operation or shutdown one diesel within 50 hours.

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>9 of 271</b> CHANGE: <b>048</b>
--	---	---

- 5.22 A delay in opening output breaker at 100 KW when unloading a diesel may result in generator motoring which causes lockout relay to actuate and trip DG output breaker and shutdown the engine.
- 5.23 A delay in loading diesel after closing output breaker may result in generator motoring which causes lockout relay to actuate and trip DG output breaker and shutdown the engine.
- 5.24 Actions such as resetting, changing control switch positions, reconfiguring components, or attempting diesel restart after failure can cause loss of data useful in diagnosing problems and should be avoided if not an emergency.
- 5.25 If diesel generator is paralleled to the grid, adjusting either Unit 1 or Unit 2 Main Generator reactive loading may result in significant changes in EDG reactive loading.
- 5.26 All EDG start attempts shall be logged in the Station Log and recorded using EDG Start/Load/Run Information Sheet (Form 1104.036A).
- 5.27 The guidance and criteria for EDG failures is contained within Unit 1 EDG Reliability Program (1032.034). Ensure System Engineering is notified to verify requirements of 1032.034 are met for valid EDG failures.
- 5.28 If Emergency Stop PB on (C-107/C-108) was used to stop EDG, lockout relay on (A308/A408) will not reset until Reset (orange) PB for applicable EDG on local control panel (C-107/C-108) is depressed.
- 5.29 Over tightening cylinder cocks can cause damage to threads and sealing surfaces of drain cocks.
- 5.30 Efficient execution of the cylinder inleakage check while Engine Control HS is in MAINT will minimize accumulation of DG unavailability time.

## 6.0 SETPOINTS

- 6.1 Fuel storage tank low level alarm: 155".
  - DG1 Emergency Diesel Fuel Tank T-57A Low Level (PDIS-5211)
  - DG2 Emergency Diesel Fuel Tank T-57B Low Level (PDIS-5212)
- 6.2 Fuel transfer pump high discharge pressure alarm: 30 psig.
  - DG1 Fuel Oil Transfer Pump P-16A Hi Disch Press (PSH-5211)
  - DG2 Fuel Oil Transfer Pump P-16B Hi Disch Press (PSH-5212)
- 6.3 Fuel oil day tank high level limit switch: stops upstream fuel transfer pump at 18.75" tank level (240 gallons).
  - DG1 Fuel Oil Day Tank T-30A Hi Level (LSH-5205)
  - DG2 Fuel Oil Day Tank T-30B Hi Level (LSH-5210)

PROC./WORK PLAN NO. 1104.036	PROCEDURE/WORK PLAN TITLE: EMERGENCY DIESEL GENERATOR OPERATION	PAGE: 169 of 271 CHANGE: 048
---------------------------------	--	---------------------------------

SUPPLEMENT 5

Page 1 of 4

DG1 FUEL TRANSFER PUMP (P-16A) CAPACITY TEST

This test demonstrates operability of P-16A and components and partially satisfies TS 5.5.8 (ANO IST program requirements). Steps are provided for measuring P-16A capacity using the timed fill rate of the associated DG skid tank.

~~1.0~~ INITIAL CONDITIONS

~~1.1~~ Check the purpose of this test:

- ~~A.~~ Regularly scheduled 24-month test.
- ☒ B. Operability test following significant maintenance (describe maintenance performed in section 4.0).
- ~~C.~~ Other (describe in section 4.0).

~~1.2~~ In Mode 5 or Mode 6 or DG1 is inoperable.

**NOTE**

Day tank level may be lowered by draining fuel oil or securing transfer pumps while engine is running.

~~1.3~~ DG1 day tank level has been lowered to ~100 gallons.

~~1.4~~ Stop watch available. (Cal Due Date 10-08-08)

~~1.4.1~~ Record stopwatch M&TE number in section 3.0.

~~1.5~~ DG1 is idle.

~~1.6~~ IF ANY loads on MCC B55 and B56 are required to be operable, THEN verify MCC B55 and B56 powered from bus B6.

2.0 TEST METHOD

~~2.1~~ Verify DG1 Fuel Transfer Pump P-16A HS (HS-5211) on C107 in OFF.

~~2.2~~ Verify DG1 Engine Control Selector switch (HS-5234) on C107 in MAINT.

~~2.3~~ Record DG1 day tank level (should be ~100 gallons) at DG1 Fuel Oil Day Tank T-30A Level (LG-5218).

105 gallons




PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>170 of 271</b> CHANGE: <b>048</b>
--	---	---

SUPPLEMENT 5

Page 2 of 4

**CAUTION**

Manual operation of Fuel Transfer Pump can cause day tank to overflow.

- ~~2.4~~ Start P-16A by placing (HS-5211) on C107 in MANUAL.
- ~~2.4.1~~ Start the stopwatch when day tank T-30A level begins to rise.
- ~~2.5~~ Continue manual transfer until day tank level reaches ~200 gallons.
- ~~2.5.1~~ Monitor level continuously. 
- ~~2.6~~ WHEN level is ~200 gallons,  
THEN perform the following:
  - ~~2.6.1~~ Stop the watch.
  - ~~2.6.2~~ Record actual T-30A level 200 gallons.
  - ~~2.6.3~~ Stop P-16A using (HS-5211).

**NOTE**

Round fractions of a second to seconds and divide seconds by 60 to obtain fraction of minute (i.e.--15.02 seconds should be rounded to 15.0 seconds. 15/60=.25 minutes).

- 2.7 Calculate average flow rate by dividing tank level change  
(\_\_\_\_\_gals) by elapsed time for fill (\_\_\_\_\_minutes).  
P-16A flow rate = \_\_\_\_\_GPM.
- 2.7.1 Record in section 3.0.
- 2.8 Place P-16A HS (HS-5211) in AUTO.
- 2.9 Return DG1 Engine Control selector switch (HS-5234) on C107 to REMOTE.
- 2.10 Acknowledge or reset all local alarms.
- 2.11 Power MCC B55 and B56 as required by ES Electrical System Operation (1107.002).

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>171 of 271</b> CHANGE: <b>048</b>
--	---	---

SUPPLEMENT 5

Page 3 of 4

3.0 ACCEPTANCE CRITERIA

3.1 Record values observed during P-16A testing AND compare with "Limiting Range For Operability."

TEST QUANTITY	INSTRUMENT	MEASURED VALUES	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? (CIRCLE YES OR NO)
P-16A flow	M&TE # <i>Su007</i>	GPM	≥10 GPM	YES      NO

3.2 IF "NO" is circled in above table,  
THEN perform the following:

- Declare P-16A inoperable.
- Notify SM.
- Verify a Condition Report initiated.
- Initiate corrective action.
- Reference Tech Spec for applicable Conditions and Required Actions.

Performed by \_\_\_\_\_ Operator Date/Time \_\_\_\_\_

Review all calculations AND verify correct.

Reviewed and verified by (SRO) \_\_\_\_\_ Date \_\_\_\_\_

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>172 of 271</b> CHANGE: <b>048</b>
--	---	---

SUPPLEMENT 5

Page 4 of 4

4.0 SHIFT MANAGER REVIEW AND ANALYSIS

(circle one)

4.1 Do all measured values recorded in the Acceptance Criteria section fall within the specified LIMITING RANGE FOR OPERABILITY? YES NO

4.2 IF answer to 4.1 is "NO",  
THEN describe action taken below.

*This supplement is being performed to document operability of P16A following complete rebuild under WO# 00017524*

4.3 Has this equipment been proven operable per the ACCEPTANCE CRITERIA? YES NO

4.4 Have all the administrative requirements of this test been satisfied (i.e., all initial blocks initialed or N/A'd, all data entered, cal due dates listed, applicable signature spaces signed, etc.)? YES NO

SHIFT MANAGER \_\_\_\_\_ DATE \_\_\_\_\_

---

## A4. Radiation Control

M/R

K/A 2.3.4

Knowledge of radiation exposure limits under normal or emergency conditions.

A1JPM-RO-DOSE-SVY2

JOB PERFORMANCE MEASURE

Unit: 1 Rev # 4 Date: 8/19/2008

TUOI NUMBER: A1JPM-RO- DOSE-SVY2

System/Duty Administrative Topic-Radiation Control  
Area: \_\_\_\_\_

Task: Calculate Stay times for yourself and another operator

KA Value RO 3.2 SRO 3.7 KA Reference 2.3.4  
☒ SRO

Approved For Administration To: RO \_\_\_\_\_

Task Location: Inside CR: \_\_\_\_\_ Outside CR: \_\_\_\_\_ Both: ☒

Suggested Testing Environment And Method (Perform Or Simulate): Perform

Plant \_\_\_\_\_ Simulator \_\_\_\_\_ Lab: Perform

Site: \_\_\_\_\_ :

Position Evaluated: X SRO: \_\_\_\_\_

RO: \_\_\_\_\_

Actual Testing Environment: \_\_\_\_\_ Plant Site: \_\_\_\_\_ Lab X

Simulator: \_\_\_\_\_

Testing Method: \_\_\_\_\_ Perform: X

Simulate: \_\_\_\_\_

Approximate Completion Time In Minutes: 15 Minutes

Reference(S) HP Survey Map of P36C, Pump Room 54.

Examinee's \_\_\_\_\_ SSN: \_\_\_\_\_

Name: \_\_\_\_\_

Evaluator's \_\_\_\_\_

Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments: \_\_\_\_\_

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

Signed \_\_\_\_\_ Date: \_\_\_\_\_

Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:**

You are an WCO with the plant at full power. A hot spot has developed on Makeup PUMP P36C. You and another WCO will be working in the vicinity of the reduction gear assembly in order to flush the lines and reduce the hot spot radiation field.

Using the supplied survey map, determine the individual stay times **for yourself AND the other WCO** without exceeding the annual administrative dose limit (Ignore dose received during transit). You have an accumulated annual Whole Body dose of 1905 mR (ANO records). The other WCO has an accumulated annual Whole Body dose of 1790 mR (ANO records). No additional dose has been received at any other site.

**Also**, calculate stay times if the air in the pump room was contaminated with a level of 0.29 DAC (stochastic) assuming no respirators are used.

Calculations should be based on ANO Unit 1 Administrative dose limits. **Provide answers with 3 significant figures (example 4.51 hours)**. Do not consider ALARA task requirements.

**TASK STANDARD:**

The examinee has correctly determined the stay times for himself and the other WCO on the assignment.

**TASK PERFORMANCE AIDS:**

HP Survey map of P36C Pump Room, Room number 54.

**SIMULATOR SETUP:**

N/A

INITIATING CUE: Determine the Stay time for you and the other WCO on the job. Also determine the stay time if the air in the pump room was contaminated with a level of 0.29 DAC (stochastic) assuming no respirators are used. **Provide answers with 3 significant figures (example 4.51 hours).**

CRITICAL ELEMENTS (c): 1,2, and 3

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
C	1. Determine the HIGHEST general area dose rate in the area of the reduction gear assembly to be used from the survey map.	Examinee has determined the HIGHEST general area dose rate in the area of the reduction gear assembly to be used from the survey map of P36C pump room.  (80 mR/hr)	—	—	—
C	2. Determine Stay time (to 3 significant figures) with no airborne contamination for both operators.  <b>Key:</b> Max dose at ANO1 is 2000 mR  AO1 has 1905mR, =>allowed dose 95mR AO2 has 1700mR, =>allowed dose 300mR  $\frac{95\text{mR}}{80\text{mR/hr}} = 1.18 \text{ hr}, \quad \frac{300\text{mR}}{80\text{mR/hr}} = 3.75 \text{ hr}$	Examinee has determined that the stay time for him/her is 1.18 hrs and the stay time for the other WCO is 3.75 hrs plus or minus 0.01 hours.	—	—	—
C	3. Determine Stay time( to 3 significant figures) WITH airborne contamination for both operators.  1DAC = 2.5mR/hr * 0.29DAC = 0.725mR/hr Total rate = 80mR/hr + 0.725mR/hr = 80.725mR/hr  $\frac{95\text{mR}}{80.725\text{mR/hr}} = 1.17 \text{ hr}$  $\frac{300\text{mR}}{80.725\text{mR/hr}} = 3.71 \text{ hr}$	Examinee has determined that the stay time for him/her is 1.17hrs and the stay time for the other WCO is 3.71 hrs plus or minus 0.01 hours.	—	—	—
<b>EXAMINER'S CUE: This concludes the JPM.</b>					

END

## EXAMINEE'S COPY

### INITIAL CONDITIONS:

You are an WCO with the plant at full power. A hot spot has developed on Makeup PUMP P36C. You and another WCO will be working in the vicinity of the reduction gear assembly in order to flush the lines and reduce the hot spot radiation field.

Using the supplied survey map, determine the individual stay times **for yourself AND the other WCO** without exceeding the annual administrative dose limit (Ignore dose received during transit). You have an accumulated annual Whole Body dose of 1905 mR (ANO records). The other WCO has an accumulated annual Whole Body dose of 1790 mR (ANO records). No additional dose has been received at any other site.

**Also**, calculate stay times if the air in the pump room was contaminated with a level of 0.29 DAC (stochastic) assuming no respirators are used.

Calculations should be based on ANO Unit 1 Administrative dose limits. **Provide answers with 3 significant figures (example 4.51 hours)**. Do not consider ALARA task requirements.


### INITIATING CUE:

INITIATING CUE: Determine the Stay time **for yourself AND the other WCO** on the job. **Also** determine the stay time if the air in the pump room was contaminated with a level of 0.29 DAC (stochastic) assuming no respirators are used. **Provide answers with 3 significant figures (example 4.51 hours)**.



# Aux building posted: RM,RWPR

335 posted RA



All Radiation values are in mrem/hour unless otherwise noted.

12.5 denotes gamma general area dose rates.

Smear contamination values are in DPM/100 Sqcm unless otherwise noted.

\* 12/13 Denotes Gamma Contact/Far reading (30 cm)

\* 12 Denotes contact dose rate (gamma)

Form to be retained for records

H. S. Denotes Hot Spot Readings

O Denotes smear location (100 sqcm.)

□ Denotes large area smear location

## Smear Data

DPM/100cm2	No.	Activity
1	20,000	
2	30,000	
3	60,000	
4	10,000	

## Alpha Smears DPM/100cm2

No. Activity

Rx. %	100
Date	09/10/2008
Time	0000:00
Dose Rate Inst.	HP-DR-170
Cal Due Date	12/31/2008
Dose Rate Inst. #2	RM-065
Cal Due Date	12/31/2008
Count Inst.	RO-705
Cal Due Date	12/31/2008
Bkg.	80 cpm D/C 10
Count Inst. #2	
Cal Due Date	12/31/2008
Bkg.	90 cpm D/C 10
Survey Frequency:	
Daily	
Bi-Weekly	
X Monthly	
Quarterly	
Job Coverage	
Other	
RWP #	4005/1
Surveyor:	John Public 1234 Badge
RP Supervisor Review:	Imma N. Charge
DANI #	011256
Page 1 of	1

## A5. Conduct of Operations

D/R

K/A 2.1.23

Ability to perform specific system and integrated plant procedures during all modes of plant operation.

A1JPM-SRO-HTBAL1

UNIT: 1 REVISION # 1 DATE: \_\_\_\_\_TUOI NUMBER: A1JPM-SRO-HTBAL1SYSTEM: Conduct of OperationsTASK: Review a Manual Heat Balance CalculationJTA: ANO-SRO-ADMIN-NORM-200KA VALUE RO 2.9 SRO 4.3 KA REFERENCE: 2.1.23APPROVED FOR ADMINISTRATION TO: RO \_\_\_\_\_ SRO XTASK LOCATION: INSIDE CR: \_\_\_\_\_ OUTSIDE CR: \_\_\_\_\_ BOTH: X

SUGGESTED TESTING ENVIRONMENT AND METHOD (PERFORM OR SIMULATE):

PLANT SITE: \_\_\_\_\_ SIMULATOR: PERFORM LAB: \_\_\_\_\_POSITION EVALUTED: RO \_\_\_\_\_ SRO XACTUAL TESTING ENVIRONMENT: PLANT SITE: \_\_\_\_\_ SIMULATOR: X LAB: \_\_\_\_\_ACTUAL TESTING METHOD: SIMULATE: \_\_\_\_\_ PERFORM: XAPPROXIMATE COMPLETION TIME IN MINUTES: 45 MINUTESREFERENCES: 1103.016 Heat Balance Calculation

EXAMINEE'S NAME: \_\_\_\_\_ SSN: \_\_\_\_\_

EVALUATOR'S NAME: \_\_\_\_\_

THE EXAMINEE'S PERFORMANCE WAS EVALUATED AGAINST THE STANDARDS CONTAINED IN THIS JPM AND IS DETERMINED TO BE:

SATISFACTORY: \_\_\_\_\_ UNSATISFACTORY: \_\_\_\_\_

PERFORMANCE CHECKLIST COMMENTS: \_\_\_\_\_

START TIME: \_\_\_\_\_ STOP TIME: \_\_\_\_\_ TOTAL TIME: \_\_\_\_\_

SIGNED: \_\_\_\_\_ DATE: \_\_\_\_\_

SIGNATURE INDICATES THIS JPM HAS BEEN COMPARTED TO ITS APPLICABLE PROCEDURE BY A QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.

**THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:**

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:** It is desired to verify the accuracy of the PMS calculated Rx Thermal Power (XPP) in order to ensure compliance with Technical Specification SR 3.3.1.2.  
The CBOT has completed 1103.016, Heat Balance Calculation, and calculated Rx thermal power to be 101.483%.  
NI's are reading an average of 99.1%. The CBOT's math has been verified to be correct by an extra RO.

**TASK STANDARD:** The examinee has correctly identified the errors in the Heat Balance Calculation. Recalculates the correct heat balance power to within 97.6 to 100.6%. Verifies compliance with Technical Specification Surveillance Requirement 3.3.1.2.

**TASK PERFORMANCE AIDS:** Copies of completed 1103.016.

**INITIATING CUE:**

- Review the operator's completed 1103.016 for accuracy.
- Verify compliance with Technical Specification SR 3.3.1.2.

**CRITICAL ELEMENTS (C):** 1, 3

(C)	PERFORMANCE CHECKLIST	STANDARDS	N/A	SAT	UNSAT
<b>NOTE:</b> Provide examinee with a copy of completed 1103.016. Examinee may state initially that the as performed Heat Balance would require adjustment of NI's to be in compliance with Tech Spec SR 3.3.1.2.					
(C)	1. Review 1103.016.	Examinee reviewed 1103.016. Examinee discovered three of four errors in calculations. 1. Step 2.4 value used for Q losses was taken from step 2.2 vs. 2.3 which makes %FP <sub>sec</sub> incorrect which makes Q <sub>PRIA</sub> 2. Step 2.5 a value of 600 was given for HHA instead of real value. 3. Step 2.5 value used for Q losses was taken from step 2.2 vs. 2.3 which makes %FP <sub>PRI</sub> incorrect. 4. Step 2.6 % full power calculation is incorrect due to above errors.			
	2. Instruct CBOT to re-perform 1103.016.	Examinee stated that 1103.016 should be re-performed.			
<b>NOTE:</b> Inform examinee that 1103.016 has been re-performed and calculated Rx thermal power is 99.99%.					
(C)	3. Verify compliance with Technical Specification surveillance SR 3.3.1.2.	Examinee concludes that SR 3.3.1.2 as recalculated Rx thermal power is within 2% of initial NI readings.			

**END**

# ENTERGY OPERATIONS INCORPORATED ARKANSAS NUCLEAR ONE

TITLE: HEAT BALANCE CALCULATION

DOCUMENT NO.  
1103.016

CHANGE NO.  
012

WORK PLAN EXP. DATE  
N/A

TC EXP. DATE  
N/A

SET #

SAFETY-RELATED  
☒ YES ☐ NO

IPTE  
☐ YES ☒ NO

TEMP ALT  
☐ YES ☒ NO

LEVEL OF USE  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL

PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO

When you see these **TRAPS**

Get these **TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Overconfidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

VERIFIED BY

DATE

TIME


FORM TITLE:

VERIFICATION COVER SHEET

FORM NO.  
1000.006A

CHANGE NO.  
053

KEY

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 12 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 6 of 15

## 2.4 Secondary Side Heat Balance

$Q_{SECA}$  = Loop A Secondary Power

$$Q_{SECA} = \frac{(H_{STMA} - H_{FWA}) \times F_{FWA}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECA} = \frac{(\underline{1243.313} - \underline{447.84}) \text{ BTU/Hr} \times \underline{5491.643} \times 10^3 \text{ Lbm/Hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECA} = \underline{1230.1863} \text{ MW}$$

$Q_{SECB}$  = Loop B Secondary Power

$$Q_{SECB} = \frac{(H_{STMB} - H_{FWB}) \times F_{FWB}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECB} = \frac{(\underline{1249.863} - \underline{447.897}) \text{ BTU/Hr} \times \underline{5529.993} \times 10^3 \text{ Lbm/Hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECB} = \underline{1299.7309} \text{ MW}$$

$\%FP_{SEC}$  = Secondary Calculated Heat Balance Power

$$\%FP_{SEC} = \frac{(Q_{SECA} + Q_{SECB} + Q_{LOSSES}) \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{SEC} = \frac{(\underline{1280.1863} + \underline{1299.7309} + \underline{21.10} \text{ (Step 2.3)}) \text{ MW} \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{SEC} = \underline{101.286} \%$$

99.98% ✓ Cor Value

Value is from step 2.2  
not 2.3

-KEY-

ERROR

# /

Either  
B or C

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 13 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 7 of 15

## 2.5 Primary Side Heat Balance

ERROR # 2

Correct value  
615.85  
Either or both

$Q_{PRIA}$  = Loop A Primary Power

$$Q_{PRIA} = \frac{(H_{HA} - H_{CA}) \times F_{RCSA}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIA} = \frac{(\text{600} - 555.6233) \text{ BTU/Hr} \times 72.54 \times 10^6 \text{ Lbm/Hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIA} = \text{943.42 MW}$$

Correct value  
1280.38

$Q_{PRIB}$  = Loop B Primary Power

$$Q_{PRIB} = \frac{(H_{HB} - H_{CB}) \times F_{RCSB}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIB} = \frac{(\text{616.45} - 555.7633) \text{ BTU/Hr} \times 73.09 \times 10^6 \text{ Lbm/Hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIB} = \text{1299.94 MW}$$

$\%FP_{PRI}$  = Primary Calculated Heat Balance Power

$$\%FP_{PRI} = \frac{(Q_{PRIA} + Q_{PRIB} + Q_{LOSSES}) \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{PRI} = \frac{(\text{943.42} + 1299.94 + \text{21.10}) \text{ MW} \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{PRI} = \text{38.179 \%}$$

Wrong value

Either or all three

100.005 %  
Correct value

SAME mistake  
as in 2.4

- KEY -



PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 14 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 8 of 15

2.6 Best Estimate of Reactor Power

$$\text{Alpha} = \frac{(\%FP_{\text{SEC}} - 15)}{85}$$

$$\text{Alpha} = \frac{(\frac{101.286}{(\text{step 2.4})} - 15)}{85}$$

$$\text{Alpha} = \underline{1.015}$$

99.98 correct value

%FP = Best Estimate Calculated Thermal Power

$$\%FP = (\text{Alpha} \times \%FP_{\text{SEC}}) + [(1 - \text{Alpha}) \times \%FP_{\text{PRI}}]$$

$$\%FP = (\frac{1.015}{99.98} \times \frac{101.286}{(\text{Step 2.4})}) + [(1 - \frac{1.015}{99.98}) \times \frac{88.179}{(\text{Step 2.5})}]$$

100.005

$$\%FP = \underline{101.433}$$

99.98 % correct value

In correct due to previous errors  
and is not representation of  
Actual power

- KEY -

ERROR # 4  
Either or both

SURVEILLANCE	FREQUENCY
<p>SR 3.3.1.2</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> <li>1. Adjust power range channel output if the absolute difference is <math>&gt; 2\%</math> RTP.</li> <li>2. Not required to be performed until 24 hours after THERMAL POWER is <math>\geq 20\%</math> RTP.</li> </ol> <p>-----</p> <p>Compare results of calorimetric heat balance calculation to power range channel output.</p>	<p>96 hours</p> <p><u>AND</u></p> <p>Once within 24 hours after a THERMAL POWER change of <math>\geq 10\%</math> RTP</p>
<p>SR 3.3.1.3</p> <p>-----NOTES-----</p> <ol style="list-style-type: none"> <li>1. Adjust the power range channel imbalance output if the absolute value of the imbalance error is <math>\geq 2\%</math> RTP.</li> <li>2. Not required to be performed until 24 hours after THERMAL POWER is <math>\geq 20\%</math> RTP.</li> </ol> <p>-----</p> <p>Compare results of out of core measured AXIAL POWER IMBALANCE to incore measured AXIAL POWER IMBALANCE.</p>	<p>31 days</p>
<p>SR 3.3.1.4</p> <p>Perform CHANNEL FUNCTIONAL TEST.</p>	<p>31 days</p>
<p>SR 3.3.1.5</p> <p>-----NOTE-----</p> <p>Neutron detectors are excluded from CHANNEL CALIBRATION.</p> <p>-----</p> <p>Perform CHANNEL CALIBRATION.</p>	<p>18 months</p>

KEY  
3.3.1-3

**JPM INITIAL TASK CONDITIONS:**

- It is desired to verify the accuracy of the PMS calculated Rx Thermal Power (XPP) in order to ensure compliance with Technical Specification SR 3.3.1.2.
- The CBOT has completed 1103.016, Heat Balance Calculation, and calculated Rx thermal power to be 101.483%
- NI's are reading an average of 99.1%.
- The CBOT's arithmetic has been verified to be correct by an extra RO.

**INITIATING CUE:**

- Review the operator's completed 1103.016 for accuracy.
- Verify compliance with Technical Specification SR 3.3.1.2.

**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

**TITLE: HEAT BALANCE CALCULATION**

**DOCUMENT NO.**  
1103.016

**CHANGE NO.**  
012

**WORK PLAN EXP. DATE**  
N/A

**TC EXP. DATE**  
N/A

**SET #**

**SAFETY-RELATED**  
☒ YES ☐ NO

**IPTE**  
☐ YES ☒ NO

**TEMP ALT**  
☐ YES ☒ NO

**LEVEL OF USE**  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL

**PROGRAMMATIC EXCLUSION PER EN-LI-100**  
☐ YES ☒ NO

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Overconfidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.**  
1000.006A

**CHANGE NO.**  
053

*SRO Handout for Examinee*

PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>1 of 27</b>  CHANGE: <b>012</b>
--	---	--

# TABLE OF CONTENTS

	Page
1.0 PURPOSE .....	2
2.0 SCOPE .....	2
3.0 DESCRIPTION .....	2
4.0 REFERENCES .....	3
4.1 REFERENCES USED IN PROCEDURE PREPARATION.....	3
4.2 REFERENCES USED IN CONJUNCTION WITH THIS PROCEDURE.....	3
4.3 NRC COMMITMENTS.....	3
5.0 TEST EQUIPMENT, SPECIAL TOOLS AND SUPPLIES .....	3
6.0 LIMITS AND PRECAUTIONS .....	3
7.0 SETPOINTS .....	3
8.0 PREREQUISITES/INITIAL CONDITIONS .....	4
9.0 INSTRUCTIONS .....	4
10.0 ACCEPTANCE CRITERIA .....	5
11.0 RESTORATION AND CHECKOUT .....	5
12.0 SUPERVISORY REVIEW .....	5
13.0 ATTACHMENTS AND FORMS .....	5
13.1 ATTACHMENT 1 - Glossary of Symbols and Constants Used in Manual Heat Balance Calculation.....	6
13.2 ATTACHMENT 2 - Manual Heat Balance Calculation.....	7
13.3 FIGURE 1 - Primary Subcooled Enthalpy.....	22
13.4 FIGURE 2 - Secondary Subcooled Enthalpy Chart.....	23
13.5 FIGURE 3 - Superheat Enthalpy Chart.....	24
13.6 FIGURE 4 - RCS Density Correction Factor.....	25
13.7 FIGURE 5 - Feedwater Venturi Thermal Expansion Correction Factor.....	26
13.8 FIGURE 6 - Feedwater Density Correction Factor.....	27

PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>2 of 27</b>  CHANGE: <b>012</b>
--	---	--

### 1.0 PURPOSE

To provide procedures for calculating heat balances that may be used for:

- 1.1 An approximation of reactor power.
- 1.2 An independent check of plant computer calculations.
- 1.3 Calibrate nuclear instrumentation if the computer is not available.
- 1.4 An independent check of the plant computer calculations to be used during startup physics testing.

### 2.0 SCOPE

- 2.1 This procedure applies to the Unit 1 power range instrumentation. It provides a standard to which the out-of-core instrumentation can be compared and calibrated.
- 2.2 This procedure can be used to determine calorimetric heat balance calculations when the plant computer is unavailable. Thus, this procedure can be performed to partially satisfy SR 3.3.1.2.

### 3.0 DESCRIPTION

- 3.1 An approximation of reactor power may be obtained in the absence of plant computer calculations. The method consists of manual heat balance calculations of reactor power using panel indications and/or the SPDS computer.
- 3.2 The plant computer calculation of reactor power has an accuracy of 2 percent or better.
- 3.3 The initial conditions as defined under Steps 8.1 & 8.2 are required for the type of calculation desired.
- 3.4 The effects of instrumentation accuracy and heat losses are far lower at higher loads. It is recommended, therefore, that reactor power be as high as convenient, preferably 80 percent of full power or greater.
- 3.5 The accuracy of the calculation is also dependent on the source and method of reading data. The most accurate readings are obtained directly from the sensors using a digital voltmeter. Plant computer indication is almost as accurate, (the points are calibrated to 0.1%), especially since there is much less time lapse during data collection. Panel indications are the least accurate, and hence lend themselves best to multiple data sets.
- 3.6 Symbols and constants used in Manual Heat Balance are defined as described in Attachment 1.

PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>3 of 27</b>  CHANGE: <b>012</b>
--	---	--

#### 4.0 REFERENCES

##### 4.1 References Used In Procedure Preparation

- 4.1.1 Unit 1 Technical Specification 3.3.1 and SR 3.3.1.2
- 4.1.2 ASME Steam Tables
- 4.1.3 B&W Document #32-1236091-00 "ANO-1 Partial Pump Analysis"
- 4.1.4 TM A180.0310 Siemens Allis, Vertical Reactor Coolant Pump Motors.
- 4.1.5 TM B015.1360 Jeumont Schneider Industrie, Reactor Coolant Pump Motor
- 4.1.6 B&W Document 32-1236536-00, RC Pump Energy
- 4.1.7 CALC-87-D-1088-06, "Steady State Containment Temperature Mathematical Model," Rev 0.
- 4.1.8 CALC-98-E-0042-01, "Manual Heat Balance Uncertainty Analysis," Rev 0.
- 4.1.9 OP-1302.037, "Beginning of Cycle Heat Balance Initialization Procedure"
- 4.1.10 OP-1302.042, "Recalibration of Loop 'B' Primary Calorimetric at Non-BOC Conditions"

##### 4.2 References Used In Conjunction With This Procedure

None.

##### 4.3 NRC Commitments

None.

#### 5.0 TEST EQUIPMENT, SPECIAL TOOLS AND SUPPLIES

None

#### 6.0 LIMITS AND PRECAUTIONS

- 6.1 When using this procedure as a result of the loss of the plant computer, a conservative uncertainty factor is applied and will result in a calculated power significantly higher than actual power. Reduce power to 80%FP prior to performing this calculation to avoid a calculated power greater than 100%.
- 6.2 Calculations per this procedure should not be undertaken or used unless the plant is at a steady state power level. (This condition exists when feedwater flow is stable, there are no changes in power readings from out-of-core instrumentation or in the generator output meter in excess of  $\pm 2\%$ , or as specified in the body of this procedure.)

#### 7.0 SETPOINTS

None

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 4 of 27 CHANGE: 012
---------------------------------	--	------------------------------

~~8.0~~

# PREREQUISITES/INITIAL CONDITIONS

~~8.1~~

Ensure steady state conditions as follows;

The Delta-TC H/A station set to balance feed flow between steam generators for either two or four RC pumps in service, or set to maintain Delta-TC within 3°F for three RC pumps in service.

- RCS  $T_{ave}$  stable  $\pm 1^\circ\text{F}$ .
- Feedwater flow stable  $\pm \frac{1}{2}\%$  (54.5 Klbm/hr).
- No changes in MW demand.

~~8.2~~

The following parameters maintained in a steady state for a minimum of 18 minutes before data is taken:

- RCS Pressure
- RCS Flow
- Turbine header pressure
- Feedwater temperature

~~9.0~~

# INSTRUCTIONS

## NOTE

If using SPDS to perform the manual heat balance calculation, SPDS function 05, Option 4, may be used to obtain data. Some data will be required to be obtained from panel indication as they are not available on SPDS.

~~9.1~~

Take data required per data sheet (points indicated on Attachment 2). Wait at least six minutes between each set of data readings.

~~9.2~~

Perform calculations using Attachment 2

~~9.2.1~~

Refer to Attachment 1 for naming conventions and descriptions.

~~9.2.2~~

The final heat balance equation is weighted as follows:

Between 0 and 15 percent power, only the primary heat balance is considered. From 15 percent to full power, the heat balance is weighted linearly with only the secondary heat balance being considered at full power. Therefore, at full power, the primary heat balance is not considered at all.

~~9.3~~

The value obtained by this method for Reactor Power should be compared with the value obtained from the plant computer calculation for Reactor Power, if available.

~~9.4~~

Calculated reactor power from Attachment 2;

%FP = 101.483 %



PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>5 of 27</b>  CHANGE: <b>012</b>
--	---	--

~~9.5~~

Reactor power calculated by either the plant monitoring system (PMS) or SPDS;

XPP = 99.99 % or

NIILP = N/A %

10.0 ACCEPTANCE CRITERIA

None

11.0 RESTORATION AND CHECKOUT

None

PERFORMED BY: Just Cooper Date/Time \_\_\_\_\_

REVIEWED BY: \_\_\_\_\_ Date/Time \_\_\_\_\_

12.0 SUPERVISORY REVIEW AND APPROVAL

APPROVED BY: \_\_\_\_\_ Date/Time \_\_\_\_\_  
Reactor Eng. Supt. or Ops Supervision

13.0 ATTACHMENTS AND FORMS

- 13.1 Attachment 1 - Glossary of Symbols and Constants Used in Manual Heat Balance Calculation
- 13.2 Attachment 2 - Manual Heat Balance Calculation
- 13.3 FIGURE 1 - Primary Subcooled Enthalpy
- 13.4 FIGURE 2 - Secondary Subcooled Enthalpy Chart
- 13.5 FIGURE 3 - Superheat Enthalpy Chart
- 13.6 FIGURE 4 - RCS Density Correction Factor
- 13.7 FIGURE 5 - Feedwater Venturi Thermal Expansion Correction Factor
- 13.8 FIGURE 6 - Feedwater Density Correction Factor

PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>6 of 27</b>  CHANGE: <b>012</b>
--	---	--

ATTACHMENT 1

GLOSSARY OF SYMBOLS AND CONSTANTS USED IN  
MANUAL HEAT BALANCE CALCULATIONS

Page 1 of 1

SYMBOL	TERM	UNITS
%FP	Percent of Reactor Full Power (100% Power = 2568 MW)	%
%FP <sub>PRI</sub>	Percent Core Thermal Power Primary	%
%FP <sub>SEC</sub>	Percent Core Thermal Power Secondary	%
WMBTU	Conversion factor for converting BTU/Hr to MW. 3412142	(BTU/Hr) /MW
F <sub>RCSA</sub>	Reactor Coolant Flow Loop A	Lbm/Hr
F <sub>RCSB</sub>	Reactor Coolant Flow Loop B	Lbm/Hr
F <sub>FWA</sub>	Main Feedwater Flow Loop A	Lbm/Hr
F <sub>FWB</sub>	Main Feedwater Flow Loop B	Lbm/Hr
F <sub>LD</sub>	Letdown Flow Lbm/Hr	Lbm/Hr
F <sub>LDG</sub>	Letdown Flow GPM	GPM
H <sub>CA</sub>	Enthalpy of RCS Cold Leg Loop A	BTU/Lbm
H <sub>CB</sub>	Enthalpy of RCS Cold Leg Loop B	BTU/Lbm
H <sub>FWA</sub>	Enthalpy of A Main Feedwater	BTU/Lbm
H <sub>FWB</sub>	Enthalpy of B Main Feedwater	BTU/Lbm
H <sub>HA</sub>	Enthalpy of RCS Hot Leg Loop A	BTU/Lbm
H <sub>HB</sub>	Enthalpy of RCS Hot Leg Loop B	BTU/Lbm
H <sub>LD</sub>	Enthalpy of Letdown	BTU/Lbm
H <sub>MU</sub>	Enthalpy of Makeup and Seal Injection	BTU/Lbm
H <sub>STMA</sub>	Enthalpy of A Steam Generator Outlet	BTU/Lbm
H <sub>STMB</sub>	Enthalpy of B Steam Generator Outlet	BTU/Lbm
P <sub>FWA</sub>	A Main Feedwater Pressure	PSIG
P <sub>FWB</sub>	B Main Feedwater Pressure	PSIG
P <sub>HA</sub>	Loop A RCS Hot Leg Pressure	PSIG
P <sub>HB</sub>	Loop B RCS Hot Leg Pressure	PSIG
P <sub>STMA</sub>	A Steam Generator Header Pressure	PSIG
P <sub>STMB</sub>	B Steam Generator Header Pressure	PSIG
Q <sub>PRI</sub>	Core Thermal Power Primary Calculation	MW
Q <sub>SEC</sub>	Core Thermal Power Secondary Calculation	MW
Q <sub>LOSSES</sub>	Summation of RCS Energy Gains and Losses	MW
Q <sub>MULD</sub>	Energy of Letdown and Makeup	MW
Q <sub>RCP</sub>	Energy of the Reactor Coolant Pumps	MW
Q <sub>RB</sub>	Energy lost from the RCS insulation to the Reactor Building. 5.385x10 <sup>6</sup> BTU/Hr @ RB average temperature 110 °F.	MW
T <sub>CA</sub>	Loop A RCS Cold Leg Temperature	°F
T <sub>CB</sub>	Loop B RCS Cold Leg Temperature	°F
T <sub>HA</sub>	Loop A RCS Hot Leg Temperature	°F
T <sub>HB</sub>	Loop B RCS Hot Leg Temperature	°F
T <sub>FWA</sub>	A Main Feedwater Temperature	°F
T <sub>FWB</sub>	B Main Feedwater Temperature	°F
T <sub>STMA</sub>	A Steam Generator Outlet Temperature	°F
T <sub>STMB</sub>	B Steam Generator Outlet Temperature	°F
D <sub>RCSA</sub>	Density Correction of RCS Hot Leg Loop A	
D <sub>RCSB</sub>	Density Correction of RCS Hot Leg Loop B	
D <sub>FWA</sub>	Density Correction of Feedwater Loop A	
D <sub>FWB</sub>	Density Correction of Feedwater Loop B	
E <sub>FWA</sub>	Thermal Expansion Correction for Feedwater Venturi Loop A	
E <sub>FWB</sub>	Thermal Expansion Correction for Feedwater Venturi Loop B	
Alpha	Linear Weighted Average of Secondary Power	

PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>7 of 27</b>  CHANGE: <b>012</b>
--	---	--

ATTACHMENT 2

Page 1 of 15

MANUAL HEAT BALANCE

**NOTE**

N/A variables for which data is not required or is not available.

**NOTE**

Wait at least 6 minutes between each set of data readings.

DESCRIPTION	VARIABLE	INDICATOR	* LOCATION	1ST READING	2ND READING	3RD READING	AVERAGE
Loop A RCS Flow	$F_{RCSA}$	XWRCAA	PMS	72.55	72.53	72.54	72.54 MLbm/hr
		FI028	SPDS				
		FI-1028	C03				
Loop B RCS Flow	$F_{RCSB}$	XWRCEA	PMS	73.07	73.12	73.08	73.09 MLbm/hr
		FI037	SPDS				
		FI-1037	C03				
Enthalpy Loop A T-hot	$H_{HA}$	XHOUTA	PMS	615.75	615.84	615.96	615.85 BTU/Lbm
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				
Enthalpy Loop B T-hot	$H_{HB}$	XHOUTB	PMS	616.37	616.39	616.59	616.45 BTU/Lbm
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				
Enthalpy Loop A T-cold	$H_{CA}$	XHINA	PMS	555.57	555.62	555.68	555.62 BTU/Lbm
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				
Enthalpy Loop B T-cold	$H_{CB}$	XHINB	PMS	555.75	555.65	555.89	555.76 BTU/Lbm
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				
Note 1		XTOUTA	PMS				
Loop A T-hot	$T_{HA}$	TI011	SPDS				
		TI-1011	C03				°F
Note 1		XTOUTB	PMS				
Loop B T-hot	$T_{HB}$	TI039	SPDS				
		TI-1039	C03				°F
Note 1		XTINA	PMS				
Loop A T-cold	$T_{CA}$	TI015	SPDS				
		TI-1015	C03				°F
Note 1		XTINB	PMS				
Loop B T-cold	$T_{CB}$	TI048	SPDS				
		TI-1046	C03				°F

\* Readings need only be taken from one location. Locations are listed in order of instrument accuracy. Circle location used.

Note 1: If Enthalpy values are available, N/A this variable.

PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>8 of 27</b>  CHANGE: <b>012</b>
--	---	--

ATTACHMENT 2

Page 2 of 15

DESCRIPTION	VARIABLE	INDICATOR	* LOCATION	1ST READING	2ND READING	3RD READING	AVERAGE
Note 1 Loop A RCS Pressure	P <sub>HA</sub>	XPRESS	PMS	N/A	N/A	N/A	PSIA
		P1023	SPDS				
		PR-1023	C04				
Note 1 Loop B RCS Pressure	P <sub>HB</sub>	XPRESS	PMS	N/A	N/A	N/A	PSIG
		P1038	SPDS				PSIA
		PR-1038	C04				PSIG
Makeup/ Letdown Flow	F <sub>LD</sub>	XWLTDN	PMS	52.05	52.08	52.11	52.08 Klbm/Hr
	F <sub>LDG</sub>	F1236	SPDS				
		FI-1236	C04				GPM
Enthalpy Letdown	H <sub>LD</sub>	XHINB	PMS	555.75	555.65	555.89	555.76 BTU/LEM
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				
A Main Feedwater Flow	F <sub>FWA</sub>	XWFWAC	PMS	5486.88	5494.81	5493.24	5491.643 Klbm/Hr
		F2628	SPDS				
		FI-2628	C03				MLbm/Hr
B Main Feedwater Flow	F <sub>FWB</sub>	XWFWBC	PMS	5525.44	5536.98	5527.56	5529.993 Klbm/Hr
		F2678	SPDS				
		FI-2678	C03				MLbm/Hr
Note 1 A MFW Temperature	T <sub>FWA</sub>	XTFWA	PMS	N/A	N/A	N/A	
		N/A	SPDS				
		TI-2629	C13				°F
Note 1 B MFW Temperature	T <sub>FWB</sub>	XTFWB	PMS	N/A	N/A	N/A	
		N/A	SPDS				
		TI-2679	C13				°F
Note 1 A MFW Pressure	P <sub>FWA</sub>	XPFIDA	PMS	N/A	N/A	N/A	PSIA
		P2837	SPDS				
		PI-2837	R34				PSIG
Note 1 B MFW Pressure	P <sub>FWB</sub>	XPFIDB	PMS	N/A	N/A	N/A	PSIA
		P2829	SPDS				
		PI-28299	R35				PSIG
Enthalpy A MFW	H <sub>FWA</sub>	XHFWA	PMS	447.78	447.95	447.94	447.89 BTU/LEM
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				
Enthalpy B MFW	H <sub>FWB</sub>	XHFWB	PMS	447.79	447.94	447.96	447.897 BTU/LEM
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				
Enthalpy A Main Steam	H <sub>STMA</sub>	XHSTMA	PMS	1243.43	1243.21	1243.3	1243.313 BTU/LEM
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				

\* Readings need only be taken from one location. Locations are listed in order of instrument accuracy. Circle location used.

Note 1: If Enthalpy values are available, N/A this variable.

PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>9 of 27</b>  CHANGE: <b>012</b>
--	---	--

ATTACHMENT 2

Page 3 of 15

DESCRIPTION	VARIABLE	INDICATOR	* LOCATION	1ST READING	2ND READING	3RD READING	AVERAGE
Enthalpy B Main Steam	H <sub>STMB</sub>	XHSTMB	PMS	1249.99	1249.65	1249.95	1249.86 BTU/LEM
		N/A	SPDS	N/A	N/A	N/A	N/A
		N/A	PANEL				
Note 1 A Main Steam Temperature	T <sub>STMA</sub>	XTSTA	PMS				°F
		N/A	SPDS				
		TI-2681	C03				
Note 1 B Main Steam Temperature	T <sub>STMB</sub>	XTSTB	PMS		N/A		°F
		N/A	SPDS				
		TI-2631	C03				
Note 1 A Main Steam Pressure	P <sub>STMA</sub>	XPSTA	PMS				PSIA
		P2618B	SPDS				
		PI-2652	C03				
Note 1 B Main Steam Pressure	P <sub>STMB</sub>	XPSTB	PMS				PSIA
		P2667B	SPDS				
		PI-2602	C03				
Reactor Power	% FP	XPP	PMS	99.93	100.06	99.98	99.99 PCT. (%)
		NI1LP	SPDS				
		NR-0514	C03				
Note 2 PRI-SEC correction factor (A)	FlowCorr A	CWRCA	PMS	1.0487	1.0487	1.0487	N/A
		N/A	SPDS	N/A	N/A	N/A	
		N/A	C03				
Note 2 PRI-SEC correction factor (B)	FlowCorr B	CWRCB	PMS	1.0473	1.0473	1.0473	N/A
		N/A	SPDS	N/A	N/A	N/A	
		N/A	C03				

\* Readings need only be taken from one location. Locations are listed in order of instrument accuracy. Circle location used.

Note 1: If Enthalpy values are available, N/A this variable.

Note 2: The primary to secondary flow correction factor constants are only needed for the SPDS/control panel calculation and are therefore directly included. These constants are cycle specific values calculated using references 4.1.9 and 4.1.10.

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 10 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 4 of 15

INITIALS

~~1.0~~

#### INITIAL CONDITIONS

~~1.1~~

ΔT H/A Station Set Per 8.1

SRP

~~1.2~~

RCS Tave Stable ±1°F

SRP

~~1.3~~

Feedwater Flow Stable ±1/2% (54.5 KLbm/hr)

SRP

~~1.4~~

No Changes in MW Demand

SRP

~~1.5~~

Verify the following parameters maintained in a Steady State Condition for at least 18 minutes prior to taking data.

SRP

- RCS Pressure
- RCS Flow
- Turbine header pressure
- Feedwater temperature

#### 2.0 MANUAL HEAT BALANCE CALCULATION USING THE PLANT MONITORING SYSTEM (PMS)

##### NOTE

Two decimal place accuracy of calculated numbers is adequate.

#### 2.1 Makeup and Letdown Energy Determination

The assumption is made that MU Flow = LD Flow and MU energy ( $H_{MU}$ ) is constant at 75.41 BTU/Lbm.

$$Q_{MULD} = (H_{LD} - H_{MU}) \times F_{LD}$$

WMBTU

$$Q_{MULD} = ( \underline{555.76} - 75.41 ) \text{ BTU/Lbm} \times \underline{52.08} \times 10^3 \text{ Lbm/hr}$$

3412142 Btu/HrMW

$$Q_{MULD} = \underline{7.332} \text{ MW}$$

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 11 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 5 of 15

## 2.2 Reactor Coolant Pump Energy

The actual calculation for the Reactor Coolant Pump energy is  $\sqrt{3} * \text{Volts} * \text{AMPS} * \text{Motor Efficiency} * \cos F$ ; with Motor Efficiency = 0.93 and  $\cos F = 0.88$ . However, a constant of 18.0E6 BTU/hr per pump is used for pump energy input.

$$Q_{RCP} = \# \text{ of Pumps Running} \times 18.0E6 \text{ BTU/hr}$$

$$3412142 \text{ Btu/HrMW}$$

$$Q_{RCP} = \frac{4}{3412142 \text{ Btu/HrMW}} \times 18.0E6 \text{ BTU/hr}$$

$$Q_{RCP} = 21.10 \text{ MW}$$

## 2.3 Total Energy Loss/Gain

ANO Engineering Calculation 87-D-1088-06, has determined the energy loss to the Reactor Building to be 5.385E6 Btu/hr at a nominal Reactor Building temperature of 110 °F which equates to approximately 1.58 MW ( $Q_{RB}$ ).

$$Q_{LOSSES} = Q_{RB} + Q_{MULD} - Q_{RCP}$$

$$Q_{LOSSES} = 1.58 \text{ MW} + \frac{7.332}{(\text{step 2.1})} \text{ MW} - \frac{21.10}{(\text{step 2.2})} \text{ MW}$$

$$Q_{LOSSES} = -12.188 \text{ MW}$$

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 12 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 6 of 15

#### 2.4 Secondary Side Heat Balance

$Q_{SECA}$  = Loop A Secondary Power

$$Q_{SECA} = \frac{(H_{STMA} - H_{FWA}) \times F_{FWA}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECA} = \frac{(\underline{1243.313} - \underline{447.89}) \text{ BTU/Hr} \times \underline{5491.643} \times 10^3 \text{ Lbm/Hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECA} = \underline{1280.1868} \text{ MW}$$

$Q_{SECB}$  = Loop B Secondary Power

$$Q_{SECB} = \frac{(H_{STMB} - H_{FWB}) \times F_{FWB}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECB} = \frac{(\underline{1249.863} - \underline{447.897}) \text{ BTU/Hr} \times \underline{5529.993} \times 10^3 \text{ Lbm/Hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECB} = \underline{1299.7309} \text{ MW}$$

$\%FP_{SEC}$  = Secondary Calculated Heat Balance Power

$$\%FP_{SEC} = \frac{(Q_{SECA} + Q_{SECB} + Q_{LOSSES}) \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{SEC} = \frac{(\underline{1280.1868} + \underline{1299.7309} + \underline{21.10} \text{ (Step 2.3)}) \text{ MW} \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{SEC} = \underline{101.286} \%$$



PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 13 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 7 of 15

## 2.5 Primary Side Heat Balance

$Q_{PRIA}$  = Loop A Primary Power

$$Q_{PRIA} = \frac{(H_{HA} - H_{CA}) \times F_{RCSA}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIA} = \frac{(\underline{600} - \underline{555.6233}) \text{ BTU/Hr} \times \underline{7254} \times 10^6 \text{ Lbm/Hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIA} = \underline{943.42} \text{ MW}$$

$Q_{PRIB}$  = Loop B Primary Power

$$Q_{PRIB} = \frac{(H_{HB} - H_{CB}) \times F_{RCSB}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIB} = \frac{(\underline{616.45} - \underline{555.7633}) \text{ BTU/Hr} \times \underline{73.09} \times 10^6 \text{ Lbm/Hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIB} = \underline{1299.94} \text{ MW}$$

$\%FP_{PRI}$  = Primary Calculated Heat Balance Power

$$\%FP_{PRI} = \frac{(Q_{PRIA} + Q_{PRIB} + Q_{LOSSES}) \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{PRI} = \frac{(\underline{943.42} + \underline{1299.94} + \underline{21.10}) \text{ MW} \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{PRI} = \underline{80.179} \%$$

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 14 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 8 of 15

2.6 Best Estimate of Reactor Power

$$\text{Alpha} = \frac{(\%FP_{\text{SEC}} - 15)}{85}$$

$$\text{Alpha} = \frac{(\frac{101.286}{(\text{step 2.4})} - 15)}{85}$$

$$\text{Alpha} = 1.015$$

%FP = Best Estimate Calculated Thermal Power

$$\%FP = (\text{Alpha} \times \%FP_{\text{SEC}}) + [(1 - \text{Alpha}) \times \%FP_{\text{PRI}}]$$

$$\%FP = (1.015 \times \frac{101.286}{(\text{Step 2.4})}) + [(1 - 1.015) \times \frac{88.179}{(\text{Step 2.5})}]$$

$$\%FP = 101.493$$

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 15 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 9 of 15

### 3.0 MANUAL HEAT BALANCE CALCULATION USING SPDS OR CONTROL PANEL INDICATION

#### NOTE

1) When using this procedure as a result of the loss of the plant computer, a conservative uncertainty factor is applied and will result in a calculated power significantly higher than actual power. Reduce power to 80%FP prior to performing this calculation to avoid a calculated power greater than 100%.

2) Two decimal place accuracy of calculated numbers is adequate.

#### 3.1 Makeup and Letdown Energy Determination

The assumption is made that MU Flow = LD Flow and MU energy ( $H_{MU}$ ) is constant at 75.41 BTU/Lbm.

Use **FIGURE 1 - Primary Subcooled Enthalpy Chart** to determine the Letdown enthalpy.

Letdown Temperature = RCS Loop B T-cold Temp. =  $T_{CB}$  = \_\_\_\_\_ °F

$$Q_{MULD} = \frac{(H_{LD} - H_{MU}) * F_{LDG} * 500}{WMBTU}$$

$$Q_{MULD} = \frac{(\text{_____} - 75.41) \text{ BTU/Lbm} * \text{_____ gpm} * 500}{\text{Lbm/hrGPM} \quad (\text{Fig. 1})}$$

3412142 Btu/HrMW

$$Q_{MULD} = \text{_____ MW}$$

IVA

#### 3.2 Reactor Coolant Pump Energy

The actual calculation for the Reactor Coolant Pump energy is  $\sqrt{3} * \text{Volts} * \text{AMPS} * \text{Motor Efficiency} * \cos F$ ; with Motor Efficiency = 0.93 and  $\cos F = 0.88$ . However, a constant of 18.0E6 BTU/hr per pump is used for pump energy input.

$$Q_{RCP} = \frac{\# \text{ of Pumps Running} * 18.0E6 \text{ BTU/hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{RCP} = \frac{\text{_____} * 18.0E6 \text{ BTU/hr}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{RCP} = \text{_____ MW}$$

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 16 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 10 of 15

### 3.3 Total Energy Loss/Gain

ANO Engineering Calculation 87-D-1088-06, has determined the energy loss to the Reactor Building to be 5.385E6 Btu/hr at a nominal Reactor Building temperature of 110 °F which equates to approximately 1.58 MW ( $Q_{RB}$ ).

$$Q_{LOSSES} = Q_{RB} + Q_{MULD} - Q_{RCP}$$

$$Q_{LOSSES} = 1.58 \text{ MW} + \frac{\text{MW}}{(\text{step 3.1})} - \frac{\text{MW}}{(\text{step 3.2})}$$

$$Q_{LOSSES} = \text{MW}$$

N/A

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 17 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 11 of 15

### 3.4 Secondary Side Heat Balance

$Q_{SECA}$  = Loop A Secondary Power

Use **FIGURE 3 - Superheat Enthalpy Chart** to determine enthalpy of the steam.

A Main Steam Temperature =  $T_{STMA}$  = \_\_\_\_\_ °F

$H_{STMA}$  = \_\_\_\_\_ BTU/Lbm

A MFW Temperature =  $T_{FWA}$  = \_\_\_\_\_ °F

Use **FIGURE 2 - Secondary Subcooled Enthalpy Chart** to determine feedwater enthalpy.

$H_{FWA}$  = \_\_\_\_\_ BTU/Lbm

Use **FIGURE 6 - Feedwater Density Correction Factor** to determine a density correction of the feedwater.

$D_{FWA}$  = \_\_\_\_\_

Use **FIGURE 5 - Feedwater Venturi Thermal Expansion Correction Factor** to determine the thermal expansion correction.

$E_{FWA}$  = \_\_\_\_\_

$$Q_{SECA} = (H_{STMA} - H_{FWA}) \times F_{FWA} \times D_{FWA} \times E_{FWA}$$

3412142 Btu/HrMW

$$Q_{SECA} = \left( \frac{\text{____}}{(\text{Fig. 3})} - \frac{\text{____}}{(\text{Fig. 2})} \right) \frac{\text{BTU}}{\text{Hr}} \times \text{____} \times \frac{**10^3 \text{ Lbm}}{\text{Hr}} \times \frac{\text{____}}{(\text{Fig 6})} \times \frac{\text{____}}{(\text{Fig 5})}$$

3412142 Btu/HrMW

$Q_{SECA}$  = \_\_\_\_\_ MW

\*\* - Multiply by  $10^6$  Lbm/Hr if using control board indications; FI-2628 and FI-2678.

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 18 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 12 of 15

$Q_{SECB}$  = Loop B Secondary Power

Use **FIGURE 3 - Superheat Enthalpy Chart** to determine enthalpy of the steam.

B Main Steam Temperature =  $T_{STMB}$  = \_\_\_\_\_ °F

$H_{STMB}$  = \_\_\_\_\_ BTU/Lbm

B MFW Temperature =  $T_{FWB}$  = \_\_\_\_\_ °F

Use **FIGURE 2 - Secondary Subcooled Enthalpy Chart** to determine feedwater enthalpy.

$H_{FWB}$  = \_\_\_\_\_ BTU/Lbm

Use **FIGURE 6 - Feedwater Density Correction Factor** to determine a density correction of the feedwater.

$D_{FWB}$  = \_\_\_\_\_

Use **FIGURE 5 - Feedwater Venturi Thermal Expansion Correction Factor** to determine the thermal expansion correction.

$E_{FWB}$  = \_\_\_\_\_

$$Q_{SECB} = \frac{(H_{STMB} - H_{FWB}) \times F_{FWB} \times D_{FWB} \times E_{FWB}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{SECB} = \frac{\left( \frac{\text{Fig. 3}}{\text{Fig. 2}} - \frac{\text{Fig. 2}}{\text{Fig. 2}} \right) \frac{\text{BTU}}{\text{Hr}} \times \text{Fig. 6} \times \frac{10^3 \text{ Lbm}}{\text{Hr}} \times \frac{\text{Fig. 5}}{\text{Fig. 5}}}{3412142 \text{ Btu/HrMW}}$$

$Q_{SECB}$  = \_\_\_\_\_ MW

N/A

\*\* - Multiply by  $10^6$  Lbm/Hr if using control board indications; FI-2628 and FI-2678.

PROC./WORK PLAN NO. <b>1103.016</b>	PROCEDURE/WORK PLAN TITLE: <b>HEAT BALANCE CALCULATION</b>	PAGE: <b>19 of 27</b> CHANGE: <b>012</b>
--	---	---

ATTACHMENT 2

Page 13 of 15

%FP<sub>SEC</sub> = Secondary Calculated Heat Balance Power

$$\%FP_{SEC} = \frac{(Q_{SECA} + Q_{SECB} + Q_{LOSSES}) \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{SEC} = \frac{(\text{ } + \text{ } + \text{ }) \text{ MW} \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{SEC} = \text{ } \%$$

### 3.5 Primary Side Heat Balance

Q<sub>PRIA</sub> = Loop A Primary Power

Loop A T-hot Temperature = T<sub>HA</sub> =            °F

Use **FIGURE 1 - Primary Subcooled Enthalpy Chart** to determine enthalpy of the RCS.

H<sub>HA</sub> =            BTU/Lbm

Loop A T-cold Temperature = T<sub>CA</sub> =            °F

H<sub>CA</sub> =            BTU/Lbm

Use **FIGURE 4 - RCS Density Correction Factor** to determine a density correction of the RCS Hot Leg.

D<sub>RCSA</sub> =           

$$Q_{PRIA} = \frac{(H_{HA} - H_{CA}) \times F_{RCSA} \times D_{RCSA} \times \text{FlowCorrA}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIA} = \frac{(\text{Fig. 1}) - (\text{Fig. 1}) \frac{\text{BTU}}{\text{Hr}} \times \text{ } \times 10^6 \frac{\text{Lbm}}{\text{Hr}} \times \text{ } \times 1.0487}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIA} = \text{ } \text{ MW}$$

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 20 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 14 of 15

$Q_{PRIB}$  = Loop B Primary Power

Loop B T-hot Temperature =  $T_{HB}$  = \_\_\_\_\_ °F

Use **FIGURE 1 - Primary Subcooled Enthalpy Chart** to determine enthalpy of the RCS.

$H_{HB}$  = \_\_\_\_\_ BTU/Lbm

Loop B T-cold Temperature =  $T_{CB}$  = \_\_\_\_\_ °F

$H_{CB}$  = \_\_\_\_\_ BTU/Lbm

Use **FIGURE 4 - RCS Density Correction Factor** to determine a density correction of the RCS Hot Leg.

$D_{RCSB}$  = \_\_\_\_\_

$$Q_{PRIB} = \frac{(H_{HB} - H_{CB}) \times F_{RCSB} \times D_{RCSB} \times \text{FlowCorrB}}{3412142 \text{ Btu/HrMW}}$$

$$Q_{PRIB} = \frac{\left( \frac{\text{Fig. 1}}{\text{Fig. 1}} - \frac{\text{Fig. 1}}{\text{Fig. 1}} \right) \frac{\text{BTU}}{\text{Hr}} \times \frac{\text{Fig. 1}}{\text{Fig. 1}} \times 10^6 \frac{\text{Lbm}}{\text{Hr}} \times \frac{\text{Fig. 1}}{\text{Fig. 4}} \times 1.0473}{3412142 \text{ Btu/HrMW}}$$

$Q_{PRIB}$  = \_\_\_\_\_ MW

N/A

$\%FP_{PRI}$  = Primary Heat Balance Power

$$\%FP_{PRI} = \frac{(Q_{PRIA} + Q_{PRIB} + Q_{LOSSES}) \times 100\%}{2568 \text{ MW}}$$

$$\%FP_{PRI} = \frac{(\text{Fig. 1} + \text{Fig. 1} + \text{Fig. 1}) \text{ MW} \times 100\%}{2568 \text{ MW}}$$

$\%FP_{PRI}$  = \_\_\_\_\_ %



PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 21 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 15 of 15

### 3.6 Best Estimate of Reactor Power

$$\text{Alpha} = \frac{(\%FP_{SEC} - 15)}{85}$$

$$\text{Alpha} = \frac{(\frac{\quad}{\text{(step 3.4)}} - 15)}{85}$$

Alpha = \_\_\_\_\_

$\%FP_B$  = Best Estimate of Calculated Thermal Power

$$\%FP_B = (\text{Alpha} \times \%FP_{SEC}) + [(1 - \text{Alpha}) \times \%FP_{PRI}]$$

$$\%FP_B = (\frac{\quad}{\text{(Step 3.4)}} \times \frac{\quad}{\text{(Step 3.4)}}) + [(1 - \frac{\quad}{\text{(Step 3.4)}}) \times \frac{\quad}{\text{(Step 3.5)}}]$$

$$\%FP_B = \frac{\quad}{\quad}$$

#### NOTE

The following step applies a factor to conservatively bound this calculation for instrument uncertainty. This will result in a calculated value significantly higher than actual power. If using this procedure as a result of the loss of the plant computer, reduce power to 80%FP prior to performing this calculation to avoid a calculated power greater than 100%.

### 3.7 Uncertainty Corrected Reactor Power


$$\%FP = \%FP_B + 20 \%RTP$$

$$\%FP = (\frac{\quad}{\quad}) + 20$$


$\%FP =$  \_\_\_\_\_

PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 22 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

FIGURE 1 - Primary Subcooled Enthalpy Chart  
for RCS Pressures between 2100 and 2200 psig



**FIGURE 2 - Secondary Subcooled Enthalpy Chart**  
for Feed Water Pressures between 950 and 1150 psig



PROC./WORK PLAN NO. 1103.016	PROCEDURE/WORK PLAN TITLE: HEAT BALANCE CALCULATION	PAGE: 24 of 27 CHANGE: 012
---------------------------------	--	-------------------------------

FIGURE 3 - Superheat Enthalpy Chart  
for Main Steam Pressures between 890 and 920 psig




FIGURE 4 - RCS Density Correction Factor  
for RCS Pressures between 2100 and 2200 psig






FIGURE 5 - Feed Water Venturi Thermal Expansion Correction Factor  
for Feed Water Pressures between 950 and 1150 psig



**FIGURE 6 - Feed Water Density Correction Factor  
for Feed Water Pressures between 950 and 1150 psig**



## A6. Conduct of Operations

M/R

K/A 2.1.34

Knowledge of primary and secondary plant chemistry limits.

A1JPM-SRO-CHEM1



# ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-SRO-CHEM1

Page 1 of 4

UNIT: 1 REV # 1 DATE: \_\_\_\_\_

TUOI NUMBER: A1JPM-SRO-CHEM1

SYSTEM/DUTY AREA: ADMINISTRATIVE TOPIC – CONDUCT OF OPERATIONS

TASK: Respond to secondary chemistry parameter out of specification

JTA#: ANO-SM-ADMIN-NORM-165

KA VALUE RO: 2.7 SRO: 3.5 KA REFERENCE: 2.1.34

APPROVED FOR ADMINISTRATION TO: RO: \_\_\_\_\_ SRO: X

TASK LOCATION: INSIDE CR: \_\_\_\_\_ OUTSIDE CR: \_\_\_\_\_ Classroom : X

SUGGESTED TESTING ENVIRONMENT AND METHOD (PERFORM OR SIMULATE):

PLANT SITE: \_\_\_\_\_ SIMULATOR: \_\_\_\_\_ Classroom: PERFORM

POSITION EVALUATED: RO: \_\_\_\_\_ SRO: X

ACTUAL TESTING ENVIRONMENT: SIMULATOR: \_\_\_\_\_ PLANT SITE: \_\_\_\_\_ Classroom: PERFORM

TESTING METHOD: SIMULATE: \_\_\_\_\_ PERFORM: X

APPROXIMATE COMPLETION TIME IN MINUTES: 15 MINUTES

REFERENCE(S): 1000.042 Steam Generator Water Chemistry Monitoring – Unit One

EXAMINEE'S NAME: \_\_\_\_\_ SSN \_\_\_\_\_ - \_\_\_\_\_ - \_\_\_\_\_

EVALUATOR'S NAME: \_\_\_\_\_

THE EXAMINEE'S PERFORMANCE WAS EVALUATED AGAINST THE STANDARDS  
CONTAINED IN THIS JPM AND IS DETERMINED TO BE:

SATISFACTORY: \_\_\_\_\_ UNSATISFACTORY: \_\_\_\_\_

PERFORMANCE CHECKLIST COMMENTS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_ Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time

SIGNED \_\_\_\_\_ DATE: \_\_\_\_\_

SIGNATURE INDICATES THIS JPM HAS BEEN COMPARED TO ITS APPLICABLE PROCEDURE BY A  
QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.

## ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-SRO-CHEM1

Page 2 of 4

### THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:** \_\_\_\_\_ The plant has been operating at 100% for 215 days. The shift chemist has just arrived in your office and has given you, the Shift Manager, form 1000.042A for SG Backup Sample to review.

**TASK STANDARD:** Examinee correctly recognizes that the threshold for Action Level 3 has been exceeded and the plant should be shutdown when value is exceeded for >2 hours.

**TASK PERFORMANCE AIDS:** 1000.042

# ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-SRO-CHEM1

Page 3 of 4

## INITIATING CUE:

As Shift Manager, review the 1000.042A form for out of specification Feedwater chlorides for accuracy and verify Chemistry recommendations are correct.

**CRITICAL ELEMENTS (C)** \_\_\_\_\_ 3 \_\_\_\_\_

(C)	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UNSAT
NOTE: Inform trainee that continuous monitor readings correspond with sample results.					
	1. Compare results of confirmatory analyses to readings from continuous monitors.	Requested readings of continuous monitors to compare with lab analyses results on 1000.042A.	_____	_____	_____
NOTE: Inform trainee that Chemistry suspects a bad polisher to be the source of the chlorides.					
	2. Identify and isolate sources of impurity ingress.	Inquired as to results of searches for source of chloride in-leakage.	_____	_____	_____
(C)	3. Refer to Attachment 6 1000.042.	Referred to Att. 6 and determined that Action Level 2 as shown on the form is incorrect and that Action Level 3 had been exceeded. Action Level 3 requires the plant to be shutdown if the value has been exceeded for >2 hours (typically within six hours) instead of the 100 hours allowed for Action Level 2.	_____	_____	_____

**END**

## **ADMINISTRATIVE JOB PERFORMANCE MEASURE**

TUOI: A1JPM-SRO-CHEM1

Page 4 of 4

### **EXAMINEE'S COPY**

#### **JPM INITIAL TASK CONDITIONS:**

- The plant had been operating at 100% for 215 days.
- The shift chemist has just arrived in your office and has given you, the Shift Manager, form 1000.042A for SG Backup Sample to review.

#### **INITIATING CUE:**

As Shift Manager, review the 1000.042A form for out of specification Feedwater chlorides for accuracy and verify Chemistry recommendations are correct.

EVENT DESCRIPTION High Chlorides in Feedwater A&B				OCCURRENCE DATE: 9/9/08		TIME: 0840		REACTOR POWER: 100		%	
PLANT STATUS PRIOR TO OCCURRENCE				Power Operations							
COMPONENT OR SYSTEM AFFECTED				Feedwater A&B							
DESCRIPTION OF CONDITION				Chlorides >5 ppb							
PARAMETER A FW Chlorides		TEST RESULTS 11.8		LIMIT <5		PARAMETER B FW Chlorides		TEST RESULTS 13.4		LIMIT <5	
ACTION RECOMMENDATIONS											
PROCEDURE REQUIREMENTS: 1000.042 page 4 of 31											
CHEMISTRY RECOMMENDATIONS: Return to below action level 2 within 100 hours											
MONITORING ACTIVITY											
SAMPLING FREQUENCY: Daily											
TIME CLOCK ENDS: Saturday											
CHEMIST REPORTING OUT OF SPEC: Gary Petri											
<input type="checkbox"/> Hideout Return for planned outage. If marked, then Shift Manager reviews may be N/A.											
REVIEWED BY											
SHIFT MANAGER:											
IN SPEC PARAMETER		TEST RESULTS		LIMIT		DATE TIME		IN SPEC PARAMETER		TEST RESULTS	
						DATE TIME				DATE TIME	
CHEMIST VERIFYING											
IN SPEC. CONDITION:				DATE: TIME:				NOTES:			
CORRECTIVE ACTION TAKEN BY OPERATIONS:											
REVIEWED BY:											
SHIFT MANAGER:											
DATE: TIME:											
DATE: TIME:											
FORM TITLE											
UNIT 1 STEAM GENERATOR MONITORING REPORT											
FORM NO. 1000.042A										CHANGE 000-00-0	

**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

**TITLE: STEAM GENERATOR WATER CHEMISTRY  
MONITORING - UNIT ONE**

**DOCUMENT NO.**  
1000.042

**CHANGE NO.**  
016

**WORK PLAN EXP. DATE**  
N/A

**TC EXP. DATE**  
N/A

**SET #**

**SAFETY-RELATED**  
☒ YES ☐ NO

**IPTE**  
☐ YES ☒ NO

**TEMP ALT**  
☐ YES ☒ NO

**LEVEL OF USE**  
☐ CONTINUOUS  
☒ REFERENCE  
☐ INFORMATIONAL

**PROGRAMMATIC EXCLUSION PER EN-LI-100**  
☐ YES ☒ NO

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Overconfidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.**  
1000.006A

**CHANGE NO.**  
053

PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 1 of 31  CHANGE: 016
-------------------------------------	--	----------------------------------

# TABLE OF CONTENTS

<u>Section No.</u>	<u>Description</u>	<u>Page No.</u>
1.0	Purpose.....	2
2.0	Scope.....	2
3.0	References.....	2
4.0	Definitions.....	4
5.0	Responsibility and Authority.....	5
6.0	Instructions.....	6
7.0	Attachments and Forms.....	8
7.1	Attachments	
7.1.1	Attachment 1, Modes 5 and 6 Cold Shutdown/Wet Layup (RCS $\leq 200^{\circ}\text{F}$ ) .....	9
7.1.2	Attachment 2, Mode 4 Hot Shutdown (RCS $>200^{\circ}\text{F}$ and $<280^{\circ}\text{F}$ ) .....	11
7.1.3	Attachment 3, Mode 3 Hot Standby (RCS $\geq 280^{\circ}\text{F}$ , Reactor not Critical) .....	14
7.1.4	Attachment 4, Mode 2 Startup (Reactor Critical at $\leq 5\%$ Reactor Power) .....	17
7.1.5	Attachment 5, Mode 1 Power Operation (Reactor Power $>5\%$ and $<15\%$ ) .....	20
7.1.6	Attachment 6, Mode 1 Power Operation (Reactor Power $\geq 15\%$ ) .....	23
7.1.7	Attachment 7, Cold Shutdown/Wet Layup Corrective Actions.....	27
7.1.8	Attachment 8, Hot Shutdown, Hot Standby, Startup, and Reactor Critical at $<15\%$ Reactor Power Corrective Actions.....	28
7.1.9	Attachment 9, Power Operation ( $\geq 15\%$ Reactor Power) Corrective Actions.....	30
7.2	Forms	
7.2.1	Form 1000.042A, Unit 1 Steam Generator Monitoring Report (electronic form)	

PROC./WORK PLAN NO. <b>1000.042</b>	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: <b>2 of 31</b>  CHANGE: <b>016</b>
--	--	--

### 1.0 PURPOSE

The purpose of this procedure is to identify a secondary water chemistry monitoring program to maximize the availability and operating life of major components such as the steam generators and the turbine.

### 2.0 SCOPE

The scope of this program is limited to:

- 2.1 Unit One;
- 2.2 Identification of a sampling schedule for the critical parameters and control points for these parameters;
- 2.3 Identification of the procedures used to measure the values of the critical parameters;
- 2.4 Identification of process sampling points;
- 2.5 Procedure for the recording and management of data;
- 2.6 Procedure defining corrective actions for off-control point chemistry conditions; and
- 2.7 A procedure identifying the authority responsible for the interpretation of the data and the sequence and timing of administrative events required to initiate corrective action.

### 3.0 REFERENCES

#### 3.1 REFERENCES USED

- 3.1.1 Pressurized Water Reactor Secondary Water Chemistry Guidelines - Revision 6. EPRI TR-1008224, Revision 6, Final Report, December, 2004, prepared by PWR Secondary Water Chemistry Guidelines Revision 6 Committee
- 3.1.2 NEI 97-06, "Steam Generator Program Guidelines"
- 3.1.3 Babcock & Wilcox BAW-1385 Water Chemistry Manual
- 3.1.4 1052.002, Chemistry Forms
- 3.1.5 1605.002, Analyses Using the UV/VIS Spectrophotometer
- 3.1.6 1605.022, Determination of Dissolved Oxygen (Chemetrics Comparator Method)
- 3.1.7 1605.026, Operation of AA-SCAN 1 AA/AE Spectrophotometer
- 3.1.8 1605.027, Determination of Solids
- 3.1.9 1605.038, Determination of Hydrazine - High Range (Titration Method)
- 3.1.10 1605.063, Chemical Analysis Using the Ion Chromatograph



PROC./WORK PLAN NO. <b>1000.042</b>	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: <b>3 of 31</b> CHANGE: <b>016</b>
--	--	--

- 3.1.11 1605.077, Determination of Insoluble and Soluble Metals
- 3.1.12 1605.084, Operation of Portable Conductivity Meters
- 3.1.13 1606.017, Operation of the Orbisphere Oxygen Detectors
- 3.1.14 1606.042, Operation of Unit 1 Hydrazine Analyzers
- 3.1.15 1606.041, Operation of Unit 1 Inline Specific and Cation Conductivity Meters
- 3.1.16 1606.044, Operation of Unit 1 Inline pH Meters
- 3.1.17 1606.045, Operation of Unit 1 Leeds & Northrup Model 7931 Dissolved Oxygen Analyzers
- 3.1.18 1606.046, Operation of Unit 1 Sodium Analyzers
- 3.1.19 1606.049, Operation of the Dionex Series 8100 On-Line Ion Chromatograph
- 3.1.20 1606.050, Operation of B&W Corrosion Product Samplers
- 3.1.21 1618.002, Collecting Unit 1 Secondary Samples
- 3.1.22 1605.101, Operation of PerkinElmer Inductively Coupled Plasma Spectrometer
- 3.1.23 Unit 1 TS 5.5.10 a-f. Section 2.0 of this procedure states the license requirements.
- 3.1.24 Feedwater Oxygen Control, S.G. Sawochka, Nov 8, 1999
- 3.1.25 NMM EN-DC-317, Entergy Steam Generator Administrative Procedure
- 3.1.26 Framatome ANP, Inc. (AREVA), Operation and Maintenance Manual 01-5070437-00 for ANO-1 Enhanced Once-Through Steam Generators
- 3.1.27 1102.001, Plant Preheatup and Precritical Checklist

PROC./WORK PLAN NO. <b>1000.042</b>	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: <b>4 of 31</b>  CHANGE: <b>016</b>
--	--	--

3.2 COMMITMENTS

None

4.0 DEFINITIONS

- 4.1 ACTION LEVEL 1 (Objective: To promptly identify and correct the cause of an out-of-guideline value without power reduction) - Corrective actions shall be implemented as soon as possible to return the parameter to within Action Level 1. If a parameter has not been returned to below the Action Level 1 value within one week following confirmation of an excursion, an engineering evaluation shall be performed to justify continuing to operate above Action Level 1.
- 4.2 Action Level 2 (Objective: To promptly identify and correct the cause of an out-of-guideline value prior to shutdown) - Corrective actions shall be implemented as soon as possible to return the parameter to below Action Level 2. If the parameter is not below the Action Level 2 value within 100 hours following confirmation of the excursion, the plant shall be in the hot standby condition within an additional 24 hours. An engineering evaluation shall be performed to assess the cause of exceeding an Action Level 2 value, and corrective actions taken to minimize the occurrence of such excursions prior to returning to power operation.
- 4.3 Action Level 3 (Objective: to correct a condition which is expected to result in rapid corrosion during continued operation. Plant shutdown may be necessary to minimize impurity ingress and limit exposure of steam generator, turbine and other secondary system materials to corrosive solutions. Plant shutdown will also reduce further damage to the steam generator by allowing cleanup of impurities as a result of hideout return.) - If a control parameter exceeds the Action Level 3 value for greater than 2 hours, or if at any time a control parameter exceeds 20 ppb for any duration, then the plant shall be taken to hot or cold shutdown as quickly as safe plant operation permits (typically <6 hours) and clean up by feed and bleed or drain and refill as appropriate until normal values are reached. Progressing to cold shutdown generally will be advisable to allow flushing of the upper regions of the once through steam generators (OTSG).
- 4.4 CONTINUOUS - A frequency where analyzer is normally in service unless it is in disrepair or undergoing maintenance.
- 4.5 INTEGRATED SAMPLE CONCENTRATION -
- IF the composite samplers are in service,  
THEN it is the concentration obtained by passing a known sample volume through special filters which are digested and analyzed later to calculate iron and copper concentrations in the bulk water.
- IF the composite samplers are undergoing corrective maintenance,  
THEN it is the average concentration of all grab sample results collected during the sampling period for the applicable parameter.

PROC./WORK PLAN NO. <b>1000.042</b>	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: <b>5 of 31</b>  CHANGE: <b>016</b>
--	--	--

4.6 REACTOR MODES (as define by Unit 1 Technical Specifications):

Mode 1 (Power Operation) - Reactor critical ( $K_{eff} \geq 0.99$ ) and rated thermal power  $>5.0\%$ .

Mode 2 (Startup) - Reactor critical ( $K_{eff} \geq 0.99$ ) and rated thermal power  $\leq 5.0\%$ .

Mode 3 (Hot Standby) - Reactor not critical ( $K_{eff} \leq 0.99$ ) with the average reactor coolant temperature (degrees F)  $\geq 280$ .

Mode 4 (Hot Shutdown) - Reactor not critical ( $K_{eff} \leq 0.99$ ) with the average reactor coolant temperature (degrees F)  $> 200$  but less than 280 and all reactor vessel head closure bolts fully tensioned.

Mode 5 (Cold Shutdown) - Reactor not critical ( $K_{eff} \leq 0.99$ ) with the average reactor coolant temperature (degrees F)  $\leq 200$  and all reactor vessel head closure bolts fully tensioned.

Mode 6 (Refueling) - One or more reactor vessel head closure bolts less than fully tensioned.

4.7 SAMPLE SOURCES - Those points in the system from which a sample is drawn for analysis.

4.8 TREND - Chemistry data plotted versus time. Provides a rapid visual method of assessing plant chemistry.

5.0 RESPONSIBILITY AND AUTHORITY

5.1 GENERAL MANAGER, PLANT OPERATIONS

The General Manager, Plant Operations is responsible for overall implementation of this procedure.

5.2 SUPERINTENDENT, CHEMISTRY

The Superintendent, Chemistry is responsible for ensuring compliance with this procedure. The Superintendent, Chemistry or designee also determines if alternate sample locations are to be used when samples are not available in the Primary Sample Room due to insufficient motive force (temperature and pressure) during startup and shutdown evolutions. If a diagnostic parameter is listed without a stated sample frequency, the Superintendent, Chemistry or designee may determine a frequency to adequately assess the parameter's influence on system chemistry.

5.3 PLANT MANAGER, OPERATIONS; MANAGER, OPERATIONS; ANO-1/OPERATIONS STAFF

The Manager, Operations, ANO-1/Operations staff responsibilities include understanding the impact of chemistry conditions on major component performance, availability, and expected life; understanding the chemistry control program and the management support for the program; and establishment of corrective action priorities.

PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 6 of 31  CHANGE: 016
-------------------------------------	--	----------------------------------

#### 5.4 CHEMISTRY STAFF

The Chemistry staff responsibilities include understanding the goals for the program, implementation of the chemistry control program, timely and knowledgeable data review to identify unusual conditions quickly and evaluation to assess the underlying chemistry fundamentals, initiation of any required corrective actions, and making any necessary changes in the chemistry monitoring requirements to improve the chemistry control program.

#### 5.5 MAINTENANCE STAFF

The Maintenance staff responsibilities include prompt and effective maintenance and repair of plant equipment required to maintain chemistry specifications.

#### 5.6 PLANNING AND SCHEDULING PERSONNEL

The Planning and Scheduling personnel responsibilities include timely issuance of corrective maintenance required to maintain chemistry within specifications.

### 6.0 INSTRUCTIONS

6.1 A secondary chemistry monitoring program to maximize steam generator availability and operating life shall be carried out on the samples, parameters, and frequencies listed on Attachments 1 through 6 according to the status mode of the unit.

6.2 Sampling and analyses of the concerned parameters shall be performed using current approved procedures.

6.3 Analysis results shall be recorded on Form 1052.002A or in the Chemistry database.

6.4 Each parameter concerned with maximizing steam generator availability and operating life should be trended as a means of rapid visual assessment of plant chemistry.

6.5 Secondary Water Chemistry Reports shall be reviewed and compared to the normal parameter values listed on Attachments 1 through 6 according to the status mode and sample source.

6.6 IF an out-of-spec. condition is noted,  
THEN request additional verification in the form of a confirmatory grab sample or obtain reading on another analyzer where possible within one hour of discovering the condition.

IF unusual conditions prevent resampling within one hour,  
THEN a Nuclear Chemistry Supervisor should be notified and a resample planned as soon as possible. The time clock starts with the initial sample.

6.7 Out-of-spec. conditions shall be promptly reported to the Superintendent, Chemistry or a Nuclear Chemistry Supervisor and also to the Shift Manager. This notification shall be reported on Form 1000.042A.

IF the out of spec condition is due to hideout return during shutdown/cooldown for planned outages,  
THEN the notification to the Shift Manager is not required.

PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 7 of 31  CHANGE: 016
-------------------------------------	--	----------------------------------

- 6.8 The Superintendent, Chemistry; Nuclear Chemistry Supervisor and/or the Shift Manager shall proceed with a plan of corrective action to bring the parameter back into a normal value range. Typical corrective actions include:
- 6.8.1 Compare results of confirmatory analyses to readings from continuous monitors.
  - 6.8.2 Increase steam generator drain and fill for removal of specific impurities. (This can only be done during certain startup periods.)
  - 6.8.3 Identify and isolate sources of impurity ingress.
  - 6.8.4 Compare results of various analyses for internal consistency.
  - 6.8.5 Increase sample and analysis frequencies for short-term trending and confirmatory analyses of critical chemistry parameters where practical.
  - 6.8.6 Refer to Attachments 7, 8, and 9 for corrective actions of specific parameters.
- 6.9 All values from analyses and instrument readings should be archived for long-term trending and review.
- 6.10 It is intended that inline chemistry analyzers are the principle method of monitoring secondary chemistry. Grab samples should be used for verification of the accuracy of inline analyzers.
- 6.11 IF an inline analyzer that is required for continuous monitoring is out-of-service for maintenance, THEN a backup grab sample or portable meter reading should be obtained approximately every 6 hours. The grab sample can be omitted if the corresponding continuous analyzer on the opposite train is operable.
- 6.12 Test parameters that cannot be monitored because of laboratory equipment failures shall be evaluated for out-of-specification conditions by a Nuclear Chemistry Supervisor or designee. The determination shall be made by evaluating the data collected on other test parameters being monitored.
- 6.13 Outage maintenance plans should minimize the impact on the ability to recirculate and sample steam generators during periods of wet layup. Once steam generators are in wet layup and sample results indicate all parameters are within specifications, follow-up sample frequencies may be altered at the discretion of the Chemistry Superintendent or designee. This sample frequency change will only be allowed to accommodate maintenance windows.

**NOTE**

Step 6.14 does not apply to temporary loss of continuous monitoring for control parameters.

- 6.14 Deviation from control parameters in this procedure and/or the EPRI Guidelines require adequate technical justification. The technical justification shall meet the requirements listed in NMM EN-DC-317, "Entergy Steam Generator Administrative Procedure". A deviation requires completion of the appropriate attachment, "Industry Guideline Deviation Approval Sheet", located in NMM EN-DC-317.

PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: 8 of 31  CHANGE: 016
-------------------------------------	--	----------------------------------

- 6.15 If continuous monitoring is lost, place high priority on correcting problem and collect grab samples every 6 hours if analyzers on both trains are inoperable.
- 6.16 The replacement steam generators have additional sample requirements imposed by the replacement vendor. Per the Technical Operation and Maintenance Manual (01-5070437-00) approved by AREVA and Entergy, EPRI secondary water chemistry control parameter requirements present and future must be adhered to in order to maintain warranty. Additionally, lead and copper are secondary diagnostic parameters with warranty implications. AREVA has provided additional parameters, frequencies, and suggested actions as recommendations. However, AREVA has requested notification of exceeded limits, deviated frequencies, and failures to monitor for all warranted and recommended items. Notification is to be performed within ninety days of each failure.

## 7.0 ATTACHMENTS AND FORMS

### 7.1 ATTACHMENTS

- 7.1.1 Attachment 1, Modes 5 and 6 Cold Shutdown/Wet Layup (RCS  $\leq 200^{\circ}\text{F}$ )
- 7.1.2 Attachment 2, Mode 4 Hot Shutdown (RCS  $>200^{\circ}\text{F}$  and  $<280^{\circ}\text{F}$ )
- 7.1.3 Attachment 3, Mode 3 Hot Standby (RCS  $\geq 280^{\circ}\text{F}$ , Reactor not Critical)
- 7.1.4 Attachment 4, Mode 2 Startup (Reactor Critical at  $\leq 5\%$  Reactor Power)
- 7.1.5 Attachment 5, Mode 1 Power Operation (Reactor Power  $>5\%$  and  $<15\%$ )
- 7.1.6 Attachment 6, Mode 1 Power Operation (Reactor Power  $\geq 15\%$ )
- 7.1.7 Attachment 7, Cold Shutdown/Wet Layup Corrective Actions
- 7.1.8 Attachment 8, Hot Shutdown, Hot Standby, Startup, and Reactor Critical at  $<15\%$  Reactor Power Corrective Actions
- 7.1.9 Attachment 9, Mode 1 Power Operation ( $\geq 15\%$  Reactor Power) Corrective Actions

### 7.2 FORMS

- 7.2.1 Form 1000.042A, Unit 1 Steam Generator Monitoring Report (electronic form)

PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 9 of 31  CHANGE: 016
-------------------------------------	--	----------------------------------

ATTACHMENT 1

Page 1 of 2

MODES 5 AND 6  
COLD SHUTDOWN/WET LAYUP  
(RCS  $\leq 200^{\circ}\text{F}$ )

Control Parameters

**NOTE**

During outages, when the time period between cold shutdown and draining the steam generators for maintenance or startup is expected to be less than seven days or the time period after completion of maintenance and startup is expected to be less than seven days, it is not necessary to place the steam generators in full wet layup (in accordance with the pH and hydrazine values below). Unless the steam generators are being drained for maintenance or personnel safety or environmental issues/concerns exist, the steam generators should be filled with feedwater and a nitrogen overpressure established. The feedwater should contain  $>5$  ppm hydrazine and  $<100$  ppb dissolved oxygen. If condenser vacuum is broken, steps should be taken to ensure oxygenated feedwater is not introduced into the steam generators. When the steam generators cannot be placed in wet layup, a nitrogen blanket or other protective measures should be instituted to limit corrosion. Coordinated efforts should be employed to minimize steam generator dry layup.

Parameter	Frequency (A)	Normal Value	Initiate Action	Value Prior to Heatup (B)
<u>Steam Generator Sample</u>				
pH at $25^{\circ}\text{C}$	(C)	$>9.5$	$\leq 9.5$	---
Hydrazine, ppm	(C)	$\geq 75, \leq 500$	$< 75, > 500$	---
Sodium, ppb	(C)	$\leq 1000$	$> 1000$	$\leq 100$
Chloride, ppb	(C)	$\leq 1000$	$> 1000$	$\leq 100$
Sulfate, ppb	(C)	$\leq 1000$	$> 1000$	$\leq 100$
Oxygen, ppb (H)	(C)	$\leq 100$		$\leq 100$

Steam Generator Fill Source

Dissolved O <sub>2</sub> , ppb	Daily (D) (E)	$\leq 100$	$> 100$
--------------------------------	---------------	------------	---------

Diagnostic Parameters

Parameter

Steam Generator

Nitrogen Overpressure, (F) - minimize oxygen ingress to the steam generators during PSIG wet lay-up

Steam Generator

Hideout Return (G) - Typical samples collected are Na, Cl, SO<sub>4</sub>, K, Mg, Ca, Al and SiO<sub>2</sub>

Steam Generator Fill Source

Conductivity, $\mu\text{mho/cm}$	Daily	Monitor for ionic impurity ingress to the steam generators
----------------------------------	-------	--

PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 10 of 31  CHANGE: 016
-------------------------------------	--	-----------------------------------

ATTACHMENT 1

Page 2 of 2

MODES 5 AND 6  
COLD SHUTDOWN/WET LAYUP  
(RCS  $\leq$  200°F)

- (A) When the secondary system is in feedwater cleanup, it may not be possible to obtain a steam generator sample. The amount of time for feedwater recirculation prior to heatup should be minimized as much as possible.
- (B) The "Value Prior to Heatup" shall be verified by the Chemistry department. The completion of Plant Preheatup and Precritical Checklist, Appendix E, in OP-1102.001 performed by the Chemistry Superintendent documents this performance. This may be based on the most recent chemistry values being in spec for value prior to heatup and at least one drain and fill being performed to remove wet lay-up chemicals prior to heatup or by sampling the OTSGs.
- (C) Sampling should be initiated within 24 hours after initial fill or after significant water additions and then sample every other day until stable, then weekly. Wet layup chemistry should be established within 48 hours of filling. If outage maintenance results in the inability to obtain a scheduled sample, then the Chemistry Superintendent or designee should review the analysis data and determine whether the change in frequency is acceptable. Document the change on Form 1052.002A or in the Chemistry database.
- (D) Deoxygenated water is preferred for the initial fill of the steam generators subsequent to a shutdown, during feed and bleed operations, and during any fills subsequent to a draindown. When oxygenated water must be used as a fill source, appropriate compensatory actions shall be taken to minimize steam generator exposure to oxygen, e.g., nitrogen sparging or addition of a reducing agent to the fill source or directly to the steam generators. It is recognized that testing of the Emergency Feedwater system may result in limited ingress of oxygenated water to the steam generators during brief periods of time since EFW source water may be high in oxygen. However, such transients should be minimized to the extent possible.
- (E) Conformance to oxygen limits should be verified prior to any fill operation, except for Emergency Feedwater testing.
- (F) A nitrogen overpressure should be maintained on the steam generators when personnel safety will not be compromised.
- (G) Hideout return assessments generally should be based on data collected during fill/drain operations immediately subsequent to shutdown.
- (H) Routine monitoring not required prior to initial heatup if hydrazine concentration is within normal range.



PROC./WORK PLAN NO. <b>1000.042</b>	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: <b>11 of 31</b> CHANGE: <b>016</b>
--	--	---

ATTACHMENT 2

Page 1 of 3

MODES 4  
HOT SHUTDOWN  
(RCS >200°F AND <280°F)

Feedwater  
Control Parameters

Parameter	Frequency	Initiate Action
pH at 25°C	3/Day	(A)
Dissolved Oxygen, ppb	Continuous	>100 (B)
Hydrazine, ppb	3/Day	<8 x CPD [O <sub>2</sub> ] (B) (C) <50 ppb (B) (E)
Suspended Solids, ppb	3/Day	>100 (B)

Feedwater  
Diagnostic Parameters (D)

Parameter	Frequency	Normal Value	Initiate Action
Silica, ppb	Daily	≤10 (G)	>10 (H) (G) (I)
Sodium, ppb	Daily	≤5 (G)	>5 (G) (J)
Sulfate, ppb	Daily	≤50 (G)	>50 (G) (J)
Chloride, ppb	Daily	≤5 (G)	>5 (G) (J)
Cation (F) Conductivity, umhos/cm	3/Day	≤1 (G)	>1 (G) (M)
Lead, ppb (G) (K)	Daily	≤1 (G)	>1 (G)

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 12 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 2

Page 2 of 3

MODES 4  
HOT SHUTDOWN  
(RCS >200°F AND <280°F)

Steam Generator  
Control Parameters (D)

Parameter	Frequency	Initiate Action
Sodium, ppb	Continuous (L)	>100 (B)
Chloride, ppb	3/Day	>100 (B)
Sulfate, ppb	3/Day	>100 (B)

Steam Generator  
Diagnostic Parameters

Parameter	Frequency	Normal Value	Initiate Action
Lead, ppb(G) (K)	Weekly	≤1 (G)	
Silica, ppb(G)	Daily	(H)	
Cation Conductivity umhos/cm (F)	3/day	≤2 (G)	>2 (G)
	Monitor organic acid concentrations and large increases in anionic contaminants		
pH at 25°C	Should be consistent with or higher than feedwater pH		
Hydrazine, ppb	For trending to assess oxidant control		

PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 13 of 31  CHANGE: 016
-------------------------------------	--	-----------------------------------

ATTACHMENT 2

Page 3 of 3

MODES 4  
HOT SHUTDOWN  
(RCS >200°F AND <280°F)

- (A) Values for pH should be  $\geq 8.8$ , but morpholine should not be greater than 75 ppm for an extended period of time.
- (B) Return to normal value within 8 hours or consider a startup/power hold. An out of spec condition should be documented on Form 1000.042A and a condition report initiated for any out of spec condition.
- (C) Oxygen concentration measured at condensate pump discharge.
- (D) Since the OTSG is operating as a recirculating steam generator at power <15%, control and assessment of impurity ingress is based on OTSG blowdown impurity concentrations.
- (E) A minimum concentration of 50 ppb hydrazine is maintained at all times to provide a reasonable residual in case of oxygen inleakage transients.
- (F) Calculated value based on strong acid anion contributions.
- (G) This parameter or limit is a steam generator replacement vendor (AREVA) recommendation and is not required by EPRI. If a limit is exceeded, a notification along with corrective actions taken should be forwarded to AREVA within ninety (90) days.
- (H) A steam generator silica limit of  $\leq 100$  ppb may be substituted for the FW silica limit at <15% power.
- (I) Return to normal value within twenty-four (24) hours.
- (J) Identify source(s) and return to normal values within twenty-four (24) hours or prior to power escalation (>15% power).
- (K) AREVA states sources of lead contamination must be managed to limit lead ingress. Lead levels must be below the limit of detectability of 1.0 ppb. The desired lead level is <0.05 ppb. For the steam generator lead sample, at least one sample shall be obtained when RCS temperature >250 degrees F and reactor power is <15%.
- (L) Alternate monitoring of the steam generators is acceptable.
- (M) Return to normal value within 24 hours or stop feeding SGs until within normal value.

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 14 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 3

Page 1 of 3

MODE 3  
HOT STANDBY  
(RCS  $\geq 280^{\circ}\text{F}$ , REACTOR NOT CRITICAL)

Feedwater  
Control Parameters

Parameter	Frequency	Initiate Action
pH at 25° C	3/Day	(A)
Dissolved Oxygen, ppb	Continuous	>10 (B)
Hydrazine, ppb	3/Day	<8 x CPD [O <sub>2</sub> ] (B) (C) <50 ppb (B) (E)
Suspended Solids, ppb	Daily	>10 (B)

Feedwater  
Diagnostic Parameters (D)

Parameter	Frequency	Normal Value	Initiate Action
Silica, ppb	Daily	$\leq 10$ (G)	>10 (G) (H) (I)
Sodium, ppb	Daily	$\leq 5$ (G)	>5 (G) (J)
Sulfate, ppb	Daily	$\leq 50$ (G)	>50 (G) (J)
Chloride, ppb	Daily	$\leq 5$ (G)	>5 (G) (J)
Cation Conductivity, umhos/cm (F)	3/Day	$\leq 0.5$ (G)	>0.5 (G) (M)
Lead, ppb (G) (K)	Daily	$\leq 1$ (G)	>1 (G)

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 15 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 3

Page 2 of 3

MODE 3  
HOT STANDBY  
(RCS  $\geq$ 280°F, REACTOR NOT CRITICAL)

Steam Generator  
Control Parameters (D)

Parameter	Frequency	Initiate Action
Sodium, ppb	Continuous (L)	>100 (B)
Chloride, ppb	3/Day	>100 (B)
Sulfate, ppb	3/Day	>100 (B)

Steam Generator  
Diagnostic Parameters

Parameter	Frequency	Normal Value	Initiate Action
Lead, ppb(G) (K)	Weekly	$\leq$ 1 (G)	
Silica, ppb(G)	Daily	(H)	
Cation Conductivity umhos/cm (F)	3/day	$\leq$ 2.0 (G)	>2.0 (G)
pH at 25°C	Monitor organic acid concentrations and large increases in anionic contaminants		
Hydrazine, ppb	Should be consistent with or higher than feedwater pH		
	For trending to assess oxidant control		

PROC./WORK PLAN NO. <b>1000.042</b>	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: <b>16 of 31</b>  CHANGE: <b>016</b>
--	--	---

ATTACHMENT 3

Page 3 of 3

MODE 3  
HOT STANDBY  
(RCS  $\geq 280^{\circ}\text{F}$ , REACTOR NOT CRITICAL)

- (A) Values for pH should be  $\geq 8.8$ , but morpholine should not be greater than 75 ppm for an extended period of time.
- (B) Return to normal value within 8 hours or consider a startup/power hold. An out of spec condition should be documented on Form 1000.042A and a condition report initiated for any out of spec condition.
- (C) Oxygen concentration measured at condensate pump discharge.
- (D) Since the OTSG is operating as a recirculating steam generator at power  $<15\%$ , control and assessment of impurity ingress is based on OTSG blowdown impurity concentrations.
- (E) A minimum concentration of 50 ppb hydrazine is maintained at all times to provide a reasonable residual in case of oxygen inleakage transients.
- (F) Calculated value based on strong acid anion contributions.
- (G) This parameter or limit is a steam generator replacement vendor (AREVA) recommendation and is not required by EPRI. If a limit is exceeded, a notification along with corrective actions taken should be forwarded to AREVA within ninety (90) days.
- (H) A steam generator silica limit of  $\leq 100$  ppb may be substituted for the FW silica limit at  $<15\%$  power.
- (I) Return to normal value within twenty-four (24) hours.
- (J) Identify source(s) and return to normal values within twenty-four (24) hours or prior to power escalation ( $>15\%$  power).
- (K) AREVA states sources of lead contamination must be managed to limit lead ingress. Lead levels must be below the limit of detectability of 1.0 ppb. The desired lead level is  $<0.05$  ppb. For the steam generator lead sample, at least one sample shall be obtained when RCS temperature  $>250$  degrees F and reactor power is  $<15\%$ .
- (L) Alternate monitoring of steam generators is acceptable.
- (M) Return to normal value within 100 hours. Do not increase power above 15% until within normal value.

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 17 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 4

Page 1 of 3

MODE 2  
STARTUP  
(REACTOR CRITICAL AT  $\leq 5\%$  REACTOR POWER)

Feedwater  
Control Parameters

Parameter	Frequency	Initiate Action
-----------	-----------	--------------------

Feedwater sample

pH at 25°C	3/Day	(A)
Dissolved Oxygen, ppb	Continuous	>5 (B)
Hydrazine, ppb	3/Day	<8xCPD [O <sub>2</sub> ] (B) (C) <50 ppb (B) (F)
Suspended Solids, ppb	Daily	>10 (B)

Feedwater  
Diagnostic Parameters (D)

Parameter	Frequency	Normal Value	Initiate Action
Silica, ppb	Daily	$\leq 10$ (H)	>10 (H) (I) (L)
Sodium, ppb	Daily	$\leq 5$ (H)	>5 (H) (J)
Sulfate, ppb	Daily	$\leq 50$ (H)	>50 (H) (J)
Chloride, ppb	Daily	$\leq 5$ (H)	>5 (H) (J)
Cation Conductivity, umhos/cm (G)	3/day	$\leq 0.2$ (H)	>0.2, >1.0, >2.0 (H) (N)
Lead ppb (H) (K)	Daily	$\leq 1$ (H)	>1 (H)

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 18 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 4

Page 2 of 3

MODE 2  
STARTUP  
(REACTOR CRITICAL AT  $\leq 5\%$  REACTOR POWER)

Steam Generator  
Control Parameters (D)

Parameter	Frequency	Initiate Action	Value prior to >5% power
Sodium, ppb	Continuous (M)	>100 (B) (E)	$\leq 100$ (E) (O)
Chloride, ppb	3/Day	>100 (B) (E)	$\leq 100$ (E) (O)
Sulfate, ppb	3/Day	>100 (B) (E)	$\leq 100$ (E) (O)

Steam Generator  
Diagnostic Parameters

Parameter	Frequency	Normal Value	Initiate Action
Lead, ppb (H) (K)	Weekly	$\leq 1$ (H)	
Silica, ppb (H)	Daily	(H) (L)	
Cation Conductivity umhos/cm (G)	3/day	$\leq 2.0$ (H)	>2.0 (H)
pH at 25°C	Should be consistent with or higher than feedwater pH		
Hydrazine, ppb	For trending to assess oxidant control		



PROC./WORK PLAN NO. <b>1000.042</b>	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: <b>19 of 31</b>  CHANGE: <b>016</b>
--	--	---

ATTACHMENT 4

Page 3 of 3

MODE 2  
STARTUP  
(REACTOR CRITICAL AT  $\leq 5\%$  REACTOR POWER)

- (A) Values for pH should be  $>8.8$ , but morpholine should not be greater than 75 ppm for an extended period of time.
- (B) Return to normal value within 8 hours or consider a startup/power hold. An out of spec condition should be documented on Form 1000.042A and a condition report initiated for any out of spec condition. For degrading conditions for sodium, chloride, or sulfate it should be noted that Note E of this attachment will become applicable at  $>250$  ppb for either contaminant.
- (C) Oxygen concentration measured at condensate pump discharge.
- (D) Since the OTSG is operating as a recirculating steam generator at power  $<15\%$ , control and assessment of impurity ingress is based on OTSG blowdown impurity concentrations.
- (E) During power escalation (reactor critical to  $15\%$  power), if either sodium, chloride, or sulfate concentration is  $>250$  ppb be in hot shutdown within 4 hours and clean up by feed and bleed or drain and refill as appropriate. To reach hot shutdown conditions within 4 hours from power operations is difficult but permissible by Unit 1 Tech Specs. Contingencies should be established prior to exceeding the 250 ppb limit.
- (F) A minimum concentration of 50 ppb hydrazine is maintained at all times to provide a reasonable residual in case of oxygen inleakage transients.
- (G) Calculated value based on strong acid anions contributions.
- (H) This parameter or limit is a steam generator replacement vendor (AREVA) recommendation and is not required by EPRI. If a limit is exceeded a notification along with corrective actions taken should be forwarded to AREVA within ninety (90) days.
- (I) Return to normal value within twenty-four (24) hours.
- (J) Identify source(s) and return to normal values within twenty-four (24) hours or prior to power escalation ( $>15\%$  power).
- (K) AREVA states sources of lead contamination must be managed to limit lead ingress. Lead levels must be below the limit of detectability of 1.0 ppb. The desired lead level is  $<0.05$  ppb. For the steam generator lead sample, at least one sample shall be obtained when RCS temperature  $>250$  degrees F and reactor power is  $<15\%$ .
- (L) A steam generator silica limit of  $<100$  ppb may be substituted for the FW silica limit at  $<15\%$  power. If limit is exceeded, then return to normal value within twenty-four (24) hours.
- (M) Alternate monitoring of steam generators is acceptable.
- (N) See Attachment 8 for cation conductivity corrective actions.
- (O) This value shall be met prior to exceeding  $>5\%$  power. Note (B) does not apply for exceeding  $5\%$  power.

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: 20 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 5

Page 1 of 3

MODE 1  
POWER OPERATION  
(REACTOR POWER >5% AND <15%)

Feedwater  
Control Parameters

Parameter	Frequency	Initiate Action
pH at 25°C	3/Day	(A)
Dissolved Oxygen, ppb	Continuous	>5 (B)
Hydrazine, ppb	3/Day	<8 x CPD[O2] (B) (C) <50 ppb (B) (F)
Suspended Solids, ppb	Daily	>10 (B)

Feedwater  
Diagnostic Parameters (D)

Parameter	Frequency	Normal Value	Initiate Action
<u>Feedwater Sample</u>			
Silica, ppb	Daily	≤10 (H)	>10 (H) (I) (L)
Sodium, ppb	Daily	≤5 (H)	>5 (H) (J)
Sulfate, ppb	Daily	≤50 (H)	>50 (H) (J)
Chloride, ppb	Daily	≤5 (H)	>5 (H) (J)
Cation Conductivity, umhos/cm (G)	3/Day	≤0.2 (H)	>0.2, >1.0, >2.0 (H) (N)
Lead, ppb (H) (K)	Daily	≤1.0 (H)	>1.0 (H)

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 21 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 5

Page 2 of 3

MODE 1  
POWER OPERATION  
(REACTOR POWER >5% AND <15%)

Steam Generator  
Control Parameters (D)

Parameter	Frequency	Initiate Action
Sodium, ppb	Continuous (M)	>250 (E)
Chloride, ppb	3/Day	>250 (E)
Sulfate, ppb	3/Day	>250 (E)

Steam Generator  
Diagnostic Parameters

Parameter	Frequency	Normal Value	Initiate Action	Value prior to >15% power
Lead, ppb(H) (K)	Weekly	≤1 (H)		
Silica, ppb(H)	Daily	(L)		
Cation Conductivity umhos/cm(G)	3/day	≤2.0 (H)	>2.0 (H)	≤2.0 (H)
	(Monitor organic acid concentrations and large increases in anionic contaminants)			
pH at 25°C	Should be consistent with or higher than feedwater pH			
Hydrazine, ppb	For trending to assess oxidant control			

PROC./WORK PLAN NO. <b>1000.042</b>	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: <b>22 of 31</b>  CHANGE: <b>016</b>
--	--	---

ATTACHMENT 5

Page 3 of 3

MODE 1  
POWER OPERATION  
(REACTOR POWER >5% AND <15%)

- (A) Values for pH should be  $\geq 8.8$ , but morpholine should not be greater than 75 ppm for an extended period of time.
- (B) Return to normal value within 8 hours or consider a startup/power hold. An out of spec condition should be documented on Form 1000.042A and a condition report initiated for any out of spec condition.
- (C) Oxygen concentration measured at condensate pump discharge.
- (D) Since the OTSG is operating as a recirculating steam generator at power <15%, control and assessment of impurity ingress is based on OTSG blowdown impurity concentrations.
- (E) During power escalation (reactor critical to 15% power), if either sodium, chloride, or sulfate concentration is >250 ppb be in hot shutdown within 4 hours and clean up by feed and bleed or drain and refill as appropriate. To reach hot shutdown conditions within 4 hours from power operations is difficult but permissible by Unit 1 Tech Specs. Contingencies should be established prior to exceeding the 250 ppb limit.
- (F) A minimum concentration of 50 ppb hydrazine is maintained at all times to provide a reasonable residual in case of oxygen inleakage transients.
- (G) Calculated value based on strong acid anion contributions.
- (H) This parameter or limit is a steam generator replacement vendor (AREVA) recommendation and is not required by EPRI. If a limit is exceeded a notification along with corrective actions taken should be forwarded to AREVA within ninety (90) days.
- (I) Return to normal value within twenty-four (24) hours.
- (J) Identify source(s) and return to normal values within twenty-four (24) hours or prior to power escalation (>15% power).
- (K) AREVA states sources of lead contamination must be managed to limit lead ingress. Lead levels must be below the limit of detectability of 1.0 ppb. The desired lead level is <0.05 ppb. For the steam generator lead sample, at least one sample shall be obtained when RCS temperature >250 degrees F and reactor power is <15%.
- (L) A steam generator silica limit of  $\leq 100$  ppb may be substituted for the FW silica limit at <15% power. If limit is exceeded, then return to normal value within twenty-four (24) hours.
- (M) Alternate monitoring of steam generators is acceptable.
- (N) See Attachment 8 for cation conductivity corrective actions.

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: 23 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 6

Page 1 of 4

MODE 1  
POWER OPERATION  
(REACTOR POWER  $\geq 15\%$ )

Feedwater  
Control Parameters

Parameter	Frequency (A)	Action Levels		
		1	2	3
Morpholine, ppm	Daily	(B)		
Hydrazine, ppb	Daily	$\leq 8 \times \text{CPD}[\text{O}_2]$ or $< 20$ ppb minimum (I)	(I)	(I)
Sodium, ppb	Continuous (C)	1	3	5 (L)
Chlorides, ppb	Daily (C)	3	5	10 (L)
Sulfates, ppb	Daily	1	3	5 (L)
Silica, ppb (M)	Weekly	10	20	
Total Iron, ppb	Weekly (D)	5		
Oxygen, ppb	Continuous (E)	5	10	

Feedwater  
Diagnostic Parameters (D)

	Frequency	Normal Value	Initiate Action
pH (B)			
Cation Conductivity, umhos/cm (N)	Daily	$\leq 0.2$ (J)	(K)
Fluoride	Fluoride transport assessment, resolution of cat. cond. observations		
Copper, ppb (F)	Weekly	$\leq 1.0$ (J)	$> 1.0$ (J)
Lead*, ppb	Weekly	$\leq 0.05$ (J)	$> 0.05$ (J)
Magnetite Fraction			

Integrated Corrosion Product Transport - Assessment of corrosion product mass transport to steam generators using integrated samples. 1/refueling cycle

\*Lead transport assessment per EPRI

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 24 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 6

Page 2 of 4

MODE 1  
POWER OPERATION  
(REACTOR POWER  $\geq 15\%$ )

Parameter	Frequency	Initiate Action
-----------	-----------	-----------------

Condensate Pump Discharge Sample (G)  
Diagnostic Parameter

Dissolved Oxygen, ppb	Continuous	>25
--------------------------	------------	-----

Action Levels

Control Parameter

	1	2	3
Dissolved Oxygen, ppb	Continuous	>10	>30 (H)

Moisture Separator Drain Samples

Diagnostic Parameters

Sodium, ppb

Chloride, ppb

Sulfate, ppb

Organic acids, ppb      Demonstrate consistency with cation conductivity.

Cation Conductivity,  $\mu\text{mho/cm}$

PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: 25 of 31  CHANGE: 016
-------------------------------------	--	-----------------------------------

ATTACHMENT 6  
MODE 1  
POWER OPERATION  
(REACTOR POWER  $\geq 15\%$ )

Page 3 of 4

- (A) No planned maintenance should be allowed that will result in a loss of sample (which would prevent meeting sample frequencies) for more than twenty-four (24) hours. During the maintenance period, grab samples (if sampling capability exists) should be collected every six (6) hours for the applicable samples. Grab samples may be taken from the corrosion product samplers or other final feedwater location if cooling is available, to satisfy the sampling requirements. Maintenance requiring the system to be down for more than twenty-four (24) hours should be scheduled to be performed during outages. If unexpected conditions require sample cooling to be unavailable for more than twenty-four (24) hours, alternate sample cooling capability should be obtained (temporary modification or procedurally allowed jumper) or alternate sampling should be evaluated by Chemistry management.
- (B) pH should be  $\geq 8.8$ , but not more than 75 ppm morpholine for extended periods of time.
- (C) Final feedwater concentrations may be calculated from moisture separator drain concentrations using a mass balance approach. Divide MSR values for sodium and chloride by 16. This approach cannot be used for sulfate since sulfate has a high portion of hideout in the steam generator.
- (D) This limit applies to steady state operation after a stabilization period, usually 1 week. Integrated sampling should be initiated at approximately 30% power after startup or as directed by Chemistry management.
- (E) Feedwater oxygen values are normally taken from the inline analyzers. If the inline analyzer is out of service, grab samples must be taken. Do not sample for feedwater oxygen at the sample room. If feedwater cannot be sampled on either feedwater train locally either by analyzer or grab sample, then condensate oxygen becomes a control parameter.
- (F) Copper analysis is used to trend and establish a baseline value per EPRI guidelines. Steam generator replacement vendor (AREVA) recommends limit and the associated action to identify and eliminate source if limit is exceeded.
- (G) Condensate pump oxygen is considered a diagnostic parameter when using localized feedwater oxygen sampling. Plant power reduction is not required based on condensate pump oxygen if localized feedwater oxygen sampling is utilized. Normally, the local feedwater oxygen analyzer is used or if analyzer is out of service, use grab samples locally. If condensate oxygen as a diagnostic parameter is greater than 25 ppb, steps should be taken to reduce condensate oxygen to avoid excessive amounts of hydrazine in feedwater.
- (H) If condensate oxygen is used as a control parameter, reduce power to 50-60% and determine source of inleakage.
- (I) In the event of loss of hydrazine feed that is not restored within 8 hours, commence plant shutdown as quickly as safe plant operation permits. If hydrazine feed is restored, the plant may return to full power. The 8 hour time clock starts when action level 1 for hydrazine is entered.

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: 26 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 6

Page 4 of 4

MODE 1  
POWER OPERATION  
(REACTOR POWER  $\geq 15\%$ )

- (J) This parameter or limit is a steam generator replacement vendor (AREVA) recommendation and is not required by EPRI. If a limit is exceeded, a notification along with corrective actions taken should be forwarded to AREVA within ninety (90) days.
- (K) The steam generator replacement vendor (AREVA) recommends the following corrective actions in the event the following calculated cation conductivity (based on strong acid anion contributions) limits are exceeded.
  - 1. IF value exceeds 0.2 umhos/cm,  
THEN return to normal value within twenty-four (24) hours  
AND immediately check chloride and sulfate.
  - 2. IF value exceeds 1.0 umhos/cm,  
THEN return to normal value within eight (8) hours  
AND immediately check chloride and sulfate.
  - 3. IF value exceeds 2.0 umhos/cm,  
THEN return to normal value within two (2) hours  
AND immediately check chloride and sulfate.
- (L) Plant shutdown required only if Action Level 3 value is exceeded for >2 hours, or if at any time for any duration the parameter exceeds 20 ppb.
- (M) Parameter included for turbine performance. Silica is not considered to impact steam generator integrity and is therefore a recommended parameter outside of NEI 97-06 requirements.
- (N) Calculated value based on strong anion contributions.



PROC./WORK PLAN NO.  1000.042	PROCEDURE/WORK PLAN TITLE:  STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 27 of 31  CHANGE: 016
-------------------------------------	--	-----------------------------------

ATTACHMENT 7

COLD SHUTDOWN/WET LAYUP CORRECTIVE ACTIONS

Steam Generator Sample

Parameter Out of Range

Corrective Action

pH

1. IF low,  
THEN add ammonia to correct and mix  
contents of steam generator.
2. Crosscheck with ammonia/hydrazine/specific  
conductivity values for consistency.

Sodium/Chloride/Sulfate

1. Feed and bleed until within range or drain  
and refill with deoxygenated makeup water  
of proper purity.
2. Check makeup water purity.

Hydrazine

1. IF low,  
THEN add hydrazine until within range.

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: 28 of 31  CHANGE: 016
---------------------------------	--	-----------------------------------

ATTACHMENT 8

Page 1 of 2

HOT SHUTDOWN, HOT STANDBY, STARTUP, AND REACTOR CRITICAL AT <15%  
REACTOR POWER CORRECTIVE ACTIONS

Feedwater Sample

Parameter Out of Range

Corrective Action

pH

1. IF too low,  
THEN increase morpholine or hydrazine feed.
2. IF pH is high,  
THEN perform one or more of the following:
  - a. Blowdown and add deionized, deoxygenated makeup water.
  - b. Evaluate appropriate polisher change-out.
  - c. Decrease morpholine or hydrazine feed.

Dissolved Oxygen

1. Check for decreasing vacuum.
2. Check hydrazine residual and add if required.
3. Check dissolved oxygen in makeup water.

Morpholine/Hydrazine

1. Adjust chemical addition.

Suspended Solids

1. Verify pH and amine concentrations are within site specific ranges.
2. Check condensate polisher performance/alignment.

Cation Conductivity

1. The steam generator replacement vendor (AREVA) recommends the following corrective actions for reactor power >5% and <15%.
  - a. IF value exceeds 0.2 umhos/cm,  
THEN return to normal value within twenty-four (24) hours after feed to SGs is initiated.
  - b. IF value exceeds 1.0 umhos/cm,  
THEN return to normal value within twenty-four (24) hours  
AND do not exceed 15% reactor power until within normal value.
  - c. IF value exceeds 2.0 umhos/cm,  
THEN return to normal value within eight (8) hours  
OR initiate cooldown with normal procedures.

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 29 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 8

Page 2 of 2

HOT SHUTDOWN, HOT STANDBY, STARTUP, AND REACTOR CRITICAL AT <15%  
REACTOR POWER CORRECTIVE ACTIONS

Steam Generator Sample

Parameter Out of Range

Corrective Action

Sodium/Chloride/  
Sulfate/Cation Conductivity

1. Drain and fill; add demineralized, deoxygenated makeup water.
2. Check effluent of condensate polishers and make appropriate changes.
3. Verify absence of condenser inleakage.
4. Check makeup water/feedwater purity.
5. IF corrective actions do not alleviate the condition,  
THEN consider cooldown, drain, and refill.

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: <b>STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE</b>	PAGE: 30 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 9

Page 1 of 2

POWER OPERATION ( $\geq 15\%$  REACTOR POWER) CORRECTIVE ACTIONS

Final Feedwater Sample

Parameter Out of Range

Corrective Action

pH	<ol style="list-style-type: none"> <li>1. Verify correct hydrazine feed.</li> <li>2. Verify correct morpholine feed.</li> <li>3. Verify absence of regenerant chemical inleakage.</li> </ol>
Morpholine/Hydrazine	<ol style="list-style-type: none"> <li>1. Adjust chemical addition.</li> </ol>
Dissolved Oxygen	<ol style="list-style-type: none"> <li>1. Check hydrazine residual; adjust to <math>\geq 8 \times \text{CPD}[\text{O}_2]</math>.</li> <li>2. Identify and reduce sources of air inleakage.</li> <li>3. Check for decreasing condenser vacuum.</li> </ol>
Chloride/Silica/ Sodium/Sulfate	<ol style="list-style-type: none"> <li>1. Request routing of MSR drains to condenser.</li> <li>2. Regenerate resins as required.</li> <li>3. Identify and eliminate source using other sample points as necessary.</li> <li>4. Investigate for possible internal source of contamination.</li> <li>5. Consider hot soaks following shutdown due to chemistry excursion.</li> </ol>
Iron	<ol style="list-style-type: none"> <li>1. Assure morpholine, pH and oxygen are in specification.</li> <li>2. Increase pH/morpholine to maximum value allowed within control range.</li> </ol>

PROC./WORK PLAN NO. 1000.042	PROCEDURE/WORK PLAN TITLE: STEAM GENERATOR WATER CHEMISTRY MONITORING - UNIT ONE	PAGE: 31 of 31 CHANGE: 016
---------------------------------	--	-------------------------------

ATTACHMENT 9

Page 2 of 2

POWER OPERATION ( $\geq 15\%$  REACTOR POWER) CORRECTIVE ACTIONS

Condensate Pump Discharge Sample

Parameter Out of Range

Corrective Action

Dissolved Oxygen

1. Identify and reduce air inleakage sources.
2. IF available,  
THEN test other available locations in feedwater train for dissolved oxygen.
3. Check for decreasing condenser vacuum.
4. Evaluate condenser oxygen removal efficiency.

## A7. Equipment Control

D/R

K/A 2.2.12

Knowledge of surveillance  
procedures.

A1JPM-SRO-SURV4

# ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-SRO-SURV4

Page 1 of 4

UNIT: 1 REV # 1 DATE: \_\_\_\_\_

TUOI NUMBER: A1JPM-SRO-SURV4

SYSTEM/DUTY AREA: ADMINISTRATIVE TOPIC – CONDUCT OF OPERATIONS

TASK: MONITOR CONDUCT OF SHIFT SURVEILLANCE TESTS

JTA#: ANO-SRO-ADMIN-NORM-200

KA VALUE RO: 3.7 SRO: 4.1 KA REFERENCE: 2.2.12

APPROVED FOR ADMINISTRATION TO: RO: \_\_\_\_\_ SRO: X

TASK LOCATION: INSIDE CR: \_\_\_\_\_ OUTSIDE CR: \_\_\_\_\_ BOTH: X

SUGGESTED TESTING ENVIRONMENT AND METHOD (PERFORM OR SIMULATE):

PLANT SITE: \_\_\_\_\_ SIMULATOR: \_\_\_\_\_ Classroom: PERFORM

POSITION EVALUATED: RO: \_\_\_\_\_ SRO: X

ACTUAL TESTING ENVIRONMENT: SIMULATOR: \_\_\_\_\_ PLANT SITE: \_\_\_\_\_ Classroom: X

TESTING METHOD: SIMULATE: \_\_\_\_\_ PERFORM: X

APPROXIMATE COMPLETION TIME IN MINUTES: 20 MINUTES

REFERENCE(S): 1106.006, Emergency Feedwater Pump Operation

EXAMINEE'S NAME: \_\_\_\_\_ SSN \_\_\_\_\_ - \_\_\_\_\_ - \_\_\_\_\_

EVALUATOR'S NAME: \_\_\_\_\_

THE EXAMINEE'S PERFORMANCE WAS EVALUATED AGAINST THE STANDARDS  
CONTAINED IN THIS JPM AND IS DETERMINED TO BE:

SATISFACTORY: \_\_\_\_\_ UNSATISFACTORY: \_\_\_\_\_

PERFORMANCE CHECKLIST COMMENTS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_ Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time

SIGNED \_\_\_\_\_ DATE: \_\_\_\_\_

SIGNATURE INDICATES THIS JPM HAS BEEN COMPARED TO ITS APPLICABLE PROCEDURE BY A  
QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.

## ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-SRO-SURV4

Page 2 of 4

### THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:** The quarterly test of Emergency Feedwater Pump (P-7B) per 1106.006,  
Supplement 11, was performed on the previous shift. The SM is performing Section 4, Shift Manager Review  
and Analysis. Plant is at 100% power.

**TASK STANDARD:** The examinee has reviewed 1106.0006, Supplement 11 and identified at  
least 3 administrative errors in the test and must include the TS time clock entry issue and the Acceptance Criteria  
Table 4 issue

**TASK PERFORMANCE AIDS:** Completed 1106.0006, Supplement 11.



## ADMINISTRATIVE JOB PERFORMANCE MEASURE

TUOI: A1JPM-SRO-SURV4

Page 3 of 4

### INITIATING CUE:

- Perform Section 4 of 1106.006 Supplement 11, "Electric Feedwater Pump (P-7B) Test."

CRITICAL ELEMENTS (C) 2

(C)	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UNSAT
	1. Review 1106.006, Supplement 11.	Examinee reviewed 1106.006, Supplement 11.			
(C)	2. Identify the two required errors and one of the other four errors.	<p>Examinee identified at least 3 of the following administrative errors, two of which must include the TS entry time clock issue and the Acceptance Criteria Table 4 issue:</p> <ul style="list-style-type: none"> <li>• <b>Step 2.1.4 entry into T.S. time clock step was N/A'd (required)</b></li> <li>• <b>Acceptance Criteria Table 4, EFW Test Recirc Flow FI-2888 recorded as 532 gpm and "YES" circled when this value is greater than Limiting Range for Operability (required)</b></li> <li>• Step 1.2.1 independent verification initials missing.</li> <li>• Step 2.27 should not be N/A if Tech Spec was correctly entered.</li> <li>• Step 3.1.1 should not be N/A if Table 4 error was corrected.</li> <li>• Step 3.2.1 stopwatch cal due date has expired.</li> </ul>			

END

ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE

TITLE: **EMERGENCY FEEDWATER PUMP  
OPERATION**

DOCUMENT NO.  
**1106.006**

CHANGE NO.  
**073**

WORK PLAN EXP. DATE  
**N/A**

SET #

SAFETY-RELATED  
☒ YES ☐ NO

IPTE  
☒ YES ☐ NO

TEMP MOD  
☒ YES ☐ NO

LEVEL OF USE  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL

PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO

When you see these **TRAPS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Get these **TOOLS**

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

VERIFIED BY

DATE

TIME

_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

FORM TITLE:

**VERIFICATION COVER SHEET**

FORM NO.  
**1000.006A**

CHANGE NO.  
**054**

— KEY —

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: 168 of 209 CHANGE: 073
---------------------------------	---	---------------------------------

SUPPLEMENT 11

Page 1 of 19

ELECTRIC EMERGENCY FEEDWATER PUMP (P-7B) TEST  
(QUARTERLY)

This test demonstrates the operability of P-7B and selected check valves by running the pump at rated flow through the recirc test header. This test satisfies SR 3.7.5.2, the required quarterly test of P-7B, by verifying it starts, and develops a discharge head at the test point that is greater than or equal to the required developed head in accordance with the Inservice Testing program (TS 5.5.8). Every 18 months, prior to refueling, a full open stroke verification of EFW Suction Line Check Valves (CS-293 and CS-294) is performed using non-intrusive test equipment.

1.0 INITIAL CONDITIONS

1.1 Check the purpose of this test.

INITIALS

- ☒ A) Regularly scheduled quarterly test
- ☐ B) Regularly scheduled 18-month test prior to refueling
- ☐ C) Operability test following significant maintenance (describe maintenance performed in section 4.0)
- ☐ D) Other (describe in section 4.0)

**NOTE**

- ✓ If test data taken under proper test conditions falls outside the Limiting Range for Operability, the component being tested is declared inoperable, even if instrument mis-calibration is suspected.
- ✓ If SPDS is specified in instrument column for recording test data and SPDS instrumentation is unavailable, the surveillance is either postponed or alternate instruments are used per the following conditions:
  - + Acceptance criteria instrument column is annotated to show the instrument number used and the cal due date.
  - + Test instrument accuracy is  $\pm 2\%$  of full scale or better.
  - + Range of test instrument is  $< 3$  times normal process value.
  - + Test instrument installed at SPDS transmitter local test connection.
  - + "Shift Manager Review and Analysis" section states the alternate instruments used and the reason for their use.

~~1.2~~ IF alternate test instruments are used,  
THEN verify instruments meet requirements for alternate test instruments, verify instrument column is annotated and explain in section 4.0.

BB

~~1.2.1~~ Alternate test instrument(s) installed.

AC

Independent Verification                     

1.2.2 Alternate test instrument(s) shall be attended unless isolated.

Signature JAN 7-3-08

Initials

- KEY -

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 171 of 209 CHANGE: 073
---------------------------------	--	---------------------------------

SUPPLEMENT 11

Page 4 of 19

2.0 TEST METHOD

**NOTE**

The EFIC system is designed to allow full flow recirc testing while at power. If the need arises for EFW during the test, the system will automatically leave the test mode and feed the steam generators as required.

2.1

Prepare system for testing and check for backleakage of SG-A EFW Supply Line Check Valve (FW-13A) and SG-B EFW Supply Line Check Valve (FW-13B) as follows:

2.1.1

Verify test recirc header depressurized AND if necessary, momentarily open EFW Test Recirc Pressure Control (CV-2888).

BB

2.1.2

Record the following data in Table 1:

A

Initial EFW Test Recirc PRESS (C09)

BB

B

Idle P-7B suction pressure

BB

2.1.3

Verify the following valves open:

- EFW P-7B to SG-A Isol (CV-2670)
- EFW P-7B to SG-B Isol (CV-2626)

BB

BB

2.1.4

IF in Mode 1—4,  
AND OTSGs are being relied upon for heat removal,  
THEN enter 72-hour time clock per TS 3.7.5 Condition B.

N/A

Time

N/A

Date

N/A

2.1.5

Open EFW Test Recirc P-7B Isolation (CV-2869).

BB

**NOTE**

- ✓ Check valve leakage is indicated by rising test header pressure and rising pump discharge piping temperature.
- ✓ A pressure spike may be indicated on PI-2888 when CV-2869 is opened. It may take 5-10 minutes for pressure to stabilize.

2.1.6

Monitor EFW Test Recirc PRESS for rising pressure.

BB

Should not BE N/A'd

- KEY -

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 178 of 209 CHANGE: 073
---------------------------------	--	---------------------------------

SUPPLEMENT 11

Page 11 of 19

- ~~2.25~~ Return system to normal as follows:
- ~~2.25.1~~ Verify CV-2869 is closed. BB
  - ~~2.25.2~~ Open CV-2626. BB
  - ~~2.25.3~~ A. Verify CV-2626 in AUTO. BB
  - ~~2.25.3~~ Open CV-2670. BB
  - ~~2.25.3~~ A. Verify CV-2670 in AUTO. BB
  - ~~2.25.4~~ Verify CV-2646 open. BB
  - ~~2.25.4~~ A. Place CV-2646 in AUTO. BB
  - ~~2.25.5~~ Verify CV-2648 is open. BB
  - ~~2.25.5~~ A. Verify CV-2648 in AUTO. BB
  - ~~2.25.6~~ Verify CV-2888 valve position demand at or near zero. BB
  - ~~2.25.6~~ A. Verify CV-2888 in AUTO. BB
  - ~~2.25.6~~ B. Verify CV-2888 setpoint at 1220 psig. BB
  - ~~2.26~~ IF installed,  
THEN remove alternate test instrument(s) and obtain independent verification. AC
  - Independent verification small
  - ~~2.27~~ IF applicable,  
THEN clear TS 3.7.5 time clock entered for performance of this test. N/A
  - Time N/A Date N/A
  - ~~2.28~~ Record vibration data recorded in Table 5. AC
  - ~~2.29~~ Review all calculations AND verify correct.
  - Reviewed and verified by:  
(SRO) Jon Dupuis Date 9-10-08
  - ~~2.30~~ Record AND review required trend data.
  - Recorded and reviewed by:  
(SE/STA/SRO) Ally Cherry Date 9-10-08
  - 2.30.1 IF available,  
THEN attach copies of graphs. SE

Should  
not be  
N/A

KEY

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>180 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

3.1 (continued)

Page 13 of 19

Table 4					
TEST QUANTITY	INSTRUMENT	MEASURED VALUES	ACCEPTABLE NORMAL RANGE	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? Circle YES or NO
Running Suction Pressure	TG1002 12/23/08 SPDS	19 psig	N/A	>7 psig	(YES) NO
Discharge Pressure	SPDS	1423 psig	N/A	≥1220 psig	(YES) NO
Discharge Pressure	PIS-2812	1423 psig	N/A	N/A	N/A
EFW Test Recirc Flow	FI-2888	532 GPM	N/A	520 to 530 gpm	(YES) NO
Pump ΔP	Discharge press minus suct press (SPDS)	1404 psid	N/A	(1) 1209 to 1460.9 psid	(YES) NO
P-7B Minimum Recirc Flow	FI-2801	105 GPM	N/A	N/A	N/A
Motor Running Current	A-311 Ammeter	(1) C Ø <u>71.5</u> amp (2) A Ø <u>71.5</u> amp (3) B Ø <u>71.5</u> amp	N/A	N/A	N/A

Note 1 Design Basis Value for Pump ΔP is 1209 psid at 520 to 530 gpm.

Exceeds Limit

KEY

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>182 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

Page 15 of 19

3.1 (continued)

Table 6					
TEST QUANTITY	INSTRUMENT	MEASURED VALUES	ACCEPTABLE NORMAL RANGE	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? Circle YES or NO
CS-1196	N/A	(6) (7) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
P-7B Run Time	Clock	38 MIN	≥10 minutes	≥5 minutes	(YES) NO
FW-56A	N/A	(2) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
FW-56B	N/A	(2) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
FW-10B	N/A	(2) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
		(5) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
FW-62	N/A	(5) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
CS-293 & CS-294 Partial Stroke	N/A	(3) (✓) if partial valve stroke is sat. (✓)		Valve stroke satisfactory	(YES) NO
CS-293 Full Stroke	(4)	(4) (✓) if full valve stroke is sat. (N/A)		N/A	N/A
CS-294 Full Stroke	(4)	(4) (✓) if full valve stroke is sat. (N/A)		N/A	N/A

Note 2 Full stroke is satisfactory when design flow is established.

Note 3 Partial stroke of one or both valves is satisfactory when flow is established.

Note 4 Analysis made by Component Engineering, during regularly scheduled 18-month test, based on data obtained with non-intrusive test equipment.

Note 5 Full stroke for recirc function is satisfactory when design recirc flow is established.

Note 6 CS-1196 full stroke is satisfactory when bearing temperature is within Acceptable Normal Range during regularly scheduled 18-month test.

Note 7 CS-1196 partial stroke is satisfactory when quarterly testing reveals no adverse observations on pump operation which would be associated with bearing performance (e.g. vibration, noise, excessive temps).

3.1.1 IF "NO" is circled in any of the tables in the preceding section,  
THEN perform the following:

- Declare applicable component inoperable
- Initiate a Condition Report
- Immediately notify Shift Manager
- Initiate corrective action.
- Reference applicable Tech Spec LCO for required actions

N/A  
Should not  
be N/A

KEY

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>183 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

Page 16 of 19

3.1.2 IF any measured value does not fall within the "Acceptable Normal Range",  
THEN initiate corrective action. N/A

3.2 Stroke Criteria

3.2.1 Compare measured values/stroke times with "Acceptable Normal Range" and "Limiting Range for Operability". BB

Stopwatch M&TE No. DES-103 Cal Due Date 8-10-08

Stopwatch M&TE No. \_\_\_\_\_ Cal Due Date \_\_\_\_\_

CAL O  
Expired

Table 7								
Valve	CNTRL Panel	Test Direct	Alternate Position Verif (using flow)	Measured Value-Stroke Time (Nearest 1/10 Sec)	Accept Normal Range Time (Sec)	Limiting Range For Operability Time (Sec)	Is Data Within Limiting Range For Operability?	Design Bases Value
CV-2648	C09	Close	(✓) if flow $\geq 70$ gpm (✓)	10.7	8.9 - 14.7	17.7	(YES) NO	57.4
CV-2646	C09	Open	(✓) if flow $\geq 520$ gpm (✓)	10.4	8.1 - 13.3	16.0 (1)	(YES) NO	N/A
CV-2646	C09	Close	(✓) if flow $\geq 70$ gpm (✓)	10.0	7.5 - 12.5	15.0	(YES) NO	57.4
CV-2648	C09	Open	(✓) if flow $\geq 520$ gpm (✓)	10.3	8.7 - 14.5	17.4 (1)	(YES) NO	N/A

Note 1 Valve stroke time  $\leq$  limiting value verifies proper fail safe operation.

3.2.2 IF "No" is circled in any space in the table above,  
THEN perform the following:

N/A

- Declare that valve inoperable
- Initiate a Condition Report
- Immediately notify the Shift Manager
- Initiate corrective action
- Reference applicable Tech Spec LCO for required actions

3.2.3 IF any measured stroke time does not fall within the "Acceptable Normal Range",  
THEN immediately retest valve or declare that valve inoperable. Refer to "Operability" section of this procedure for additional guidance. N/A

Performed by Bob Bunker Operator Date/Time 9/10/08 0230  
AL Corp 9/10/08 0230

KEY



## **ADMINISTRATIVE JOB PERFORMANCE MEASURE**

TUOI: A1JPM-SRO-SURV4

Page 4 of 4

### **EXAMINEE'S COPY**

#### **JPM INITIAL TASK CONDITIONS:**

- The quarterly test of Emergency Feedwater Pump (P-7B) per 1106.006, Supplement 11, was performed on the previous shift.
- The SM is performing Section 4, Shift Manager Review and Analysis.
- Plant 100% power

#### **INITIATING CUE:**

- **Perform Section 4 of 1106.006 Supplement 11, "Electric Feedwater Pump (P-7B) Test."**

**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

**TITLE: EMERGENCY FEEDWATER PUMP  
OPERATION**

**DOCUMENT NO.  
1106.006**

**CHANGE NO.  
073**

**SET #**

**WORK PLAN EXP. DATE  
N/A**

**SAFETY-RELATED  
☒ YES ☐ NO**

**IPTE  
☒ YES ☐ NO**

**TEMP MOD  
☒ YES ☐ NO**

**LEVEL OF USE  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL**

**PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO**

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.  
1000.006A**

**CHANGE NO.  
054**

*SRO STUDENT HANDOUT*

PROC./WORK PLAN NO.  1106.006	PROCEDURE/WORK PLAN TITLE:  EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 168 of 209 CHANGE: 073
-------------------------------------	--	---------------------------------

SUPPLEMENT 11

Page 1 of 19

ELECTRIC EMERGENCY FEEDWATER PUMP (P-7B) TEST  
(QUARTERLY)

This test demonstrates the operability of P-7B and selected check valves by running the pump at rated flow through the recirc test header. This test satisfies SR 3.7.5.2, the required quarterly test of P-7B, by verifying it starts, and develops a discharge head at the test point that is greater than or equal to the required developed head in accordance with the Inservice Testing program (TS 5.5.8). Every 18 months, prior to refueling, a full open stroke verification of EFW Suction Line Check Valves (CS-293 and CS-294) is performed using non-intrusive test equipment.

~~1.0~~ INITIAL CONDITIONS

INITIALS

~~1.1~~

Check the purpose of this test.

- ☒ A) Regularly scheduled quarterly test
- ☐ B) Regularly scheduled 18-month test prior to refueling
- ☐ C) Operability test following significant maintenance (describe maintenance performed in section 4.0)
- ☐ D) Other (describe in section 4.0)

NOTE

- ✓ If test data taken under proper test conditions falls outside the Limiting Range for Operability, the component being tested is declared inoperable, even if instrument mis-calibration is suspected.
- ✓ If SPDS is specified in instrument column for recording test data and SPDS instrumentation is unavailable, the surveillance is either postponed or alternate instruments are used per the following conditions:
  - ✓ Acceptance criteria instrument column is annotated to show the instrument number used and the cal due date.
  - ✓ Test instrument accuracy is  $\pm 2\%$  of full scale or better.
  - ✓ Range of test instrument is  $< 3$  times normal process value.
  - ✓ Test instrument installed at SPDS transmitter local test connection.
  - ✓ "Shift Manager Review and Analysis" section states the alternate instruments used and the reason for their use.

~~1.2~~

IF alternate test instruments are used,  
THEN verify instruments meet requirements for alternate test instruments, verify instrument column is annotated and explain in section 4.0.

BB

~~1.2.1~~

Alternate test instrument(s) installed.

AC

Independent Verification \_\_\_\_\_

~~1.2.2~~

Alternate test instrument(s) shall be attended unless isolated.

←

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: 169 of 209 CHANGE: 073
---------------------------------	---	---------------------------------

SUPPLEMENT 11

Page 2 of 19

- ~~1.3~~ Verify EFW Pumps (P-7A AND P-7B) off. BB
- ~~1.4~~ Verify system aligned per System Alignment Verification section of 1015.001, Conduct of Operations. BB
- ~~1.5~~ IF this is the regularly scheduled 18-month test, or a test to prove operability after significant maintenance, THEN verify digital pyrometer available. N/A
- M&TE # N/A cal due date N/A.
- ~~1.6~~ IF this is the regularly scheduled 18-month test, THEN have Component Engineering Test Engineer set up their non-intrusive test equipment on EFW Suction Line Check Valves (CS-293 and CS-294), (both simultaneously) in preparation for obtaining full open stroke verification data. N/A
- ~~1.7~~ Portable vibrometer available to obtain vibration readings. BB
- ~~1.8~~ Stopwatch available for stroke time measurements. BB
- ~~1.8.1~~ Record stopwatch M&TE numbers and cal due date in section 3.0. BB
- ~~1.9~~ No EFIC system test being performed. BB
- ~~1.10~~ Verify the following EFW flow path valve positions with control power available to applicable control valves.
- ~~1.10.1~~ EFW P-7B Suction from CST (CV-2800) open. BB
- ~~1.10.2~~ EFW Serv Wtr Loop I Isolation (CV-3850) closed. BB
- ~~1.10.3~~ EFW P-7B Suction from SW (CV-2803) closed. BB

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>170 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

Page 3 of 19

~~1.11~~

Verify normal standby parameters by performing the following.

~~1.11.1~~

Check pump oil level normal.

I.B. AC

O.B. AC

~~1.11.2~~

Check motor oil level normal.

I.B. AC

O.B. AC

1.11.3 Verify Pressure Control CV-2888 set at 1220 PSIG and valve demand indicating ~0%.

BB

~~1.11.4~~

IF this test is being performed following significant maintenance on P-7B, THEN perform the following:

A. Vent P-7B seals using:

- EFW Pmp P-7B Inbrd Mech Seal Vent (CS-1211) N/A
- EFW Pmp P-7B Outbrd Mech Seal Vent (CS-1212) N/A

B. Close the following valves:

- CS-1211 N/A
- CS-1212 N/A

~~1.12~~

Check (✓) applicable plant condition(s) and acknowledge prerequisites for pump test.

BB

(✓) Unit in Mode 1—3

- P-7A Operable
- 72-hour time clock will be entered during this test per TS 3.7.5 Condition B.

( ) Unit in Mode 4

- Test can be performed provided neither steam generator is being credited for RCS heat removal (TS 3.7.5)

( ) Unit in Mode 5 or 6

- No restriction

~~1.13~~

IF in Mode 1—3, THEN verify no RPS, ESAS or DROPS test being performed.

BB

~~1.14~~

Operator available to obtain P-7B running current readings at A-311.

BB

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 171 of 209 CHANGE: 073
---------------------------------	--	---------------------------------

SUPPLEMENT 11

Page 4 of 19

~~2.0~~ TEST METHOD

**NOTE**

The EFIC system is designed to allow full flow recirc testing while at power. If the need arises for EFW during the test, the system will automatically leave the test mode and feed the steam generators as required.

~~2.1~~

Prepare system for testing and check for backleakage of SG-A EFW Supply Line Check Valve (FW-13A) and SG-B EFW Supply Line Check Valve (FW-13B) as follows:

~~2.1.1~~

Verify test recirc header depressurized AND if necessary, momentarily open EFW Test Recirc Pressure Control (CV-2888).

BB

~~2.1.2~~

Record the following data in Table 1:

A. Initial EFW Test Recirc PRESS (C09)

BB

B. Idle P-7B suction pressure

BB

~~2.1.3~~

Verify the following valves open:

• EFW P-7B to SG-A Isol (CV-2670)

BB

• EFW P-7B to SG-B Isol (CV-2626)

BB

~~N/A~~

IF in Mode 1—4,  
AND OTSGs are being relied upon for heat removal,  
THEN enter 72-hour time clock per TS 3.7.5 Condition B.

N/A

Time N/A Date N/A

~~2.1.5~~

Open EFW Test Recirc P-7B Isolation (CV-2869).

BB

**NOTE**

- ✓ Check valve leakage is indicated by rising test header pressure and rising pump discharge piping temperature.
- ✓ A pressure spike may be indicated on PI-2888 when CV-2869 is opened. It may take 5-10 minutes for pressure to stabilize.

~~2.1.6~~

Monitor EFW Test Recirc PRESS for rising pressure.

BB

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: 172 of 209 CHANGE: 073
---------------------------------	---	---------------------------------

SUPPLEMENT 11

Page 5 of 19

~~2.1.7~~

IF indicated pressure on PI-2888 is >40 PSIG,  
THEN perform the following:

N/A

A. Notify the Shift Manager.

1. Verify a WR/WO submitted.

B. Monitor EFW discharge pipe temperature for steam binding of EFW pump.

C. IF steam binding is indicated,  
THEN refer to "Relieving EFW Pump Steam Bind" section of this procedure and perform appropriate steps.

~~2.1.8~~

Record final EFW test recirc pressure in Table 1.

BB

~~2.1.9~~

Record FW-13A and FW-13B backleakage results in Table 1.

BB

**CAUTION**

Modulating valves may indicate full closed yet not be fully torqued closed thereby allowing leakage past valve.

~~2.1.10~~

Close CV-2670 (modulating valve) AND Hold control switch in CLOSE until valve torques closed.

BB

~~A.~~ Verify CV-2670 in AUTO.

BB

~~2.1.11~~

Close CV-2626 (modulating valve) AND hold control switch in CLOSE until valve torques closed.

BB

~~A.~~ Verify CV-2626 in AUTO.

BB

~~2.1.12~~

Place EFW P-7B to SG-A CNTRL (CV-2646) in HAND.

BB

~~A.~~ Close CV-2646.

BB

~~2.1.13~~

IF this is the regularly scheduled 18-month test,  
THEN inform the test engineer to start his non-intrusive test equipment on EFW Suction Line Check Valves (CS-293 and CS-294), (both simultaneously) in preparation for obtaining full open stroke verification data.

N/A

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: 173 of 209 CHANGE: 073
---------------------------------	---	---------------------------------

SUPPLEMENT 11

Page 6 of 19

- 2.2 Start P-7B by placing handswitch to START. BB
- 2.2.1 Record start time 0132. BB
- 2.3 Adjust EFW Test Recirc Control Valve (CV-2888) as necessary to obtain 520 to 550 GPM test flow, as indicated on P7B FLOW TO OTSG B (SPDS). BB
- 2.3.1 Record EFW Flow P-7B to SG-B (SPDS and FI-2648) in Table 2. BB
- 2.3.2 Record Alternate Position Verification for CV-2648 - "Open", in Table 7. BB
- 2.4 IF this is the regularly scheduled 18-month test, THEN inform the test engineer to stop his non-intrusive test equipment on CS-293 and CS-294. N/A
- 2.5 Check EFW Pump (P-7A) shaft to ensure shaft is not rotating. AC
- 2.5.1 Record in Table 2 Seating of P-7A min. recirc check (FW-61). BB
- 2.6 Stroke test EFW P-7B to SG-B CNTRL (CV-2648) closed as follows:
- 2.6.1 Place CV-2648 in HAND. BB

**NOTE**

CV-2648 stroke is performed by starting stopwatch when pushbutton is depressed and stopping stopwatch when valve position indicator stops at closed position (near 0%) while verifying consistent agreement with valve position demand and flow indication.

- 2.6.2 WHILE timing valve stroke AND monitoring valve position and flow, THEN close CV-2648. BB
- 2.6.3 Record measured closing time in Table 7. BB
- 2.6.4 Verify EFW Flow P-7B to SG-B (FI-2648) reduces to ~0 gpm AND record Alternate Position Verification for CV-2648 - "Closed", in Table 7. BB
- 2.7 In Table 3, record P-7B minimum recirc flow as indicated on EFW Pump P-7B Min Flow Recirc Indicator (FI-2801). BB



PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: 174 of 209 CHANGE: 073
---------------------------------	---	---------------------------------

SUPPLEMENT 11

Page 7 of 19

- 2.8 Stroke test EFW P-7B to SG-A CNTRL (CV-2646) open as follows:

**NOTE**

CV-2646 stroke is performed by starting stopwatch when pushbutton is depressed and stopping stopwatch when valve position indicator stops at open position (near 100%) while verifying consistent agreement with valve position demand and flow indication.

- 2.8.1 WHILE timing valve stroke  
AND monitoring valve position and flow,  
THEN open CV-2646. BB
- 2.8.2 Record measured opening time in Table 7. BB
- 2.9 Adjust EFW Test Recirc Pressure Control (CV-2888) as necessary to obtain 520 to 550 GPM test flow as indicated on P7B FLOW TO OTSG A (SPDS). BB
- 2.9.1 Record EFW Flow P-7B to SG-A (SPDS and FI-2646) in Table 3. BB
- 2.9.2 Record Alternate Position Verification for CV-2646 - "Open", in Table 7. BB
- 2.10 Stroke test EFW Flow Control (CV-2646) closed as follows:

**NOTE**

CV-2646 stroke is performed by starting stopwatch when pushbutton is depressed and stopping stopwatch when valve position indicator stops at closed position (near 0%) while verifying consistent agreement with valve position demand and flow indication.

- 2.10.1 WHILE timing valve stroke  
AND monitoring valve position and flow,  
THEN close CV-2646. BB
- 2.10.2 Record measured closing time in Table 7. BB
- 2.10.3 Verify EFW Flow P-7B to SG-A (FI-2646) reduces to ~0 gpm and record Alternate Position Verification for CV-2646 - "Closed", in Table 7. BB
- 2.11 Open CV-2646 (demand at 100% open). BB

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: 175 of 209 CHANGE: 073
---------------------------------	---	---------------------------------

SUPPLEMENT 11

Page 8 of 19

~~2.12~~ Stroke test EFW Flow Control CV-2648 open as follows:

**NOTE**

CV-2648 stroke is performed by starting stopwatch when pushbutton is depressed and stopping stopwatch when valve position indicator stops at open position (near 100%) while verifying consistent agreement with valve position demand and flow indication.

~~2.12.1~~ WHILE timing valve stroke  
AND monitoring valve position and flow,  
THEN open CV-2648.

BB

~~2.12.2~~ Record measured opening time in Table 7.

BB

**NOTE**

The following steps consist of pump IST data collection requirements and will require flow to be adjusted 520 to 530 gpm.

~~2.13~~ Adjust EFW Test Recirc Pressure Control (CV-2888) as necessary to obtain 520 to 530 GPM test recirc flow at EFW Test Recirc Flow indicator (FI-2888).

BB

~~2.14~~ After 2 minutes of pump operation perform the following:

• Record applicable data in Table 4.

BB

• Take vibrometer readings per data sheet of this supplement.

AC

~~2.15~~ Adjust CV-2888 until one of the following occurs:

BB

• P-7B discharge pressure 1220 PSIG (PIS-2812 or SPDS)

• CV-2888 is full open

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: 176 of 209 CHANGE: 073
---------------------------------	---	---------------------------------

SUPPLEMENT 11

Page 9 of 19

- 2.16 While adjusting **EFW Flow Control Valves** (CV-2646 and CV-2648) as follows, enter data and plot data points on the pump curve in this supplement.

**NOTE**

- This data is for pump performance evaluation and is not intended as acceptance criteria. See section 3.0 for acceptance criteria.
- With CV-2646 and CV-2648 both closed, the pump flow will be through the minimum recirculation line, as read on EFW Pump P-7B Min Flow Recirc indicator (FI-2801).

- |        |   |           |
|--------|---|-----------|
| 2.16.1 | Close CV-2646 and CV-2648 to obtain minimum flow (FI-2801).   | <u>BB</u> |
| 2.16.2 | Adjust CV-2646 and CV-2648 as necessary to obtain ~300 GPM combined flow of EFW Test Recirc Flow indicator (FI-2888) and minimum recirc flow (FI-2801). | <u>BB</u> |
| 2.16.3 | Adjust CV-2646 and CV-2648 as necessary to obtain ~400 GPM combined flow of FI-2888 and FI-2801.  | <u>BB</u> |
| 2.16.4 | Adjust CV-2646 and CV-2648 as necessary to obtain ~500 GPM combined flow of FI-2888 and FI-2801.  | <u>BB</u> |
| 2.16.5 | Adjust CV-2646 and CV-2648 as necessary to obtain ~600 GPM combined flow of FI-2888 and FI-2801.  | <u>BB</u> |
| 2.16.6 | Fully open CV-2646 <u>AND</u> CV-2648 to obtain combined full flow of FI-2888 and FI-2801.  | <u>BB</u> |
| 2.17   | Leave CV-2646 <u>AND</u> CV-2648 open for remainder of test.  | <u>BB</u> |

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>177 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

Page 10 of 19

**NOTE**

Bearing temperatures are considered stable when three consecutive readings at ten minute intervals vary no more than 3%.

- 2.18 IF this is the regularly scheduled 18-month test, N/A  
OR is to prove operability after significant maintenance, N/A  
THEN continue test until pump and motor bearing temperatures are stable.
- 2.18.1 Record applicable temperatures in Table 5. N/A  
OTHERWISE mark N/A here and in Table 5.
- 2.19 Record in Table 6 stroke of P-7B Brg Clnng Rtn Ck (CS-1196). BB
- 2.20 WHEN P-7B has run for at least 10 minutes, BB  
THEN close CV-2869.
- 2.21 Stop P-7B. Record stop time 0210. BB
- 2.21.1 Record difference in P-7B start time and P-7B stop time as "P-7B Run Time" in Table 6. BB
- 2.22 IF RCS temperature is >280°F, BB  
THEN verify P-7B handswitch is in normal-after-stop.
- 2.23 Record in Table 6 stroking of the following valves. BB
- ✓ SG-A EFW Supply Line Check Valve (P-7B Disch) (FW-56A)
  - ✓ SG-B EFW Supply Line Check Valve (P-7B Disch) (FW-56B)
  - ✓ P-7B Recirc Check Valve (FW-10B)
  - ✓ P-7B Min Recirc Check (FW-62)
  - ✓ EFW Suction Line Check Valves (CS-293 and CS-294)
- 2.24 IF this is a regularly scheduled 18-month test, N/A  
THEN obtain results of Component Engineering analysis on full open stroke verification of EFW Suction Line Check Valves (CS-293 and CS-294) and enter in Table 6. N/A  
OTHERWISE mark N/A here and in Table 6.

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 178 of 209 CHANGE: 073
---------------------------------	--	---------------------------------

SUPPLEMENT 11

Page 11 of 19

- ~~2.25~~ Return system to normal as follows:
- ~~2.25.1~~ Verify CV-2869 is closed. BB
- ~~2.25.2~~ Open CV-2626. BB
- ~~2.25.3~~ A. Verify CV-2626 in AUTO. BB
- ~~2.25.4~~ Open CV-2670. BB
- ~~2.25.5~~ A. Verify CV-2670 in AUTO. BB
- ~~2.25.6~~ Verify CV-2646 open. BB
- ~~2.25.7~~ A. Place CV-2646 in AUTO. BB
- ~~2.25.8~~ Verify CV-2648 is open. BB
- ~~2.25.9~~ A. Verify CV-2648 in AUTO. BB
- ~~2.25.10~~ Verify CV-2888 valve position demand at or near zero. BB
- ~~2.25.11~~ A. Verify CV-2888 in AUTO. BB
- ~~2.25.12~~ B. Verify CV-2888 setpoint at 1220 psig. BB
- ~~2.26~~ IF installed, THEN remove alternate test instrument(s) and obtain independent verification. AC
- Independent verification small
- ~~2.27~~ IF applicable, THEN clear TS 3.7.5 time clock entered for performance of this test. N/A
- Time N/A Date N/A
- ~~2.28~~ Record vibration data recorded in Table 5. AC
- ~~2.29~~ Review all calculations AND verify correct.
- Reviewed and verified by: John Dupuis Date 9-10-08  
(SRO)
- ~~2.30~~ Record AND review required trend data.
- Recorded and reviewed by: John Dupuis Date 9-10-08  
(SE/STA/SRO)
- 2.30.1 IF available, THEN attach copies of graphs. SE

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>179 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

3.0 ACCEPTANCE CRITERIA

Page 12 of 19

- 3.1 Compare results/measured values observed during P-7B testing with "Acceptable Normal Range" and "Limiting Range For Operability".

55

Table 1					
TEST QUANTITY	INSTRUMENT	MEASURED VALUES	ACCEPTABLE NORMAL RANGE	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? Circle YES or NO
Initial EFW Test Recirc Pressure	PI-2888	14 psig	N/A	N/A	N/A
P-7B Idle Suction Pressure	TC 1002 12/25/08 SPDS	20 psig	N/A	N/A	N/A
Final EFW Test Recirc Pressure	PI-2888	14 psig	N/A	N/A	N/A
FW-13A & FW-13B Closure (backleakage)	Final Recirc Press minus initial Recirc Press	0 psig	<30 PSIG	<40 PSIG	<input checked="" type="radio"/> YES NO

Table 2					
TEST QUANTITY	INSTRUMENT	MEASURED VALUES	ACCEPTABLE NORMAL RANGE	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? Circle YES or NO
EFW Flow P-7B to SG-B	SPDS	535 GPM	N/A	520 to 550 gpm	<input checked="" type="radio"/> YES NO
EFW Flow P-7B to SG-B	FI-2648	537 GPM	N/A	N/A	N/A
FW-61	N/A	(✓) if valve seating sat. (✓)		valve seats sat.	<input checked="" type="radio"/> YES NO

Table 3					
TEST QUANTITY	INSTRUMENT	MEASURED VALUES	ACCEPTABLE NORMAL RANGE	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? Circle YES or NO
P-7B Minimum Recirc Flow	FI-2801	110 GPM	100-140 GPM	75-150 GPM	<input checked="" type="radio"/> YES NO
EFW Flow P-7B to SG-A	SPDS	540 GPM	N/A	520 to 550 gpm	<input checked="" type="radio"/> YES NO
EFW Flow P-7B to SG-A	FI-2646	543 GPM	N/A	N/A	N/A

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>180 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

3.1 (continued)

Page 13 of 19

Table 4					
TEST QUANTITY	INSTRUMENT	MEASURED VALUES	ACCEPTABLE NORMAL RANGE	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? Circle YES or NO
Running Suction Pressure	TG1002 12/25/08 SPDS	19 psig	N/A	>7 psig	<input checked="" type="radio"/> YES NO
Discharge Pressure	SPDS	1423 psig	N/A	≥1220 psig	<input checked="" type="radio"/> YES NO
Discharge Pressure	PIS-2812	1428 psig	N/A	N/A	N/A
EFW Test Recirc Flow	FI-2888	532 GPM	N/A	520 to 530 gpm	<input checked="" type="radio"/> YES NO
Pump ΔP	Discharge press minus suct press (SPDS)	1404 psid	N/A	(1) 1209 to 1460.9 psid	<input checked="" type="radio"/> YES NO
P-7B Minimum Recirc Flow	FI-2801	105 GPM	N/A	N/A	N/A
Motor Running Current	A-311 Ammeter	(1) C Ø <u>71.5</u> amp (2) A Ø <u>71.5</u> amp (3) B Ø <u>71.5</u> amp	N/A	N/A	N/A

Note 1 Design Basis Value for Pump ΔP is 1209 psid at 520 to 530 gpm.

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>181 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

3.1 (continued)

Page 14 of 19

Table 5					
TEST QUANTITY	INSTRUMENT	MEASURED VALUES	ACCEPTABLE NORMAL RANGE	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? Circle YES or NO
O.B. Motor Brg Vibration *(1)	Vibrometer	.027 IN/SEC	N/A	N/A	N/A
I.B. Motor Brg Vibration *(2)	Vibrometer	.045 IN/SEC	N/A	N/A	N/A
I.B. Pump Brg Vibration Vertical *(3)	Vibrometer	.035 IN/SEC	≤0.082 IN/SEC	≤0.198 IN/SEC	(YES) NO
I.B. Pump Brg Vibration Horizontal *(4)	Vibrometer	.046 IN/SEC	≤0.105 IN/SEC	≤0.252 IN/SEC	(YES) NO
O.B. Pump Brg Vibration Vertical *(5)	Vibrometer	.033 IN/SEC	≤0.102 IN/SEC	≤0.246 IN/SEC	(YES) NO
O.B. Pump Brg Vibration Horizontal *(6)	Vibrometer	.061 IN/SEC	≤0.152 IN/SEC	≤0.366 IN/SEC	(YES) NO
O.B. Pump Brg Vibration Axial *(7)	Vibrometer	.060 IN/SEC	≤0.207 IN/SEC	≤0.498 IN/SEC	(YES) NO
I.B. Pump Brg Temp *(8)	Pyrometer	N/A °F	<165 °F	165 °F	YES (N/A) NO
O.B. Pump Brg Temp *(9)	Pyrometer	N/A °F	<165 °F	165 °F	YES (N/A) NO

\* See attached drawing.



PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>182 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

Page 15 of 19

3.1 (continued)

Table 6					
TEST QUANTITY	INSTRUMENT	MEASURED VALUES	ACCEPTABLE NORMAL RANGE	LIMITING RANGE FOR OPERABILITY	IS DATA WITHIN LIMITING RANGE? Circle YES or NO
CS-1196	N/A	(6) (7) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
P-7B Run Time	Clock	38 MIN	≥10 minutes	≥5 minutes	(YES) NO
FW-56A	N/A	(2) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
FW-56B	N/A	(2) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
FW-10B	N/A	(2) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
		(5) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
FW-62	N/A	(5) (✓) if valve stroke is satisfactory (✓)		Valve stroke satisfactory	(YES) NO
CS-293 & CS-294 Partial Stroke	N/A	(3) (✓) if partial valve stroke is sat. (✓)		Valve stroke satisfactory	(YES) NO
CS-293 Full Stroke	(4)	(4) (✓) if full valve stroke is sat. (N/A)		N/A	N/A
CS-294 Full Stroke	(4)	(4) (✓) if full valve stroke is sat. (N/A)		N/A	N/A

Note 2 Full stroke is satisfactory when design flow is established.

Note 3 Partial stroke of one or both valves is satisfactory when flow is established.

Note 4 Analysis made by Component Engineering, during regularly scheduled 18-month test, based on data obtained with non-intrusive test equipment.

Note 5 Full stroke for recirc function is satisfactory when design recirc flow is established.

Note 6 CS-1196 full stroke is satisfactory when bearing temperature is within Acceptable Normal Range during regularly scheduled 18-month test.

Note 7 CS-1196 partial stroke is satisfactory when quarterly testing reveals no adverse observations on pump operation which would be associated with bearing performance (e.g. vibration, noise, excessive temps).

3.1.1 IF "NO" is circled in any of the tables in the preceding section,  
THEN perform the following:

- Declare applicable component inoperable
- Initiate a Condition Report
- Immediately notify Shift Manager
- Initiate corrective action.
- Reference applicable Tech Spec LCO for required actions

N/A

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>183 of 209</b> CHANGE: <b>073</b>
--	---	---

SUPPLEMENT 11

Page 16 of 19

3.1.2

IF any measured value does not fall within the "Acceptable Normal Range",  
THEN initiate corrective action.

N/A

3.2

Stroke Criteria

3.2.1

Compare measured values/stroke times with "Acceptable Normal Range" and "Limiting Range for Operability".

BB

Stopwatch M&TE No. DES-103 Cal Due Date 8-10-08

Stopwatch M&TE No. \_\_\_\_\_ Cal Due Date \_\_\_\_\_

Table 7

Valve	CNTRL Panel	Test Direct	Alternate Position Verif (using flow)	Measured Value-Stroke Time (Nearest 1/10 Sec)	Accept Normal Range Time (Sec)	Limiting Range For Operability Time (Sec)	Is Data Within Limiting Range For Operability?	Design Bases Value
CV-2648	C09	Close	(✓) if flow $\geq 0$ gpm (✓)	<u>10.7</u>	8.9 - 14.7	17.7	(YES) NO	57.4
CV-2646	C09	Open	(✓) if flow $\geq 520$ gpm (✓)	<u>10.4</u>	8.1 - 13.3	16.0 (1)	(YES) NO	N/A
CV-2646	C09	Close	(✓) if flow $\geq 0$ gpm (✓)	<u>10.0</u>	7.5 - 12.5	15.0	(YES) NO	57.4
CV-2648	C09	Open	(✓) if flow $\geq 520$ gpm (✓)	<u>10.3</u>	8.7 - 14.5	17.4 (1)	(YES) NO	N/A

Note 1 Valve stroke time  $\leq$  limiting value verifies proper fail safe operation.

3.2.2

IF "No" is circled in any space in the table above,  
THEN perform the following:

N/A

- Declare that valve inoperable
- Initiate a Condition Report
- Immediately notify the Shift Manager
- Initiate corrective action
- Reference applicable Tech Spec LCO for required actions

3.2.3

IF any measured stroke time does not fall within the "Acceptable Normal Range",  
THEN immediately retest valve or declare that valve inoperable. Refer to "Operability" section of this procedure for additional guidance.

N/A


Performed by Bob Bankner Operator Date/Time 9/10/08 0230  
AL Coys 9/10/08 0230

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 184 of 209 CHANGE: 073
---------------------------------	--	---------------------------------

SUPPLEMENT 11

Page 17 of 19

Hold vibrometer probe tip firmly against the survey point marker, perpendicular to the surface. Locations of markers are depicted.



POINT NUMBER	VELOCITY IN/SEC
1	.027
2	.045
3	.035
4	.046
5	.033
6	.061
7	.060

Vibrometer No. DUA-006


Cal Due Date 12-22-08

Performed By Ad Cook

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 185 of 209 CHANGE: 073
---------------------------------	--	---------------------------------

SUPPLEMENT 11

Page 18 of 19



FI-2888	FI-2801	Flow Rate (gpm)	Pressure (psig)
200	105	(1) 190	1600
310	110	300	1575
410	105	400	1528
520	106	500	1440
620	100	600	1365
740	100	720	1237

Note 1 With CV-2646 and CV-2648 both closed, record flow as read on EFW Pump P-7B Min Recirc Flow (FI-2801).

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: 186 of 209 CHANGE: 073
---------------------------------	---	---------------------------------

SUPPLEMENT 11

Page 19 of 19

4.0 SHIFT MANAGER REVIEW AND ANALYSIS

(circle one)

- 4.1 Do all measured values recorded in the Acceptance Criteria section fall within the specified "Limiting Range For Operability"? YES NO
- 4.2 Do all measured values recorded in Acceptance Criteria section fall within the "Acceptable Normal Range"? YES NO
- 4.2.1 IF "NO" AND reason is pump related, THEN initiate corrective action and schedule to double test frequency.
- 4.3 Do all measured valve stroke times recorded in Acceptance Criteria section fall within the "Acceptable Normal Range"? YES NO
- 4.3.1 IF "NO", and successful retest or engineering assessment of valve was performed, THEN document results below.
- 4.3.2 IF "NO", and retest was not successful OR engineering assessment shows valve to be inoperable, THEN write a Condition Report, initiate corrective action and reference applicable Tech Spec for LCO.
- 4.4 IF answer to either 4.1, 4.2 or 4.3 is "NO", THEN describe the action taken below:
- TG1002 Cal due date: 12/25/08) used in place  
of SPDS P-7A suction pressure due to  
SPDS point failure (WR 0053062)
- 4.5 Has this equipment been proven operable per the Acceptance Criteria? YES NO
- 4.6 Have all the administrative requirements of this test been satisfied (i.e., all initial blocks initialed or N/A'd, all data entered, cal due dates listed, applicable signature spaces signed, etc.)? YES NO

SHIFT MANAGER \_\_\_\_\_ DATE \_\_\_\_\_

## A4. Radiation Control

N/R

K/A 2.3.4

Knowledge of radiation exposure limits under normal or emergency conditions.

A1JPM-SRO-DOSE-SVY2

JOB PERFORMANCE MEASURE

Unit: 1 Rev # 4 Date: 8/19/2008

TUOI NUMBER: A1JPM-SRO- DOSE-SVY2

System/Duty Administrative Topic-Radiation Control  
Area: \_\_\_\_\_

Task: Calculate Stay times for yourself and another operator

KA Value RO 3.2 SRO 3.7 KA Reference 2.3.4  
☒ SRO ☒

Approved For Administration To: RO \_\_\_\_\_

Task Location: Inside CR: \_\_\_\_\_ Outside CR: \_\_\_\_\_ Classroom: ☒

Suggested Testing Environment And Method (Perform Or Simulate): Perform

Plant \_\_\_\_\_ Simulator \_\_\_\_\_ Classroom: Perform

Site: \_\_\_\_\_ :

Position Evaluated: X SRO: \_\_\_\_\_

RO: \_\_\_\_\_

Actual Testing Environment: \_\_\_\_\_ Plant Site: \_\_\_\_\_ Classroom X

Simulator: \_\_\_\_\_

Testing Method: \_\_\_\_\_ Perform: X

Simulate: \_\_\_\_\_

Approximate Completion Time In Minutes: 15 Minutes

Reference(S) HP Survey Map of P36C, Pump Room 54.

Examinee's \_\_\_\_\_ SSN: \_\_\_\_\_

Name: \_\_\_\_\_

Evaluator's \_\_\_\_\_

Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments: \_\_\_\_\_

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

Signed \_\_\_\_\_ Date: \_\_\_\_\_

Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:**

You are an WCO with the plant at full power. A hot spot has developed on Makeup PUMP P36C. You and another WCO will be working in the vicinity of the reduction gear assembly in order to flush the lines and reduce the hot spot radiation field.

Using the supplied survey map, determine the individual stay times **for yourself AND the other WCO** without exceeding the annual administrative dose limit (Ignore dose received during transit). You have an accumulated annual Whole Body dose of 1905 mR (ANO records). The other WCO has an accumulated annual Whole Body dose of 1790 mR (ANO records). No additional dose has been received at any other site.

**Also**, calculate stay times if the air in the pump room was contaminated with a level of 0.29 DAC (stochastic) assuming no respirators are used.

Calculations should be based on ANO Unit 1 Administrative dose limits. **Provide answers with 3 significant figures (example 4.51 hours)**. Do not consider ALARA task requirements.

**TASK STANDARD:**

The examinee has correctly determined the stay times for himself and the other WCO on the assignment.

**TASK PERFORMANCE AIDS:**

HP Survey map of P36C Pump Room, Room number 54.

**SIMULATOR SETUP:**

N/A



INITIATING CUE: Determine the Stay time for you and the other WCO on the job. Also determine the stay time if the air in the pump room was contaminated with a level of 0.29 DAC (stochastic) assuming no respirators are used. **Provide answers with 3 significant figures (example 4.51 hours).**

CRITICAL ELEMENTS (c): 1, 2, and 3

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
C	1. Determine the HIGHEST general area dose rate in the area of the reduction gear assembly to be used from the survey map.	Examinee has determined the HIGHEST general area dose rate in the area of the reduction gear assembly to be used from the survey map of P36C pump room.  (80 mR/hr)	_____	_____	_____
C	2. Determine Stay time (to 3 significant figures) with no airborne contamination for both operators.  <b>Key:</b> Max dose at ANO1 is 2000 mR  AO1 has 1905mR, =>allowed dose 95mR AO2 has 1700mR, =>allowed dose 300mR  $\frac{95\text{mR}}{80\text{mR/hr}} = 1.18 \text{ hr}, \quad \frac{300\text{mR}}{80\text{mR/hr}} = 3.75 \text{ hr}$	Examinee has determined that the stay time for him/her is 1.18 hrs and the stay time for the other WCO is 3.75 hrs plus or minus 0.01 hours.	_____	_____	_____
C	3. Determine Stay time( to 3 significant figures) WITH airborne contamination for both operators.  1DAC = 2.5mR/hr * 0.29DAC = 0.725mR/hr Total rate = 80mR/hr + 0.725mR/hr = 80.725mR/hr  $\frac{95\text{mR}}{80.725\text{mR/hr}} = 1.17 \text{ hr}$  $\frac{300\text{mR}}{80.725\text{mR/hr}} = 3.71 \text{ hr}$	Examinee has determined that the stay time for him/her is 1.17hrs and the stay time for the other WCO is 3.71 hrs plus or minus 0.01 hours.	_____	_____	_____
<b>EXAMINER'S CUE: This concludes the JPM.</b>					

END

## EXAMINEE'S COPY

### INITIAL CONDITIONS:

You are an WCO with the plant at full power. A hot spot has developed on Makeup PUMP P36C. You and another WCO will be working in the vicinity of the reduction gear assembly in order to flush the lines and reduce the hot spot radiation field.

Using the supplied survey map, determine the individual stay times **for yourself AND the other WCO** without exceeding the annual administrative dose limit (Ignore dose received during transit). You have an accumulated annual Whole Body dose of 1905 mR (ANO records). The other WCO has an accumulated annual Whole Body dose of 1790 mR (ANO records). No additional dose has been received at any other site.

**Also**, calculate stay times if the air in the pump room was contaminated with a level of 0.29 DAC (stochastic) assuming no respirators are used.



Calculations should be based on ANO Unit 1 Administrative dose limits. **Provide answers with 3 significant figures (example 4.51 hours)**. Do not consider ALARA task requirements.

### INITIATING CUE:

Determine the Stay time **for yourself AND the other WCO** on the job. **Also** determine the stay time if the air in the pump room was contaminated with a level of 0.29 DAC (stochastic) assuming no respirators are used. **Provide answers with 3 significant figures (example 4.51 hours)**.

**Aux building**  
**posted: RM,RWPR**

335 posted RA



All Radiation values are in mrem/hour unless otherwise noted.  
 12.5 denotes gamma general area dose rates.  
 Smear contamination values are in DPM/100 Sqcm unless otherwise noted.  
 \* 12/13 Denotes Gamma Contact/Far reading (30 cm)  
 \* 12 Denotes contact dose rate (gamma) \* 12 B Denotes Beta Contact Dose Rate  
 Form to be retained for records

H. S. Denotes Hot Spot Readings  
 O Denotes smear location (100 sqcm.)  
☐ Denotes large area smear location

STUDENT Handout

Smear Data		Rx. % 100	
No.	Activity	Date	Time
1	20,000	01/12/2004	0000:00
2	30,000		
3	60,000		
4	10,000		

Dose Rate Inst. #1	HP-DR-170
Cal Due Date	12/31/2008
Dose Rate Inst. #2	RM-065
Cal Due Date	12/31/2008
Count Inst.	RO-705
Cal Due Date	12/31/2008
Bkg.	80 cpm D/C 10
Count Inst. #2	
Cal Due Date	12/31/2008
Bkg.	90 cpm D/C 10

Survey Frequency:	
Daily	
Bi-Weekly	
X Monthly	
Quarterly	
Job Coverage	
Other	

RWP #	4005/1
Surveyor:	John Public
RP Supervisor Review:	Imma N. Charge
DANI #	011256
Page 1 of	1

## A8. Emergency Procedures / Plan

N/S

K/A 2.4.41

Knowledge of the Emergency  
Action Level thresholds and  
classification.

A1JPM-SRO-EAL11

JOB PERFORMANCE MEASURE

Unit: 1 Rev # 2 Date: 7/03/2008

TUOI NUMBER: A1JPM-SRO-EAL11

System/Duty Area: Administrative Topic-Emergency Procedures/Plan

Task: Determine Emergency Action Level

JA# \_\_\_\_\_

KA Value RO 2.9 SRO 4.6 KA Reference 2.4.41

Approved For Administration To: RO ☐ SRO ☒

Task Location: Inside CR: ☒ Outside CR: ☐ Both: ☐

Suggested Testing Environment And Method (Perform Or Simulate): Simulate

Plant Simulator Perform Lab:  
Site: \_\_\_\_\_ : \_\_\_\_\_

Position Evaluated: RO: \_\_\_\_\_ SRO: X

Actual Testing Environment: Simulator: X Plant Site: \_\_\_\_\_ Lab \_\_\_\_\_

Testing Method: Simulate: \_\_\_\_\_ Perform: X

Approximate Completion Time In Minutes: 15 Minutes **TIME CRITICAL**

Reference(S) : 1903.010 Emergency Action Level Classification, 1903.011, Emergency Response Notifications

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

Signed \_\_\_\_\_ Date: \_\_\_\_\_

Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

**THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:**

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:**

Reactor power reduced to 60% to secure "B" RCP due to lower seal degradation.  
When "B" RCP was secured H2 bus tripped.  
ATC operator manually tripped the Reactor one minute after the Loss of the H2 bus.  
Reactor trip immediate actions were complete.  
Shift Engineer reports a 40 gpm leak into the Reactor building from "B" RCP seal.

**TASK STANDARD:**

1. The examinee correctly classifies this event as an **Alert** per 6.2 makes notifications to plant personnel per 1903.011M thru step 4.
2. **TIME CRITICAL MUST MAKE AN ALERT CALL 6.2 FINISH 1903.011M through step 6 WITHIN 20 MINUTES of START of JPM (5 minutes to recognize EAL entry and 15 minutes to make call and notifications.)**

**TASK PERFORMANCE AIDS:**

1903.010 Attachments 1 and 3, 1903.011 Attachment 2, and 1903.011M

**SIMULATOR SETUP:**

N/A

INITIATING CUE: For the given plant conditions, determine the applicable EAL classification and initiate notifications per the applicable Shift Manager Emergency Direction and Control Checklist in 1903.011 thru step 4.

CRITICAL ELEMENTS (c): 4, 5, and 6

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	1. Compare event conditions with the Index of EALs, Attachment 1 of 1903.010, Emergency Action Level Classification.	Turned to Attachment 1 of 1903.010, Index of EALs.	_____	_____	_____
	2. Turn to appropriate EAL and compare EAL criteria with event conditions.	Turned to a specific EAL in Safety System Function, Attachment 3 of 1903.010.	_____	_____	_____
	3. Declare the emergency classification.  TIME _____	Declared or stated the event is an ALERT per EAL 6.2, based on valid RPS trip set point was exceeded and RPS fails to initiate an automatic trip and manual trip was successful.	_____	_____	_____
NOTE; Examinee may mention he meets EAL 2.1 criteria due to RCS leakage which is a NUE put does not need to call this EAL Alert is a higher classification than NUE.					
C	4. Begin completion of form 1903.011M, Alert Emergency Direction and Control Checklist for Shift Manager.	Began completion of form 1903.011M Alert Emergency Direction and Control Checklist for Shift Manager.  Examinee fills in the data on items 1 and 2.	_____	_____	_____
C	5. Direct affected Unit Shift Engineer to activate CNS per Attachment 9.	Examinee simulates directing Unit 1 SE to activate CNS per Attachment 9 of 1903.011M, step 3.1.	_____	_____	_____
NOTE: Examiner should Role play as Unit 1 Shift Engineer, acknowledging the direction from SM to activate CNS.					
C	6. Direct the unaffected Unit Shift Engineer to perform notifications using form 1903.011-Y, Emergency Class Initial Notification Message.  TIME _____	<b>TIME CRITICAL WITHIN 15 MINUTES OF STUDENT REGONIZING EAL ENTRY</b> Examinee simulate directing Unit 2 SE to perform notifications using form 1903.011-Y, Emergency Class Initial Notification Message.	_____	_____	_____

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
NOTE: Examiner should Role play as Unit 2 Shift Engineer, acknowledging the direction from SM to perform notifications as directed.					
	7. Inform the Control Room Staff of the Emergency Class declaration.	Inform the Control Room Staff of the Emergency Class declaration			
<b>EXAMINER'S CUE: This concludes the JPM.</b>					

END



PROC./WORK PLAN NO. 1903.010	PROCEDURE/WORK PLAN TITLE: EMERGENCY ACTION LEVEL CLASSIFICATION	PAGE: 51 of 149 CHANGE: 040
---------------------------------	---	--------------------------------

ATTACHMENT 3  
UNIT 1  
SAFETY SYSTEM FUNCTION

6.2

CONDITION:

Reactor Protection System Failure to Complete an Automatic Trip

EMERGENCY CLASSIFICATION:

Alert

MODES 1-2

CRITERIA:

1. A valid RPS trip setpoint is exceeded on ANY TWO RPS channels and the RPS fails to initiate and complete an automatic trip that brings the reactor subcritical.
- AND
2. DSS trip or subsequent efforts to manually trip the Reactor from the Control Room and bring it subcritical are successful.

RELATED EALS:

	TAB
RPS Failure to Complete a Manual Trip	<u>6</u>
Core Melt	<u>1</u>
Core Damage Indicated with an ICC Condition	<u>1</u>
Loss of or Challenge to 3 Fission Product Barriers	<u>1</u>

- KEY -

PROC./WORK PLAN NO. <b>1903.010</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY ACTION LEVEL CLASSIFICATION</b>	PAGE: <b>30 of 149</b>  CHANGE: <b>040</b>
--	--	--

ATTACHMENT 3  
UNIT 1  
RCS LEAKAGE

2.1

CONDITION:

RCS Leakage greater than Technical Specification limits requiring a plant shutdown or cooldown

EMERGENCY CLASSIFICATION:

Notification of Unusual Event

MODES 1-4

CRITERIA:

**NOTE**

RCS leakage is defined as a loss of RCS inventory due to a leak in the RCS or a supporting system that is not or cannot be isolated within 10 minutes.

1. RCS leakage exceeds ANY of the following:
  - a. No pressure boundary LEAKAGE
  - b. 1 gpm unidentified LEAKAGE
  - c. 10 gpm identified LEAKAGE

AND
2. A plant shutdown or cooldown has commenced.

RELATED EALS:

TAB

RCS Leakage >Normal Makeup Capacity (50 gpm)  
TS LCOs  
OTSG Tube Leak

2  
6  
3

- /KEY -

# ALERT

This form is intended to be used by the person with Emergency Direction and Control when an Alert has been declared.

☒ 1. Alert declared: Unit 1 Time \_\_\_\_\_ Date \_\_\_\_\_

**\*\*EMERGENCY CLASSIFICATION ANNOUNCEMENT SHOULD BE MADE WITHIN 15 MINUTES OF THE DECLARATION\*\***

☒ 2. Conditions warranting declaration of an Alert:  
EAL No. 6.2 Description: Failure of RPS to complete an Automatic Trip

☐ 3. Notification Communicator

☒ 3.1 Single/Dual Unit Emergency

☒ 1. Activate CNS

IF CNS already activated for an Alert or higher emergency class,  
THEN go to step 2 below.

Direct one of the unit's Shift Engineers (SE of unit with ED&C preferred) to activate CNS in accordance with Attachment 9 of this procedure.

N/A ☒ Use Section 8 of Attachment 9 if ERO is at risk due to site conditions (e.g. security event, toxic gas release, major onsite fire, etc). ERO will respond to the Alternate EOF.

☒ Use Section 1 of Attachment 9 for normal ERO callout.

☒ 2. Direct one of the unit's Shift Engineers (SE from unit that does not have ED&C or unaffected unit is preferred) to perform notifications using Form 1903.011-Y, Emergency Class Initial Notification Message.

N/A ☐ 3.2 Additional Notification Communicator is Available

N/A ☐ 1. IF a Notification Communicator is available,  
THEN request the Notification Communicator to perform notifications in accordance with Form 1903.011-Y, Emergency Class Initial Notification Message.

☒ 4. Inform the Control Room staff of the Emergency Class declaration.

☒ 5. Inform both units' operators in the field to log onto the Emergency RWP.

- KEY -

FORM TITLE:

**ALERT EMERGENCY DIRECTION AND CONTROL CHECKLIST**

FORM NO.

**1903.011M**

REV.

**030**

- ☒ 6. Make the following announcement over the plant paging system (dial 197):

"Attention all personnel. Attention all personnel. An Alert Emergency Class has been declared on Unit 1 (One/Two). Emergency response personnel report to your designated assembly areas. All other personnel continue normal activities unless instructed otherwise."

☐ 6.1 Dial 197 and repeat the above announcement.

☐ 6.2 Make the above announcement over the EOF Public Address System (dial 199 and pause approximately 15 sec.)

- ☐ 7. IF on-site personnel hazards exits,  
(P-15456) THEN direct implementation of protective actions as necessary.

☐ 7.1 Refer to Form 1903.030C, "Localized Evacuation Checklist", to determine if a localized evacuation will be performed.

- ☐ 8. IF an approach route to the plant site should be avoided,  
THEN instruct Security to direct incoming traffic. (Examples of this include security situations in which onsite/offsite personnel are directed to the EOF, radiological releases that prohibit entry through the Primary Access Point.)

- ☐ 9. Direct Chemistry personnel (Initial Dose Assessor) to the Control Room to implement procedure 1904.002, "Offsite Dose Projection - RDACS Computer Method".

Performed by: \_\_\_\_\_

- KEY -

FORM TITLE: <b>ALERT EMERGENCY DIRECTION AND CONTROL CHECKLIST</b>	FORM NO. <b>1903.011M</b>	REV. <b>030</b>
---	------------------------------	--------------------

**EXAMINEE'S COPY**

**INITIAL CONDITIONS:**

Reactor power reduced to 60% to secure "B" RCP due to lower seal degradation.

When "B" RCP was secured H2 bus tripped.

ATC operator manually tripped the Reactor one minute after the Loss of the H2 bus.

Reactor trip immediate actions were complete.

Shift Engineer reports a 40 gpm leak into the Reactor building from "B" RCP seal.

**INITIATING CUE:**

For the given plant conditions, determine the applicable EAL classification and initiate notifications per the applicable Shift Manager Emergency Direction and Control Checklist in 1903.011 thru step 4.

Facility: <u>ANO-1</u>		Date of Examination: <u>9-8-2008</u>
Exam Level: RO <input checked="" type="checkbox"/> SRO-I <input type="checkbox"/> SRO-U <input type="checkbox"/>		Operating Test No.: <u>2008-1</u>
Control Room Systems® (8 for RO); (7 for SRO-I); (2 or 3 for SRO-U, including 1 ESF)		
System / JPM Title	Type Code*	Safety Function
C1. A1JPM-RO-HYD01, Place Hydrogen Recombiner M-55A in operation 028 A4.01 (RO 4.0/SRO 4.0)	D/EN/P/S	5 Containment Integrity
S1. A1JPM-RO-CRD03 Transfer a Group of Rods to the Auxiliary Power Supply 003 AA2.01 (RO 3.7/SRO 3.9)	A/D/S	1 Reactivity Control
S2. A1JPM-RO-MUP01 Isolate Letdown, Restore Makeup and Seal Injection 004 A4.06 (RO 3.6/SRO 3.1)	D/E/L/S	2 Reactor Coolant System Inventory Control
S3. A1JPM-RO-PZR05 CONTROL RCS PRESSURE RESPOND TO LOW RCS PRESSURE 010 A3.02 (RO 3.6/SRO 3.5)	N/A/S	3 Reactor Pressure Control
S4. A1JPM-RO-DHR03 Establish Decay Heat Removal Using P-34A 005 A4.01 (RO 3.6/SRO 3.4)	A/D/L/S	4 Heat Removal From Reactor Core (Primary)
S5. A1JPM-RO-EDG04 Emergency Diesel Generator (EDG) System 064 A4.07 (RO 3.4/SRO 3.4)	A/D/EN/S	6 Electrical
S6. A1-JPM-RO-RPS05 Place Channel "A" in a Tripped Condition BW E02.EA1.1 (RO 4.0/SRO 3.6)	D/E/S	7 Instrumentation

S7.	A1-JPM-RO-SW003 Service Water and Auxiliary Cooling Water System 076 A2.01 (RO 3.5/SRO 3.7)	A/D/E/S	8 Plant Service Systems
In-Plant Systems <sup>@</sup> (3 for RO); (3 for SRO-I); (3 or 2 for SRO-U)			
P1.	A1JPM-RO-EFW03 Relieve steam binding of an Emergency Feedwater Pump 061 K5.05 (RO 2.7/SRO 3.2)	D/E/R/EN	4 Heat Removal From Reactor Core (Secondary)
P2.	A1JPM-RO-RPS06 Remove Power from CRD System Due to "D" RPS channel trip relay failure. 012 A2.06 (RO 4.4/SRO 4.7)	N	7 Instrumentation
P3.	ANO-1-JPM-RO-GRW01, Waste Gas Decay Tank release 071 A4.26 (RO 3.1/SRO 3.9)	D/P/R	9 Radioactivity Release
<sup>@</sup> All RO and SRO-I control room (and in-plant) systems must be different and serve different safety functions; all 5 SRO-U systems must serve different safety functions; in-plant systems and functions may overlap those tested in the control room.			
* Type Codes		Criteria for RO / SRO-I / SRO-U	
(A)lternate path		4-6 / 4-6 / 2-3	
(C)ontrol room		$\leq 9 / \leq 8 / \leq 4$	
(D)irect from bank		$\geq 1 / \geq 1 / \geq 1$	
(E)mergency or abnormal in-plant		$\geq 1 / \geq 1 / \geq 1$	
(EN)gineered safety feature		- / - / $\geq 1$ (control room system)	
(L)ow-Power / Shutdown		$\geq 1 / \geq 1 / \geq 1$	
(N)ew or (M)odified from bank including 1(A)		$\geq 2 / \geq 2 / \geq 1$	
(P)revious 2 exams		$\leq 3 / \leq 3 / \leq 2$ (randomly selected)	
(R)CA		$\geq 1 / \geq 1 / \geq 1$	
(S)imulator			

Facility: ANO Unit 1Date of Examination: 9/5/2008Exam Level: RO ☐ SRO-I ☐ SRO-U ☒Operating Test No.: 2008-1Control Room Systems<sup>@</sup> (8 for RO); (7 for SRO-I); (2 or 3 for SRO-U, including 1 ESF)

System / JPM Title	Type Code*	Safety Function
S3. A1JPM-RO-PZR05 CONTROL RCS PRESSURE IN RESPOND TO LOW RCS PRESSURE 010 A3.02 (RO 3.6/SRO 3.5)	N/A/S	3 Reactor Pressure Control
S4. A1JPM-RO-DHR03 Establish Decay Heat Removal Using P-34A 005 A4.01 (RO 3.6/SRO 3.4)	A/D/L/S	4 Heat Removal From Reactor Core (Primary)
S5. A1JPM-RO-EDG04 Emergency Diesel Generator (EDG) System 064 A4.07 (RO 3.4/SRO 3.4)	A/D/EN/S	6 Electrical

In-Plant Systems<sup>@</sup> (3 for RO); (3 for SRO-I); (3 or 2 for SRO-U)

P1. A1JPM-RO-EFW03 Relieve steam binding of an Emergency Feedwater Pump 061 K5.05 (RO 2.7/SRO 3.2)	D/E/R/EN	4 Heat Removal From Reactor Core (Secondary)
P2. A1JPM-RO-RPS06 Remove Power from CRD System Due to "D" RPS channel trip relay failure. 012 A2.06 (RO 4.4/SRO 4.7)	N	7 Instrumentation

@ All RO and SRO-I control room (and in-plant) systems must be different and serve different safety functions; all 5 SRO-U systems must serve different safety functions; in-plant systems and functions may overlap those tested in the control room.

\* Type Codes

Criteria for RO / SRO-I / SRO-U



---

# C1. Containment Integrity

D/EN/P/S

K/A 028 A4.01

Place Hydrogen Recombiner M-55A in operation.

A1JPM-RO-HYD01

## JOB PERFORMANCE MEASURE

UNIT: 1 REV # 5 DATE: \_\_\_\_\_TUOI NUMBER: ANO-1-JPM-RO-HYD01SYSTEM/DUTY AREA: HYDROGEN RECOMBINER AND PURGE CONTROL SYSTEMTASK: PLACE HYDROGEN RECOMBINER M55A IN OPERATIONJTA#: 10285120101KA VALUE RO: 4.0 SRO: 4.0 KA REFERENCE: 028 A4.01APPROVED FOR ADMINISTRATION TO: RO: X SRO: XTASK LOCATION: INSIDE CR: X OUTSIDE CR: \_\_\_\_\_ BOTH: \_\_\_\_\_

SUGGESTED TESTING ENVIRONMENT AND METHOD (PERFORM OR SIMULATE):

PLANT SITE: \_\_\_\_\_ SIMULATOR: PERFORM LAB: \_\_\_\_\_

POSITION EVALUATED: RO: \_\_\_\_\_ SRO: \_\_\_\_\_

ACTUAL TESTING ENVIRONMENT: SIMULATOR: \_\_\_\_\_ PLANT SITE: \_\_\_\_\_ LAB: \_\_\_\_\_

TESTING METHOD: SIMULATE: \_\_\_\_\_ PERFORM: \_\_\_\_\_

APPROXIMATE COMPLETION TIME IN MINUTES: 15 MINUTESREFERENCE(S): 1104.031 change 019EXAMINEE'S NAME: \_\_\_\_\_ SSN      -      -     

EVALUATOR'S NAME: \_\_\_\_\_

THE EXAMINEE'S PERFORMANCE WAS EVALUATED AGAINST THE STANDARDS  
CONTAINED IN THIS JPM AND IS DETERMINED TO BE:

SATISFACTORY: \_\_\_\_\_ UNSATISFACTORY: \_\_\_\_\_

PERFORMANCE CHECKLIST COMMENTS:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_ Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time

SIGNED \_\_\_\_\_ DATE: \_\_\_\_\_  
SIGNATURE INDICATES THIS JPM HAS BEEN COMPARED TO ITS APPLICABLE PROCEDURE BY A  
QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.

TUOI NUMBER: ANO-1-JPM-RO-HYD01

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

JPM INITIAL TASK CONDITIONS: A LOCA has occurred. Containment hydrogen concentra-  
tion is 2.0%. Both hydrogen recombiners are shutdown. Containment pressure is  
20.4 psia. Pre-LOCA containment temperature was 120°F.

TASK STANDARD: Hydrogen recombiner M55A in operation at power setting of 57  
KW to 59 KW on JI-1000.

TASK PERFORMANCE AIDS: 1104.031 sections 8.1 , 8.2, and Attachment B

TUOI NUMBER: ANO-1-JPM-RO-HYD01

INITIATING CUE:

The SS/CRS directs that you place both hydrogen Recombiners (M55A/B) in standby and then place M55A in operation at the power required for containment pressure at 20.4 psia and pre-loca containment temperature at 120°F.

(C)	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UNSA T
	1. Verify power adjust potentiometer for M-55A is set at zero.  <u>POSITIVE CUE:</u> Power adjust potentiometer for M55A is set at zero on C26.	Verified power adjust potentiometer set to zero on C26 (if not already at zero used knurled knob on power adjust potentiometers on C26 and turned to the left and set at zero using HS-7472).	_____	_____	_____
(C)	2. Turn hydrogen Recombiner M55A on.  <u>POSITIVE CUE:</u> M55A red light ON.  <u>NEGATIVE CUE:</u> M55A green light ON.	Turned on hydrogen Recombiner M55A using HS-7470 on C26.	_____	_____	_____
	3. Select thermocouple #1, 2 or 3 to input to Recombiner temperature indicator TI-2300.  <u>POSITIVE CUE:</u> thermocouple #1, 2 or 3 selected as desired to input to TI-2300.	Thermocouple #1, 2 or 3 selected to input to TI-2300 using hand switch HS-7474 on C26.	_____	_____	_____
	4. Increase power to ~5 KW  <u>POSITIVE CUE:</u> Power on JI-1000 indicates 5KW.	Slowly adjusted potentiometer clockwise until power on JI-1000 on C26 indicated ~5 KW. without overshooting target setting	_____	_____	_____

TUOI NUMBER: ANO-1-JPM-RO-HYD01

(C)	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UNSAT
	5. Slowly increase power to 10 KW. <u>POSITIVE CUE:</u> Power is at 10 KW on JI-1000.	Increased power to ~10 KW using power adjust potentiometer on C26. without overshooting target setting	_____	_____	_____
	6. Record Initial time at 10 KW.	Records initial time at 10 KW	_____	_____	_____
	7. Verify power adjust potentiometer for M-55B is set at zero. <u>POSITIVE CUE:</u> Power adjust potentiometer for M55B is set at zero on C26.	Verified power adjust potentiometer set to zero on C26 (if not already at zero used knurled knob on power adjust potentiometer on C26 and turned to the left and set at zero using HS-7473).	_____	_____	_____
(C)	8. Turn hydrogen Recombiner M55B on. <u>POSITIVE CUE:</u> M55B red lights ON. <u>NEGATIVE CUE:</u> M55B green lights ON.	Turned on hydrogen Recombiner M55B using HS-7471 on C26.	_____	_____	_____
	9. Select thermocouple #1, 2 or 3 to input to Recombiner temperature indicator TI-2301.  POSITIVE CUE: thermocouple #1, 2 or 3 selected as desired to input to TI-2301.	Thermocouple #1, 2 or 3 selected to input to TI-2301 using hand switch HS-7475 on C26.	_____	_____	_____
	10. Increase power to ~5 KW. <u>POSITIVE CUE:</u> Power on JI-1001 indicates 5KW.	Slowly adjusted potentiometer clockwise until power on JI-1001 on C26 indicated ~5 KW.	_____	_____	_____
	11. Slowly increase power to 10 KW. <u>POSITIVE CUE:</u> Power is at 10 KW on JI-1000.	Increased power to ~10 KW using power adjust potentiometer on C26. without overshooting target setting	_____	_____	_____
	12. Record Initial time at 10 KW.	Records initial time at 10 KW	_____	_____	_____

<p>NOTE: Evaluator inform examinee to disregard taking data every 30 minutes on Attachment D.</p>					
	<p>13. Verify M55A has been at 10 KW for at least 10 minutes.</p> <p><u>POSITIVE CUE:</u> Ten minutes have elapsed.</p>	<p>Verify M55A is at ~10 KW for at least 10 minutes by comparing current time to time recorded in step 8.1.1 E 1.</p>			
	<p>14. Slowly increase power to 20 KW on M55A and hold for 5 minutes.</p> <p><u>POSITIVE CUE:</u> Power at 20 KW on JI-1000.</p> <p>NOTE: inform examinee that five minutes have elapsed after 1 minute at 20 KW.</p>	<p>Increased power on M55A to ~20 KW using power adjust potentiometer on C26. without overshooting target setting</p>	—	—	—
(C)	<p>15. Determine power required from Attachment B page 1 based on containment pressure.</p>	<p>Determined Recombiner power using Attachment B page 1 to be between 57 and 59 KW.</p>	—	—	—
(C)	<p>16. Slowly increase power to 57-59 KW range.</p> <p><u>POSITIVE CUE:</u> Hydrogen concentration decreasing on QI-7457 and M55A maintaining power at determined value.</p> <p><u>NEGATIVE CUE:</u> Hydrogen concentration increasing on QI-7457.</p>	<p>Power increased to 57 to 59 range using power adjust potentiometer on C26.</p>	—	—	—

END

JPM ID: ANO-1-JPM-RO-HYD01

## INITIAL CONDITIONS:

A LOCA has occurred.  
Containment hydrogen concentration is 2.0%.  
Both hydrogen recombiners are shutdown.  
Containment pressure is 20.4 psia.  
Pre-LOCA containment temperature was 120°F.

## INITIATING CUE:

The SS/CRS directs that you place both hydrogen recombiners (M55A/B) in standby and then place M55A in operation per 1104.031, "Containment Hydrogen Control" steps 8.1 through 8.2 E.

ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE

TITLE: <b>CONTAINMENT HYDROGEN CONTROL</b>  SET #	DOCUMENT NO. <b>1104.031</b>	CHANGE NO. <b>019</b>
	WORK PLAN EXP. DATE <b>N/A</b>	TC EXP. DATE <b>N/A</b>
	SAFETY-RELATED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	IPTE <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
	TEMP ALT <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	LEVEL OF USE <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> REFERENCE <input type="checkbox"/> INFORMATIONAL
	PROGRAMMATIC EXCLUSION PER EN-LI-100 <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	

When you see these **TRAPS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Get these **TOOLS**

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

VERIFIED BY	DATE	TIME
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

FORM TITLE: <b>VERIFICATION COVER SHEET</b>	FORM NO. <b>1000.006A</b>	CHANGE NO. <b>053</b>
--	------------------------------	--------------------------



PROC./WORK PLAN NO. <b>1104.031</b>	PROCEDURE/WORK PLAN TITLE: <b>CONTAINMENT HYDROGEN CONTROL</b>	PAGE: <b>8 of 58</b> CHANGE: <b>019</b>
--	---	--

**CAUTION**

Hydrogen recombiner, M55A or M55B, should be placed in operation following a LOCA as soon as time permits and must be in operation before hydrogen concentration reaches 3.0% as indicated on the highest reading H<sub>2</sub> analyzer.

8.0 Placing Hydrogen Recombiner (M55A or M55B) in Operation

**NOTE**

- Both M55A and M55B are placed in standby, then either may be placed in operation.
- The term "slowly" used in this section means raising potentiometer settings slowly enough to witness KW rise without overshooting the target setting.

8.1 Place both M55A and M55B in standby as follows.

8.1.1 Place M55A in standby by performing the following:

- A. Verify Power Adjust Potentiometer is set at zero for M55A.
- B. Start M55A by placing HS-7470 in ON.
- C. Select thermocouple #1, 2, or 3 (HS-7474) to input to M55A Temperature (TI-2300).
- D. Slowly turn power adjust potentiometers clockwise to raise power to 5 KW as indicated on M55A Power (JI-1000).
- E. Slowly raise power to 10 KW.
  1. Record initial time at 10 KW: \_\_\_\_\_
  2. Maintain 10 KW output for standby service.

PROC./WORK PLAN NO. <b>1104.031</b>	PROCEDURE/WORK PLAN TITLE: <b>CONTAINMENT HYDROGEN CONTROL</b>	PAGE: <b>9 of 58</b> CHANGE: <b>019</b>
--	---	--

- 8.1.2 Place M55B in standby by performing the following:
- A. Verify Power Adjust Potentiometer is set at zero for M55B.
  - B. Start M55B by placing HS-7471 in ON.
  - C. Select thermocouple #1, 2, or 3 (HS-7475) to input to M55B Temperature (TI-2301).
  - D. Slowly turn power adjust potentiometers clockwise to raise power to 5 KW as indicated on M55B Power (JI-1001).
  - E. Slowly raise power to 10 KW.
    1. Record initial time at 10 KW: \_\_\_\_\_
    2. Maintain 10 KW output for standby service.

**CAUTION**

Hydrogen Recombiner, M55A or M55B, should be placed in operation following a LOCA as soon as time permits and must be in operation before hydrogen concentration reaches 3.0% as indicated on the highest reading H<sub>2</sub> analyzer.

- 8.2 Place recombiners in operation as follows:

- 8.2.1 Place M55A in-service by performing the following:
- A. During heatup, monitor and record all three thermocouple temperatures every 30 minutes on Attachment D.
  - B. Verify M55A has been at 10 KW for at least 10 minutes.
  - C. Slowly raise power to 20 KW AND hold for 5 minutes.
  - D. Determine power required from Recombiner Power (M-55A) Versus Containment Pressure (Attachment B of this procedure) based on containment pressure.
    - 1) KW setting \_\_\_\_\_

**CAUTION**

Recombiner power >75 KW and temperature >1450°F may cause heater failure.

- 2) Slowly raise power to the value determined above.

PROC./WORK PLAN NO. 1104.031	PROCEDURE/WORK PLAN TITLE: CONTAINMENT HYDROGEN CONTROL	PAGE: 10 of 58 CHANGE: 019
---------------------------------	--	-------------------------------

- E. Verify proper recombiner operation by observing the following:

**NOTE**

- Hydrogen concentration reduction is the long-term, primary method of verification.
- H<sub>2</sub> concentration reduction shall be used regardless of recombiner power or temperature indication as the verification of proper recombiner operation.

- Hydrogen concentration stable or dropping at % Hydrogen (QI-7457 and QI-7459).
- Recombiner maintaining power at value determined

**NOTE**

- Thermocouples are non-Q and will not be reliable indicators in a post-LOCA environment.
- Recombiner temperature can aid in trending recombiner operation. The following steps are provided as guidelines.
- Recombiner temperature may be plotted on Attachment C for verifying thermocouple operation and estimating time when recombination temperature will be reached.

- F. Establish validity of temperature indication by comparing  $\Delta T$  between thermocouples.

1. IF all three thermocouples fall within a 60°F band,  
THEN average the three temperatures.
2. IF no two thermocouples are within 60°F of each other,  
THEN thermocouples should be considered inaccurate.
3. IF difference of the three temperatures >60°F,  
AND two temperatures are within 60°F,  
THEN average the closest two.


- G. Monitor for indication that recombiner operating temperature of 1225°F has been reached.

PROC./WORK PLAN NO. 1104.031	PROCEDURE/WORK PLAN TITLE: CONTAINMENT HYDROGEN CONTROL	PAGE: 21 of 58 CHANGE: 019
---------------------------------	--	-------------------------------

ATTACHMENT B

Page 1 of 2

**RECOMBINER POWER (M-55A)  
VERSUS  
CONTAINMENT PRESSURE**



Note: Use pre- LOCA average Reactor Building Temperature from SPDS (TAVRB1) from history file if available. Otherwise use logs.

---

# S1. Reactivity Control

A/D/S

K/A 003 AA2.01

Transfer a Group of Rods to the  
Auxiliary Power Supply.

A1JPM-RO-CRD003

## JOB PERFORMANCE MEASURE

Unit: 1 Rev # 10 Date: \_\_\_\_\_JPM ID: A1JPM-RO-CRD03System/Duty Area: Control Rod Drive SystemTask: Transfer a Group of Rods to the Auxiliary Power Supply  
ANO1-RO-CRD-NORM-12, ANO1-RO-AOP-OFFNORM-15, ANO1-RO-EOP-EMERG-4, ANO1-SRO-EOP-  
JTA# EMERG-2KA Value RO 3.7 SRO 3.9 KA Reference: 003 AA2.01Approved For Administration To: RO X SRO XTask Location: Inside CR X Outside CR \_\_\_\_\_ Both \_\_\_\_\_

Suggested Testing Environment and Method (Perform or Simulate ):

Plant Site: \_\_\_\_\_ Simulator: Perform Lab: \_\_\_\_\_

Position Evaluated: RO: \_\_\_\_\_ SRO: \_\_\_\_\_

Actual Testing Environment: Plant Site \_\_\_\_\_ Simulator \_\_\_\_\_ Lab \_\_\_\_\_

Testing Method: Perform \_\_\_\_\_ Simulate \_\_\_\_\_

Approximate Completion Time in Minutes: 10 MinutesReference(s): 1105.009 Section 8.0 Transfer to Auxiliary Supply, 1203.003 CRD Malfunction , 1202.001 Reactor Trip

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

\*Signed \_\_\_\_\_ Date \_\_\_\_\_

\*Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

JPM ID: A1JPM-RO-CRD03

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

JPM INITIAL TASK CONDITIONS:

The ICS is in manual per 1105.004 Section 7.0 "Transferring ICS Control Stations to HAND."

SIMULATOR SETUP:

- Reactor Power any power level > 20%
- ICS in HAND per 1105.004 Section 7.0.
- Triggers may be used. Intent is to have the simulator ready to drop three control rods in Group 4 when the Manual Transfer switch is depressed at step 8.9 of 1105.009.
- Use malfunctions: RD280, RD302 and RD306

TASK STANDARD:

This is an alternate success path JPM. Reactor is manually tripped and immediate actions performed from memory.

TASK PERFORMANCE AIDS:

1105.009 Section 8.0.

JPM ID: A1JPM-RO-CRD03

INITIATING CUE: The CRS/SM directs you to transfer Group 4 rods to the Auxiliary Power Supply in accordance with 1105.009 Section 8.0, for Rod exercise.

CRITICAL ELEMENTS (C): 2, 3, 5, 6, 7, 8, 9, 11

(C)	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	1. Verify transfer reset lamp is ON and TR CF lamp is OFF.  <u>POSITIVE CUE:</u> Transfer reset lamp is ON and TR CF lamp is OFF.	On CRD Diamond Panel, condition of both lights was checked. Transfer reset lamp was ON and TR CF lamp was OFF.	—	—	—
C	2. Place Group select switch to Group 4.  <u>POSITIVE CUE:</u> Group select switch is in Group 4 position.	On CRD Diamond Panel, Group Select Switch was placed in Group 4 position.	—	—	—
C	3. Set Single Select Switch to ALL.  <u>POSITIVE CUE:</u> Single Select Switch is in ALL position.	On CRD Diamond Panel, Single Select Switch was selected to ALL.	—	—	—
	4. Set Auto/Manual Switch to Manual.  <u>POSITIVE CUE:</u> Manual lamp is ON.	On CRD Diamond Panel, Manual mode verified. MANUAL lamp verified ON.	—	—	—
C	5. Set SEQ.-SEQ OR. switch to SEQ. OR position.  <u>POSITIVE CUE:</u> SEQ OR backlight lamp is ON.	On CRD Diamond Panel, SEQ.-SEQ OR. switch was selected to SEQ. OR position.	—	—	—
C	6. Set Group/Auxiliary Switch to Auxiliary.  <u>POSITIVE CUE:</u> AUX PB backlight is verified on and Control On lamp is lighted for Group 4.	On CRD Diamond Panel, Group/AUX PB was selected to AUX.	—	—	—
(C)	7. Set Speed Select Switch to JOG.  <u>POSITIVE CUE:</u> SY backlight is ON.	On CRD Diamond Panel, Speed Select Switch was selected to JOG position.	—	—	—
C	8. Set Clamp/Clamp Release Switch to CLAMP.  <u>POSITIVE CUE:</u> CLAMP CONFIRM lamp on.	On CRD Diamond Panel, selected Clamp/Clamp Release Switch to CLAMP.	—	—	—

Note to Simulator Operator:

Activate Dropped Rod malfunctions when Group 4 control on indicating lights on PI panel come on.



(C)	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
(C)	<p>9. Press Manual Transfer Switch.</p> <p><u>POSITIVE CUE:</u></p> <p>Manual Transfer Switch is depressed. TR CF lamp comes on, and Group 4 Control-on White lights on the CRD Position Indicating Panel on.</p>	On CRD Diamond Panel, manual transfer PB was depressed.	—	—	—
<p>Note to evaluator:</p> <p>If simulating task, inform examinee that Group 4 rods #3, #5, and #7 rod bottom (green) lights are on.</p>					
	<p>10. Identify dropped rods.</p> <p><u>FAULTED CUE:</u></p> <p>Rod bottom lights ON for Group 4 Rods #3, #5, and #7.</p>	Identified dropped rods by observing the rod bottom lights on C-13 PI panel.	—	—	—
C	<p>11. Perform Rx Trip immediate actions.</p> <ul style="list-style-type: none"> <li>Manually Trip Rx.               <ul style="list-style-type: none"> <li>A. Verify all rods inserted <u>AND</u> Reactor power dropping.</li> </ul> </li> <li>Manually trip Turbine.               <ul style="list-style-type: none"> <li>A. Verify Turbine throttle and governor valves closed.</li> </ul> </li> <li>Check adequate SCM.</li> </ul> <p><u>POSITIVE CUE:</u></p> <ul style="list-style-type: none"> <li>All rods inserted AND reactor power is dropping.</li> <li>Turbine throttle and governor valves are closed.</li> <li>SCM is adequate at 50°F and rising.</li> </ul> <p><u>NEGATIVE CUE:</u></p> <p>Power stabilizes at ~80% if no manual runback or power lowering as operator manually runs plant back.</p>	<p>Tripped the reactor by depressing the reactor trip pushbutton.</p> <ul style="list-style-type: none"> <li>Verified all rods inserted <u>AND</u> Reactor power dropping.</li> </ul> <p>Depressed the Turbine manual trip pushbutton.</p> <ul style="list-style-type: none"> <li>Verified Turbine throttle and governor valves closed.</li> <li>Checked SCM adequate.</li> </ul>	—	—	—
<p>EXAMINER NOTE:</p> <p>When step 3 of 1202.001 (immediate actions) is complete, inform the examinee the JPM is complete.</p>					

END

JPM ID: A1JPM-RO-CRD03

## **INITIAL CONDITIONS:**

**The ICS is in manual per 1105.004 Section 7.0 “Transferring ICS Control Stations to HAND.”**

## **INITIATING CUE:**

**The CRS/SM directs you to transfer Group 4 rods to the Auxiliary Power Supply in accordance with 1105.009 Section 8.0, for Rod exercise.**

**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

**TITLE: CRD SYSTEM OPERATING PROCEDURE**

**DOCUMENT NO.  
1105.009**

**CHANGE NO.  
026**

**WORK PLAN EXP. DATE  
N/A**

**TC EXP. DATE  
N/A**

**SET #**

**SAFETY-RELATED  
☒ YES ☐ NO**

**IPTE  
☒ YES ☐ NO**

**TEMP ALT  
☐ YES ☒ NO**

**LEVEL OF USE  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL**

**PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO**

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.  
1000.006A**

**CHANGE NO.  
053**

PROC./WORK PLAN NO. <b>1105.009</b>	PROCEDURE/WORK PLAN TITLE: <b>CRD SYSTEM OPERATING PROCEDURE</b>	PAGE: <b>27 of 91</b> CHANGE: <b>026</b>
--	---	---

## 8.0 Transfer to Auxiliary Supply

### **CAUTION**

For Safety Group rod insertion >1.5% (4 second insertion) below its out limit, with the Reactor critical, enter applicable TS 3.1.5 Condition A or B. This is not applicable for physics tests or rod exercise surveillances.

### **NOTE**

- Active fuel is 2 3/8" (~1.7%) below a fully withdrawn control rod.
- TR CF lamp must be off and GROUP lamp on before a transfer reset can be accomplished.
- TR CF lamp on indicates one or more CRD on the AUX bus.
- For information or troubleshooting purposes, the Description section of this procedure contains the expected light indications to be received for given switch/pushbutton manipulations.
- Diamond panel operations are actual or potential reactivity manipulations and require Licensed Operator peer check.

#### 8.1 Verify the following:

- TRANS RESET lamp on
- TR CF lamp off

#### 8.2 Set GROUP SELECT SWITCH to desired Group 1-8.

#### 8.3 Set SINGLE SELECT SWITCH to desired CRDM: 1-12 or ALL.

#### 8.4 Set AUTO-MANUAL switch to MANUAL.

#### 8.5 Set SEQ-SEQ OR switch to SEQ OR.

#### 8.6 Set GROUP-AUXIL switch to AUXIL.

#### 8.7 Set SPEED SELECTOR switch to JOG.

#### 8.7.1 IF SY lamp energizes and de-energizes, THEN set SPEED SELECTOR switch to RUN.

A. Notify CRS/SM.

B. Contact I&C and SYE for assistance.

#### 8.8 Set CLAMP-CLAMP REL switch to CLAMP.

#### 8.9 Press MAN TRANS switch.

#### 8.10 Set CLAMP-CLAMP REL switch to CLAMP REL.

PROC./WORK PLAN NO. 1105.009	PROCEDURE/WORK PLAN TITLE: CRD SYSTEM OPERATING PROCEDURE	PAGE: 28 of 91 CHANGE: 026
---------------------------------	--	-------------------------------

**NOTE**

- If any portion of a group is transferred to the Aux Supply, only those rods transferred will respond to a command to move. All rods associated with Group 8 will move if commanded, regardless of how many rods are transferred to the Aux Supply.
- With any group transferred to the Aux Supply, control rods may be returned to automatic and that group will function normally.

8.11 Set GROUP-AUXIL switch to GROUP.

8.12 IF movement at RUN speed is desired,  
THEN set speed switch to RUN.

**NOTE**

- For information or troubleshooting purposes, the Description section of this procedure contains the expected light indications to be received for given switch/pushbutton manipulations.
- Diamond panel operations are actual or potential reactivity manipulations and require Licensed Operator peer check.

9.0 Transfer from Auxiliary Supply

**NOTE**

If a CRDM is selected that is NOT already on auxiliary supply, it will be transferred to auxiliary supply. PI Panel CONTROL ON lamp will be on if CRDM is transferred to auxiliary supply.

9.1 Set GROUP SELECT SWITCH to group with CRDM(s) on auxiliary supply.

9.2 Set SINGLE SELECT SWITCH to desired CRDM: 1-12 or ALL.

9.3 Set AUTO-MANUAL switch to MANUAL.

9.4 Set SEQ/SEQ OR switch to SEQ OR.

9.5 Set GROUP/AUXIL switch to AUXIL.

9.6 Set SPEED SELECTOR switch to JOG.

9.6.1 IF SY lamp energizes and de-energizes,  
THEN set SPEED SELECTOR switch to RUN.

- Notify CRS/SM.
- Refer to TS for operability.
- Contact I&C and SYE for assistance.

9.7 Set CLAMP-CLAMP REL switch to CLAMP.

9.8 Press MAN TRANS switch and release.

9.9 Set CLAMP-CLAMP REL switch to CLAMP REL.

---

## S2. Reactor Coolant System Inventory Control

D/E/L/S

K/A 004 A4.06

Isolate Letdown, Restore Makeup  
and Seal Injection.

A1JPM-RO-MUP01

JOB PERFORMANCE MEASURE

Unit: 1 Rev # 11 Date: \_\_\_\_\_

JPM ID: A1JPM-RO-MUP01

System/Duty Area: Makeup and Purification

Task: Isolate Letdown, Restore Makeup and Seal Injection

JTA# ANO1-RO-EOP-EMERG-55

KA Value RO 3.6 SRO 3.1 KA Reference: 004 A4.06

Approved For Administration To: RO X SRO X

Task Location: Inside CR X Outside CR \_\_\_\_\_ Both \_\_\_\_\_

Suggested Testing Environment and Method (Perform or Simulate ):

Plant Site: \_\_\_\_\_ Simulator: Perform Lab: \_\_\_\_\_

Position Evaluated: RO: \_\_\_\_\_ SRO: \_\_\_\_\_

Actual Testing Environment: Plant Site \_\_\_\_\_ Simulator \_\_\_\_\_ Lab \_\_\_\_\_

Testing Method: Perform \_\_\_\_\_ Simulate \_\_\_\_\_

Approximate Completion Time in Minutes: 15 Minutes

Reference(s): 1202.001 Reactor Trip (step 9) and 1202.012 RT-1 Restore normal Makeup and Seal Injection

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

\*Signed \_\_\_\_\_ Date \_\_\_\_\_

\*Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

JPM ID: A1JPM-RO-MUP01

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

JPM INITIAL TASK CONDITIONS:

The reactor has just tripped.

NOTE: The examinee is to check the operating HPI pump supplying normal Makeup and Seal Injection post reactor trip. The examinee will find that the operating HPI pump is off. The examinee will then have to perform the contingencies of 1202.001 Step 9.

SIMULATOR SETUP: Trip the reactor from any at power IC and then turn off the P-36A aligned as the running "OP" HPI pump.

TASK STANDARD:

P-36A HPI pump running with seal injection and normal makeup re-established per RT-1.

TASK PERFORMANCE AIDS:

Copy of 1202.001 step 9 (Check OP HPI pump supplying normal Makeup and Seal Injection) and 1202.012 RT-1 (Restore normal Makeup and Seal Injection).



JPM ID: A1JPM-RO-MUP01

INITIATING CUE: The CRS/SM directs you to perform step 9 of the Reactor Trip procedure. The Operating HPI pump will be restarted

Examiner Cue: Only provide the applicant the 1201.001 procedure

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
<b>INSTRUCTOR NOTE:</b>					
	1. Check OP HPI pump supplying normal Makeup and Seal Injection.  <u>POSITIVE CUE:</u> OP HPI Pump is OFF.	Identified that the Operating HPI pump is OFF.	—	—	—
C	2. Isolate Letdown <u>POSITIVE CUE:</u> CV-1221 green light only ON <u>or</u> CV-1214 and CV1216 green lights only ON.	Isolated letdown by closing CV-1221 (Letdown Coolers Outlet) using handswitch on C16 <u>or</u> by closing CV-1214 and CV-1216 using handswitches on C18 (Letdown Cooler Outlet valves).	—	—	—
INSTRUCTOR NOTE: The following steps are performed per Repetitive Task 1					
C	3. Close RC Pump Seals Total INJ Flow control valve (CV-1207).  <u>POSITIVE CUE:</u> CV-1207 indicates closed.	Placed in HAND by depressing the white pushbutton on C04 and closed CV-1207. Observed position indicator reads zero.	—	—	—
C	4. Close Pressurizer Level Control valve (CV-1235).  <u>POSITIVE CUE:</u> CV-1235 indicates closed.	Placed in HAND by depressing the white pushbutton on C04 and closed CV-1235. Observed valve demand reads zero.	—	—	—
	5. Verify RCP Seal INJ Block CV-1206 closed.  <u>POSITIVE CUE:</u> Green light only ON.  <u>NEGATIVE CUE:</u> Red light ON.	On C04, verified CV-1206 closed.	—	—	—
	6. Verify RCS Makeup Block valves CV-1233 and CV-1234 open.  <u>POSITIVE CUE:</u> CV-1233 and CV-1234 red lights ON, green lights OFF.	On C16 and C18 verified CV-1233 and CV-1234 open.	—	—	—

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	<p>7. Verify <u>both</u> HPI RECIRC valves CV-1300 and 1301 open <u>or</u> fully open CV-1235.</p> <p><u>POSITIVE CUE:</u> CV-1300 and CV-1301 red lights ON, green lights OFF.</p>	On C16 and C18, verified CV-1300 and CV-1301 are open (also acceptable if fully opened CV-1235 instead).	—	—	—
C	<p>8. Start AUX Lube Oil Pump for OP HPI pump (P-64A, B or C).</p> <p><u>POSITIVE CUE:</u> Red light ON.</p> <p><u>NEGATIVE CUE:</u> Green light ON.</p>	Started AUX Lube Oil Pump for the OP HPI Pump (P64A, B or C) using handswitch on C16 or C18. Observed red light ON above handswitch.	—	—	—
C	<p>9. Start OP HPI Pump (P36A, B or C).</p> <p><u>POSITIVE CUE:</u> Red light ON.</p> <p><u>NEGATIVE CUE:</u> Green light ON.</p>	Started OP HPI Pump (P36A, B, or C) using handswitch on C16 or C18. Observed red light ON above handswitch	—	—	—
	<p>10. Stop AUX Lube Oil Pump for the OP HPI Pump just started (P-64A, B or C).</p> <p><u>POSITIVE CUE:</u> Green light ON.</p>	Stopped AUX Lube Oil Pump for the OP HPI Pump (P-64A, B or C) using handswitch on C16 or C18. Observed green light ON above handswitch.	—	—	—
C	<p>11. Place CV-1206 in OVRD.</p> <p><u>POSITIVE CUE:</u> OVRD light ON.</p>	Placed CV-1206 in OVRD using the NORMAL/OVRD pushbutton on C04. Observed OVRD light ON.	—	—	—
C	<p>12. Open CV-1206.</p> <p><u>POSITIVE CUE:</u> Red light ON.</p>	Opened CV-1206 using handswitch located on C04. Observed red light ON above handswitch.	—	—	—
	<p>13. Check RCP Seal Bleed off temps are &lt; 180°F</p> <p><u>POSITIVE CUE:</u> RCP Seal Bleed off temps are &lt; 180°F.</p>	On PMS or RCP seal recorders verified RCP Seal Bleed off temps are < 180°F.			

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
C	<p>14. Open CV-1207 slowly to achieve 30-40 gpm RCP Seal Total INJ Flow.</p> <p><u>POSITIVE CUE:</u> CV-1207 indicates open, FLOW light ON.</p> <p><u>NEGATIVE CUE:</u> Flow light OFF.</p> <p><u>NOTE:</u> FLOW light should come ON above CV-1206 OVRD light when seal injection flow is ~22 gpm.</p>	Slowly opened CV-1207 using manual toggle switch on C04. Established ~30-40 gpm seal injection flow. Observed FLOW light ON.	—	—	—
	<p>15. Place CV-1207 in AUTO.</p> <p><u>POSITIVE CUE:</u> Red light ON.</p>	Placed CV-1207 in automatic position by depressing the red AUTO pushbutton on C04. Observed red light ON at CV-1207 controller.	—	—	—
	<p>16. WHEN RCP Seals Total INJ Flow is above setpoint of ~22 gpm (CV-1206 FLOW light on).</p> <p><u>POSITIVE CUE:</u> Injection flow is 23 gpm, CV-1206 FLOW light is on.</p>	Verify RCP seal injection flow is above setpoint ~ 22 gpm and CV-1206 FLOW light is on.	—	—	—
	<p>17. Place CV-1206 OVRD pushbutton to normal (OVRD light off).</p> <p><u>POSITIVE CUE:</u> CV-1206 OVRD pushbutton is normal i.e. OVRD light is off.</p>	Place CV-1206 OVRD pushbutton to normal.	—	—	—
	<p>18. Adjust PZR level setpoint to 100 inches.</p> <p><u>POSITIVE CUE:</u> PZR level setpoint at 100 inches.</p>	Turn Pressurizer Level Controller level setpoint to 100 inches.			
C	<p>19. Place CV-1235 (Pressurizer Level Control valve) controller in AUTO position.</p> <p><u>POSITIVE CUE:</u> Red AUTO light ON.</p>	Placed CV-1235 in automatic position by depressing the red AUTO pushbutton on C04. Observed red light ON at valve controller.	—	—	—

END

JPM ID: A1JPM-RO-MUP01

## **INITIAL CONDITIONS:**

**The reactor has just tripped.**

## **INITIATING CUE:**

**The CRS/SM directs you to perform step 9 of the Reactor Trip procedure. The Operating HPI pump will be restarted**

ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE

TITLE: REACTOR TRIP

DOCUMENT NO.  
1202.001

CHANGE NO.  
031

WORK PLAN EXP. DATE  
N/A

SET #

SAFETY-RELATED  
☒ YES ☐ NO

IPTE  
☐ YES ☒ NO

TEMP MOD  
☐ YES ☒ NO

LEVEL OF USE  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL

PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO

When you see these **TRAPS**

Get these **TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

VERIFIED BY

DATE

TIME

_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

FORM TITLE:

VERIFICATION COVER SHEET

FORM NO.  
1000.006A

CHANGE NO.  
054

INSTRUCTIONS

8. (Continued)

9. Check OP HPI pump supplying normal Makeup and Seal Injection.

CONTINGENCY ACTIONS**CAUTION**

The following step will result in load shed of non-vital 4160V buses A1 and A2.

**NOTE**

SU2 is considered available if all the following conditions are met:

- AUTO X-FMR energized from 500KV
- AUTO X-FMR aligned to SU2
- **No** Unit 2 buses aligned to SU2
- SU2 V REG 3% reduction disabled

b) **IF** SU2 only is available,  
**THEN** energize bus from SU2 (use SYNC switch).

(1) **IF** non-vital 4160V bus feeder breaker fails to close,  
**THEN** attempt to reset breaker anti-pump feature by taking handswitch to PULL-TO-LOCK **AND** releasing.

9. Perform the following:

A. Isolate Letdown by closing either:

Letdown Coolers Outlet (CV-1221)

**OR**

Letdown Cooler Outlets  
(CV-1214 and 1216).

B. Restore normal Makeup and Seal Injection (RT-1).

ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE

TITLE: **REPETITIVE TASKS**

DOCUMENT NO.  
**1202.012**

CHANGE NO.  
**007**

WORK PLAN EXP. DATE  
**N/A**

SET #

SAFETY-RELATED  
☒ YES ☐ NO

IPTE  
☐ YES ☒ NO

TEMP MOD  
☐ YES ☒ NO

LEVEL OF USE  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL

PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO

When you see these **TRAPS**

Get these **TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Overconfidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

VERIFIED BY

DATE

TIME

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

FORM TITLE:

**VERIFICATION COVER SHEET**

FORM NO.  
**1000.006A**

CHANGE NO.  
**054**

**1. Restore normal Makeup and Seal Injection:**

- A. Place RC Pump Seals Total INJ Flow (CV-1207) in HAND **AND** close.
- B. Place Pressurizer Level Control (CV-1235) in HAND **AND** close.
- C. Verify RCP Seal INJ Block (CV-1206) closed.
- D. Verify RCS Makeup Block valves open (CV-1233 and 1234).
- E. Verify **one** of the following:
  - **Both** HPI RECIRC valves open (CV-1300 and 1301)
  - Fully open CV-1235 to prevent dead-heading pump
- F. **IF** P36B will be used, **THEN** verify the following selected to energized bus:
  - P36B Bus Select MOD Control
  - P64B Transfer Switch
- G. Start AUX Lube Oil pump for OP or STBY HPI pump.
- H. Start OP or STBY HPI pump.
- I. Stop AUX Lube Oil pump.
- J. Place CV-1206 in OVRD **AND** open.
- K. **IF** RCP Seal Bleedoff temps are  $\leq 180^{\circ}\text{F}$ ,  
**THEN** slowly open CV-1207 until RCP Seals Total INJ Flow is 30 to 40 gpm **AND** place in AUTO.
- L. **IF** RCP Seal Bleedoff temps are  $>180^{\circ}\text{F}$ ,  
**THEN** slowly open CV-1207 until RCP Seals Total INJ Flow is 8 to 12 gpm.
  - 1) Record current time \_\_\_\_\_.
  - 2) Maintain 8 to 12 gpm total flow  $\geq 30$  minutes.
  - 3) After 30 minutes, slowly open CV-1207 until 30 to 40 gpm total flow is reached **AND** place in AUTO.
- M. **WHEN** RCP Seals Total INJ Flow is above setpoint of  $\sim 22$  gpm (CV-1206 FLOW light on),  
**THEN** return CV-1206 OVRD pushbutton to normal (OVRD light off)
- N. Adjust Pressurizer Level Control Setpoint to 100" **AND** place CV-1235 in AUTO.

**END**



---

## S3. Reactor Pressure Control

N/A/S

K/A 010 A3.02

Control RCS Pressure  
Respond to Low RCS Pressure.

A1JPM-RO-PZR05

## JOB PERFORMANCE MEASURE

Unit: 1 Rev # 2 Date: \_\_\_\_\_JPM ID: A1JPM-RO-PZR05System/Duty Area: PRESSURIZERTask: Respond to Low RCS Pressure due to stuck open spray valve

JTA# \_\_\_\_\_

KA Value RO 3.6 SRO 3.5 KA Reference: 010 A3.02Approved For Administration To: RO X SRO XTask Location: Inside CR X Outside CR \_\_\_\_\_ Both \_\_\_\_\_

Suggested Testing Environment and Method (Perform or Simulate ):

Plant Site: \_\_\_\_\_ Simulator: Perform Lab: \_\_\_\_\_Position Evaluated: RO: X SRO: XActual Testing Environment: Plant Site \_\_\_\_\_ Simulator X Lab \_\_\_\_\_Testing Method: Perform X Simulate \_\_\_\_\_Approximate Completion Time in Minutes: 15 MinutesReference(s): 1203.012H Annunciator K09 corrective Action K09-C1; 1203.015 Pressurizer systems Failure

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

Start Time	Stop Time	Total Time
_____	_____	_____

\*Signed \_\_\_\_\_ Date \_\_\_\_\_

\*Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

JPM ID: A1JPM-RO-PZR05

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

JPM INITIAL TASK CONDITIONS:

The Reactor is at 38% power with 3 RCP's running "D" RCP is secured.

SIMULATOR SETUP: Have the Spray valve stuck open CV-1008 and have the spray valve isolation valve CV-1009 failed open. Spray valve should be open slightly and have RCS pressure going down slowly with all PZR heaters on. Have RCS pressure Hi/Lo alarm in K09-C1. **Simulator should be frozen until candidate is ready.** Then start simulator  
**THIS IS AN ALTERNATE PATH JPM**

TASK STANDARD:

Trip Reactor and Stop "C" RCP to stop RCS pressure decrease. Tripping the reactor must be performed prior to reaching the RPS low pressure set point. Stopping "C" RCP should be prior to reaching ESAS trip set point of 1590 psig

TASK PERFORMANCE AIDS:

Copy of 1203.015 section 6 Pressurizer Spray Valve (CV-1008) and 1203.012H Annunciator K09 corrective action for K09-C1 window RCS Pressure Hi/Lo

JPM ID: A1JPM-RO-PZR05

INITIATING CUE: The CRS/SM directs you to respond Annunciator K09-C1 RCS Pressure HI/LO alarm.

Examiner Cue: Only provide applicant the ACA procedure.

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
<b>INSTRUCTOR NOTE:</b>					
	1. Confirm alarm by comparing RC pressure indications on C04  <u>POSITIVE CUE:</u> All RCS pressure indicators are going down .	Identified that all RCS pressure indicators are going down	—	—	—
	2. Refer to COLR figures for RC Pressure Limits.  <u>POSITIVE CUE:</u> RC Pressure Limits Checked.	COLR limits may not be referenced during Press Transient  Or COLR RC Press. Limits reviewed.			
	3. Verify all Pressurizer heaters are on  <u>POSITIVE CUE:</u> All pressurizer heaters are on.	Identifies all Pressurizer heaters are on	—	—	—
	4. Verify Pressurizer Spray (CV 1008) closed.  <u>Negative CUE:</u> Pressurizer Spray (CV 1008) open.	Identifies Pressurizer Spray (CV 1008) opened. Attempts to close Pressurizer Spray (CV 1008) and valve will not close	—	—	—
	5. Verify ERV (PSV-1000) closed.  <u>POSITIVE CUE:</u> ERV (PSV-1000) closed.	Identifies ERV (PSV-1000) closed	—	—	—
	<b>Examiner Cue:</b> When asked provide applicant AOP 6. Refers to Pressurizer Systems failure 1203.015  <u>POSITIVE CUE:</u> Hand student Pressurizer Systems failure 1203.015	Refers to Pressurizer Systems failure 1203.015 section 6 Pressurizer Spray valve (CV-1008) Failure.	—	—	—
	7. Close Pressurizer Spray Isolation valve CV-1009  <u>Negative CUE:</u> Pressurizer Spray Isolation valve CV-1009 open.	Attempts to close Pressurizer Spray isolation valve (CV 1009) and valve will not close	—	—	—

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	8. Verify all Pressurizer heaters are on <u>POSITIVE CUE:</u> All pressurizer heaters are on.	Identifies all Pressurizer heaters are on	—	—	—
C	9. Trip Reactor <u>POSITIVE CUE:</u> Reactor tripped	Student Trips Reactor verifies all rods are inserted and Reactor power is going down. <b>This must be done prior to reaching an automatic RPS set point of low RCS pressure 1800 psig</b>	—	—	—
	10. Verifies Turbine is tripped <u>POSITIVE CUE:</u> Turbine is tripped.	Verifies all throttle and governors valves are shut	—	—	—
	11. Verifies Sub Cooling Margin is adequate <u>POSITIVE CUE:</u> SCM is adequate	Verifies SCM is >30 degrees f	—	—	—
	12. Start "C" RCP HP Oil Lift pump (P63C) <u>POSITIVE CUE:</u> RCP HP Oil Lift pump (P63C) starts and due to caution tag start P-80	Starts "C" RCP HP Oil Lift pump P63C and due to caution tag start P-80	—	—	—
	13. Start "C" RCP Backstop Lube Oil pump (P81C) <u>POSITIVE CUE:</u> RCP Backstop Lube Oil pump (P81C) starts.	Starts "C" RCP Backstop Lube Oil pump (P81C)	—	—	—
C	14. Stop "C" RCP (P-32C) <u>POSITIVE CUE:</u> "C" RCP (P-32C) stops	Stopped "C" RCP (P-32C) prior to RCS pressure drops below 1590 psig ESAS set point	—	—	—
<b>Note to Examiner : Tell student JPM complete</b>					

END

ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE

TITLE: <b>PRESSURIZER SYSTEMS FAILURE</b>          SET #	DOCUMENT NO. <div style="text-align: center;">1203.015</div>	CHANGE NO. <div style="text-align: center;">014</div>
	WORK PLAN EXP. DATE <div style="text-align: center;">N/A</div>	TC EXP. DATE <div style="text-align: center;">N/A</div>
	SAFETY-RELATED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	IPTE <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
	TEMP ALT <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	LEVEL OF USE <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> REFERENCE <input type="checkbox"/> INFORMATIONAL
	PROGRAMMATIC EXCLUSION PER EN-LI-100 <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	

**When you see these TRAPS**

Time Pressure  
 Distraction/Interruption  
 Multiple Tasks  
 Over Confidence  
 Vague or Interpretive Guidance  
 First Shift/Last Shift  
 Peer Pressure  
 Change/Off Normal  
 Physical Environment  
 Mental Stress (Home or Work)

**Get these TOOLS**

Effective Communication  
 Questioning Attitude  
 Placekeeping  
 Self Check  
 Peer Check  
 Knowledge  
 Procedures  
 Job Briefing  
 Coaching  
 Turnover

VERIFIED BY	DATE	TIME

FORM TITLE: <div style="text-align: center; margin-top: 10px;"><b>VERIFICATION COVER SHEET</b></div>	FORM NO. <div style="text-align: center;">1000.006A</div>	CHANGE NO. <div style="text-align: center;">053</div>
---	--	--

## SECTION 6 -- PRESSURIZER SPRAY VALVE (CV-1008) FAILURE

## ENTRY CONDITIONS

**One or more of the following:**

- CV-1008 closed when it should be open.
  - Normal operation: Opens - 2205 psig  
Closes - 2155 psig
  - Power >80% and MFP trip: Opens - 2080 psig  
Closes - 2030 psig

- CV-1008 open when it should be closed.

Abnormal change in RC pressure.

## SECTION 6 -- PRESSURIZER SPRAY VALVE (CV-1008) FAILURE

## INSTRUCTIONS

1. **IF** failed open,  
**THEN** place Pressurizer Spray Control switch in HAND AND attempt to close CV-1008 (modulating valve).

**NOTE**

CV-1009 torque switch can be overridden in the OPEN or CLOSE direction by holding the hand switch in the respective position.

- A. **IF** CV-1008 will NOT close,  
**THEN** close Pressurizer Spray Isolation Valve (CV-1009).
- B. Verify Pressurizer heaters return RCS pressure to normal.

**CAUTION**

Pressurizer spray shall not be used if the temperature difference between the Pressurizer and the spray fluid is  $>430^{\circ}\text{F}$  (TRM 3.4.3). Closing CV-1009 isolates the CV-1008 bypass spray flow.

- C. **IF** necessary,  
**THEN** control spray flow by cycling Pressurizer Spray Isolation Valve (CV-1009) open and closed.
- D. **IF** both CV-1008 and CV-1009 do NOT close  
**AND** RCS pressure is dropping,  
**THEN** perform the following:
  - 1) Verify all PZR heaters ON.
  - 2) Immediately begin reducing load to 40% at 10%/min per Rapid Plant Shutdown (1203.045).
  - 3) **IF** 4 RCPs are running  
**AND** BOTH of the following conditions are met:
    - Load is reduced to  $\leq 675$  MWe ( $\leq 75\%$  load)
    - Reactor power is  $\leq 75\%$ ,**THEN** perform the following:
    - a. Start "C" RCP HP Oil Lift Pump (P-63C) and "C" RCP Backstop Lube Oil Pump (P-81C).
    - b. Stop "C" RCP (P-32C).
    - c. **WHEN** zero speed is indicated,  
**THEN** stop P-63C and P-81C.

(continued)



## SECTION 6 -- PRESSURIZER SPRAY VALVE (CV-1008) FAILURE

**NOTE**

In Modes 1 and 2, operation with only one RCP in each loop causes entry into TS 3.4.4 Condition A.

- 4) **IF** 3 RCPs running  
**AND** all of the following conditions are met:
  - Load is reduced to  $\leq 360$  MWe ( $\leq 40\%$  load)
  - Reactor power is  $\leq 55\%$ ,
  - "C" and "D" RCPs in-service**THEN** perform the following:
  - a) Start "C" RCP HP Oil Lift Pump (P-63C) and "C" RCP Backstop Lube Oil Pump (P-81C).
  - b) Stop "C" RCP (P-32C).
  - c) **WHEN** zero speed is indicated,  
**THEN** stop P-63C and P-81C.
  - d) Enter TS 3.4.4 Condition A.
- 5) **IF** 3 RCPs running,  
**AND** "D" RCP is secured,  
**THEN** perform the following:
  - a) Trip Reactor.
  - b) Secure P-32C as follows:
    - (1) Start "C" RCP HP Oil Lift Pump (P-63C) and "C" RCP Backstop Lube Oil Pump (P-81C).
    - (2) Stop "C" RCP (P-32C).
    - (3) **WHEN** zero speed is indicated,  
**THEN** stop P-63C and P-81C.
  - c) Perform Reactor Trip (1202.001) while continuing with this procedure.
  - d) Enter TS 3.4.5 Condition A.
- 6) **WHEN** conditions permit a reactor building entry,  
**THEN** attempt to manually close either CV-1008 or CV-1009.

E. Contact Ops Manager.

(continued)

## SECTION 6 -- PRESSURIZER SPRAY VALVE (CV-1008) FAILURE

2. **IF** failed closed,  
**THEN** hold the plant at steady state conditions.
- A. **IF** CV-1008 is energized,  
**THEN** place Pressurizer Spray Control Mode switch in HAND AND attempt to cycle CV-1008 (a modulating valve) open and closed.
- B. Write a Condition Report to evaluate continued operation of the plant with inoperable Spray Valve.
- C. Contact Ops Manager AND consider one or both of the following:
- 1) **IF** CV-1008 will NOT open,  
**THEN** commence a shutdown per Power Reduction and Plant Shutdown (1102.016) and Plant Shutdown and Cooldown (1102.010).
- To prevent lifting of relief valves, reduce power slowly while shutting down. ←
  - RC pressure can be regulated by manual control of Pressurizer heaters. ←
- 2) **WHEN** conditions permit a reactor building entry,  
**THEN** perform the following:
- a. Close CV-1009 from C04.
  - b. Attempt to manually open CV-1008 in reactor building.

**CAUTION**

Pressurizer spray shall not be used if the temperature difference between the Pressurizer and the spray fluid is >430°F (TRM 3.4.3). Closing CV-1009 isolates the CV-1008 bypass spray flow.

- c. **IF** CV-1008 can be opened,  
**THEN** control RCS pressure and spray line temperature by cycling CV-1009 open and closed.

**END**

JPM ID: A1JPM-RO-PZR05

## **INITIAL CONDITIONS:**

**The Reactor is at 38% power with 3 RCP's running "D"  
RCP is secured.**

## **INITIATING CUE:**

**The CRS/SM directs you to respond Annunciator K09-C1  
RCS Pressure HI/LO alarm**

# ENTERGY OPERATIONS INCORPORATED ARKANSAS NUCLEAR ONE

**TITLE: ANNUNCIATOR K09 CORRECTIVE ACTION**

**DOCUMENT NO.**  
**1203.012H**

**CHANGE NO.**  
**036**

**WORK PLAN EXP. DATE**  
**N/A**

**TC EXP. DATE**  
**N/A**

**SET #**

**SAFETY-RELATED**  
☒ **YES**    ☐ **NO**

**IPTE**  
☐ **YES**    ☒ **NO**

**TEMP ALT**  
☐ **YES**    ☒ **NO**

**LEVEL OF USE**  
☒ **CONTINUOUS**  
☐ **REFERENCE**  
☐ **INFORMATIONAL**

**PROGRAMMATIC EXCLUSION PER EN-LI-100**  
☐ **YES**    ☒ **NO**

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.**  
**1000.006A**

**CHANGE NO.**  
**053**

PROC./WORK PLAN NO. <b>1203.012H</b>	PROCEDURE/WORK PLAN TITLE: <b>ANNUNCIATOR K09 CORRECTIVE ACTION</b>	PAGE: <b>5 of 62</b> CHANGE: <b>036</b>
---	--	--

Page 1 of 2

Location: C14

Device and Setpoint:

RC Pressure Loop A Narrow Range (PS-1023)  $\geq 2255$  psig  
or  $< 2055$  psig

RC Pressure Loop B Narrow Range (PS-1038)  $\geq 2255$  psig  
Or  $< 2055$  psig

RCS  
PRESSURE  
HI/LO

Alarm: K09-C1

#### 1.0 OPERATOR ACTIONS

##### NOTE

The following indicators should read nearly alike except during three RCP operation.

1. Confirm alarm by comparing RC pressure indications on C04.
  - RC Pressure Narrow Range Loop A recorder (PR-1023)
  - RC Pressure Narrow Range Loop B recorder (PR-1038)
  - RC Pressure Wide Range Loop B recorder (PI-1041)
  - RC Pressure Wide Range Loop B indicator (PR-1042)

##### NOTE

A malfunctioning pressure instrument can insert an erroneous trip signal to the RPS.

2. Refer to COLR Figures for RC pressure limits.
3. IF RC pressure is confirmed low,  
THEN perform the following:
  - A. Verify all pressurizer heaters on.
  - B. Verify Pressurizer Spray (CV-1008) closed.
  - C. Verify ERV (PSV-1000) closed.
  - D. Refer to Pressurizer Systems Failure (1203.015).
4. IF RC pressure is confirmed high,  
THEN perform the following:
  - A. Verify Pressurizer Spray (CV-1008) open.
  - B. Verify all pressurizer heaters are off.
  - C. Refer to Pressurizer Systems Failure (1203.015).
5. IF transient is caused by ICS malfunction,  
OR ICS instrument failure  
THEN take manual control of affected H/A station AND refer to ICS Abnormal Operation (1203.001).
6. Refer to SASS MISMATCH K07-B4 (1203.012F)

PROC./WORK PLAN NO. 1203.012H	PROCEDURE/WORK PLAN TITLE: ANNUNCIATOR K09 CORRECTIVE ACTION	PAGE: 6 of 62 CHANGE: 036
----------------------------------	---	------------------------------

K09-C1 Page 2 of 2

2.0 PROBABLE CAUSES

- Malfunctioning pressure instrument
- ICS malfunction

3.0 REFERENCES

Window Arrangement Annunciator K09 (E-459, sheets 1-4)

---

## S4. Heat Removal from Reactor Core (Primary)

A/D/L/S

K/A 005 A4.01

Establish Decay Heat Removal  
Using P-34A.

A1JPM-RO-DHR03

## JOB PERFORMANCE MEASURE

Unit: 1 Rev # 5 Date: \_\_\_\_\_JPM ID: A1JPM-RO-DHR03System/Duty Area: Decay Heat RemovalTask: Establish Decay Heat Removal Using P-34AJTA# ANO1-RO-DHR-NORM-2KA Value RO 3.6 SRO 3.4 KA Reference 005 A4.01Approved For Administration To: RO X SRO XTask Location: Inside CR: X Outside CR: \_\_\_\_\_ Both: \_\_\_\_\_

Suggested Testing Environment And Method (Perform or Simulate ):

Plant Site: \_\_\_\_\_ Simulator: \_\_\_\_\_ Perform \_\_\_\_\_ Lab: \_\_\_\_\_

Position Evaluated: RO: \_\_\_\_\_ SRO: \_\_\_\_\_

Actual Testing Environment: Simulator : \_\_\_\_\_ Plant Site: \_\_\_\_\_ Lab: \_\_\_\_\_

Testing Method: Simulate: \_\_\_\_\_ Perform: \_\_\_\_\_

Approximate Completion Time In Minutes: 20 MinutesReference(s): 1104.004 Chg 077 and 1102.010

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

\*Signed : \_\_\_\_\_ Date: \_\_\_\_\_

\*Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.



JPM ID: A1JPM-RO-DHR03

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

JPM INITIAL TASK CONDITIONS:

A plant shutdown and cooldown is in progress. Plant Shutdown and Cooldown procedure 1102.010 is complete to Step 10.8. "C" and "D" RCP's are in service. RCS temperature is 260 °F and RCS pressure is 240 psig. The Decay Heat Removal System is filled and vented. Breakers B-5255/ B-6255/ B-5651 (for CV-1050, CV-1410 and CV-1404 DH Suction valves) are closed and Category E/Locked Component entry has been made. RP has been notified.

TASK STANDARD:

P-34A decay heat pump started and then secured due to SW cooling supply valve CV-3840 failure to open.

*This is a FAULTED JPM.*

TASK PERFORMANCE AIDS:

1104.004 DHR Operating Procedure

SIMULATOR SETUP:

Comply with initial task conditions above and also:

Select HOT SHUTDOWN as the mode on PMS.

Use Control Valve Malfunctions CV3840 SW P34A BRG CLR E50A and set severity value to 0 to prevent CV-3840 from opening before the decay heat pump is started.

When the decay heat pump is started then use Meter Overrides C13 AO\_TR6500P DH P34A PP BRG 2, PT16 and fail to Analog Value 200 ramped over 60 seconds. Use Annunciator Cry Wolf K09E8 DH PMP/MTR BRG TEMP HI to ON within 1 minute.

JPM ID: A1JPM-RO-DHR03

INITIATING CUE: The SM/CRS directs that DHR Pump P34A be placed in service with DHR flow at ~2800 gpm per 1104.004 section 7.2.

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	1. Establish a Plant Computer Programmable Annunciator alarm for P-34A discharge pressure of 400 psig (P1404).  <u>POSITIVE CUE:</u> Plant computer programmable annunciator alarm is established.	Selected K02-E8 and K02-F8 from the alarm menu and verified P1404 assigned to either K02-E8 or K02-F8 or assigned P1404 to either K02-E8 or K02-F8. Selected Data Base Manager from the Maintenance menu or by typing DBM. Input P1404 and verified the HOT SHUTDOWN alarm set to 400 psig or set alarm to 400 psig.	—	—	—
	a. Verify that PMS current plant mode and refueling mode assignment are consistent for this setting.  <u>POSITIVE CUE:</u> PMS Plant Mode Assignment is set to HOT SHUTDOWN Mode.	Verified that PMS current Plant Mode Assignment is selected to the proper Mode (HOT SHUTDOWN) using Plant Mode Assignment from the Utilities Menu or by observing Mode at the bottom of any PMS screen.	—	—	—
C	2. Close Decay Heat P-34A Suction from BWST (CV-1436).  <u>POSITIVE CUE:</u> CV-1436 red light off, green light on.	Moved the control switch for CV-1436 to the closed position.	—	—	—
C	3. Open Decay Heat P-34A Suction from RCS (CV-1434).  <u>POSITIVE CUE:</u> CV-1434 red light on, green light off.	Moved the control switch for CV-1434 to the open position.	—	—	—
	4. Open the following valves. <ul style="list-style-type: none"> <li>E-35A Sample Valve (SS-41A)</li> <li>E-35B Sample Valve (SS-41B)</li> </ul> <u>POSITIVE CUE:</u> Waste Control Operator reports that SS-41A and SS-41B are open	Dispatched the Waste Control Operator to open sample valves SS-41A and SS-41B.	—	—	—
	5. Verify white Open Permit light ON at CV-1410 handswitch on C16.  <u>POSITIVE CUE:</u> White open permit light is on.	Verified white open permit light at CV-1410 on.	—	—	—
C	6. Open DH Suction Valve CV-1410.  <u>POSITIVE CUE:</u> CV-1410 red light on, green light off.	Moved the control switch for DH suction valve CV-1410 to the open position.	—	—	—

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	7. Verify white Open Permit light ON at CV-1050 handswitch on C18.  <u>POSITIVE CUE:</u> B-5255 is closed and open permit light is on.	Verified white open permit light at CV-1050 on.	—	—	—
C	8. Open DH Suction Valve CV-1050  <u>POSITIVE CUE:</u> CV-1050 red light on, green light off.	Moved control switch for DH suction valve CV-1050 to the open position.	—	—	—
C	9. Open DH Suction RB Isolation CV-1404.  <u>POSITIVE CUE:</u> CV-1404 red light on, green light off.	Moved control switch for DH suction RB Isolation valve CV-1404 to the open position.	—	—	—
	10. Close decay heat cooler E-35A outlet valve CV-1428.  <u>POSITIVE CUE:</u> CV-1428 closed.	Moved control switch for decay heat cooler E-35A outlet CV-1428 to the close position.	—	—	—
C	11. Position E-35A Cooler Bypass (CV-1433) to ~ 75% as indicated on HIC-1433.  <u>POSITIVE CUE:</u> CV-1433 ~ 75% open.	Used HIC-1433 and set CV-1433 demand to ~ 75% open.	—	—	—
C	12. Open LPI/Decay Heat Block CV-1401  <u>POSITIVE CUE:</u> CV-1401 red light on, green light off.	Moved control switch for LPI/Decay Heat Block CV-1401 to the open position.	—	—	—
<p><b>NOTE TO IA OPERATOR:</b> Use Valve Malfunctions CV3840 SW P34A BRG CLR E50A and set severity value to 0 to prevent CV-3840 from opening.</p> <p>When pump is started then use Meter Overrides C13 AO_TR6500P DH P34A PP BRG 2, PT16 and fail to Analog Value 200 ramped over 60 seconds. Use Annunciator Cry Wolf K09E8 DH PMP/MTR BRG TEMP HI to ON within 1 minute.</p> <p><b>NOTE TO EXAMINER:</b> Examinee may clear the Decay Heat vault of personnel prior to starting the pump</p>					
C	13. Start P-34A.  <u>POSITIVE CUE:</u> P34A started, red light ON.  <u>NEGATIVE CUE:</u> P34A did not start, green light ON and no flow indicated.	Placed the breaker control switch for Decay Heat Removal Pump P-34A in the start/on position.	—	—	—
	14. Verify LPI/Decay Heat Pump Brg CLR E-50A Inlet (CV-3840) and Decay HT CLR Service Water E-35A Inlet (CV-3822) open.  <u>POSITIVE CUE:</u> CV-3822 red light is on, green light off.  <u>NEGATIVE CUE:</u> CV-3840 green light ON, red light OFF.	On C-18, verified CV-3822 red open indication ON and green closed indication OFF. Identified that CV-3840 did NOT open.	—	—	—

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	15. Attempt to open CV-3840 locally.  <u>POSITIVE CUE:</u> WCO has been dispatched to manually open CV-3840.	Directed Waste Control Operator to open CV-3840 locally.	—	—	—
	16. Monitor P-34A bearing temperatures.  <u>Faulted Cue:</u> P-34A bearing temperature is 175°F and rising.	Monitored P-34A temperature at recorder TR6500 on C13 or on the plant computer.	—	—	—
C	17. Stop P-34A. if bearing temperature exceeds 170 F  <u>POSITIVE CUE:</u> Green light ON, red light OFF for P-34A.  <u>NEGATIVE CUE:</u> P-34A bearing temperatures at 199°F and rising.	Placed breaker control switch for Decay Heat Removal Pump P-34A in the open position. Prior to pump tripping.	—	—	—

END

JPM ID: A1JPM-RO-DHR03

## **INITIAL CONDITIONS:**

**A plant shutdown and cooldown is in progress.**

**Plant Shutdown and Cooldown procedure 1102.010 is complete to Step 10.8. "C" and "D" RCP's are in service.**

**RCS temperature is 260 °F and RCS pressure is 240 psig.**

**The Decay Heat Removal System is filled and vented.**

**Breakers B-5255/ B-6255/ B-5651 (for CV-1050, CV-1410 and CV-1404 DH Suction valves) are closed and Category E/Locked Component entry has been made..**

**RP has been notified.**

## **INITIATING CUE:**

**The SM/CRS directs that DHR Pump P34A be placed in service with DHR flow at ~2800 gpm per 1104.004 section 7.2.**

**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

**TITLE: DECAY HEAT REMOVAL OPERATING  
PROCEDURE**

**DOCUMENT NO.  
1104.004**

**CHANGE NO.  
078**

**SET #**

**WORK PLAN EXP. DATE  
N/A**

**SAFETY-RELATED  
☒ YES ☐ NO**

**IPTE  
☐ YES ☒ NO**

**TEMP MOD  
☒ YES ☐ NO**

**LEVEL OF USE  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL**

**PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO**

**When you see these TRAPS**

**Get these TOOLS**

**Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)**

**Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover**

**VERIFIED BY**

**DATE**

**TIME**

_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.  
1000.006A**

**CHANGE NO.  
054**

PROC./WORK PLAN NO. <b>1104.004</b>	PROCEDURE/WORK PLAN TITLE: <b>DECAY HEAT REMOVAL OPERATING PROCEDURE</b>	PAGE: <b>14 of 280</b> CHANGE: <b>078</b>
--	---	--

- 7.1.5 RCS pressure less than Decay Heat System Maximum Pressure limit of Plant Shutdown and Cooldown (1102.010), Attachment A.
- 7.1.6 RCS temperatures <280°F.
- 7.1.7 RP notified of changing radiological conditions in Auxiliary Building.

{4.3.2, 4.3.4, 4.3.5}

#### CAUTION

- Following any significant core damage, the effects on access to vital areas due to high radiation levels should be considered prior to placing the Decay Heat system into service.
- If RCS is drained down and both DH pumps are running, extra caution shall be exercised to prevent vortex formation at the pump suction.
- The Decay Heat System shall be isolated from the RCS when RC temperature is >280°F.
- Decay Heat pump discharge relief setpoint is 445 +22.5/-13.35 psig. Discharge pressure should be maintained <400 psig to prevent challenging the relief.

#### NOTE

- Normally one pump is aligned for Decay Heat Removal and one for LPI. If heat loads are high, both Decay Heat trains may be utilized for Decay Heat Removal.
- If known leakage exists on a single loop (i.e., Decay Heat pump seal leakage), preference is to be given to the other loop for long-term operation after Pressurizer cooldown is complete. The last completed Decay Heat Removal System Integrity Test and Leak Rate Determination (1305.011 Supplement 1 and 2) can aid in determining preferred loop for service.
- SPDS Diagnostic display for LPI may be helpful in monitoring LPI (Decay Heat) pump performance.

#### 7.2 Decay Heat Removal With Low Pressure Injection (Decay Heat) Pump (P-34A)

- 7.2.1 IF Decay Heat system has been drained for any reason, THEN applicable piping and components should be filled and vented per "Decay Heat System Fill & Vent" section of this procedure.
- 7.2.2 Establish a Plant Computer Programmable Annunciator alarm for P-34A discharge pressure of 400 psig (P1404).
  - A. Verify that PMS current plant mode and refueling mode assignment are consistent for this setting.

PROC./WORK PLAN NO. <b>1104.004</b>	PROCEDURE/WORK PLAN TITLE: <b>DECAY HEAT REMOVAL OPERATING PROCEDURE</b>	PAGE: <b>15 of 280</b> CHANGE: <b>078</b>
--	---	--

**CAUTION**

- With RC pressure >75 psig and DH suction piping aligned to the RCS, exceeding design pressure of suction piping from BWST will occur if Decay Heat P-34A Suction from BWST (CV-1436) and Decay Heat P-34A Suction from RCS (CV-1434) are open at the same time.
- The interlock to prevent the suction from RCS valves (CV-1434 and CV-1435) opening unless suction from BWST valves (CV-1436 and CV-1437) are closed does not prevent CV-1436 and CV-1437 from opening after CV-1434 and CV-1435 are open.

- 7.2.3 Close Decay Heat P-34A Suction from BWST (CV-1436).
- 7.2.4 Open Decay Heat P-34A Suction from RCS (CV-1434).
- 7.2.5 Open the following valves.
- E-35A Sample Valve (SS-41A)
  - E-35B Sample Valve (SS-41B)
- 7.2.6 IF Decay Heat Suction Valve (CV-1410) is closed,  
THEN perform the following to open CV-1410:
- A. Unlock and close B-6255, CV-1410 power supply breaker.
  - B. Make appropriate entry on Category E/Locked Component Log (E-DOC 1015.001H).
  - C. Verify white Open Permit light ON at CV-1410 handswitch on C16.
  - D. Open CV-1410.
- 7.2.7 IF Decay Heat Suction Valve (CV-1050) is closed,  
THEN perform the following to open CV-1050:
- A. Verify CV-1050 power supply breaker B-5255 closed.
  - B. Verify white Open Permit light ON at CV-1050 handswitch on C18.
  - C. Open CV-1050.
- 7.2.8 IF DH Suction RB Isolation Valve (CV-1404) is closed,  
THEN perform the following to open CV-1404:
- A. Unlock and close B-5651 (CV-1404 power supply breaker).
  - B. Make appropriate entry on Category E/Locked Component Log (E-DOC 1015.001H).
  - C. Open CV-1404.



PROC./WORK PLAN NO. <b>1104.004</b>	PROCEDURE/WORK PLAN TITLE: <b>DECAY HEAT REMOVAL OPERATING PROCEDURE</b>	PAGE: <b>16 of 280</b> CHANGE: <b>078</b>
--	---	--

- 7.2.9 Close DHR Cooler E-35A Outlet (CV-1428) (modulating valve).
- 7.2.10 Position E-35A Cooler Bypass (CV-1433) to ~ 75% open.
- 7.2.11 Open LPI/Decay Heat Block (CV-1401) (modulating valve).

**WARNING**

At RC pressure >220 psig with DH flow throttled, the DH pump discharge relief can lift during pump start. Consideration should be given to clearing personnel from the "A" DH Vault prior to starting P-34A.

**CAUTION**

DH pump will be damaged if either Decay Heat Suction valve CV-1050 or CV-1410 closes while pump is operating.

**NOTE**

- CV-1050 will close automatically if Core Flood Tank T-2A Outlet (CV-2415) comes off its closed seat or if RC pressure exceeds 320 psig.
- CV-1410 will close automatically if Core Flood Tank T-2B Outlet (CV-2419) comes off its closed seat or if RC pressure exceeds 385 psig.
- The auto close interlock is automatically reset when RCS pressure is <290 psig.

- 7.2.12 Start P-34A.
- 7.2.13 WHEN P-34A is started,  
THEN verify the following valves open:
- LPI/Decay Heat Pump Brg Clr E-50A Inlet (CV-3840)
    - IF CV-3840 fails to open,  
THEN attempt to open locally
    - IF pump bearing temperatures exceed 170°F,  
THEN stop P-34A.
  - DHR Clr Service Water E-35A Inlet (CV-3822)
- 7.2.14 After P-34A start, monitor Pressurizer level for indication of discharge relief (PSV-1407) lifting.
- A. IF Pressurizer level starts dropping,  
THEN stop P-34A.
1. Check DH pump discharge relief reseats.
  2. Throttle CV-1433 further open prior to attempting restart of P-34A.

PROC./WORK PLAN NO. 1104.004	PROCEDURE/WORK PLAN TITLE: <b>DECAY HEAT REMOVAL OPERATING PROCEDURE</b>	PAGE: 17 of 280 CHANGE: 078
---------------------------------	---	--------------------------------

7.2.15 Adjust CV-1433 to establish DH Removal flow within the following limits:

- $\leq 3500$  gpm from P-34A
- P-34A discharge pressure  $<400$  psig
- WHEN Rx core decay heat load allows,  
AND if RCS pressure is atmospheric or RCS has N<sub>2</sub> overpressure,  
THEN maintain total DH flow  $\leq 2000$  gpm.

7.2.16 IF required by Surveillance Test Schedule,  
THEN perform Part 2 of Supplement 3 of this procedure before proceeding.

**NOTE**

If LPI (Decay Heat) Room Cooler (VUC-1A) breaker is open, VUC-1B will not auto start. When VUC-1A breaker is open, VUC-1B must be run continuously in manual to ensure P-34A operability.

7.2.17 WHEN P-34A is started,  
THEN verify LPI (Decay Heat) Room Cooler (VUC-1A) starts.

- A. IF VUC-1A does not start,  
THEN verify LPI (Decay Heat) Room Cooler (VUC-1B) starts.

7.2.18 Adjust the following DECAY HEAT VORTEX WARNING setpoints, using SPDS computer POINT MAINTENANCE/UPDATE ALARMING DISPLAY function to values just below and above the current value of Decay Heat Pump motor current (I1A305).

- "A" SPDS KP34ALO
- "A" SPDS KP34AHI
- "B" SPDS KP34ALO
- "B" SPDS KP34AHI

7.2.19 Establish restrictions around protected areas and tag interconnecting system valves per Attachment J of Decay Heat Removal and LTOP System Control (1015.002).

**NOTE**

Lower limit for RCS and SFP temperature is 73°F.

7.2.20 Continue cooldown per "Establishing Cooldown Rate Using Decay Heat Removal System" section of this procedure when directed by 1102.010.

7.2.21 IF it is desired to operate both Decay Heat systems on the RCS,  
THEN place P-34B inservice per applicable steps of "Shifting Operating Decay Heat Loops" of this procedure.

---

S5. Electrical

A/D/EN/S

K/A 064 A4.07

Emergency Diesel Generator  
(EDG) System.

A1JPM-RO-EDG04

## JOB PERFORMANCE MEASURE

Unit: 1 Rev # 4 Date: \_\_\_\_\_JPM ID: A1JPM-RO-EDG04System/Duty Area: Emergency Diesel Generator (EDG) SystemTask: Parallel DG1 to the GridJTA# ANO1-RO-EDG-NORM-10KA Value RO 3.4 SRO 3.4 KA Reference 064 A4.07Approved For Administration To: RO X SRO XTask Location: Inside CR: X Outside CR: \_\_\_\_\_ Both: \_\_\_\_\_

Suggested Testing Environment And Method (Perform or Simulate ):

Plant Site: \_\_\_\_\_ Simulator: Perform Lab: \_\_\_\_\_Position Evaluated: RO: X SRO: XActual Testing Environment: Simulator: X Plant Site: \_\_\_\_\_ Lab: \_\_\_\_\_Testing Method: Simulate: \_\_\_\_\_ Perform: XApproximate Completion Time In Minutes: 10 MinutesReference(s): 1104.036 Emergency Diesel Generator Operation

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

Start Time	Stop Time	Total Time
_____	_____	_____

\*Signed \_\_\_\_\_ Date: \_\_\_\_\_

:

\*Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

JPM ID: A1JPM-RO-EDG04

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

JPM INITIAL TASK CONDITIONS:

DG1 is running with its output breaker open and its service water inlet valve (CV-3806) open.

TASK STANDARD:

DG1 tripped and output breaker open (due to its load continuing to rise uncontrollably). ***PRIOR to EDG TRIPPING ON ITS ON***

***This is an Alternate Success Path JPM.***

TASK PERFORMANCE AIDS:

Synch switch handle, 1104.036 Section 7.0.

SIMULATOR SETUP:

- Start VEF-24A and VEF-24B DG Room Exhaust Fans on C19.
- Verify DG1 Volts Select switch NOT in OFF on C10.
- Start DG1 on C10.
- Verify CV-3806 open (SW to DG1).

When the DG1 output breaker is closed, then insert switch override C10 DI\_DG1\_GV\_LW Lower, DG1, Governor Control to FALSE and insert switch override C10 DI\_DG1\_GV\_RA Raise, DG1, Governor Control to TRUE which will fail the governor hand switch in the raise position, this will cause the DG1 load to rise without control. Allow the governor to manually lower load but when switch released from lower position load will raise again

- IOR DI\_DG1\_GV\_RA True

JPM ID: A1JPM-RO-EDG04

INITIATING CUE: The CRS/SM directs you to parallel DG1 to the grid and load DG1 to ~2750 KW starting at 1104.036 Step 7.11. All procedural steps from 7.1 to 7.10 have been performed and/or acknowledged for DG1.

Critical Tasks: 1, 3, 4, and 5

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UNSA T
C	<p>1. Place Synchronize switch for DG1 Output Breaker A-308 to ON.</p> <p><u>POSITIVE CUE:</u> Incoming and running voltmeters indicating; synchroscope rotating.</p> <p><u>NEGATIVE CUE:</u> Synchroscope off.</p>	On C10, placed Synchronize switch for breaker A-308 to ON position.	_____	_____	_____
	<p>2. Adjust DG1 voltage regulator (INCOMING) to within a range of RUNNING voltage -0/+20 volts.</p> <p><u>POSITIVE CUE:</u> INCOMING and RUNNING voltages are matched.</p> <p>NOTE: Voltages may be verified matched on C10 or SPDS or on plant computer.</p>	On C10, adjusted DG1 voltage regulator control switch to match INCOMING voltage to within a range of RUNNING voltage -0/+20 volts.	_____	_____	_____
C	<p>3. Adjust DG1 governor control until frequency is ~60 Hz with synchroscope rotating slowly in FAST direction (clockwise).</p> <p><u>POSITIVE CUE:</u> Frequency ~60 Hz, synchroscope slowly in FAST direction.</p> <p><u>NEGATIVE CUE:</u> Synchroscope rotating in the SLOW direction.</p>	On C10, adjusted DG1 governor control switch to achieve frequency at ~60 Hz with synchroscope rotating slowly in FAST direction (clockwise).	_____	_____	_____

JPM ID: A1JPM-RO-EDG04

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UNSAT
<p><b>NOTE: IA Operator</b> → When the DG1 output breaker is closed, then insert switch override C10 DI_DG1_GV_LW Lower, DG1, Governor Control to FALSE and insert switch override C10 DI_DG1_GV_RA Raise, DG1, Governor Control to TRUE which will fail the governor hand switch in the raise position, this will cause the DG1 load to rise without control. Allow the governor to manually lower load but when switch released from lower position load will raise again</p> <ul style="list-style-type: none"> <li>• <b>IOR DI_DG1_GV_RA True</b></li> </ul>					
C	<p>4. As synchroscope approaches 12 o'clock position (~5 min. 'til) close DG1 Output Breaker A-308.</p> <p><u>POSITIVE CUE:</u> A-308 red light ON, green light OFF.</p>	On C10, closed DG1 Output Breaker A-308.	—	—	—
C	<p>5. Operator identifies uncontrollable rising load and trips DG1.</p> <p><u>POSITIVE CUE:</u> DG1 green light ON, red light OFF.</p> <p><u>NEGATIVE CUE:</u> DG1 load at 2800 KW and rising.</p>	<p>On C10, tripped DG1 (stop pushbutton or to lockout) and output breaker opened.</p> <p><b><i>PRIOR to EDG TRIPPING ON overspeed</i></b></p>	—	—	—

END

JPM ID: A1JPM-RO-EDG04

## **INITIAL CONDITIONS:**

**DG1 is running with its output breaker open and its service water inlet valve (CV-3806) open.**

## **INITIATING CUE:**

**The CRS/SM directs you to parallel DG1 to the grid and load DG1 to ~2750 KW starting at 1104.036 Step 7.11. All procedural steps from 7.1 to 7.10 have been performed and/or acknowledged for DG1.**



**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>  SET #	DOCUMENT NO. 1104.036	CHANGE NO. 048
	WORK PLAN EXP. DATE N/A	
	SAFETY-RELATED <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO	IPTE <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO
	TEMP MOD <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	LEVEL OF USE <input checked="" type="checkbox"/> CONTINUOUS <input type="checkbox"/> REFERENCE <input type="checkbox"/> INFORMATIONAL
	PROGRAMMATIC EXCLUSION PER EN-LI-100 <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	

When you see these **TRAPS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Get these **TOOLS**

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

VERIFIED BY	DATE	TIME
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

FORM TITLE: <b>VERIFICATION COVER SHEET</b>	FORM NO. 1000.006A	CHANGE NO. 054
--	-----------------------	-------------------

PROC./WORK PLAN NO. 1104.036	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: 16 of 271 CHANGE: 048
---------------------------------	---	--------------------------------

7.9

Start the Diesel Generator as follows:

7.9.1

Perform the following on C19 or locally:

- Verify VEF-24A running.
- Verify VEF-24B running.
- Check damper TV-7901A open.
- Check damper TV-7901B open.

7.9.2

Verify DG1 Volts Select switch on C10 NOT in OFF.

7.9.3

Depress DG1 START pushbutton on C10.

7.9.4

Verify Service Water to DG1 Coolers (CV-3806) opens.

**CAUTION**  
With DG paralleled to the grid, grid disturbance could cause damage to DG.

7.10

IF DG1 is paralleled to the grid  
AND the reactor trips or offsite power is lost,  
THEN perform the following:

7.10.1

Verify ONE of the following conditions:

- A. DG1 feeding A3 and separated from the grid as follows:
  - A1 to A3 Feeder Breaker (A-309) open.
  - DG1 Output Breaker (A-308) closed.
- B. DG1 idling as follows:
  - A1 to A3 Feeder Breaker (A-309) closed.
  - DG1 Output Breaker (A-308) open.

7.10.2

Adjust DG1 voltage to ~4160 volts and frequency to ~ 60 Hz.

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>17 of 271</b> CHANGE: <b>048</b>
--	---	--

**CAUTION**

Diesel run time unloaded or at low load (<75%) should be minimized in order to prevent carbon fouling (improper combustion) and excessive turbocharger gear train wear.

**NOTE**

- To burn out carbon fouling in the exhaust system when diesel has run with <20% load for ≥4.5 hours, it is recommended that it be loaded ≥75% for ≥30 minutes.
- SPDS points (E1A3), ES Bus A3 voltage (running) and (E1DG1), DG1 voltage (incoming) can be used as comparison points.

7.11 Parallel DG1 to the grid as follows:

- 7.11.1 Place Synchronize switch for DG1 Output Breaker (A-308) to ON.
- 7.11.2 Adjust DG voltage regulator (INCOMING) to within a range of RUNNING voltage -0/+20 volts (prefer near match).
- 7.11.3 Adjust DG1 governor control until frequency is ~60 Hz with synchroscope rotating slowly in FAST direction (clockwise).

PROC./WORK PLAN NO. <b>1104.036</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY DIESEL GENERATOR OPERATION</b>	PAGE: <b>18 of 271</b> CHANGE: <b>048</b>
--	---	--

**CAUTION**

A delay in loading diesel after closing output breaker may result in generator motoring which causes lockout relay to actuate and trip DG output breaker and shutdown the engine.

**NOTE**

- If synchroscope is rotating too fast, sync-check relay will prevent breaker from closing.
- Gradual and uniform load changes minimize engine wear and internal stresses. A 100% load change should take ~90 sec. Longer loading times are acceptable when delays are caused by reactive load adjustments or equipment monitoring.

7.11.4 As synchroscope approaches 12 o'clock position (~5 min 'til), close DG1 Output Breaker (A-308).

A. Immediately begin raising load gradually to full load (2750 KW) using DG1 governor control (~90 seconds).

B. Maintain ~0 KVARs using DG1 voltage regulator.

7.11.5 Place synchronize switch for DG1 Output Breaker (A-308) to OFF.

7.12 Begin taking DG logs every 30 minutes at full load for the first hour and hourly thereafter per DG1 Logsheet (OPS-A15a).



---

## S6. Instrumentation

D/E/S

K/A B/W E02.EA1.1

Place Channel “A” in a Tripped  
Condition.

A1JPM-RO-RPS05

## JOB PERFORMANCE MEASURE

Unit: 1 Rev # 4 Date: \_\_\_\_\_JPM ID A1-JPM-RO-RPS05System/Duty Area: Reactor Protection SystemTask: Place Channel "A" in a Tripped ConditionJA# ANO1-RO-RPS-NORM-4KA Value RO 4.0 SRO 3.6 KA Reference B/W E02.EA1.1Approved For Administration To: RO X SRO XTask Location: Inside CR: X Outside CR: \_\_\_\_\_ Both: \_\_\_\_\_

Suggested Testing Environment And Method (Perform Or Simulate #):

Plant Site: \_\_\_\_\_ Simulator#: \_\_\_\_\_ Perform \_\_\_\_\_ Lab: \_\_\_\_\_

Position Evaluated: RO: X SRO: \_\_\_\_\_Actual Testing Environment: Simulator: X Plant Site: \_\_\_\_\_ Lab \_\_\_\_\_

Testing Method: Simulate: \_\_\_\_\_ Perform: \_\_\_\_\_

Approximate Completion Time In Minutes: 10 MinutesReference(S) 1105.001 NI & RPS OPERATING PROCEDURE  
:

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

Signed \_\_\_\_\_ Date: \_\_\_\_\_

# SIGNATURE INDICATES THIS JPM HAS BEEN COMPARED TO ITS APPLICABLE PROCEDURE BY A QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.

JPM ID: A1-JPM-RO-RPS05

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:** Plant at any at power level with no EFIC channels in bypass and A RPS channel in bypass.

**TASK STANDARD:** "A" RPS Channel in a Tripped Condition

**TASK PERFORMANCE:** 1105.001 NI & RPS OPERATING PROCEDURE STEP 13

JPM ID: A1-JPM-RO-RPS05

INITIATING CUE: The CRS directs you to Place RPS Channel "A" in a Tripped Condition per Section 13 "Placing a Channel in a Tripped Condition in Support of NI Calibration, Channel Maintenance or Channel Calibration When One Channel is Inoperable" section of 'NI & RPS OPERATING PROCEDURE' (1105.001) through step 13.5. SM has suspended the SRO peer check.

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	1. Verify no RPS channel tripped.  <u>POSITIVE CUE:</u> RPS Channel "A", "B", "C", and "D" Trip module REACTOR TRIP light is on dim.	Observed RPS Channel "A", "B", "C", and "D" Trip module REACTOR TRIP light on dim.	—	—	—
C	2. Verify RPS channel that is to be tripped is NOT in Manual Bypass.  <u>POSITIVE CUE:</u> RPS Channel "A" maintenance bypass key is inserted in Trip Module.  <u>NOTE:</u> If requested inform applicant to continue with procedure	RPS Channel "A" removed from Manual Bypass.	—	—	—
C	3. Momentarily depress the top Test switch on the Building Pressure Contact Buffer in RPS channel A.  <u>POSITIVE CUE:</u> Top Test switch on the Building Pressure Contact Buffer is depressed.	Top Test switch on the Building Pressure Contact Buffer depressed in RPS channel A.	—	—	—
	4. Verify the following: <ul style="list-style-type: none"> <li>On Building Pressure Contact Buffer, both Input State lamps go ON.</li> <li>The Reactor Trip module Subsystem Trip lamp goes ON bright.</li> <li>All RPS Channel Reactor Trip modules and Indicating Panel Protective Subsystem lamps for the tripped channel go ON bright.</li> </ul> <u>POSITIVE CUE:</u> Building Pressure Contact Buffer, both Input State lamps are ON. The Reactor Trip module Subsystem Trip lamp are ON bright. All RPS Channel Reactor Trip modules and Indicating Panel Protective Subsystem lamps for the "A" channel are ON bright.  <u>NEGATIVE CUE:</u> Building Pressure Contact Buffer, both Input State lamps are OFF. The Reactor Trip module Subsystem Trip lamp are DIM. All RPS Channel Reactor Trip modules and Indicating Panel Protective Subsystem lamps for the "A" channel are DIM.	Observed the following: <ul style="list-style-type: none"> <li>On Building Pressure Contact Buffer, both Input State lamps go ON.</li> <li>The Reactor Trip module Subsystem Trip lamp goes ON bright.</li> <li>All RPS Channel Reactor Trip modules and Indicating Panel Protective Subsystem lamps for the tripped channel go ON bright.</li> </ul>	—	—	—

Continued



JPM ID: A1-JPM-RO-RPS05

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
	<p>5. Make station log entry stating RPS Channel (A, B, C or D) has been manually tripped to satisfy LCO 3.3.1 Required Action A.1.</p> <p><u>POSITIVE CUE:</u> Additional operator has made the station log entry.</p>	Direct or initiate station log entry.	_____	_____	_____

END

JPM NUMBER: A1-JPM-RO-RPS05

## **INITIAL CONDITIONS:**

**Plant is at 100% power  
“A” RPS channel in manual bypass**

## **INITIATING CUE:**

**The CRS directs you to Place RPS Channel “A” in a Tripped Condition per Section 13 “Placing a Channel in a Tripped Condition in Support of NI Calibration, Channel Maintenance or Channel Calibration When One Channel is Inoperable” section of ‘NI & RPS OPERATING PROCEDURE’ (1105.001) through step 13.5. SM has suspended the SRO peer check**

# ENTERGY OPERATIONS INCORPORATED ARKANSAS NUCLEAR ONE

**TITLE: NI & RPS OPERATING PROCEDURE**

**DOCUMENT NO.**  
**1105.001**

**CHANGE NO.**  
**023**

**SET #**

**WORK PLAN EXP. DATE**  
**N/A**

**TC EXP. DATE**  
**N/A**

**SAFETY-RELATED**  
☒ **YES**    ☐ **NO**

**IPTE**  
☐ **YES**    ☒ **NO**

**TEMP ALT**  
☐ **YES**    ☒ **NO**

**LEVEL OF USE**  
☒ **CONTINUOUS**  
☐ **REFERENCE**  
☐ **INFORMATIONAL**

**PROGRAMMATIC EXCLUSION PER EN-LI-100**  
☐ **YES**    ☒ **NO**

**When you see these TRAPS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

**Get these TOOLS**

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**


**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.**  
**1000.006A**

**CHANGE NO.**  
**053**

PROC./WORK PLAN NO. 1105.001	PROCEDURE/WORK PLAN TITLE: NI & RPS OPERATING PROCEDURE	PAGE: 18 of 32 CHANGE: 023
---------------------------------	--	-------------------------------

**NOTE**

- De-energizing the Programmer Control Assembly is NOT required for a DC breaker failure.
- Failure of either the undervoltage or shunt trip device in an CRD trip breaker requires entering TS 3.3.4 Condition A.
- Failure of CRD trip breaker for reasons other than loss of either undervoltage or shunt trip device requires performance of TS 3.3.4 Condition B actions within 1 hour.
- Per TS 3.3.4 Bases, the electronic trip relays associated with Group 8 are not required to be tripped.

12.5.2      IF desired,  
                 THEN in the following cabinets, pull the Programmer Control Assembly 120V BUS 2 (F-3) fuse.

- CRD System Aux Supply A (C-72)
- CRD System Group 5 Regulating Supply A (C-64)
- CRD System Group 6 Regulating Supply A (C-66)
- CRD System Group 7 Regulating Supply A (C-68)

13.0    Placing a Channel in a Tripped Condition in Support of NI Calibration, Channel Maintenance or Channel Calibration When One Channel is Inoperable

**CAUTION**

Tripping an RPS channel with one channel already tripped will cause a reactor trip.

**NOTE**

- The Reactor Trip module Test Trip lamp will illuminate bright while the top Test switch on the Building Pressure Contact Buffer is depressed.
- SRO Peer Check is required for all action steps contained in this section.

13.1      Verify no RPS channel tripped.

13.2      Verify channel that is to be tripped is NOT in Manual Bypass.

13.3      For channel selected to be tripped, momentarily depress the top Test switch on the Building Pressure Contact Buffer.

PROC./WORK PLAN NO. 1105.001	PROCEDURE/WORK PLAN TITLE: <b>NI &amp; RPS OPERATING PROCEDURE</b>	PAGE: 19 of 32 CHANGE: 023
---------------------------------	---	-------------------------------

13.4 Verify the following:

- 13.4.1 On Building Pressure Contact Buffer, both Input State lamps go ON.
- 13.4.2 The Reactor Trip module Subsystem Trip lamp goes ON bright.
- 13.4.3 All RPS Channel Reactor Trip modules and Indicating Panel Protective Subsystem lamps for the tripped channel go ON bright.

13.5 Make station log entry stating RPS Channel (A, B, C or D) has been manually tripped to satisfy LCO 3.3.1 Required Action A.1.

**NOTE**

- Test and Maintenance Tags are not required to be removed.
- SASS Trip may occur due to maintenance.
- I&C procedure or work order should direct the positioning of Neutron Flux HS (HS-509) depending on the work performed.

13.6 IF danger tags installed,  
THEN remove Protective Tag from Manual Bypass key switches (Channel Bypass) on untripped channels per Protective and Caution Tagging (EN-OP-102).

13.6.1 Make station log entry stating "tags have been removed on RPS Channels (list channels)".

**NOTE**

- Test and Maintenance Tags are not required to be removed.
- SASS Trip may occur due to maintenance.
- I&C procedure or work order should direct the positioning of Neutron Flux HS (HS-509) depending on the work performed.

13.7 IF desired to perform NI Calibration,  
THEN direct I&C to perform NI Calibration.

13.7.1 For each channel to be bypassed, enter TS 3.3.1 Condition B for 2 channels of RPS inoperable.

**NOTE**

TS 3.3.1 Required Action B.1 is met at the completion of step 13.4.

13.8 IF desired to perform RPS Channel Calibration or Maintenance,  
THEN direct I&C to perform RPS Channel Calibration or Maintenance.

13.8.1 For each channel to be bypassed, enter TS 3.3.1 Condition B for 2 channels of RPS inoperable.

---

## S7. Plant Service System

A/D/E/S

K/A 076 A2.01

Service Water and Auxiliary  
Cooling Water System.

A1JPM-RO-SW003

## JOB PERFORMANCE MEASURE

Unit: 1 Rev # 9 Date: \_\_\_\_\_JPM ID: A1JPM-RO-SW003System/Duty Area: Service Water and Auxiliary Cooling Water SystemTask: Transfer of Service Water Suction from the Lake to the Emergency Cooling PondJTA# ANO1-RO-SWACW-NORM-31KA Value RO 3.5 SRO 3.7 KA Reference: 076 A2.01Approved For Administration To: RO X SRO XTask Location: Inside CR X Outside CR \_\_\_\_\_ Both \_\_\_\_\_

Suggested Testing Environment and Method (Perform or Simulate ):

Plant Site: \_\_\_\_\_ Simulator: Perform Lab: \_\_\_\_\_

Position Evaluated: RO: \_\_\_\_\_ SRO: \_\_\_\_\_

Actual Testing Environment: Plant Site \_\_\_\_\_ Simulator \_\_\_\_\_ Lab \_\_\_\_\_

Testing Method: Perform \_\_\_\_\_ Simulate \_\_\_\_\_

Approximate Completion Time in Minutes: \_\_\_\_\_ 15 Minutes

Reference(s): 1104.029 SW and Aux Cooling System (Section 10.2)

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

\*Signed \_\_\_\_\_ Date \_\_\_\_\_

\*Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

JPM ID: A1JPM-RO-SW003

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee

JPM INITIAL TASK CONDITIONS:

Service Water Pumps P-4A and P-4C are presently running. Sluice Gates SG-1, SG-2 and SG-4 are open. All other Sluice Gates are closed. Service Water Pump P-4B MOD is selected to the A4 Bus. Engineering SW flow test requires shifting P-4A SW suction from the Lake to the Emergency Cooling Pond. The ECP level is at ~5.65 feet, temperature is ~78°F, ECP suction screens are clean. Unit 2 has been notified, that we DO NOT intend to lower ECP level.

TASK STANDARD:

P-4A SW pump running with its Sluice Gate 1 reopened (or SG-3 also acceptable) following the failure of Sluice Gate 5 to open.

***This is an Alternate Success Path JPM.***

TASK PERFORMANCE AIDS: 1104.029 Section 10

SIMULATOR SETUP:

- Align P-4B MOD to A4 position.
- Verify SG-1, SG-2 and SG-4 open.
- Verify SG-3, SG-5, SG-6, SG-7 closed.
- Fail SG-5 in the closed position (Control valve malfunctions, SG5 to zero).



JPM ID: A1JPM-RO-SW003

INITIATING CUE: The CRS/SM directs you to transfer "A" SW bay suction from the lake to the emergency pond using 1104.029 Section 10.

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
INSTRUCTOR NOTE: Sluice Gate Stroke times are 3 to 4 minutes.					
	1. Select Service Water Diagnostic Instrumentation display on SPDS for the "A" SW pump.  <u>POSITIVE CUE:</u> "A" SW pump diagnostic display is selected on SPDS.	Selected Service Water Diagnostic Instrumentation display on SPDS for the "A" SW pump.	—	—	—
	2. Verify "A" SW Bay Level > 332 feet.  <u>POSITIVE CUE:</u> "A" SW Bay Level at ~338 feet.	Verified "A" SW Bay Level > 332 feet on SPDS.	—	—	—
	3. Ensure "B" SW Bay is supplied by "C" Service Water Bay or Emergency Cooling Pond.  <u>POSITIVE CUE:</u> SG-4 and SG-2 are open with red lights ON.	Verified "B" SW Bay supplied by "C" Service Water Bay by verifying SG-4 open.	—	—	—
	4. Verify SG-3 closed.  <u>POSITIVE CUE:</u> Green light ON, red light OFF for sluice gate 3.  <u>NEGATIVE CUE:</u> Red light ON, green light OFF for sluice gate 3.	Verified that sluice gate 3 is closed.	—	—	—
C	5. Close Lake Supply to "A" SW Bay SG-1.  <u>POSITIVE CUE:</u> Green light ON, red light OFF for sluice gate 1.  <u>NEGATIVE CUE:</u> Red light ON, green light OFF for sluice gate 1.	Closed sluice gate 1 by taking SG-1 handswitch to the close position and observing the correct light indication.	—	—	—

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
C	<p>6. Without delay, open Pond Supply to "A" SW Bay SG-5.</p> <p><u>FAULTED CUE:</u> SG-5 red light OFF, green light ON.</p> <p><u>NEGATIVE CUE:</u> "A" SW Bay Level Lo alarm in.</p>	On C26, positioned the handswitch for SG-5 to the open position. Identified Sluice gate 5 failure to open from handswitch. The valve did not respond and did not observe the correct light indication (Red light does NOT come ON).	—	—	—
C	<p>7. Without delay, re-open lake Supply to "A" SW Bay SG-1 or SG-3.</p> <p><u>POSITIVE CUE:</u> SG-1 or SG-3 opened without delay, red light ON, green light OFF. SG-1 breaker opens when SG-1 switch is taken to open and applicant must open SG-3</p> <p><u>NEGATIVE CUE:</u> "A" SW Bay Level Lo alarm in, SG-1 OR SG-3 green light ON (as applicable).</p>	Opened sluice gate 3 by taking handswitch to the open position and observing the correct light indication (red light ON, green light OFF for SG-3).	—	—	—
	<p>8. Stop and inform CRS/SM.</p> <p><u>POSITIVE CUE:</u> CRS/SM informed.</p>	Stopped and informed CRS/SM.	—	—	—
After the CRS/SM is informed Examinee should state task is completed or Examiner may tell Examinee that the JPM is complete.					

END

JPM ID: A1JPM-RO-SW003

## **INITIAL CONDITIONS:**

**Service Water Pumps P-4A and P-4C are presently running. Sluice Gates SG-1, SG-2 and SG-4 are open. All other Sluice Gates are closed. Service Water Pump P-4B MOD is selected to the A4 Bus. Engineering SW flow test requires shifting P-4A SW suction from the Lake to the Emergency Cooling Pond. The ECP level is at ~5.65 feet, temperature is ~78°F, ECP suction screens are clean.**

**Unit 2 has been notified, we DO NOT intend to lower ECP level.**

## **INITIATING CUE:**

**The CRS/SM directs you to transfer “A” SW bay suction from the lake to the emergency pond using 1104.029 Section 10.**

# ENTERGY OPERATIONS INCORPORATED ARKANSAS NUCLEAR ONE

**TITLE: SERVICE WATER AND AUXILIARY COOLING  
SYSTEM**

**DOCUMENT NO.**  
1104.029

**CHANGE NO.**  
071

**SET #**

**WORK PLAN EXP. DATE**  
N/A

**SAFETY-RELATED**  
☒ YES ☐ NO

**IPTE**  
☐ YES ☒ NO

**TEMP MOD**  
☐ YES ☒ NO

**LEVEL OF USE**  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL

**PROGRAMMATIC EXCLUSION PER EN-LI-100**  
☐ YES ☒ NO

**When you see these TRAPS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

**Get these TOOLS**

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.**  
1000.006A

**CHANGE NO.**  
054

PROC./WORK PLAN NO. 1104.029	PROCEDURE/WORK PLAN TITLE: SERVICE WATER AND AUXILIARY COOLING SYSTEM	PAGE: 24 of 273 CHANGE: 071
---------------------------------	--	--------------------------------

**NOTE**

- One or all of the SW bays may be aligned to ECP. If all SW bays are aligned, consider aligning at least one bay back to lake early before desired level is reached.
- The ECP contains 4,560,000 gallons/foot.
- Example calc for lowering 0.3 feet with 1 of 2 in-service bays aligned and sum of SW Loop 1, SW Loop 2, ACW total flow rate of 10,000 gpm, with NO discharge back to ECP:

$$\frac{4,560,000 \text{ gal/ft} \times 0.3 \text{ ft}}{(10,000 \text{ gpm} / 2)} = \sim 274 \text{ minutes } (\sim 4.5 \text{ hours})$$

D. Estimate duration of evolution and record below:

\_\_\_\_\_ minutes / hours

1. Obtain SRO review of calculation.

10.2.4 IF needed,  
THEN align "A" SW bay to ECP by performing the following:

**CAUTION**

Analyses for Unit 1 long-term containment cooling following a Design Bases LOCA do not account for the SW Pump suction initially aligned to the ECP. In such a case, long-term containment cooling will eventually require SW suction from the lake. Therefore, time spent with SW Pump suction aligned to the ECP with the SW Pump in operation, other than "Loss of Dardanelle Reservoir" or "Excessive debris accumulation at the Intake Structure", or "Controlled Conditions" to support Maintenance or Testing, should be minimized.

A. Select Service Water Diagnostic Instrumentation display on SPDS for the "A" SW pump.

**CAUTION**

With SW Bay Level starting at  $\leq 332$  feet and SW Flow  $\geq 8000$  gpm, SW pump NPSH limits could be exceeded during suction transfer from Lake to Pond. This could result in pump damage.

B. Except during SW emergencies, verify "A" SW Bay Level  $> 332$  feet.

C. Ensure "B" SW Bay is being supplied by one of the following:

- "C" Service Water Bay
- Emergency cooling pond

D. Verify SG-3 closed.

PROC./WORK PLAN NO. 1104.029	PROCEDURE/WORK PLAN TITLE: SERVICE WATER AND AUXILIARY COOLING SYSTEM	PAGE: 25 of 273 CHANGE: 071
---------------------------------	--	--------------------------------



**NOTE**

- Any delay during the performance of the following series of steps could result in lowering "A" SW Bay level.
- Aligning a SW Pump suction to Emergency Cooling Pond will cause the ECP level to drop.

- E. Close Lake Supply to "A" SW Bay (SG-1).
- F. Without delay, open Pond Supply to "A" SW Bay (SG-5).
- G. IF SG-5 fails to operate,  
THEN open one of the following sluice gate combinations to supply SW bay until condition can be resolved:
- Open SG-1.
  - Open SG-3,  
AND if needed to supply "B" SW bay, THEN open SG-4.
1. Stop and inform CRS/SM.

**CAUTION**

Sediment may enter pump suction when going on emergency pond.

- H. Monitor P-4A discharge pressure and strainer  $\Delta P$  while in this configuration.
- I. Verify successful transfer from lake to pond by observing a rise in bay level indication on SPDS and proper sluice gate position indication.
- J. IF a LOCA occurs while in this configuration,  
THEN align all SW pump suctions to the lake, per "Transferring from Emergency Pond to Lake", section of this procedure. 
- K. IF a loss of lake event occurs while in this configuration,  
THEN perform the following: 
1. Check ECP level  $\geq 5.6$  ft.
  2. IF ECP level  $< 5.6$  ft.  
THEN align all SW pump suctions to the lake, per "Transferring from Emergency Pond to Lake" section of this procedure.
  3. GO TO Natural Emergencies (1203.025).

---

P1. Heat Removal from Reactor  
Core (Secondary)

D/E/R/EN

K/A 061 K5.05

Relieve steam binding of an  
Emergency Feedwater Pump.

A1JPM-RO-EFW03

## JOB PERFORMANCE MEASURE

Unit: 1 Rev # 10 Date: \_\_\_\_\_  
JPM ID: A1JPM-RO-EFW03

System/Duty Area: Emergency Feedwater

Task: Relieve Steam Binding of an Emergency Feedwater Pump

JTA# ANO1-WCO-EFW-NORM-12

KA Value RO 2.7 SRO 3.2 KA Reference 061 K5.05

Approved For Administration To: RO X SRO X

Task Location: Inside CR: \_\_\_\_\_ Outside CR: X Both: \_\_\_\_\_

Suggested Testing Environment And Method (Perform Or Simulate):

Plant Site: Simulate Simulator: \_\_\_\_\_ Lab: \_\_\_\_\_

Position Evaluated: RO: \_\_\_\_\_ SRO: \_\_\_\_\_

Actual Testing Environment: Simulator: \_\_\_\_\_ Plant Site: X Lab \_\_\_\_\_

Testing Method: Simulate: X Perform: \_\_\_\_\_

Approximate Completion Time In Minutes: \_\_\_\_\_ 18 Minutes

Reference(S) 1106.006, Emergency Feedwater Operation  
:  
\_\_\_\_\_  
\_\_\_\_\_

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

Signed \_\_\_\_\_ Date: \_\_\_\_\_

Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.



JPM ID: A1JPM-RO-EFW03

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

JPM INITIAL TASK CONDITIONS:

EFW pump P-7B is steam bound due to back leakage from the "B" OTSG

P-7B is stopped

"B" OTSG feed line is hot.

Pyrometer readings taken at the penetration, pump casing, and discharge piping are 215 °F.

CV-2626 has been closed.

EFW CST, T41B, temperature is 80 °F.

You have a contact pyrometer in your possession (simulated).

TASK STANDARD:

P-7B pump casing is cooled to < 180 °F and P-7B is realigned for normal operation.

TASK PERFORMANCE AIDS:

Copy of OP 1106.06 Section 14.0.

INITIATING CUE: The SM/CRS directs that you relieve steam binding of EFW Pump P-7B and realign pump for normal operation. Per 1106.006 Emergency Feedwater pump Operation section 14.0 Relieving EFW pump Steam Bind steps 14.1.1 through 14.1.4 have been completed.

C	PERFORMANCE CHECKLIST	STANDARDS	N/A	SAT	UN SAT
TRANSITION NOTE: The examinee should proceed to the Auxiliary Building 335' elevation EFW pump room.					
C	1. Shift P-7B minimum recirc flow to the discharge flume.  <u>POSITIVE CUE:</u> FW-12B is open, valve stem is UP.	Shifted minimum recirc flow to the discharge flume by opening FW-12B.	—	—	—
C	2. Isolate minimum recirc flow line from P-7B to the CST.  <u>POSITIVE CUE:</u> FW-11B is closed, valve stem is DOWN.	Isolated minimum recirc flow line from P-7B to the CST by unlocking and closing FW-11B.	—	—	—
INSTRUCTOR NOTE: Inform examinee that the CRS has made an entry in the Category E/Locked Component Log.					
C	3. Gravity flow cold water from CST through EFW pump P-7B via minimum recirc to flume until the temperature difference between pump casing and fluid being pumped is <100 °F.  <u>POSITIVE CUE:</u> P-7B Pump casing is cooled down to 170 °F.  <u>NEGATIVE CUE:</u> Pump casing is NOT cooling down.	Measured temperature of P-7B using contact pyrometer. Allowed gravity flow of cold CST water through EFW pump to flume until pyrometer reading was < 180°F.	—	—	—
C	4. Align Minimum Recirc to the CST.  <u>POSITIVE CUE:</u> FW-11B is open, stem is UP. Valve is locked.	Aligned Minimum Recirc to the CST by opening and locking FW-11B.	—	—	—
INSTRUCTOR NOTE: Inform examinee that the CRS will send another operator to perform independent verification on FW-11B.					
C	5. Isolate minimum recirc discharge to flume.  <u>POSITIVE CUE:</u> FW-12B is closed, stem is DOWN.  <u>NEGATIVE CUE:</u> Flow indicated on EFW flow recirc indicator FI-2801.	Isolated minimum recirc discharge to flume by closing FW-12B.	—	—	—

END

**INITIAL CONDITIONS:**

**EFW pump P-7B is steam bound due to back leakage from the "B" OTSG**

**P-7B is stopped**

**"B" OTSG feed line is hot.**

**Pyrometer readings taken at the penetration, pump casing, and discharge piping are 215 °F.**

**CV-2626 has been closed.**

**EFW CST, T41B, temperature is 80 °F.**

**You have a contact pyrometer in your possession (simulated).**

**INITIATING CUE:**

**The SM/CRS directs that you relieve steam binding of EFW Pump P-7B and realign pump for normal operation. Per 1106.006 Emergency Feedwater pump Operation section 14.0 Relieving EFW pump Steam Bind steps 14.1.1 through 14.1.4 have been completed.**

**ENTERGY OPERATIONS INCORPORATED  
ARKANSAS NUCLEAR ONE**

**TITLE: EMERGENCY FEEDWATER PUMP  
OPERATION**

**DOCUMENT NO.  
1106.006**

**CHANGE NO.  
073**

**SET #**

**WORK PLAN EXP. DATE  
N/A**

**SAFETY-RELATED  
☒ YES ☐ NO**

**IPTE  
☒ YES ☐ NO**

**TEMP MOD  
☒ YES ☐ NO**

**LEVEL OF USE  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL**

**PROGRAMMATIC EXCLUSION PER EN-LI-100  
☐ YES ☒ NO**

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____
_____	_____	_____

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.  
1000.006A**

**CHANGE NO.  
054**

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 24 of 209 CHANGE: 073
---------------------------------	--	--------------------------------

14.0 Relieving EFW Pump Steam Bind

**NOTE**

- ✓ Events have occurred at other facilities where backleakage from hot feedwater systems has resulted in inoperable EFW pumps due to steam binding. The configuration of the EFW system at ANO makes the condition unlikely, however, this section of the procedure provides instructions for relieving this condition should it occur. Steam binding may be detected through rising EFW discharge pipe temperature, surveillances, or a failure of the pump to develop a discharge pressure when started.
- ✓ Steam binding renders affected EFW pump inoperable.

14.1 Perform the following to relieve steam binding of an EFW Pump (P-7A OR P-7B):

14.1.1 IF P-7A OR P-7B is running,  
THEN secure pump.

14.1.2 Determine which EFW line has backleakage by checking temperature by touch at each EFW line at the penetrations.

**NOTE**

- EFW piping temperatures of  $>150^{\circ}\text{F}$  may place the EFW piping in an unanalyzed condition. The affected EFW pump may be inoperable. A Condition Report should be initiated to determine operability.
- EFW piping temperature of  $>240^{\circ}\text{F}$  at Reactor Building penetration may place the penetration in an unanalyzed condition. A Condition Report should be initiated to determine operability.

14.1.3 Using a pyrometer, obtain temperatures at the following locations:

- A Locally at the penetrations.
- B The affected pump casing.
- C The affected pump discharge piping.

PROC./WORK PLAN NO. 1106.006	PROCEDURE/WORK PLAN TITLE: EMERGENCY FEEDWATER PUMP OPERATION	PAGE: 25 of 209 CHANGE: 073
---------------------------------	--	--------------------------------

{4.3.2}

NOTE

- The EFW Isolation valves are gate valves which are susceptible to thermal binding. If a valve is closed hot, and then cooled down, it may bind during future attempts to open. This could place an unanalyzed load on the valve and its operation could become degraded. For this reason, a Condition Report and an engineering evaluation will be required prior to returning the system, train, or path, to operable status.
- Refer to "Operability" section, EFW Isolation Valve paragraph.

14.1.4 Close the EFW isolation to the SGs for the affected pump:

*N/A* EFW P-7A to SG-B Isol (CV-2620)

☒ EFW P-7B to SG-B Isol (CV-2626)

*N/A* EFW P-7A to SG-A Isol (CV-2627)

☒ EFW P-7B to SG-A Isol (CV-2670)

14.1.5 Shift minimum recirc flow for affected EFW pump discharge to flume by slowly opening applicable valve:

- P-7A Mini Recirc Disch to Flume Isol (FW-12A)

- P-7B Mini Recirc Disch to Flume Isol (FW-12B)

14.1.6 Isolate minimum recirc flow for affected EFW pump discharge to CST by unlocking and closing applicable valve:

- P-7A Minimum Recirc to CST (FW-11A)

- P-7B Minimum Recirc to CST (FW-11B)

A. Make appropriate entry on Category E/Locked Component Log (E-DOC 1015.001H).

14.1.7 While monitoring EFW CST T-41B level, gravity flow cold water from CST through EFW pump via minimum recirc to flume until the temperature difference between pump casing and fluid being pumped is <100°F, as measured by pyrometer.

14.1.8 Open and lock the aligned minimum recirc discharge to CST:

- FW-11A

- FW-11B

A. Perform required independent verification AND enter on Category E/Locked Component Log (E-DOC 1015.001H).

14.1.9 Close the aligned minimum recirc discharge to flume:

- FW-12A

- FW-12B

PROC./WORK PLAN NO. <b>1106.006</b>	PROCEDURE/WORK PLAN TITLE: <b>EMERGENCY FEEDWATER PUMP OPERATION</b>	PAGE: <b>26 of 209</b> CHANGE: <b>073</b>
--	---	--

{4.3.2}

- 14.1.10 Contact Engineering to perform an analysis on the EFW Isolation gate valve(s) that will be stroked in the following process.

**CAUTION**

Affected EFW pump should not be operated with a temperature difference of >100°F between pump casing and fluid being pumped.

- 14.1.11 Start the affected EFW pump per applicable portions of Supplements 2, 11 or 12 of this procedure.
- 14.1.12 Cycle the EFW Isolation valve for the affected EFW pipe that had indications of backleakage:
- EFW P-7A to SG-B Isol (CV-2620)
  - EFW P-7B to SG-B Isol (CV-2626)
  - EFW P-7A to SG-A Isol (CV-2627)
  - EFW P-7B to SG-A Isol (CV-2670)
- 14.1.13 Verify affected check valve seats.
- A. IF check valve seats,  
THEN secure the affected EFW pump.
- B. IF check valve does NOT seat,  
THEN leave EFW pump in service recircing to CST  
AND consult with Operations Manager.

---

## P2. Instrumentation

N

K/A 012 A2.06

Remove Power from CRD System  
due to “D” RPS channel trip relay  
failure.

A1JPM-RO-RPS06



## JOB PERFORMANCE MEASURE

Unit: 1 Rev # 3 Date: \_\_\_\_\_JPM ID A1JPM-RO-RPS06System/Duty Area: Reactor Protection SystemTask: Remove Power from CRD System Due to "D" RPS channel trip relay failure.JA# ANO1-RO-RPS-NORM-2KA Value RO 4.4 SRO 4.7 KA Reference 012 A2.06Approved For Administration To: RO X SRO XTask Location: Inside CR: \_\_\_\_\_ Outside CR: X Both: \_\_\_\_\_

Suggested Testing Environment And Method (Perform Or Simulate #):

Plant Site: Simulate Simulator#: \_\_\_\_\_ Lab: \_\_\_\_\_Position Evaluated: RO: X SRO: XActual Testing Environment: Simulator #: \_\_\_\_\_ Plant Site: X Lab \_\_\_\_\_Testing Method: Simulate: X Perform: \_\_\_\_\_Approximate Completion Time In 15 MinutesReference(S): 1105.001 NI & RPS OPERATING PROCEDURE

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

Signed # \_\_\_\_\_ Date: \_\_\_\_\_

# SIGNATURE INDICATES THIS JPM HAS BEEN COMPARED TO ITS APPLICABLE PROCEDURE BY A QUALIFIED INDIVIDUAL (NOT THE EXAMINEE) AND IS CURRENT WITH THAT REVISION.

JPM ID: A1JPM-RO-RPS06

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

JPM INITIAL TASK CONDITIONS:

**The plant is at 100% power.**

**"D" RPS Reactor Trip Module will not trip its output devices.**

TASK STANDARD: **Power removed from the DC Hold and SCR Gating Circuits associated with "D" RPS channel.**

TASK PERFORMANCE:      1105.001      **NI & RPS OPERATING PROCEDURE STEP 12.0**

JPM ID: A1JPM-RO-RPS06

INITIATING CUE: The CRS directs you to remove power from the DC hold and SCR gating circuits associated with "D" RPS channel per procedure 1105.001 NI & RPS OPERATING PROCEDURE step 12.0

Critical Tasks Steps: 4,5, and 6

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
<b>TRANSITION NOTE:</b> The examinee should move to the Computer Room on the 404 elevation.					
	1. Verify "A" and "B" CRD AC Breaker closed.  <u>POSITIVE CUE:</u> "A" and "B" CRD AC breakers closed..	At the CRD AC breaker cabinets, verified red "Closed" indication on (C49) the "A" and "B" CRD AC breakers.	—	—	— —
	2. Verify all four CRD DC Breakers closed (DC #1, #2, #3 and #4).  <u>POSITIVE CUE:</u> CRD DC Breakers DC#1, DC#2, DC#3, and DC#4 are closed.	At the CRD DC breaker cabinets, verified red "Closed" indication on (C 53 C&D) CRD DC breakers DC#1, DC#2, DC#3, and DC#4.	—	—	— —
	3. Verify at least 2 Gate Drives energized in each regulating and auxiliary power supply cabinet (total of 10 cabinets).  <u>POSITIVE CUE:</u> 2 red LEDs are illuminated in each of the listed cabinets..	Observed red LED illuminated on at least 2 Gate Drives in regulating cabinets:  — C72 — C67 — C73 — C68 — C64 — C69 — C65 — C70 — C66 — C71	—	—	— —
C	4. Trip CRD breakers DC#3.  <u>POSITIVE CUE:</u> CRD DC breaker DC#3 is open.	In CRD System DC Breaker Cabinet C-53D, depressed manual TRIP button for breaker DC #3.	—	—	— —
C	5. Trip CRD breakers DC#4.  <u>POSITIVE CUE:</u> CRD DC breaker DC#4 is open.	In CRD System DC Breaker Cabinet C-53, depressed manual TRIP button for breaker DC #4.	—	—	— —

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
C	<p>6. De-energize the gate drives associated with the "D" RPS cabinet</p> <p><u>POSITIVE CUE:</u> 120V ABT (F-3) fuse in cabinets C-72, C-64, C-66, and C-68 are removed.</p> <p><u>NEGATIVE CUE:</u> CRD system power associated with "D" RPS cabinet is not removed.</p>	<p>De-energized the gate drives by pulling the Programmer Control Assembly 120V BUS 2, (F-3) fuse in cabinets:</p> <ul style="list-style-type: none"> <li>• CRD System Aux Supply A (C-72)</li> <li>• CRD System Group 5 Regulating Supply A (C-64)</li> <li>• CRD System Group 6 Regulating Supply A (C-66)</li> <li>• CRD System Group 7 Regulating Supply A (C-68)</li> </ul>	—	—	—

END

JPM NUMBER: A1JPM-RO-RPS06

## INITIAL CONDITIONS:

The plant is at 100% power.

“D” RPS Reactor Trip Module will not trip its output devices.

## INITIATING CUE:

The CRS directs you to remove power from the DC hold and SCR gating circuits associated with “D” RPS channel per procedure 1105.001 NI &RPS OPERATING PROCEDURE step 12.0

# ENTERGY OPERATIONS INCORPORATED ARKANSAS NUCLEAR ONE

**TITLE: NI & RPS OPERATING PROCEDURE**

**DOCUMENT NO.**  
**1105.001**

**CHANGE NO.**  
**023**

**SET #**

**WORK PLAN EXP. DATE**  
**N/A**

**TC EXP. DATE**  
**N/A**

**SAFETY-RELATED**  
☒ YES ☐ NO

**IPTE**  
☐ YES ☒ NO

**TEMP ALT**  
☐ YES ☒ NO

**LEVEL OF USE**  
☒ CONTINUOUS  
☐ REFERENCE  
☐ INFORMATIONAL

**PROGRAMMATIC EXCLUSION PER EN-LI-100**  
☐ YES ☒ NO

**When you see these TRAPS**

**Get these TOOLS**

Time Pressure  
Distraction/Interruption  
Multiple Tasks  
Over Confidence  
Vague or Interpretive Guidance  
First Shift/Last Shift  
Peer Pressure  
Change/Off Normal  
Physical Environment  
Mental Stress (Home or Work)

Effective Communication  
Questioning Attitude  
Placekeeping  
Self Check  
Peer Check  
Knowledge  
Procedures  
Job Briefing  
Coaching  
Turnover

**VERIFIED BY**

**DATE**

**TIME**

**FORM TITLE:**

**VERIFICATION COVER SHEET**

**FORM NO.**  
**1000.006A**

**CHANGE NO.**  
**053**

PROC./WORK PLAN NO. <b>1105.001</b>	PROCEDURE/WORK PLAN TITLE: <b>NI &amp; RPS OPERATING PROCEDURE</b>	PAGE: <b>16 of 32</b> CHANGE: <b>023</b>
--	---	---

12.0 Removing Power From a Portion of the CRD System Due to a RPS Channel or RPS Trip Device Failure:

**NOTE**

- The Gate Drives are located in the upper section of each of the regulating and auxiliary power supply cabinets (C72, C73, C64, C65, C66, C67, C68, C69, C70 and C71); representing Group 5, 6, 7, 8 and the aux power supply).
- There are 6 gate drives in each regulating and auxiliary power supply cabinet, each representing a phase of CRD power.
- A red LED (LED1) on each of the Gate Drives indicates that the Gate Drive is energized. A minimum of 2 Gate Drives energized in each regulating and auxiliary power supply cabinets indicates the electronic trips are NOT tripped.

12.1 Verify CRD System does not have any tripped trip devices by performing the following:

12.1.1 Verify "A" and "B" CRD AC Breaker closed.

12.1.2 Verify all four CRD DC Breakers closed (DC #1, #2, #3 and #4).

12.1.3 Verify at least 2 Gate Drives energized in each regulating and auxiliary power supply cabinet (total of 10 cabinets).

___ C72	___ C67
___ C73	___ C68
___ C64	___ C69
___ C65	___ C70
___ C66	___ C71

**NOTE**

- Failure of either the undervoltage or shunt trip device in an CRD trip breaker requires entering TS 3.3.4 Condition A.
- Failure of CRD trip breaker for reasons other than loss of either undervoltage or shunt trip device requires performance of TS 3.3.4 Condition B actions within 1 hour.
- One inoperable Reactor Protection System Reactor Trip Module requires performance of actions associated with applicable TS 3.3.4 Condition(s) within 1 hour.

12.2 IF desired to open "A" CRD AC breaker associated with "A" RPS channel, THEN perform the following at AC Breaker Cabinet (C-49):

12.2.1 Depress "A" AC Breaker manual TRIP button.

PROC./WORK PLAN NO. <b>1105.001</b>	PROCEDURE/WORK PLAN TITLE: <b>NI &amp; RPS OPERATING PROCEDURE</b>	PAGE: <b>17 of 32</b> CHANGE: <b>023</b>
--	---	---

12.3 IF desired to open "B" CRD AC breaker associated with "B" RPS channel, THEN perform the following at AC Breaker Cabinet (C-49):

12.3.1 Depress "B" AC Breaker manual TRIP button.

12.4 IF desired to remove power from the DC Hold and SCR Gating Circuits associated with "C" RPS channel, THEN perform the following:

**NOTE**

DC#1 and DC#2 are located in the right hand side of CRD System DC Breaker Cabinet (C-53).

12.4.1 Depress manual TRIP button for the following breakers:

- A. DC#1
- B. DC#2

**NOTE**

- De-energizing the Programmer Control Assembly is not required for a DC breaker failure.
- With one or more electronic trip relays inoperable, performance of TS 3.3.4 Condition C action is required within one hour.
- Per TS 3.3.4 bases, the electronic trip relays associated with Group 8 are not required to be operable.

12.4.2 IF desired, THEN in the following cabinets, pull the Programmer Control Assembly 120V ABT (F-2) fuse.

- CRD System Aux Supply A (C-72)
- CRD System Group 5 Regulating Supply A (C-64)
- CRD System Group 6 Regulating Supply A (C-66)
- CRD System Group 7 Regulating Supply A (C-68)

12.5 IF desired to remove power from the DC Hold and SCR Gating Circuits associated with "D" RPS channel, THEN perform the following:

**NOTE**

DC#3 and DC#4 are located in the left hand side of CRD System DC Breaker Cabinet (C-53).

12.5.1 Depress manual TRIP button for the following breakers:

- A. DC#3
- B. DC#4



PROC./WORK PLAN NO. 1105.001	PROCEDURE/WORK PLAN TITLE: NI & RPS OPERATING PROCEDURE	PAGE: 18 of 32 CHANGE: 023
---------------------------------	--	-------------------------------

**NOTE**

- De-energizing the Programmer Control Assembly is NOT required for a DC breaker failure.
- Failure of either the undervoltage or shunt trip device in an CRD trip breaker requires entering TS 3.3.4 Condition A.
- Failure of CRD trip breaker for reasons other than loss of either undervoltage or shunt trip device requires performance of TS 3.3.4 Condition B actions within 1 hour.
- Per TS 3.3.4 Bases, the electronic trip relays associated with Group 8 are not required to be tripped.

12.5.2      IF desired,  
                 THEN in the following cabinets, pull the Programmer Control Assembly 120V BUS 2 (F-3) fuse.

- CRD System Aux Supply A (C-72)
- CRD System Group 5 Regulating Supply A (C-64)
- CRD System Group 6 Regulating Supply A (C-66)
- CRD System Group 7 Regulating Supply A (C-68)

13.0    Placing a Channel in a Tripped Condition in Support of NI Calibration, Channel Maintenance or Channel Calibration When One Channel is Inoperable

**CAUTION**

Tripping an RPS channel with one channel already tripped will cause a reactor trip.

**NOTE**

- The Reactor Trip module Test Trip lamp will illuminate bright while the top Test switch on the Building Pressure Contact Buffer is depressed.
- SRO Peer Check is required for all action steps contained in this section.

13.1      Verify no RPS channel tripped.

13.2      Verify channel that is to be tripped is NOT in Manual Bypass.

13.3      For channel selected to be tripped, momentarily depress the top Test switch on the Building Pressure Contact Buffer.

---

## P3. Radioactivity Release

D/P/R

K/A 071 A4.26

Waste Gas Decay Tank release.

A1JPM-RO-GRW01

TUOI NUMBER: ANO-1-JPM-RO-GRW01

## .JOB PERFORMANCE MEASURE

Unit: 1 Rev # 4 Date: \_\_\_\_\_TUOI NUMBER: ANO-1-JPM-RO-GRW01System/Duty Area: Gaseous Radwaste / Radioactivity ReleaseTask: Commence Waste Gas Decay Tank ReleaseJA# ANO1-WCO-GZ01-NORM-11KA Value RO 3.1 SRO 3.9 KA Reference 071 A4.26Approved For Administration To: RO ☒ SRO ☒Task Location: Inside CR: ☐ Outside CR: ☒ Both: ☐

Suggested Testing Environment And Method (Perform Or Simulate #):

Plant Site: Simulate Simulator#: \_\_\_\_\_ Lab: \_\_\_\_\_

Position Evaluated: RO: \_\_\_\_\_ SRO: \_\_\_\_\_

Actual Testing Environment: Simulator #: \_\_\_\_\_ Plant Site: X Lab \_\_\_\_\_Testing Method: Simulate: X Perform: \_\_\_\_\_Approximate Completion Time In Minutes: 15 MinutesReference(S): 1104.022, Chg. 034-00-0, Att. C

Examinee's Name: \_\_\_\_\_ SSN: \_\_\_\_\_

Evaluator's Name: \_\_\_\_\_

The Examinee's performance was evaluated against the standards contained in this JPM and is determined to be:

Satisfactory: \_\_\_\_\_ Unsatisfactory: \_\_\_\_\_

Performance Checklist Comments:

\_\_\_\_\_

\_\_\_\_\_

\_\_\_\_\_

Start Time \_\_\_\_\_ Stop Time \_\_\_\_\_ Total Time \_\_\_\_\_

Signed # \_\_\_\_\_ Date: \_\_\_\_\_

# TQ-202 attachment 9 is complete and on file for performance of this JPM for the current Reactor core configuration.

Signature indicates this JPM has been compared to its applicable procedure by a qualified individual (not the examinee) and is current with that revision.

TUOI NUMBER: ANO-1-JPM-RO-GRW01

THE EXAMINER SHALL REVIEW THE FOLLOWING WITH THE EXAMINEE:

The examiner shall review the "Briefing Checklist - System Walkthrough" portion of OP 1064.023 Attachment 6 with the examinee.

**JPM INITIAL TASK CONDITIONS:**

The Shift Chemist has returned Gaseous Release Permit 1GW-2008-002 to the Control Room for T-18A Waste Gas Decay Tank.

A Pre-Job brief has been conducted and a second operator is available for verification of reach rod operated valves.

The CRS directs you to commence T-18A release beginning with step 4.3.2 of 1104.022, Att. C.

**TASK STANDARD:**

Release commenced per 1104.022, Att. C, at flow rate specified.

**TASK PERFORMANCE AIDS:** 1104.022, Att. C

TUOI NUMBER: ANO-1-JPM-RO-GRW01

INITIATING CUE: The CRS directs you to commence T-18A release beginning with step 4.3.2 of 1104.022, Att. C through step 4.7.

C	PERFORMANCE CHECKLIST	STANDARD	N/A	SAT	UN SAT
C	1. Open T-18A outlet valve. <u>POSITIVE CUE:</u> GZ-13A open and verified by second operator.	Operator opened T-18A outlet valve, GZ-13A.	—	—	—
	2. Verify other decay tank outlet isolations closed. <u>POSITIVE CUE:</u> GZ-13B/C/D closed.	Operator verified outlet valves GZ-13B/C/D closed.	—	—	—
	3. Determine RE 4830 is operable <u>POSITIVE CUE:</u> RE 4830 is operable	Determines RE 4830 is operable and N/A step	—	—	—
C	4. Open CV-4820 outlet isolation GZ-15. <u>POSITIVE CUE:</u> GZ-15 is open.	Operator opened CV-4820 outlet isolation GZ-15.	—	—	—
	5. Notify control room of intent to begin release. <u>POSITIVE CUE:</u> Control Room notified.	Operator contacted control room and informed them of intent to begin release.	—	—	—
	6. Record release data. <u>POSITIVE CUE:</u> Data recorded and chart recorders marked.	Operator recorded in Att. C Release number, start time, date and tank being released and marked chart recorders with same information. Operator will contact control room and have them mark RR-4830.			
C	7. Open discharge header flow control valve using HIC-4820. <u>POSITIVE CUE:</u> CV-4820 opened and data recorded	Operator opened CV-4820 and established release flow rate listed on preliminary report.			
<b>EXAMINER NOTE:</b> <b>Remaining steps are continuous action steps until release is complete. JPM is complete</b>					

END

TUOI NUMBER: ANO-1-JPM-RO-GRW01

**INITIAL CONDITIONS:**

**The Shift Chemist has returned Gaseous Release Permit 1GW-2008-002 to the Control Room for T-18A Waste Gas Decay Tank.**

**A Pre-Job brief has been conducted and a second operator is available for verification of reach rod operated valves.**

**INITIATING CUE:**

**The CRS directs you to commence T-18A release beginning with step 4.3.2 of 1104.022, Att. C through step 4.7.**

PROC./WORK PLAN NO. 1104.022	PROCEDURE/WORK PLAN TITLE: GASEOUS RADWASTE SYSTEM	PAGE: 44 of 52 CHANGE: 034-00-0
---------------------------------	---	------------------------------------

ATTACHMENT C

GASEOUS RELEASE PERMIT

Page 1 of 9

PERMIT # 1GW2008-02 (Assigned by Chemistry) 9-4-2008  
Date

- 1.0 REQUEST (Operations) INITIALS
- 1.1 Waste Gas Decay Tank (circle one): DMT
- T-18A T-18B T-18C T-18D
- 1.2 Initial tank pressure 85 psig. DMT

DMT **NOTE**  
If plant and tank conditions permit, short-lived gaseous activity should be held for a minimum of 30 days to allow for decay.

- 1.3 Ensure tags have been hung on tank to be released per "Waste Gas Decay Tanks (T18A thru D)" section of this procedure. DMT

Date tags hung: 6/18/2008

Duration tags hung: 78 days

- 1.4 IF short-lived gaseous activity is present, THEN perform one of the following:
- 1 Hold tank contents for a minimum of 30 days. DMT
- 2 Explain why tank contents must be released in <30 days. N/A

- 1.5 Check Gaseous Radwaste Process Monitor (RI-4830) available by one of the following methods (ODCM App.1, 2.2-2.1.a):

1.5.1 IF monitor count rate is  $\leq 1000$  cpm, THEN select CHECK SOURCE on RI-4830 and verify that the monitor responds to check source with a count rate rise  $>100$  cpm. N/A

1.5.2 IF monitor count rate  $>1000$  cpm, THEN verify that count rate is  $<8.9E6$ . DMT

1.5.3 IF neither 1.5.1 nor 1.5.2 can be satisfied, THEN RI-4830 shall be considered unavailable for this release. N/A

PROC./WORK PLAN NO. 1104.022	PROCEDURE/WORK PLAN TITLE: GASEOUS RADWASTE SYSTEM	PAGE: 45 of 52 CHANGE: 034-00-0
---------------------------------	---	------------------------------------

ATTACHMENT C

Page 2 of 9

①/6 Shift Manager/CRS Approval Abel Leander  
SM/CRS

①/7 Submitted to Chemistry for analysis  
by: Paul Taylor Date 9/4/2008 Time 0430

②/0 ANALYSIS (Chemistry)

②/1 Sample of tank T-18A for gamma spectroscopy obtained  
by: Jamie Chinnity

②.1.1 Record M&TE number CRO-026  
Cal Expiration Date 12-21-08

**NOTE**  
If an independent sample and analysis is needed per step 2.4, independent sampling and analysis may be performed concurrently with the following steps.

②/2 Gamma spectroscopy performed by: Jamie Chinnity

②/3 Gamma spectroscopy report reviewed by: Mike Proch

③/4 IF Gaseous Radwaste (RI-4830) is inoperable  
OR is unavailable (per steps 1.5 or 3.5.1),  
THEN perform the following:  
OTHERWISE mark 2.4.1 and 2.4.2 N/A. (ODCM App.1, Table 2.2-1)

2.4.1 An independent sample shall be obtained and analyzed.  
Independent sample and analysis performed by:  
N/A Date N/A

2.4.2 An independent verification of computer input data shall be  
performed. Independent verification performed by:  
N/A Date N/A

②/5 Preliminary release report generated by: Jamie Chinnity

②/6 Tank pressure at which release is to be terminated 0 psig  
by: Jamie Chinnity

②/7 SPING 2 setpoint value(s) adjusted per 1604.051 and Form 1604.051E  
by: Jamie Chinnity

②/8 Preliminary report returned to operations  
by: Jamie Chinnity Date 9/4/2008 Time 0700



PROC./WORK PLAN NO. 1104.022	PROCEDURE/WORK PLAN TITLE: <b>GASEOUS RADWASTE SYSTEM</b>	PAGE: 46 of 52 CHANGE: 034-00-0
---------------------------------	--	------------------------------------

ATTACHMENT C

Page 3 of 9

3.0 VERIFICATION OF TECH SPEC COMMITMENTS (Operations)

3.1 Verify Waste Gas Decay Tank circled in step 1.1 is the same tank as:

- ☒ Tank that was sampled in step 2.1 and
- ☒ Same tank as listed on preliminary report.

DMT  
DMT

3.1.1 Verify appropriate signature on preliminary report.

DMT

3.2 Verify no other gaseous release in progress.

DMT

3.3 Verify Radwaste Area Exhaust Fan (VEF-8A or VEF-8B) running (circle one).

DMT

3.4 Verify SPING 2 Radwaste Area (RX-9825) status is "Normal" on RDACS (ODCM App. 1, 2.2-2.2.a, b, and c).

DMT

3.5 IF Gaseous Radwaste (RI-4830) is operable AND is available, THEN verify proper operation of the associated interlocks and the Gaseous Waste DISCH Flow (FR-4831) as follows: (ODCM App.1, Table 2.2-1). OTHERWISE mark step 3.5 N/A and GO TO step 3.6.

DMT

3.5.1 Check Gaseous Radwaste Process Monitor (RI-4830) available by one of the following methods (ODCM App.1, 2.2-2.1.a):

☒ IF monitor count rate is  $\leq 1000$  cpm, THEN select CHECK SOURCE on RI-4830 AND verify that the monitor responds to check source with a count rate rise  $> 100$  cpm.

N/A

☒ B. IF monitor count rate  $> 1000$  cpm, THEN verify that count rate is  $< 8.9E6$ .

DMT

☒ N/A IF neither A nor B above can be satisfied, THEN RI-4830 shall be considered unavailable AND N/A the remainder of this step.

N/A

3.5.2 Verify tank outlet valves closed:

- ☒ T-18A Outlet Isolation (GZ-13A)
- ☒ T-18B Outlet Isolation (GZ-13B)
- ☒ T-18C Outlet Isolation (GZ-13C)
- ☒ T-18D Outlet Isolation (GZ-13D)

DMT  
DMT  
DMT  
DMT

3.5.3 Verify Station Vent Discharge Valve (CV-4830) open.

DMT

3.5.4 Verify FR-4831 indicates system flow from T-17 purge.

DMT

PROC./WORK PLAN NO. 1104.022	PROCEDURE/WORK PLAN TITLE: <b>GASEOUS RADWASTE SYSTEM</b>	PAGE: 48 of 52 CHANGE: 034-00-0
---------------------------------	--	------------------------------------

ATTACHMENT C

Page 5 of 9

3.7 Shift Manager/CRS approval to proceed with release:

AL  
SM

**NOTE**

Simultaneous radioactive gaseous releases are not permitted.

Abel Leader SM/CRS Unit 1  
Nathan Shiffy SM/CRS Unit 2

4.0 RELEASE (Operations)

4.1 IF Gaseous Radwaste (RI-4830) is operable  
AND is available,  
THEN perform the following:

4.1.1 Record RI-4830 pre-release,  
as-found setpoint: 2.8E3 cpm. out

4.1.2 Record Setpoint from preliminary report:  
Setpoint: 3.4E5 cpm out

4.1.3 IF setpoint from preliminary report is <50,000 cpm,  
THEN 50,000 cpm should be used as this release  
setpoint. NA

4.1.4 Adjust setpoint to 3.4E5 cpm  
(from preliminary report, or 50,000 cpm,  
whichever is greater). out

K. Licensed Operator, other than individual  
who initially set RI-4830 setpoint  
independently verify correct RI-4830  
setpoint from preliminary report.

Independent verification by df

4.2 Verify T-18s Discharge to Gaseous Radwaste Discharge Header  
Flow Control Valve (CV-4820) closed. out

4.3 Align T-18 for release as follows:

4.3.1 Remove tag on the T-18 outlet valve. out

PROC./WORK PLAN NO. <b>1104.022</b>	PROCEDURE/WORK PLAN TITLE: <b>GASEOUS RADWASTE SYSTEM</b>	PAGE: <b>49 of 52</b> CHANGE: <b>034-00-0</b>
--	--	--

ATTACHMENT C

Page 6 of 9

**NOTE**

The following step can cause the alarm "T-18 DISCHARGE LINE PRESSURE HIGH" and is expected for this alignment. Alarm should clear when release starts.

4.3.2 Open the outlet valve of the tank to be released. Check the (✓) valve that is opened. \_\_\_\_\_

- ( ) T-18A Outlet Isolation (GZ-13A)
- ( ) T-18B Outlet Isolation (GZ-13B)
- ( ) T-18C Outlet Isolation (GZ-13C)
- ( ) T-18D Outlet Isolation (GZ-13D)

4.3.3 Verify other outlet isolations closed. \_\_\_\_\_

4.3.4 IF Gaseous Radwaste (RI-4830) is inoperable  
OR is unavailable,  
THEN perform independent verification of  
step 4.3 (ODCM App.1, Table 2.2-1).

Independent verification \_\_\_\_\_

4.4 Open CV-4820 Outlet Isol (GZ-15). \_\_\_\_\_

4.5 Notify control room of intent to begin release. \_\_\_\_\_

4.6 Record the following data: \_\_\_\_\_

- Release Permit Number \_\_\_\_\_
- Release Start Time \_\_\_\_\_
- Date \_\_\_\_\_
- Tank being released \_\_\_\_\_

4.6.1 Mark the same data on the following recorders: \_\_\_\_\_

- Gaseous Waste DISCH Flow (FR-4831) \_\_\_\_\_
- Process Radiation Monitoring Effluent Recorder (RR-4830) \_\_\_\_\_

PROC./WORK PLAN NO. 1104.022	PROCEDURE/WORK PLAN TITLE: GASEOUS RADWASTE SYSTEM	PAGE: 50 of 52 CHANGE: 034-00-0
---------------------------------	---	------------------------------------

ATTACHMENT C

Page 7 of 9

**NOTE**

If "T-18 DISCHARGE LINE PRESSURE HIGH" alarm is present, then HS-4820 must be held in the open position while operating HIC-4820. When alarm is clear, then HS-4820 may be released.

- 4.7 While monitoring FR-4831, slowly operate HIC-4820 to open CV-4820 and establish the release flow rate listed on the preliminary report:  
≤ 10 cfm (ODCM App.1, 2.2-2.1.b).

- 4.8 IF CV-4830 trips closed during release due to high radiation,  
THEN this release shall be terminated per Waste Gas Discharge Line Radiation High (1203.006).

**NOTE**

An empty and isolated T-18 can pressurize during a release due to pressure in the discharge header leaking back through a discharge valve that is not gas tight. To ensure that the second T-18 was pressurized from the releasing tank it must meet the following criteria:

- Initial T-18 pressure was ~0 psig.
- Pressure rise began when release path aligned.
- No other venting or no Waste Gas Compressor operation was in progress.
- No other T-18 experienced a coincident pressure drop.

Under this condition the release may continue.

- 4.9 WHEN tank pressure is ~ \_\_\_\_\_ psig (value listed in step 2.6 of this attachment),  
THEN terminate release as follows:

4.9.1 Close CV-4820.

4.9.2 Verify flow rate on FR-4831 drops to the approximate flow setup for T-17 purge.

4.9.3 Close CV-4820 Outlet Isol (GZ-15).

4.10 Notify control room that release is complete.

4.11 Record the following data:

- Time release completed \_\_\_\_\_
- Date \_\_\_\_\_
- Release permit number \_\_\_\_\_

4.11.1 Mark same data on the following recorders:

- FR-4831
- RR-4830

PROC./WORK PLAN NO. 1104.022	PROCEDURE/WORK PLAN TITLE: GASEOUS RADWASTE SYSTEM	PAGE: 51 of 52 CHANGE: 034-00-0
---------------------------------	---	------------------------------------

ATTACHMENT C

Page 8 of 9

- 4.12 Close outlet valve of tank that was released.  
Check (✓) the valve that is closed: \_\_\_\_\_
- ( ) GZ-13A  
( ) GZ-13B  
( ) GZ-13C  
( ) GZ-13D
- 4.13 Remove tag from inlet valve of tank that was released. \_\_\_\_\_
- 4.14 Record final tank pressure \_\_\_\_\_ psig. \_\_\_\_\_
- 4.15 Pressurize tank released to ~2 psig with N<sub>2</sub> as follows:
- 4.15.1 Place N<sub>2</sub> to T-18s regulator (PCV-4805) into service as follows:
- A. Open the following valves:
- PCV-4805 Inlet Valve (N<sub>2</sub>-4805-1) \_\_\_\_\_
  - PCV-4805 Outlet Valve (N<sub>2</sub>-4805-2) \_\_\_\_\_
- B. Set PCV-4805 at -15-18 psig. \_\_\_\_\_
- 4.15.2 Momentarily open N<sub>2</sub> supply to tank.  
Check (✓) the valve that is opened: \_\_\_\_\_
- ( ) T-18A N<sub>2</sub> Inlet Isol (N<sub>2</sub>-15)  
( ) T-18B N<sub>2</sub> Inlet Isol (N<sub>2</sub>-16)  
( ) T-18C N<sub>2</sub> Inlet Isol (N<sub>2</sub>-17)  
( ) T-18D N<sub>2</sub> Inlet Isol (N<sub>2</sub>-18)
- A. Close the T-18 N<sub>2</sub> Inlet Isol opened above. \_\_\_\_\_
- 4.15.3 IF nitrogen to T-18s is no longer required,  
THEN close the following valves:
- PCV-4805 Inlet Valve (N<sub>2</sub>-4805-1) \_\_\_\_\_
  - PCV-4805 Outlet Valve (N<sub>2</sub>-4805-2) \_\_\_\_\_

PROC./WORK PLAN NO. 1104.022	PROCEDURE/WORK PLAN TITLE: GASEOUS RADWASTE SYSTEM	PAGE: 52 of 52 CHANGE: 034-00-0
---------------------------------	---	------------------------------------

ATTACHMENT C

Page 9 of 9

4.16 Purge and restore RE-4830 as follows:

4.16.1 Raise Waste Gas Surge Tank (T-17) pressure to greater than atmospheric but below 16.9 psia to avoid start of Waste Gas Compressor (C-9A or C-9B) by slightly opening PCV-4812 Bypass Valve (N<sub>2</sub>-4812-3).

4.16.2 IF RE-4830 was operable for this release AND RE-4830 has been purged to minimum reading, THEN perform one of the following:

- Adjust alarm setpoint to the as-found setpoint recorded previously for this release, or
- Adjust to new setpoint by performing Radiation Monitoring System Check and Test (1305.001) Supplement 5 for RI-4830.

4.16.3 Verify N<sub>2</sub>-4812-3 closed.

4.16.4 Check PCV-4812 maintains T-17 pressure greater than atmospheric pressure.

A. IF PCV-4812 does NOT maintain adequate T-17 pressure, THEN verify WR/WO initiated to check setpoint.

Performed by \_\_\_\_\_ Ops

Accepted by \_\_\_\_\_ SM/CRS

4.17 Permit and preliminary report returned to Chemistry for final analysis of data.

5.0 SPING Restoration (Chemistry)

5.1 Adjust SPING 2 setpoint per Form 1604.051E.

Chemistry Supervisor \_\_\_\_\_ Date \_\_\_\_\_

PROC./WORK PLAN NO. 1104.022	PROCEDURE/WORK PLAN TITLE: <b>GASEOUS RADWASTE SYSTEM</b>	PAGE: 47 of 52 CHANGE: 034-00-0
---------------------------------	--	------------------------------------

ATTACHMENT C

Page 4 of 9

- ~~3.5.5~~ Open T-18s Discharge to Gaseous Radwaste Discharge Header Flow Control Valve (CV-4820). DMT
- ~~3.5.6~~ Verify ABVH Diversion to T-17 (CV-4806) closed. DMT
- ~~3.5.7~~ Place RI-4830 in CHECK SOURCE. DMT
- ~~N/A~~ IF necessary, THEN lower alarm setpoint until high alarm is received. N/A
- ~~3.5.8~~ Verify Gaseous Radwaste Disch Isol (CV-4830) closes. DMT
- ~~3.5.9~~ Verify CV-4820 closes. DMT
- ~~A.~~ Lower HIC-4820 to ~ 0% open. DMT
- ~~3.5.10~~ Verify CV-4806 opens. DMT
- ~~3.5.11~~ Verify system flow on FR-4831 is ~0. DMT
- ~~3.5.12~~ Verify appropriate alarms on control panels.
- ~~WASTE GAS DISCHARGE LINE RAD HI (K115-B5)~~ DMT
  - ~~Gaseous Radwaste Monitor (RI-4830) alarm~~ DMT
  - ~~PROCESS MONITORS HIGH RAD (K10-B2)~~ DMT
  - ~~RADWASTE GAS PANEL TROUBLE (K09-D5)~~ DMT
- ~~3.5.13~~ Reset RI-4830. DMT
- ~~3.5.14~~ Open CV-4830. DMT
- ~~3.5.15~~ Verify system flow on FR-4831 indicates purge flow. DMT
- ~~3.5.16~~ Close CV-4806. DMT
- ~~3.5.17~~ Clear alarms. DMT
- ~~3.6~~ IF RI-4830 is inoperable, OR is unavailable, THEN perform the following:
- ~~3.6.1~~ Open CV-4830. N/A
  - ~~3.6.2~~ Close CV-4806. N/A
  - ~~3.6.3~~ Verify step 2.4 has been performed. N/A

Facility: ANO-1

Scenario No.: 1-R5

Op-Test No.: 2008-1

Examiners: \_\_\_\_\_ Operators: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Initial Conditions:**

90% power due to dispatcher direction for loss of 500KV.

C2A IA compressor is out of service for overhaul.

ULD is failed and will not lower power.

RPS is failed and will not initiate a RX trip.

Provide stop watch for surveillance.

Two rods will fail to insert on the RX trip.

**Turnover:**

Day shift normal working day.

90% power due to dispatcher direction for loss of 500KV line as a result of storm damage to the Mabelvale 500KV line. No storms are currently in the area.

C2A IA compressor is out of service for overhaul.

1104.005 Supplement 2 RB Spray Red Train Valves Quarterly Test is in progress complete through step 2.2.2. This is not the 18 month surveillance.

Crew will continue in surveillance after turnover.

Event No.	Malf. No.	Event Type*	Event Description
1	N/A	N (SRO, BOP)	Perform 1104.005 Supplement 2 RB Spray Red Train Valves Quarterly Test
2	DI_ICC0009L	N (SRO) R (ATC)	Dispatcher directs power reduction to 700Mwe ULD is failed
3	AI_FIC1207	I (SRO, ATC)	RCP total flow setpoint fails to high
4	CV016	C (SRO, BOP)	RCP seal failure
5	DI_ICC0009L	N (SRO) R (ATC)	Power reduction ULD is failed
6	DI_H24T	M (ALL)	Loss of H2 bus
	CO_P32A	N/A	<b>If power &lt;55%,</b> Trip 'A' RCP when H2 bus is lost (Contingency to ensure RPS trip setpoint is reached.)
7	RP246,7,8,9	C (SRO, ATC)	RPS is failed Manual RX trip <b>(TS) (ATC-CT)</b>

CONTINUED



Event No.	Malf. No.	Event Type*	Event Description
8	RD362 RD363	C (SRO, ATC)	Stuck rod <b>(TS)</b> Stuck rod <b>(ATC-CT)</b>
9	CV020 RC006 ES259 CV-1300	M (ALL) C (BOP)	'B' RCP seal failure ~700gpm RCS leak <b>(TS) (BOP-CT)</b> ESAS Channel 1 fails to actuate <b>(TS) (ATC-CT)</b> CV1300 Fails open
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor			

**Scenario #1-R5 Objectives**

- 1) Evaluate individual ability to perform the valve stroke test of the Engineered Safeguards Reactor Building Spray Block Valve.
- 2) Evaluate individual ability to recognize and respond to a failed reactor coolant pump total seal injection flow controller setpoint.
- 3) Evaluate individual ability to recognize and respond a degraded reactor coolant pump seal.
- 4) Evaluate individual ability to perform a plant power reduction.
- 5) Evaluate individual ability to recognize and respond a failed unit load demand input to the integrated control system.
- 6) Evaluate individual ability to recognize and respond a loss of a 6900V H bus and resulting loss of a reactor coolant pump.
- 7) Evaluate individual ability to recognize and respond to a reactor trip condition where RPS fails to trip the reactor.
- 8) Evaluate individual ability to recognize and respond to two stuck control rods and initiate emergency boration.
- 9) Evaluate individual ability to recognize and respond a post trip reactor coolant pump seal failure.
- 10) Evaluate individual ability to recognize and respond a reactor coolant system leak inside the reactor building.
- 11) Evaluate individual ability to recognize when conditions require the entry into technical specifications conditions.
- 12) Evaluate individual ability to recognize and respond to a medium reactor coolant system leak.
- 13) Evaluate individual ability to recognize and respond to failure of an ES channel to actuate.
- 14) Evaluate individual ability to recognize and respond a failed open ES component.

**SCENARIO #1-R5 NARRATIVE**

The crew will assume the watch at 90% power. The Mabelvale 500KV line is out of service due to storm related damage in south east Arkansas. The down power was completed 4 hours ago. Reactor engineering has directed that rods can be used to account for the xenon transient.

1104.005 Supplement 2 RB Spray Red Train Valves Quarterly Test is complete through step 2.2.2. The crew should brief the remaining steps of the surveillance. The BOP will perform the stroke test **(BOP-N) (SRO-N)**.

The dispatcher will call and direct U1 power be reduced to ~700Mwe in the next 10 minutes. The CRS should calculate the required rate and direct power reduction per 1203.045 Rapid Plant Shutdown. The ATC should recognize that the ULD is not responding and power is not lowering. The ATC should reduce power to ~700 Mwe using the SG/RX Master station in hand. **(ATC-R) (SRO-N)**

The controlling RCP total seal injection flow setpoint will fail high. **(ATC-I) (SRO-I)**. This will cause CV-1207 RCP Seal Injection Control Valve to fail open raising total seal injection flow to maximum. Annunciator K08-D7 RCP Seal Cavity Press HI/LO will alarm due to the high seal injection flow. The CRS should reference 1203.012G K08 Annunciator Corrective Action. The ACA will direct the CRS to 1203.031 Reactor Coolant Pump and Motor Emergency. The crew should recognize high seal injection flow on C04 and take manual control of CV-1207 to establish 8-10gpm individual seal injection flow.

The RCP seal injection transient will cause the 'B' RCP lower seal to fail **(BOP-C) (SRO-C)**. The CRS should implement 1203.031 Reactor Coolant Pump and Motor Emergency and reduce power to ~60% in order to stop the 'B' RCP using 1103.006 **(ATC-R) (SRO-N)** The ATC should reduce power to ~60% using the SG/RX Master station in hand.

At ~65% power or as directed by the lead evaluator a loss of the H2 bus will occur resulting in a loss of two RCP's (B and D) **(BOP-M) (SRO-M) (ATC-M)**. If reactor power is <55% then the 'A' RCP will be tripped along with the H2 bus by the simulator instructor to create the condition for the recognition of an RPS failure. The ATC should recognize the reactor should have tripped and manually trip the reactor.

**(ATC-C) (SRO-C) (ATC-CT) (TS)**.

**TS 3.3.1 Condition C**

**CT criteria - The reactor should be manually tripped within 2 minutes of the loss of the H2 bus.**

Two control rods will fail to fully insert on the Rx trip. **(SRO-C) (ATC-C)** The ATC should recognize and report this condition during the immediate action report. The CRS will direct 1202.012, RT-12 Emergency Boration to be performed. **(ATC-CT)**

**TS 3.1.4 Condition C**

**CT criteria – Emergency boration should be started within 5 minutes of the RX trip.**

**CONTINUED**

**SCENARIO #1-R5 NARRATIVE CONTINUED**

~10 minutes post trip a ~700gpm leak will occur in the reactor building from the failed RCP seal **(ALL-M) (TS)**. Subcooling margin will be lost requiring the BOP to trip all running RCP's within 2 minutes. **(BOP-CT)** All ESAS channels will auto actuate except ES Ch.1. The crew should recognize the leak and recognize ES Ch. 1 failed to actuate. The ATC should manually actuate ES Ch.1 from C04 **(ATC-CT)**. CV-1300 on ES Ch.2 fails to close. The BOP should recognize the open valve and attempt to close it manually. The CRS will direct operation per either 1202.002 Loss of Subcooling Margin or 1202.010 ESAS. Either procedure is acceptable. If the CRS enters ESAS he will eventually be directed to 1202.002 Loss of Subcooling Margin.

**TS 3.4.13 Condition A**

**CT-Criteria RCP' should be tripped within 2 minutes of the loss of SCM.**

**CT criteria - ESAS Ch. 1 should be manually actuated before RT-10 is reported complete.**

Simulator Instructions for Scenario 1-R5				
Event No.	Time	Malf. No.	Value/ Ramp Time	Event Description
<b>Recall IC 101</b> <b>IMF RP246,7,8,9</b> <b>IRF CO_C2A off</b> <b>IOR DO_C2ASLG</b> <b>IRF B5106 OPEN</b> <b>IRF B5110 OPEN</b> <b>IMF RD362 OPEN</b> <b>IMF RD363 OPEN</b> <b>IMF ES259</b> <b>IMF CV1300</b>				
<b>RPS failed</b> <b>C2A IA compressor OOS</b> <b>C2A IA compressor OOS</b> <b>Mabelvale 500KV switchyard breaker open</b> <b>Mabelvale 500KV switchyard breaker open</b> <b>Group 2 Rod 4</b> <b>Group 6 Rod 8</b> <b>ES Channel 1 fails to auto actuate</b> <b>Failed open</b>				
1	0	N/A	N/A	Perform remaining steps of 1104.005 Supplement 2 RB Spray Red Train Valves Quarterly Test.
2	12	N/A IOR DI_ICC0009L	N/A False	Dispatcher directs power reduction to 700Mwe ULD is failed
3	22	IOR AI_FIC1207	1.0	RCP total flow setpoint fails high. This will result CV-1207 Seal Injection control valve traveling full open.
4	Seal Inj. 8-10 gpm	IMF CV016	N/A	RCP seal failure requiring power reduction and securing of the RCP.
5	As directed by SRO	IOR DI_ICC0009L	False	Power reduction to ~60%
6	65% or as directed by the Lead Evaluator	IMF ED462	N/A	Loss of H2 bus when RCP is secured.
	If power <55%	IOR DI_HS1022SP	True	Trip of 'A' RCP (Contingency to ensure RPS trip setpoint is reached.)
7	Initial	IMF RP246,7,8,9	N/A	RPS is failed requiring a manual RX trip on a loss of two RCP's >55% power <b>(TS) (ATC-CT) criteria - The reactor should be manually tripped within 2 minutes of the loss of the H2 bus.</b>
8	Initial	IMF RD362 IMF RD363	100 100	Two control rods will fail to insert <b>TS 3.1.4 Condition C</b> <b>CT criteria – Emergency boration should be started within 5 minutes of the RX trip.</b>

CONTINUED

Simulator Instructions for Scenario 1-R5				
Event No.	Time	Malf. No.	Value/ Ramp Time	Event Description
9	Rx trip +10 min	IMF CV020 IMF RC006 IMF ES259 IMF CV1300	100 0.08 N/A 1	'B' RCP seal failure  ~700gpm RCS leak <b>(TS) (ATC-CT)</b> <b>criteria – ESAS should be actuated before RT-10 reported complete.</b>

Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 1
Event Description: Perform remaining steps in 1104.005 Supplement 2 Red train Spray Valve Test.			
Time	Position	Applicant's Actions or Behavior	
0	BOP	Implement 1104.005 Supplement 2 step 2.2.2.	
	BOP	Verify Makeup Tank pressure > 25 psig.	
	BOP	Verify one of the following valves closed: <ul style="list-style-type: none"> <li>• RB Sump Line A Outlet (CV-1405)</li> <li>or</li> <li>• RB Sump Line A Outlet (CV-1414)</li> </ul>	
	BOP	Open BWST T-3 Outlet (CV-1407).	
	BOP	While timing stroke, open CV-2401 (modulating valve).	
	BOP	Record stroke time in Table 1.	
	BOP	Close CV-2401 (modulating valve, hold control switch in CLOSE until valve torques closed). Verify closed indication.	
	BOP	Record closed stroke in Table 1.	
	BOP	Close CV-1407.	
EXAMINER NOTE This event is complete when Supplement 2 is complete OR As directed by the Lead Evaluator			

Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 2
Event Description: Dispatcher directs a power reduction to 700Mwe. ULD is failed			
Time	Position	Applicant's Actions or Behavior	
EXAMINER NOTE Dispatcher will call requiring a power reduction to 700Mwe net output for unit 1 in the next 10 minutes.			
12	CRS	Direct operations per 1203.045 Rapid Plant Shutdown.	
	ATC	Commence a plant shutdown at 0.5 to 10% per minute. <ul style="list-style-type: none"><li>Place ULD in manual.</li><li>Attempt Toggle down to CRS directed megawatt setting ~700 Mwe.</li></ul>	
	BOP	Recognize and report ULD not responding to a lowering command.	
	CRS	Direct power reduction using SG/RX master.	
	BOP	Place SG/RX master to hand.	
	BOP	Lower plant power to <60%.	
	ATC BOP	Monitor ICS and EHC subsystems for proper integrated response.	
	CRS	Direct chemistry or the AO to secure Zinc Injection.	
	CRS	If the CRS intends to stop heater drain pumps then direct AO to Removing MSR DI From Service.	
	BOP	At <75% stop Heater Drain Pumps (P8A and P8B) (CRS may elect to keep the P8's running based upon P8 flow.) If Heater Drain Pumps are secured then the CRS will direct: <ul style="list-style-type: none"><li>Verify Hi Lvl Dump Isolations open:<ul style="list-style-type: none"><li>CV-3041A (at B-3252)</li><li>CV-3037A (at B-4252)</li></ul></li><li>Verify Low Level Condenser Spray CV-2907 and CV-2868 (HS-2907 on C02) open.</li></ul>	
	ATC	As time permits after the runback refer to "Contingency Reactivity Plans" and Exhibit A (Operation of APSR Group) of Power Operation (1102.004) (This may not occur depending on operator response time and scenario time line.)	
EXAMINER NOTE This event is complete when plant power is at 700Mwe OR As directed by the Lead Evaluator			



Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 3
Event Description: RCP total flow setpoint fails high. This will result CV-1207 Seal Injection control valve traveling full open.			
Time	Position	Applicant's Actions or Behavior	
22	ATC	Recognize, acknowledge, and report Annunciator K08-B7 RCP Bleedoff Flow HI.	
	CRS	Implement 1203.012G Annunciator K08 Corrective Action.	
	CRS	GO TO "Seal Degradation" section of Reactor Coolant Pump and Motor Emergencies (1203.031).	
	BOP	Verify the following valves are open: <ul style="list-style-type: none"> <li>• RCP Seal Bleed off (Normal) Return (CV-1274)</li> <li>• RCP Seal Bleed off (Normal) from P-32D (CV-1270)</li> <li>• RCP Seal Bleed off (Normal) from P-32C (CV-1271)</li> <li>• RCP Seal Bleed off (Normal) from P-32B (CV-1272)</li> <li>• RCP Seal Bleed off (Normal) from P-32A (CV-1273)</li> </ul>	
	ATC	Verify RCP Seal INJ Block (CV-1206) open.	
EXAMINER NOTE If directed the WCO will report nothing abnormal with CV-1207.			
	ATC	Manually adjust RC Pump Seals Total INJ Flow (CV-1207) to establish 32 to 40 gpm by verifying individual seal injection flow rates 8 to 10 gpm.	
	CRS	Provide Attachment A of this procedure to a Control Board Operator to aid in monitoring seal parameters.	
EXAMINER NOTE This event is complete when RCS seal injection flow is 8 to 10 gpm. OR As directed by the Lead Evaluator			

Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 4 & 5
Event Description: RCP seal failure Power Reduction			
Time	Position	Applicant's Actions or Behavior	
RCP seal Inj. 8-10 gpm	BOP	Recognize and report 'B' RCP seal failure.	
	CRS	Direct operations per 1203.012G K08 Annunciator Corrective Action and 1203.031 Reactor Coolant Pump and Motor Emergency	
	ANY	Determine Seal bleed off temp >40°F above 1st stage seal temp.	
	CRS	Implement Rapid Plant Shutdown (1203.045). <ul style="list-style-type: none"> <li>Direct power reduction using SG/RX Master</li> </ul>	
	ATC	Reduce reactor power to within the capacity of the unaffected RCP combination, using Rapid Plant Shutdown (1203.045) .	
	BOP	Lower SG/RX master to hand.	
	BOP	Lower plant power to <60%.	
	ATC BOP	Monitor ICS and EHC subsystems for proper integrated response.	
	CRS	Direct chemistry or the AO to secure Zinc Injection. (If not already performed)	
	CRS	If the CRS intends to stop heater drain pumps then direct AO to perform Removing MSR DI From Service. (If not already performed)	
	BOP	At <75% stop Heater Drain Pumps (P8A and P8B) (CRS may elect to keep the P8's running based upon P8 flow.) If Heater Drain Pumps are secured then the CRS will direct: <ul style="list-style-type: none"> <li>Verify Hi Lvl Dump Isolations open: <ul style="list-style-type: none"> <li>CV-3041A (at B-3252)</li> <li>CV-3037A (at B-4252)</li> </ul> </li> <li>Verify Low Level Condenser Spray CV-2907 and CV-2868 (HS-2907 on C02) open.</li> </ul> (If not already performed)	
	ATC	As time permits after the runback refer to "Contingency Reactivity Plans" and Exhibit A (Operation of APSR Group) of Power Operation (1102.004) (This may not occur depending on operator response time and scenario time line.)	

## EVENT 4 &amp; 5 CONTINUED

Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 4 & 5 CONTINUED
Event Description: RCP seal failure			
<b>Time</b>	<b>Position</b>	<b>Applicant's Actions or Behavior</b>	
	ATC	As time permits after the runback refer to "Contingency Reactivity Plans" and Exhibit A (Operation of APSR Group) of Power Operation (1102.004). (This may not occur depending on operator response time and scenario time line.)	
EXAMINER NOTE This event is complete when plant power is <65% OR As directed by the Lead Evaluator			

Op-Test No.: 2008-1

Scenario No.: 1-R5

Event No.: 6 &amp; 7 &amp; 8

## Event Description:

Loss of H2 bus when RCP is secured.

RPS is failed requiring a manual RX trip on a loss of two RCP's &gt;55% power.

Two control rods fail to insert on Rx trip.

Time	Position	Applicant's Actions or Behavior
65% or as directed by the Lead Evaluator	ANY	Recognize loss of H2 bus and two RCP's. Recognize RPS failed to complete an automatic trip. <b>TS 3.3.1 Condition C</b>
	CRS	Direct operations per 1202.001 Reactor Trip Emergency Operating Procedure.
	CRS	Direct manual trip of the reactor and performance of immediate actions. (ATC may trip the reactor before the CRS direction.)
	ATC	Manually Trip Rx. <ul style="list-style-type: none"> <li>• Verify all rods inserted</li> <li>AND</li> <li>• Reactor power dropping.</li> </ul> <b>CT criteria - The reactor should be manually tripped within 2 minutes of the loss of the H2 bus.</b>
	CRS	Direct the performance of RT-12 Emergency Boration. <b>TS 3.1.4 Condition C</b> <b>CT criteria – Emergency boration should be started within 5 minutes of the RX trip.</b>
Emer. Boration Actions	ATC	Set Batch Controller for maximum batch size as follows: a) Depress lower DISPLAY b) Depress TOTAL c) Depress TOTAL RESET d) Depress BATCH SET e) Depress 9, six times f) Depress ENTER g) Depress lower DISPLAY
	ATC	Verify Condensate to Batch Controller (CV-1251) closed.
	ATC	Open Batch Controller Outlet (CV-1250).
	ATC	Verify both Letdown Filters in service (F-3A and B).
	ATC	Record initial BAAT (T-6) level _____ in.
	ATC	Start available Boric Acid Pump(s) (P-39A or B or both).
	ATC	Start Batch Controller by depressing RUN key.

## EVENT 6 &amp; 7 &amp; 8 CONTINUED

Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 6 & 7 & 8 CONTINUED
Event Description: Loss of H2 bus when RCP is secured. RPS is failed requiring a manual RX trip on a loss of two RCP's >55% power. Two control rods fail to insert on Rx trip.			
Time	Position	Applicant's Actions or Behavior	
Emer. Boration Actions	ATC	Adjust Batch Controller Flow CNTRL VLV (CV-1249) to 100% open as follows: a) Depress VALVE SET b) Depress numbers: 1, 0, 0 c) Depress ENTER d) Depress lower DISPLAY e) Depress RATE	
	ATC	Adjust Pressurizer Level Control Setpoint to 220".	
	ATC	Open BWST Outlet to OP HPI Pump (CV-1407 or 1408).	
	ATC	When PZR level is >100", Then establish maximum Letdown flow.	
	ATC	Perform the following as necessary to maintain MU Tank level 55 to 86": a) Close Batch Controller Outlet (CV-1250). b) Stop running Boric Acid Pump(s) (P-39A, P-39B). c) Place 3-Way valve in BLEED. d) When MU Tank level is lowered to desired level, Then perform the following: (1) Return 3-Way valve to LETDOWN. (2) Start available Boric Acid Pump(s) (P-39A or B or both). (3) Open Batch Controller Outlet (CV-1250). (These steps may not be required)	
	ATC	As time permits, determine actual required boration as follows: a) Obtain required boron concentration from the Plant Data Book b) Calculate batch add required using Plant Computer <b>OR</b> Soluble Poison Concentration Control (1103.004), Attachment A.3, "Calculation of Feed Volume For Batch Boration or Dilution". c) Use 1103.004, Attachment D, "Volume of BAAT vs. Depth of Liquid" to determine desired final BAAT level.	
	ATC	When required amount of boric acid has been added per step 14) as determined by Reactor Engineering. (LOCA will occur prior to completing boric acid addition)	
	BOP	Manually trip Turbine. Verify Turbine throttle and governor valves closed.	
	ATC or BOP	Check adequate SCM.	
	CRS	Advise Shift Manager to implement Emergency Action Level Classification (1903.010).	

### EVENT 6 & 7 & 8 CONTINUED

## Appendix D Required Operator Actions Form ES-D-2

Op-Test No.: 2008-1	Scenario No.: 1-R5	Event No.: 6 & 7 & 8 CONTINUED
Event Description: Loss of H2 bus when RCP is secured. RPS is failed requiring a manual RX trip on a loss of two RCP's >55% power. Two control rods fail to insert on Rx trip.		
Time	Position	Applicant's Actions or Behavior
	ATC	Reduce Letdown by closing Orifice Bypass (CV-1223). (This is not performed due to emergency boration)
	BOP	Open BWST Outlet to OP HPI pump (CV-1407 or 1408).
	ATC	Pressurizer Level Control setpoint to 100".
	BOP	Check for proper electrical response.
	ANY	Check OP HPI pump supplying normal Makeup and Seal Injection.
	ATC	Check both SG levels remain <410".
	ANY	Check Instrument Air Header press >75 psig.
	ANY	Check all NNI power available.
	ANY	Check all ICS power available.
	ATC	Check SG press >900 psig.
	ANY	Check MSSV OPEN alarm clear (K07-C5).
	ANY	Check MSIVs open.
	ANY	Check Turb BYP valves operate to maintain SG press 970 to 1020 psig.
	ANY	Place both Feedwater Demands in HAND AND verify demand at zero.
	ANY	Check Main Block valves closed (CV-2625 and 2675).
	ANY	Check Low Load Block valves closed (CV-2624 and 2674).
	ANY	Check Startup valves maintain SG levels 20 to 40".
	ANY	Verify MFW pumps run back and then operate to maintain >70 psid across Startup valves.
	ANY	Check the following in service: <ul style="list-style-type: none"> <li>Two Service Water pumps (P4A, B, or C).</li> <li>ICW pump supplying Nuclear loop (P33C or B).</li> <li>ICW pump supplying Non-nuclear loop (P33A or B).</li> <li>RB Cooling Fans (VSF1A, B, C, D, and E)</li> <li>Previously running Main Chiller(s) (VCH1A, B)</li> </ul>

**EVENT 6 & 7 & 8 CONTINUED**

Op-Test No.: 2008-1

Scenario No.: 1-R5

Event No.: 6 & 7 & 8  
CONTINUED

## Event Description:

Loss of H2 bus when RCP is secured.

RPS is failed requiring a manual RX trip on a loss of two RCP's &gt;55% power.

Two control rods fail to insert on Rx trip.

Time	Position	Applicant's Actions or Behavior
	ANY	Check ESAS Actuation alarms clear on K11.
	ANY	Check RCS press >1700 psig.
	ATC	Check Pressurizer Level Control valve (CV-1235) maintains PZR level >55".
	ANY	Check PZR steam space integrity.
	ATC	Verify ERV, Pressurizer Spray, and Pressurizer Heaters operate to control RCS press 2050 to 2250 psig.
	ANY	Check at least one RCP running.
	ATC	Check RCS T-cold remains >540 ° F.
	ANY	Check adequate SCM.
	ATC	Check RCS temp remains either: <ul style="list-style-type: none"> <li>• 580 ° F T-hot with any RCP on</li> <li>OR</li> <li>• 610 ° F CET temp with all RCPs off.</li> </ul>
	BOP	Check SG tube integrity.
	ANY	Check RCS integrity.
<p style="text-align: center;"><b>EXAMINER NOTE</b>  This event is complete when Emergency Boration is started  OR  As directed by the Lead Evaluator</p>		

Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 9
Event Description: A ~700gpm RCS leak will develop in the RX building resulting in ESAS actuation.			
Time	Position	Applicant's Actions or Behavior	
Trip + 10 min	ANY	Recognize and report lower PZR level and RCS pressure.	
	ANY	Diagnose RCS leak inside containment. <b>TS 3.4.13 Condition A</b>	
	ANY	Recognize and report ESAS Channels 2, 3, 4, 5, & 6 actuated.	
	ANY	Recognize and report ES Channel 1 failed to actuate.	
	ATC	Manually actuate ES channel 1. <b>CT criteria – ES channel 1 should be actuated before RT-10 is reported complete.</b>	
If ESAS is entered	CRS	Direct operations per 1202.010 ESAS, or 1202.002 Loss of Subcooling Margin.	
	ANY	Check adequate SCM.	
	ANY	Recognize and report a loss of SCM.	
	BOP	IF <2 minutes have elapsed, THEN trip all RCPs. <b>CT-Criteria RCP' should be tripped within 2 minutes of the loss of SCM.</b>	
	ATC	Verify Reflux Boiling setpoint selected for EFW.	
	BOP	Verify proper ESAS actuation (RT 10).	
	BOP	Recognize and report CV1300 failed to close.	
	BOP	Attempt to manually close CV1300.	
	ATC	IF MU Tank level drops below 18", THEN close Makeup Tank Outlet (CV-1275). (MUT not expected to go below 18".	
	ATC	Isolate Pressurizer Spray Line as follows: A. Place Pressurizer Spray Control in HAND AND verify closed (CV-1008). B. Close Pressurizer Spray Isolation (CV-1009).	
	ATC	Verify ERV Isolation (CV-1000) closed.	
	ANY	Check Nuclear Loop ICW process monitor alarm clear.	
	ANY	Check SG tube integrity.	
	ANY	Check RCS press stabilizes >150 psig. (RCS pressure will stabilize >150psig)	
	ANY	Check adequate CET SCM.	

## EVENT 9 CONTINUED



Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 9 CONTINUED
Event Description: A ~700gpm RCS leak will develop in the RX building resulting in ESAS actuation.			
Time	Position	Applicant's Actions or Behavior	
Actions for LOSM EOP	CRS	Transition to 1202.002 Loss of Subcooling Margin.	
	BOP	Check elapsed time since loss of adequate SCM: • IF <2 minutes have elapsed, THEN trip all RCPs. <b>CT-Criteria RCP' should be tripped within 2 minutes of the loss of SCM.</b>	
	N/A	Initiate full HPI (RT 3). (ESAS will be actuated resulting in full HPI)	
	ATC	IF MU Tank level drops below 18", THEN close Makeup Tank Outlet (CV-1275). (MUT not expected to go below 18").	
	ATC BOP	Verify proper EFW actuation and control (RT 5). (The BOP may perform RT-5 as part of RT-10)	
	ATC	Trip both MFW pumps.	
	ANY	Check ESAS Actuation alarms clear on K11. IF RCS press is >150 psig, THEN verify proper ESAS actuation (RT 10). (RCS pressure will be >150 psig)	
	ATC	Isolate Pressurizer Spray Line as follows: A. Place Pressurizer Spray Control in HAND AND verify closed (CV-1008). B. Close Pressurizer Spray Isolation (CV-1009).	
	ATC	Verify ERV Isolation (CV-1000) closed.	
	ANY	Check Nuclear Loop ICW process monitor alarm clear.	
	ANY	Check SG tube integrity.	
	ANY	CET SCM is adequate, THEN control RCS press low within limits of Figure 3 (RT 14). (SCM will not be adequate)	
	ANY	Check RCS press remains $\geq 150$ psig.	
	ANY	Check SG levels at or approaching 370 to 410".	
	ANY	Check primary to secondary heat transfer in progress. (Primary to secondary heat transfer will not be in progress)	
	ATC	Raise primary to secondary $\Delta T$ to 40 to 60°F by adjusting TURB BYP or ATM Dump Control System to establish SG press within limits of Figure 5.	
	BOP	IF SG press drops below 720 psig, THEN bypass MSLI. a) On Initiate module in each EFIC cabinet, place each SG bypass toggle switch in BYPASS and release.	

## EVENT 9 CONTINUED

Op-Test No.: 2008-1		Scenario No.: 1-R5	Event No.: 9 CONTINUED
Event Description: A ~700gpm RCS leak will develop in the RX building resulting in ESAS actuation.			
Time	Position	Applicant's Actions or Behavior	
Action s for LOSM EOP	ANY	Check primary to secondary heat transfer in progress. (Primary to secondary heat transfer will not be in progress)	
	N/A	IF RCPs cannot be run due to either inability to maintain adequate CET SCM OR H1 and H2 bus degraded voltage (<6900V), THEN bump RCPs to establish primary to secondary heat. <ul style="list-style-type: none"><li>Establish PZR level <math>\geq 180</math>".</li></ul> (Pressurizer level can not be established $\geq 180$ " therefore RCP's will not be bumped)	
	ATC	Verify SG levels at or approaching 370 to 410".	
	CRS	IF an uncontrolled RCS cooldown is occurring due to HPI/break flow, regardless of SG status, THEN GO TO Small Break LOCA Cooldown (1203.041).	
EXAMINER NOTE This scenario may be terminated when the CRS transitions to 1203.041 OR As directed by the Lead Evaluator			

Facility: ANO-1

Scenario No.: 2-R5

Op-Test No.: 2008-1

Examiners: \_\_\_\_\_ Operators: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

**Initial Conditions:**

100% Power

EFIC is failed and will not auto actuate.

C2A IA compressor is out of service for overhaul.

Provide picture of RS-4

**Turnover:**

Day shift normal working day.

C2A IA compressor is out of service for overhaul.

Currently under a severe thunderstorm warning for the next hour. All actions of 1203.025

Natural Emergencies are complete.

Swap ICW pumps to have P33A and P33B running to allow visual inspection of P33C. The Inside AO has been briefed and is standing by the ICW pumps. P33B had not been drained.

Event No.	Mal. No.	Event Type*	Event Description
1	N/A	N (SRO, BOP)	Swap operating ICW pumps
2	Lightning strike	N/A	Lightning strike
	DI-DG2S K01A3		#2 EDG auto start #2 EDG Auto Start Alarm
	CV-3807	C (SRO, BOP)	#2 EDG SW valve fails to open <b>(TS)</b> . #2 EDG Shutdown
3	N/A	N (SRO) R (ATC)	Dispatcher directs a power reduction to 700Mwe in the next 15 minutes.
4	Lightning strike	I (SRO, ATC)	Lightning strike
	ED451		Loss of the NNI Y power supply.
5	ED183	M (ALL)	Loss of Offsite Power/Degraded Power
6	DG175	C (SRO, BOP)	#1 EDG will not auto start <b>(BOP-CT)</b>
	DI_DG1_VR-LW		#1 EDG voltage low (<4100V)
7	FW621	C (SRO, ATC)	EFIC fails <b>(ATC-CT) (TS)</b>
8	DG173	M (ALL)	#1 EDG will trip <b>(TS)</b>
	A901	N/A	Alternate AC Generator available. <b>(BOP-CT)</b>
* (N)ormal, (R)eactivity, (I)nstrument, (C)omponent, (M)ajor			

**Scenario #2-R5 Objectives**

- 1) Evaluate individual ability to perform the swapping of the operating ICW pumps.
- 2) Evaluate individual ability to recognize and respond to the false auto start of emergence diesel generator.
- 3) Evaluate individual ability to recognize and respond to the failure to open of the service water supply valve on an operating emergence diesel generator.
- 4) Evaluate individual ability to reduce plant power.
- 5) Evaluate individual ability to recognize and respond to the loss of the 'Y' Non-Nuclear Instrumentation system.
- 6) Evaluate individual ability to recognize and respond to a loss of offsite power.
- 7) Evaluate individual ability to recognize and respond to failure of the emergence diesel generator to auto start.
- 8) Evaluate individual ability to recognize and respond to the failure of the Emergency Feedwater Initiation and Control system to automatically actuate emergency feedwater.
- 9) Evaluate individual ability to recognize and respond to the tripping of the remaining emergence diesel generator putting the plant in a blackout condition.
- 10) Evaluate individual ability to perform the energizing of a vital bus from the alternate AC generator.
- 11) Evaluate individual ability to recognize when conditions require the entry into technical specifications conditions.

**SCENARIO #2-R5 NARRATIVE**

The crew will assume the watch at 100% power. C2A IA compressor is out of service for overhaul. It is a day shift normal working day. ANO is currently under a severe thunderstorm warning for the next hour. All actions of 1203.025 Natural Emergencies are complete.

The crew will start P33B and secure P33C per 1104.028 ICW Operating Procedure step 10.2 **(BOP-N) (SRO-N)**. This is being performed in order to visually inspect the motor rotor. P33B had not been drained.

A lightning strike will cause the auto start of the #2 EDG. The CRS should direct operations per 1203.012A Annunciator K01 Corrective Actions. The crew should determine it is a spurious actuation. The #2 EDG SW valve CV-3807 will not open resulting in no cooling flow to the EDG **(BOP-C) (SRO-C)**. The crew should take the #2 EDG to lockout to prevent an automatic trip of the EDG **(TS)**.

**TS 3.8.1. Condition B**

The dispatcher will call and direct U1 to reduce net generator output to 700Mwe **(SRO-N) (ATC-R)**.

A second lightning strike will result in the loss on NNI-Y power supply **(ATC-I) (SRO-I)**. The crew should recognize the loss of NNI-Y power. The CRS should implement 1203.047 Loss of NNI Power. The power supply breakers on RS-4 bkr 9 and Y01 bkr 39 will not reset. Breakers S-1 and S-2 on the NNI-Y power supply will not be tripped.

Letdown flow and pressure indication will be lost on C04. The letdown orifice bypass valve will fail to 50% reducing letdown flow. CFT pressure instrumentation will be lost along with NaOH tank temperature. All NNI-Y inputs to PMS/PDS will be lost or fail to mid scale.

A loss of offsite power will occur due to storm related grid instabilities **(SRO-M) (ATC-M) (BOP-M)**. The reactor will trip automatically. The CRS will direct operations per 1202.001 Rx Trip. After the immediate actions are complete the CRS will transition to either 1202.008 Blackout or 1202.007 Degraded Power depending on when the BOP manually starts the #1 EDG.

The #1 EDG will not auto start requiring the BOP to manually start the EDG **(BOP-C) (BOP-CT)**. The #1 EDG voltage will be <4100V requiring the BOP to raise EDG voltage.

**CT criteria – The BOP should start the #1 EDG before the 15 minute criteria for declaring an SAE for a station blackout.**

The EFIC system is failed and will not automatically actuate EFW on the Loss of Offsite Power **(ATC-C) (SRO-C)**. The ATC should manually actuate EFW from the remote switch matrix **(ATC-CT) (TS)**. The ATC will perform 1202.012 Repetitive Tasks RT-5 Verify proper EFW actuation and control. EFW may be manually actuated before the step in the EOP that directs verifying EFW actuated.

**TS 3.3.11 Condition B**

**CT – EFW should be manually actuated before the ERV opens in automatic.**

CONTINUED

**SCENARIO #2-R5 NARRATIVE CONTINUED**

The #1 EDG will trip putting the plant into a blackout **(SRO-M) (ATC-M) (BOP-M) (TS)**. The CRS will direct operations per 1202.008 Blackout.

**TS 3.8.1 Condition E, 3.0.3**

The alternate AC generator will become available. The BOP should energize the A3 bus from the AAC generator **(BOP-CT)**.

**CT criteria – The AAC generator should be placed in service within 20 minutes of regaining the AAC Generator.**

Simulator Instructions for Scenario 2-R5				
Event No.	Time	Malf. No.	Value/ Ramp Time	Event Description
<b>Recall IC 102</b> <b>IMF FW621</b> <b>IRF CO_C2A off</b> <b>IOR DO_C2ASLG</b> <b>IMF DG175</b> <b>IMF CV3807 Off</b> <b>IRF K01E7 Off</b> <b>IOR DI_DG1_VR_LW 15sec</b>				
<b>EFIC failure</b> <b>C2A IA compressor OOS</b> <b>C2A IA compressor OOS</b> <b>#1 EDG fails to auto start</b> <b>#2 EDG SW valve fails closed</b> <b>D01 Trouble off</b> <b>#1 EDG voltage low</b>				
1	0	N/A	N/A	Swap operating ICW pumps to have P33A and P33B running.
2	10	T1 IRF Lightning IOR DI-DG2S IOR DI_DG2SP IRF K01A3  DRF Lightning	True True False On	Lightning strike will cause the auto start of #2 EDG.
	Initial	IMF CV-3807	0	#2 EDG SW valve will not open following the EDG auto start. This will require the operators to shutdown #2 EDG. <b>(TS)</b>
3	18	N/A	N/A	Dispatcher will call and direct a power reduction to 700 Mwe in the next 15 minutes.
4	28	T2 IRF Lightning IMF ED451	True N/A	Another lightning strike will result in the loss of the NNI Y power supply.
5	36	IMF ED183	N/A	A Loss of Offsite Power will occur resulting in an automatic reactor trip.
6	Initial	IMF DG175	N/A	The #1 EDG will not auto start requiring the operators to manually start the EDG. <b>(BOP-CT) criteria – The BOP should start the #1 EDG before 15 minute criteria for declaring an SAE for a station blackout.</b>

CONTINUED

Simulator Instructions for Scenario 2-R5				
Event No.	Time	Malf. No.	Value/ Ramp Time	Event Description
7	Initial	IMF FW621	N/A	EFIC is failed and will not automatically actuate EFW. <b>(TS) (ATC-CT) criteria - EFW should be manually actuated before the ERV opens in automatic.</b>
U2 will report ACC Generator is running slow. Maintenance has been dispatched.				
8	48	IMF DG173	N/A	The #1 EDG will trip putting the plant into a blackout. <b>(TS)</b>
	At T=52 U2 will report AAC Generator has been repaired and is running normally with 2A901 closed.			
	52	IRF A901	Closed	The Alternate AC Generator will become available. <b>(BOP-CT) CT criteria – The AAC generator should be placed in service within 20 minutes of regaining the AAC Generator.</b>



Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 1
Event Description: Swap operating ICW pumps to have P33A and P33B running.			
Time	Position	Applicant's Actions or Behavior	
	CRS	Direct performance of 1104.028 ICW Operating Procedure step 10.2.	
0	BOP	Open A/B crossconnect valves: <ul style="list-style-type: none"> <li>• ICW Pumps Suction Crossconnect (CV-2241)</li> <li>• ICW Pumps Discharge Crossconnect (CV-2239)</li> </ul>	
	BOP	Direct AO to vent P-33B as necessary by opening ICW Pump P-33B Vent (ICW-1191).	
	BOP	Start P-33B.	
	BOP	When P-33B has run at least 3 minutes, Then stop P-33C.	
	BOP	Verify flow is normal (~2000 gpm) on ICW Coolers Inlet Flow Non-Nuc (FI-2218) (CO9).	
EXAMINERS NOTE: This event is complete when ICW flows are verified normal OR As directed by the Lead Evaluator			

Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 2
Event Description: <ul style="list-style-type: none"> <li>• Lightning strike will cause the auto start of #2 EDG.</li> <li>• #2 EDG SW valve will not open following the EDG auto start. This will require the operators to shutdown #2 EDG.</li> </ul>			
Time	Position	Applicant's Actions or Behavior	
10	CRS	Acknowledge and report Annunciator K01A3 EDG 2 AUTO START COMMAND.	
	CRS	Direct plant operation per K01A3 EDG 2 AUTO START COMMAND.	
	BOP	Verify that DG2 auto start.	
	BOP	Check bus A4 energized from bus A1.	
	BOP	Check bus B6 energized.	
	ANY	Verify SERV WTR to DG2 CLRS (CV-3807) opens. Recognize and report CV3807 will not open.	
<b>EXAMINEERS NOTE</b> If called the AO will report CV-3807 cannot be opened locally.			
	CRS	Direct #2 EDG be placed in lockout. (BOP may try to push stop P/B first. EDG will stop but then restart) <b>TS 3.8.1. Condition B</b>	
<b>EXAMINEERS NOTE</b> If called U2 will report Alternate AC Generator is available.			
	CRS	Contact work management to investigate cause of EDG start.	
	CRS	Refer to TS 3.8.1 Condition B for operability requirements.	
	CRS	Verify proper MOD alignment for Service Water Pump (P-4B) and Makeup Pump (P-36B) per Makeup & Purification System Operation (1104.002) AND Service Water and Auxiliary Cooling System (1104.029).	
<b>EXAMINERS NOTE:</b> This event is complete when #2 EDG is in lockout OR As directed by the Lead Evaluator			

Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 3
Event Description: Dispatcher will call and direct a power reduction to 700MWe in the next 15 minutes.			
Time	Position	Applicant's Actions or Behavior	
18	CRS	Direct operations per 1203.045 Rapid Plant Shutdown.	
	ATC	Commence a plant shutdown at 0.5 to 10% per minute. <ul style="list-style-type: none"> <li>• Place ULD in manual</li> <li>• Lower ULD setpoint to ~730 MWe</li> </ul>	
	ATC BOP	Monitor ICS and EHC subsystems for proper integrated response.	
	ATC	Refer to "Contingency Reactivity Plans.	
	CRS	At <90%, direct Zinc Injection be secured.	
	ATC	Stabilize power ~700 Mwe.	
EXAMINERS NOTE: This event is complete when power is stable at ~700 Mwe OR As directed by the Lead Evaluator			

Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 4
Event Description: Another lightning strike will result in the loss of the NNI Y power supply.			
Time	Position	Applicant's Actions or Behavior	
28	ANY	Recognize the loss of NNI-Y power. Recognize and report loss of letdown flow and pressure indication on C04. Recognize and report CV-1223 at 50%.	
	CRS	Direct operations per 1203.047 Loss of NNI Power.	
	ATC BOP	Verify NNI X-powered instruments selected on C03, C04, and C13. (Green light on for each SASS parameter) (CRS may direct placing SASS selector switch to the X position)	
	ATC	Check NNI Y AC power available.	
<b>EVALUATOR NOTE:</b> <b>The BOP will go to back of control room to a picture of RS-4 to simulate resetting Breaker RS-4 bkr 9.</b> <b>The evaluator will tell the BOP that bkr 9 will not reset.</b>			
	BOP	Reset <b>AND</b> close Normal supply breaker RS-4 bkr 9.	
	CRS	Dispatch an operator to reset <b>AND</b> close Alternate supply breaker Y01 bkr 39, while continuing with this procedure.	
<b>EXAMINERS NOTE:</b> <b>Report as AO that Y01 bkr 39 will not reset.</b>			
	CRS	Dispatch an operator to reset NNI Y power supply using Reactor Coolant System NNI (1105.006), "Resetting NNI Power Supplies" section, while continuing with this procedure. The S-1 and S-2 switches are on the NNI power supply and will not be tripped. Time will not permit any operator actions to be accomplished by the outside control room operator.	
<b>EXAMINERS NOTE:</b> This event is complete when instruments are verified selected to NNI-X power and power supply breakers Y01 bkr 39 and RS-4 bkr 9 are reported as not closing OR As directed by the Lead Evaluator			

Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 5
Event Description: A Loss of Offsite Power will occur resulting in an automatic reactor trip.			
Time	Position	Applicant's Actions or Behavior	
36	ANY	Recognize and report a loss of offsite power.	
	CRS	Direct operations per 1202.001 RX trip.	
	ATC	Manually Trip Rx, Verify all rods inserted and Reactor power dropping.	
	BOP	Manually trip Turbine, Verify Turbine throttle and governor valves closed.	
	ANY	Check adequate SCM.	
<p style="text-align: center;">EXAMINERS NOTE: This event is complete when the immediate actions of 1202.001 are complete OR As directed by the Lead Evaluator</p>			

Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 6 & 7
Event Description: <ul style="list-style-type: none"> <li>The #1 EDG will not auto start requiring the operators to manually start the EDG.</li> <li>EFIC is failed and will not automatically actuate EFW.</li> </ul>			
Time	Position	Applicant's Actions or Behavior	
LOOP	ANY	Recognize #1 EDG failed to auto start.	
	BOP	Manually start #1 EDG. <b>(BOP-CT) CT criteria – The BOP should start the #1 EDG before the 15 minute criteria for declaring an SAE for a station blackout.</b>	
	CRS	Direct operations per 1202.007 Degraded Power.	
	BOP	Verify both EDGs supplying associated ES buses with proper voltage, frequency and loading: <ul style="list-style-type: none"> <li>4100 to 4200V</li> <li>59.5 to 60.5 Hz</li> <li>≤2750 kw</li> </ul>	
	BOP	Recognize #1 EDG voltage is low.	
	BOP	Adjust #1 EDG voltage to ~4160V.	
	BOP	Verify 480V MCC B55 and 56 power supply is selected to B5.	
	BOP	Close ACW Isolation (CV-3643).	
	BOP	Close CV-3640	
	BOP	Close CV-3820	
	ANY	Recognize and report Service Water Pump discharge pressure high alarm. (CRS may elect to place additional SW loads in service)	
	CRS	Dispatch an operator to restore EDG. (May not be performed as #2 EDG is known to be OOS.)	
EXAMINERS NOTE:			
U2 will report ACC Generator is running slow. Maintenance has been dispatched.			
	CRS	Request U2 start AAC Generator.	
	BOP	Verify P36B Bus Select MOD Control selected to A3.	
	BOP	Verify P4B Bus Select MOD Control selected to bus A3.	

## EVENT 6 &amp; 7 CONTINUED

Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 6 & 7 CONTINUED
Event Description: <ul style="list-style-type: none"> <li>The #1 EDG will not auto start requiring the operators to manually start the EDG.</li> <li>EFIC is failed and will not automatically actuate EFW.</li> </ul>			
Time	Position	Applicant's Actions or Behavior	
	BOP	Verify SW to DG1 CLRs open (CV-3806).	
	BOP	Verify a Service Water pump P4A on after 15-second time delay.	
	ATC	Actuate MSLI for both SGs AND verify proper actuation and control of EFW and MSLI (RT 6). <b>TS 3.3.11 Condition B</b> <b>(ATC-CT) CT – EFW should be manually actuated before the Electromatic Relief Valve (ERV) opens in automatic.</b>	
	ATC	Operate ATM Dump CNTRL valves in HAND to minimize cycling and conserve Instrument Air. (Crew may determine ADV's not cycling and leave in auto)	
	ANY	Check RCS press remains $\geq 1700$ psig PZR level remains $\geq 30$ ".	
	BOP	Isolate Letdown by closing Letdown Cooler Outlets (CV-1214 and 1216).	
	ANY	Check OP and STBY HPI pumps off.	
	BOP	Place RCP Seals Bleedoff (Alternate Path to Quench Tank) controls in CLOSE (SV-1270, 1271, 1272 and 1273).	
	BOP	Isolate RCP Seal Bleedoff (Normal) by closing CV-1270, 1271, 1272, and 1273.	
	ATC	IF PZR level is $\geq 55$ ", THEN verify Proportional Control Pressurizer Heaters operating in AUTO.	
	ATC BOP	Place the following breakers in handswitches in PULL-TO-LOCK. <ul style="list-style-type: none"> <li>A1, A2, H1, H2</li> <li>Condensate pumps (P2A, B and C)</li> <li>ICW pumps (P33A, B and C)</li> </ul>	
	ATC	Verify RCP Seal INJ Block closed (CV-1206).	
	BOP	Close RCS Makeup Block (CV-1233 or 1234).	
	BOP	Open BWST Outlet to OP HPI pump CV-1407.	
EXAMINERS NOTE: This event is complete when CV-1407 is open OR As directed by the Lead Evaluator			

Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 8
Event Description: The #1 EDG will trip putting the plant into a blackout. The Alternate AC Generator will become available.			
Time	Position	Applicant's Actions or Behavior	
48	ANY	Recognize and report #1 EDG tripped. <b>TS 3.8.1 Condition E, 3.0.3</b>	
	CRS	Direct operations per 1202.008 Blackout.	
	ATC	Verify proper EFW actuation and control (RT 5). (CRS may direct ATC to re-perform RT5. RT 5 was performed during the Degraded Power event.)	
	CRS	Dispatch an operator to restore EDG (May not be performed as #2 EDG is known to be OOS.)	
<b>EXAMINERS NOTE:</b> U2 will report Maintenance is working on the ACC Generator			
	CRS	Request U2 start AAC Generator.	
	ATC	Check adequate SCM is maintained.	
	ATC	Place P7B handswitch in PULL-TO-LOCK.	
	BOP	Check off-site power available.	
	CRS	Direct dispatcher to take emergency actions to restore power, including system load shed if necessary.	
	CRS	Transition to step 33.	
	CRS	Dispatch an operator to take manual control of EFW pump (P7A) using Emergency Feedwater pump Operation (1106.006).	
<b>EXAMINEERS NOTE</b> Call as U2 and report AAC Generator is running normally and 2A-901 is closed.			
52	CRS	Transition to step 2 of 1202.008 Blackout.	
	CRS	Direct BOP to energize A3 using ES Electrical System Operation (1107.002), Alternate AC Generator Operation" section. <b>(BOP-CT) CT criteria – The AAC generator should be placed in service within 20 minutes of regaining the AAC Generator.</b>	
	BOP	Place DG1 Output Breaker (A-308) in PULL-TO-LOCK.	
	BOP	Verify A1 to A3 Supply Breaker (A-309) open.	

**EVENT 8 CONTINUED**



Op-Test No.: 2008-1		Scenario No.: 2-R5	Event No.: 8 CONTINUED
Event Description: The #1 EDG will trip putting the plant into a blackout. The Alternate AC Generator will become available.			
Time	Position	Applicant's Actions or Behavior	
	BOP	Verify A3-A4 Tie Breakers open (A-310 and A-410).	
	BOP	Verify no bus A3 Lockout.	
	BOP	Turn Synchronize switch on for A3-A4 Tie Breakers (A-310 and A-410).	
	BOP	Close A3-A4 Crosstie (A-310).	
	BOP	Turn Synchronize switch off.	
	BOP	Coordinate with Unit 2 to ensure 2K9 is NOT overloaded when starting loads on bus A3.	
	BOP	If desired, Then start Service Water Pump P-4A or B per Service Water and Auxiliary Cooling System (1104.029).	
	CRS	GO TO 1202.007, "DEGRADED POWER" procedure.	
EXAMINERS NOTE: This scenario is complete when A3 is powered from the AAC Generator OR CRS transitions back to 1202.007 Degraded Power OR As directed by the Lead Evaluator			

Facility: ANO-1			Date of Exam: 9-8-2008			Operating Test No.: 2008-1								
A P P L I C A N T	E V E N T  T Y P E	Scenarios												
		1			2			3 (Spare)			T O T A L	M I N I M U M (*)  R   I   U		
		CREW POSITION			CREW POSITION			CREW POSITION						
		S R O	A T C	B O P	S R O	A T C	B O P	S R O	A T C	B O P				
RO 1, 2, 3	RX		2, 5						3		2	1	1	0
	NOR					1		1, 3	7	1	1	1	1	
	I/C		3, 7, 8			2, 6		2, 4, 6, 9	4, 6, 9	2, 4, 5, 6, 9	5	4	4	2
	MAJ		6, 9			5, 8		6, 7	7, 6	6, 7	4	2	2	1
	TS							6, 6, 7			0	0	2	2
SRO-U 2, 3, 5	RX					3					0	1	1	0
	NOR	1, 2, 5									3	1	1	1
	I/C	3, 4, 7, 8, 9				4, 7					5	4	4	2
	MAJ	6, 9				5, 8					2	2	2	1
	TS	7, 8, 9, 9									4	0	2	2
SRO-U 1, 4, 6	RX										0	1	1	0
	NOR			1	1, 3						2	1	1	1
	I/C			4, 9	2, 4, 6, 7						4	4	4	2
	MAJ			6, 9	5, 8						2	2	2	1
	TS				2, 7, 8						3	0	2	2

Instructions:

- Check the applicant level and enter the operating test number and Form ES-D-1 event numbers for each event type; TS are not applicable for RO applicants. ROs must serve in both the "at-the-controls (ATC)" and "balance-of-plant (BOP)" positions; Instant SROs must serve in both the SRO and the ATC positions, including at least two instrument or component (I/C) malfunctions and one major transient, in the ATC position. If an Instant SRO *additionally* serves in the BOP position, one I/C malfunction can be credited toward the two I/C malfunctions required for the ATC position.
- Reactivity manipulations may be conducted under normal or *controlled* abnormal conditions (refer to Section D.5.d) but must be significant per Section C.2.a of Appendix D. (\*) Reactivity and normal evolutions may be replaced with additional instrument or component malfunctions on a 1-for-1 basis.
- Whenever practical, both instrument and component malfunctions should be included; only those that require verifiable actions that provide insight to the applicant's competence count toward the minimum requirements specified for the applicant's license level in the right-hand columns.

Facility:	ANO-1		Date of Examination:	09/08/2008		Operating Test No.:	2008-1	
Competencies	APPLICANTS							
	RO			SRO-U				
	SCENARIO			SCENARIO				
	1	2	3 (Spare)	1	2	3 (Spare)		
Interpret/Diagnose Events and Conditions	2, 3, 6, 7, 8, 9	2, 4, 5, 6, 8	2, 4, 5, 6, 7, 9	2, 3, 4, 6, 7, 8, 9	2, 4, 5, 6, 7, 8	2, 4, 5, 6, 7, 9		
Comply With and Use Procedures (1)	2, 3, 5, 6, 7, 8, 9	1, 2, 4, 5, 6, 8	1, 2, 3, 4, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 7, 8	1, 2, 3, 4, 5, 6, 7, 8, 9		
Operate Control Boards (2)	2, 3, 5, 6, 7, 8, 9	1, 2, 4, 5, 6, 8	1, 3, 4, 6, 7, 8, 9	N/A	N/A	N/A		
Communicate and Interact	2, 3, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 8	1, 2, 3, 4, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 7, 8, 9		
Demonstrate Supervisory Ability (3)	N/A	N/A	N/A	1, 2, 3, 4, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 7, 8	1, 2, 3, 4, 5, 6, 7, 8, 9		
Comply With and Use Tech. Specs. (3)	N/A	N/A	N/A	7, 8, 9, 9	2, 7, 8	6, 6, 7		
Notes: (1) Includes Technical Specification compliance for an RO. (2) Optional for an SRO-U. (3) Only applicable to SROs.								

**Instructions:**

*Check the applicants' license type and enter one or more event numbers that will allow the examiners to evaluate every applicable competency for every applicant.*