

October 6, 2008

Mr. Thomas L. Williamson
Manager, GGNS COLA Project
Entergy Nuclear
1340 Echelon Parkway
Jackson, MS 39213

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 10 RELATED TO
SRP SECTION 02.02.03 FOR THE GRAND GULF COMBINED LICENSE
APPLICATION

Dear Mr. Williamson:

By letter dated February 27, 2008, Entergy Operations Incorporated (EOI) submitted for approval a combined license application pursuant to 10 CFR Part 52. The U. S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter. To support the review schedule, you are requested to respond within 30 days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, I can be reached at 301-415-2890 or by e-mail at Andrea.Johnson@nrc.gov.

Sincerely,

/RA/

Andrea M. Johnson, Project Manager
ESBWR/ABWR Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket No. 052-0024
eRAI Tracking No. 896, 1005, 902, 1068

Enclosure:
Request for Additional Information

October 6, 2008

Mr. Thomas L. Williamson
Manager, GGNS COLA Project
Entergy Nuclear
1340 Echelon Parkway
Jackson, MS 39213

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION LETTER NO. 10 RELATED TO
SRP SECTION 02.02.03 FOR THE GRAND GULF COMBINED LICENSE
APPLICATION

Dear Mr. Williamson:

By letter dated February 27, 2008, Entergy Operations Incorporated (EOI) submitted for approval a combined license application pursuant to 10 CFR Part 52. The U. S. Nuclear Regulatory Commission (NRC) staff is performing a detailed review of this application to enable the staff to reach a conclusion on the safety of the proposed application.

The NRC staff has identified that additional information is needed to continue portions of the review. The staff's request for additional information (RAI) is contained in the enclosure to this letter. To support the review schedule, you are requested to respond within 30 days of the date of this letter. If changes are needed to the safety analysis report, the staff requests that the RAI response include the proposed wording changes.

If you have any questions or comments concerning this matter, I can be reached at 301-415-2890 or by e-mail at Andrea.Johnson@nrc.gov.

Sincerely,
/RA/
Andrea M. Johnson, Project Manager
ESBWR/ABWR Projects Branch 1
Division of New Reactor Licensing
Office of New Reactors

Docket No. 052-0024
eRAI Tracking No. 1266
Enclosure:
Request for Additional Information
Distribution:
PUBLIC
BSosa, NRO
MTonacci, NRO
BABeywickrama, NRO
AJohnson, NRO

STammara, NRO
CCox, NRO
SBrock, OGC
NRO_DNRL_NGE2
NRO_DNRL_NGE1

ADAMS Accession No. ML082800284

NRO-002

OFFICE	RSAC/TR	RSAC/BC	OGC	NGE2/L-PM
NAME	STammara	CCox	SBrock	MTonacci
DATE	09/18/08	09/18/08	09/26/08	10/06/08

*Approval captured electronically in the electronic RAI system.

OFFICIAL RECORD COPY

Grand Gulf, Unit 3 COLA
Entergy Operations, Inc.
Docket No. 52-024
SRP Section: 02.02.03 - Evaluation of Potential Accidents
Application Section: 2.2.3

QUESTION

02.02.03-1

RG 1.206 provides guidance regarding the information that is needed to ensure potential hazards in the site vicinity are identified and evaluated to meet the siting criteria in 10 CFR 100.20 and 10 CFR 100.21. FSAR Section 2.2.3.1.2 does not provide clearly this information needed by the NRC staff to perform an independent review of that section to confirm that the applicant conforms to the GGNS ESP COL Action item 2.2-1. Please clarify and provide the bases and methodology for calculating the toxic chemical concentrations at the intake of control room, and potential toxic chemical concentration inside the control room with potential air flow rates. Also provide the modeling assumptions and inputs for accidental chemical release scenarios and evaporation characteristics, dispersion and transport mechanisms, distances to control room, and resulting concentrations both at intake to control room and also in the control room if the intake to control room concentration exceeds the limiting concentration.