



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

October 17, 2008

Mr. Michael D. Wadley  
Site Vice President  
Prairie Island Nuclear Generating Plant  
Northern States Power-Minnesota  
1717 Wakonade Drive East  
Welch, MN 55089

SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNITS 1 AND 2 –  
CORRECTION OF ERROR IN AMENDMENT NO. 6 OF MATERIAL LICENSE  
SNM-2506 FOR THE INDEPENDENT SPENT FUEL STORAGE FACILITY  
REGARDING THE TRANSFER OF OPERATING AUTHORITY (TAC NOS.  
L24245, MD9622, AND MD9623)

Dear Mr. Wadley:

By letter dated April 16, 2008, as supplemented by letter dated August 6, 2008, you applied for the subject amendment. On September 22, 2008, the U. S. Nuclear Regulatory Commission staff issued amendment No. 6 to material license SNM-2506, for the independent spent fuel storage installation (ISFSI).

Subsequently, Mr. J. Arias of your staff identified an administrative error on page 6-1 of the technical specifications (TSs) for the Prairie Island Nuclear Generating Plant (PINGP) ISFSI. The amendment number in the page footer is incorrectly identified as "Amendment 4 dtd. September 22, 2008." The correct amendment number is "Amendment 6." Enclosed please find a corrected TS page 6-1 of the PINGP ISFSI.

The correction does not change the approval conveyed by Amendment No. 6, or the conclusion reached by the associated safety evaluation. We apologize for any inconvenience this error may have caused you.

Sincerely,

A handwritten signature in black ink, reading "Thomas J. Wengert".

Thomas J. Wengert, Senior Project Manager  
Plant Licensing Branch III-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-282, 50-306, and 72-10

Enclosure:  
As stated

cc w/encls: Distribution via ListServ

ENCLOSURE

CORRECTED TECHNICAL SPECIFICATION PAGE 6-1 FOR AMENDMENT NO. 6

INDEPENDENT SPENT FUEL STORAGE INSTALLATION

MATERIAL LICENSE NO. SNM-2506

PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNITS 1 AND 2

## 6.0 ADMINISTRATIVE CONTROLS

### 6.1 GENERAL

The Prairie Island ISFSI is located on the Prairie Island Nuclear Generating Plant site and will be managed and operated by Northern States Power Company, a Minnesota corporation (NSPM) staff. The administrative controls shall be in accordance with the requirements of the Prairie Island Nuclear Generating Plant Facility Operating Licenses (DPR-42 and -60) and associated Technical Specifications, as appropriate.

### 6.2 ENVIRONMENTAL MONITORING PROGRAM

The licensee shall include the Prairie Island ISFSI in the environmental monitoring program for the Prairie Island Nuclear Generating Plant. An environmental monitoring program is required pursuant to 10 CFR 72.44(d)(2). The licensee shall include the ISFSI in the environmental monitoring report for the Prairie Island Nuclear Generating Plant, and a copy shall be sent to the Director, Office of Nuclear Material Safety and Safeguards.

### 6.3 ANNUAL ENVIRONMENTAL REPORT

An annual report, as required by 10 CFR 72.44(d)(3), shall be submitted to the NRC Region III, Office, with a copy to the Director, Office of Nuclear Material Safety and Safeguards, within 60 days after January 1 of each year. This report should specify the quantity of each of the principal radionuclides released to the environment in liquid and in gaseous effluents during the previous year of operation and such other information as may be required by the Commission to estimate maximum potential radiation dose commitment to the public resulting from effluent release.

October 17, 2008

Mr. Michael D. Wadley  
Site Vice President  
Prairie Island Nuclear Generating Plant  
Northern States Power-Minnesota  
1717 Wakonade Drive East  
Welch, MN 55089

SUBJECT: PRAIRIE ISLAND NUCLEAR GENERATING PLANT, UNITS 1 AND 2 – CORRECTION OF  
ERROR IN AMENDMENT NO. 6 OF MATERIAL LICENSE SNM-2506 FOR THE  
INDEPENDENT SPENT FUEL STORAGE FACILITY REGARDING THE TRANSFER OF  
OPERATING AUTHORITY (TAC NOS. L24245, MD9622, AND MD9623)

Dear Mr. Wadley:

By letter dated April 16, 2008, as supplemented by letter dated August 6, 2008 you applied for the subject amendment. On September 22, 2008, the U. S. Nuclear Regulatory Commission staff issued amendment No. 6 to material license SNM-2506, for the independent spent fuel storage installation (ISFSI).

Subsequently, Mr. J. Arias of your staff identified an administrative error on page 6-1 of the technical specifications (TSs) for the Prairie Island Nuclear Generating Plant (PINGP) ISFSI. The amendment number in the page footer is incorrectly identified as "Amendment 4 dtd. September 22, 2008." The correct amendment number is "Amendment 6." Enclosed please find a corrected TS page 6-1 of the PINGP ISFSI.

The correction does not change the approval conveyed by Amendment No. 6, or the conclusion reached by the associated safety evaluation. We apologize for any inconvenience this error may have caused you.

Sincerely,

/RA/

Thomas J. Wengert, Senior Project Manager  
Plant Licensing Branch III-1  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket Nos. 50-282, 50-306, and 72-10




Enclosure:  
As stated

cc w/encls: Distribution via ListServ

DISTRIBUTION

PUBLIC	LPL3-1 r/f	RidsNrrDorlLpl3-1Resource
RidsNrrLATHarris Resource	RidsOGCRpResource	RidsAcrcAcnw_MailCTRRResource
RidsNrrDirsltsbResource	G. Hill, OIS	RidsRgn3MailCenterResource
J. Goshen, NMSS	RidsNrrDorlDprresource	RidsNrrPMPrairieIsland Resource

**ADAMS ACCESSION NO: ML082810543**

OFFICE	NRR/LPL3-1/PM	NRR/LPL3-1/LA	NMSS/BC	NRR/LPL3-1/BC
NAME	TWengert 	THarris 	EBenner*	LJames 
DATE	10/15/08	10/15/08	10/14/08*	10/17/08

\* Concurrence via email

OFFICIAL RECORD COPY