

**From:** James Kim  
**Sent:** Wednesday, October 08, 2008 3:03 PM  
**To:** 'Devincentis, Jim'  
**Subject:** Vermont Yankee Nuclear Power Station – ACCEPTANCE OF REQUESTED LICENSING ACTION RE: TS Changes to Main Steam Isolation Valve SR (TAC NO. MD9726)

**SUBJECT:** Vermont Yankee Nuclear Power Station – ACCEPTANCE OF REQUESTED LICENSING ACTION RE: Technical Specification Changes to Main Steam Isolation Valve Surveillance Requirements (TAC NO. MD9726)

By letter dated September 22, 2008, you submitted a license amendment request to revise the Technical Specification (TS) to remove the requirement to perform quarterly closure time testing of the Main Steam Isolation Valves (MSIVs) by deleting TS Surveillance requirement 4.7.D.1.c. Operability testing of the MSIVs will continue to be required by the Vermont Yankee Inservice Test Program. The purpose of this communication is to provide the results of the NRC staff's acceptance review of this amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence. If you have any questions, please contact me.

**James Kim**  
Licensing Project Manager  
U. S. NRC, NRR/DORL  
301-415-4125(Office)  
301-415-2102 (Fax)  
[James.Kim@nrc.gov](mailto:James.Kim@nrc.gov)

---

**E-mail Properties**

Mail Envelope Properties ()

Subject: Vermont Yankee Nuclear Power Station ? ACCEPTANCE OF REQUESTED LICENSING ACTION RE: TS Changes to Main Steam Isolation Valve SR (TAC NO. MD9726)  
Sent Date: 10/08/2008 2:54:45 PM  
Received Date: 10/08/2008 3:03:00 PM  
From: James Kim

Created By: James.Kim@nrc.gov

Recipients:  
jdevinc@entergy.com ('Devincentis, Jim')  
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	10183	10/08/2008

Options

Expiration Date:  
Priority: olImportanceNormal  
ReplyRequested: False  
Return Notification: False

Sensitivity: olNormal  
Recipients received: