

15.4 Reactivity and Power Distribution Anomalies

The information in this section of the reference ABWR DCD, including all subsections, tables, and figures, is incorporated by reference with the following departures and supplements.

STD DEP Admin

15.4.2.1 Features of the ABWR Automatic Thermal Limit Monitoring System (ATLM)

STD DEP Admin

In the ABWR, the Automatic Thermal Limit Monitoring (ATLM) System performs the rod block monitoring function. The ATLM System is a dual channel subsystem of the Rod Control and Information System (RCIS). In each ATLM channel there are two independent thermal limit monitoring devices. One device monitors the MCPR limit and protects the operating limit of the MCPR, and the other device monitors the APLHGR limit and protects the operating limit of the APLHGR. The rod block algorithm and setpoint of the ATLM System are based on actual online core thermal limit information. If any one of the two limits is reached, either due to control rod withdrawal or recirculation flow increase, control rod withdrawal permissive is removed. Detailed description of the ATLM System is presented in ~~Reference 15.4-1~~ and Chapter 7.

15.4.5 Recirculation Flow Control Failure with Increasing Flow

15.4.5.2.1.3 Identification of Operator Actions

STD DEP Admin

Reactor pressure is controlled as required, depending on whether scram occurs and, if scram occurs, whether a restart or cooldown is planned. In general, following a scram, the corrective action is to hold reactor pressure and condenser vacuum for restart after the malfunction has been repaired. The following is the sequence of operator actions expected during the course of the event, assuming restart. The operator should:

- (3) Switch the reactor mode switch to the ~~STARTUP~~SHUTDOWN position

15.4.11 COL License Information

15.4.11.1 Mislocated Fuel Bundle Accident

The following site-specific supplement addresses COL License Information Item 15.5.

The analysis results of the fuel bundle mislocated event will be prepared based on ~~implementation of the GESTAR Amendment 28 (Reference 15.4-6) requirements and~~ NRC approved methods and provided as an amendment to the FSAR in accordance with 10 CFR 50.71(e), at least one year prior to fuel load. This analysis will reflect the final fuel design for the initial core loading. (COM 15.4-1)

15.4.11.2 Misoriented Fuel Bundle Accident

The following site-specific supplement addresses COL License Information Item 15.6.

The analysis results of the fuel bundle misoriented event will be prepared based on ~~implementation of the GESTAR Amendment 28 (Reference 15.4.6) requirements~~ NRC approved methods and provided as an amendment to the FSAR in accordance with 10 CFR 50.71(e), at least one year prior to fuel load. This analysis will reflect the final fuel design for the initial core loading. (COM 15.4-2)

~~15.4.12 References~~

~~The following site-specific supplement adds the following reference.~~

~~GESTAR II Amendment 28, "Mislocated Fuel Bundle Event Licensing Basis Change to Comply with Standard Review Plan 15.4.7," NEDE 24011.~~