

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50259

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #SQM-6-005-X02

Category: 88

Confidentiality: Yes No (I&H)

Supervisor Notified: Yes No Nuclear Safety Related YES

Concern: WELDER CERTIFICATION TEST RECORDS WERE POTENTIALLY FALSIFIED FOR AN INDIVIDUAL (KNOWN), BY AGREEMENT BETWEEN ENGINEERING (KNOWN) AND GENERAL FOREMAN (KNOWN). OCCURRED IN MARCH 1985. ADDITIONAL DETAILS KNOWN. ANONYMOUS CONCERN.

NO FOLLOW-UP REQUIRED.

William A. ... JAN 24 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS, ERT _____

NSRS EGFG

OTHERS (SPECIFY) OGG

*welding
welder*

Bernard J. ... 128 86
NSRS Date

EMPLOYEE CONCERN ASSIGNMENT REQUEST

To: Director - NSRS

TRANSMITTAL NUMBER T50-229

ERT has received the Employee Concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #: SDP-5-004-002

5-76-163-268

Category: 52

Confidentiality: N/A YES N/A NO (I & H)

Supervisor Notified: XX YES NO Nuclear Safety Related-Yes

Concern: The configuration of the electrical equipment in the Transfer Canal is not per the drawing. Details known to GTC and withheld to maintain confidentiality. Nuclear Power Concern. No further information may be released. CI has no further information.

No follow up required.

concerning to group

William M. Schen

MANAGER, ERT DATE

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS *PCS*

OTHERS (SPECIFY) _____

Operational Control

Robert F. Dugher *1-24-86*

NSRS DATE

man's

EMPLOYEE CONCERN ASSIGNMENT REQUEST

To: Director - NSRS

TRANSMITTAL NUMBER - T50-229

ERT has received the Employee Concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #: SPW-S-004-003

I-86-104-0611

Category: 53

Confidentiality: N/A YES N/A NO (I & H)

Supervisor Notified: YES NO Nuclear Safety Related - YES

Concern: Sequoyan: New material has been ordered scrapped by a Supervisor and later retrieved by a different group. This could represent a lack of control regarding scrapped material. Names/details known to OTC and withheld to maintain confidentiality. No further information may be released. Nuclear Power Concern. CI has no further information.

No follow up required.

SAO/...

William A. Schu

MANAGER, ERT DATE

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS *PKS*

OTHERS (SPECIFY) _____

material control

Barry P. Stephen

NSRS

1-24-82
DATE

EMPLOYEE CONCERN ASSIGNMENT REQUEST

To: Director - NSRS

TRANSMITTAL NUMBER - 150-229

ERT has received the Employee Concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #: SQP-5-004-004

J-76-165-000

Category: 53

Confidentiality: N/A YES N/A NO (I & H)

Supervisor Notified: XX YES NO Nuclear Safety Related - YES

Concern: Seduoyan: CI is frequently directed by Supervisor to violate procedures. Supervisor argues with CI when CI refuses to violate the procedures. Names/details known to OITL and withheld to maintain confidentiality. No further information may be released. Nuclear Power Concern. CI has no further information.

No follow up required.

CONFIDENTIAL

William M. [Signature]
MANAGER, ERT DATE

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS *PC*

OTHERS (SPECIFY) _____

QA Violation

Robert P. [Signature] 1-24-86
NSRS DATE

EMPLOYEE CONCERN ASSIGNMENT REQUEST

To: Director - NSRS

TRANSMITTAL NUMBER - 150-224

ERT has received the Employee Concern identified below. AND HAS assigned the indicated category and priority:

Priority: 1

Concern #: 502-S-005-002
I-56706

Category: 52

Confidentiality: N/A YES N/A NO (1 & 2)

Supervisor Notified: XX YES

NO Nuclear Safety Related YES

Concern: Sequoyah: In 1976-77, Aux Bldg, elevation 142, level I, in the MOV Board Room 1A, between column lines A-1 to A-6 and "R" line holes were left in the ceiling under the conduit and cable tray supports. Rebar was hit while drilling the holes, so the hole location was moved, and the old holes were left with the shells installed and the holes not filled with grout. Details known to QTC withheld to maintain confidentiality. No further information may be released. CI has no additional information. Conet. Dept. concern. No further information may be released.

No follow-up required.

William A. ...

MANAGER, ERT

DATE

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____ ROUTE to UT FOR ERT ASSIGNMENT

NSRS/ERT _____

NSRS YES

OTHERS (SPECIFY) _____

*Carol
Am. hrs*

Brian P. ...

NSRS

1-24-85
DATE

EMPLOYEE CONCERN ASSIGNMENT REQUEST

To: Director - NRSB RECID: 150-229

ERT has received the Employee Concern identified below, and has assigned the indicated category and priority:

Priority: 1 Concern #: 5045-005-005
Category: 02 Confidentiality: N/A YES N/A NO (I & H)
Supervisor Notified: XX YES NO Nuclear Safety Related: Yes

CONCERN: See above in 150-229, HUI building, elevation 749 of Unit 1, in the MV Board Room in between column lines A-2 to A-8 and "C" line nonconforming conditions with the installation of conduit and cable tray supports such as, but not limited to anchor shells, incorrectly installed, anchor shells wrong size anchors, cut rebar, modified support plates, and anchor holes not filled were identified. However these nonconforming conditions were not documented and appropriate action implemented. Details known to ERT, withers to maintain confidentiality. No further information may be released. CI has not additional information. Const. Dept. concern.

No follow-up required.

William M. ...
MANAGER, ERT UNIT

NRSB has assigned responsibility for investigation of the above concern to:

ERT ROUTE TO TOP ASSIGNMENT TO ERT

NRS/ERT

NRSB ✓ RLS

OTHERS (SPECIFY)

*Civil
medals*

James F. ...
NRSB UNIT

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50246

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #SQP-6-003-003

IP-206-55A

Category: 52

Confidentiality: ___Yes___ No (I&H)

Supervisor Notified: ___Yes___ No Nuclear Safety Related YES

Concern: CONDUIT IS CURRENTLY BEING REMOVED AND REINSTALLED (REROUTED) WITHOUT PROPER DOCUMENTATION. LOWER CONTAINMENT, FAN ROOM #1, UNIT 2, APPROXIMATELY ELEV. 680'. WORK PLAN 11882: NUCLEAR POWER CONCERN. CI HAS NO FURTHER INFORMATION.

207/Conduit Reroutes

JAN 17 1986

Manager, ERT

Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS *p.s*

OTHERS (SPECIFY) _____

*Operation
Control*

Bruce A. ...
NSRS

1-24-86
Date

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50246

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #WBM-5-008-001

Category: 52

Confidentiality: Yes No (I&H)

Supervisor Notified: Yes No Nuclear Safety Related YES

Concerns: B-001 TYPE PIPE SUPPORT ON SAFETY-RELATED SYSTEM (EX. AFW, SIS) HAVE A WELDING-CAUSED CONDITION WHICH PRODUCES AN ELLIPTICAL SHAPE IN THE SUPPORT TUBE. TESTING NEEDS TO BE DONE TO DETERMINE IF THE DISTORTION OF THE SUPPORT TUBE CAUSED OVERSTRESSING IN INSTRUMENT/DRAIN LINE IT SUPPORTS. NUCLEAR POWER CONCERN. CI HAS NO FURTHER INFORMATION.

Pipe Support

[Signature] JAN 17 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS *FDW*

OTHERS (SPECIFY) _____

Hanger Design

Bruce J. Dieffen 1-24-86
NSRS Date

may 16

PSR

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50259

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #WBM-6-004-004

Category: 53

Confidentiality: Yes No (I&H)

Supervisor Notified: Yes No Nuclear Safety Related YES

Concern: TVA IS OPERATING THEIR NUCLEAR PLANTS UNDER PROGRAMS AND LETTERS OF RELIEF WHICH HAVE BEEN SUBMITTED TO THE NRC FOR APPROVAL, BUT FOR WHICH NO APPROVAL HAS BEEN RECEIVED. BECAUSE THE THIRD PARTY INSPECTION AT THE TVA NUCLEAR PLANTS WORK TO THESE PROGRAMS AND LETTERS AS IF THEY HAD BEEN APPROVED, THE PROGRAM EFFECTIVENESS IS DILUTED IF NOT USELESS. NO FURTHER INFORMATION IN FILE. ANONYMOUS CONCERN.

NO FOLLOW-UP REQUIRED.

W. W. Stein JAN 24 1966
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS ✓ x1

OTHERS (SPECIFY) _____

QA effect

Bruce L. Lichten 1-28-66
NSRS Date

May 16

PSR

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50259

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #WBM-6-004-005

Category: 53

Confidentiality: Yes No(I&H)

Supervisor Notified: Yes No Nuclear Safety Related YES

Concern: TVA DOES NOT REPORT TO THE NRC, IN THE NUCLEAR IN-SERVICE FORM (NIS-1) ALL OUTSTANDING PROGRAMS, LETTERS OF RELIEF, AND OTHER ITEMS WHICH EXIST AT THEIR NUCLEAR PLANTS (GENERIC). NO FURTHER INFORMATION IN FILE. ANONYMOUS CONCERN.

NO FOLLOW-UP REQUIRED.

William S. Schuman JAN 24 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS XI

OTHERS (SPECIFY) _____

QA
Effect

Barbara L. Griffin 1-28-86
NSRS Date

2/2/86

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50259

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #WBM-6-004-007

Category: 53

Confidentiality: Yes No (I&H)

Supervisor Notified: Yes No Nuclear Safety Related YES

Concern: MANY MEMBERS OF NUCLEAR PLANT MANAGEMENT ARE NOT AWARE OF THE EXISTENCE OF THE NUCLEAR QUALITY ASSURANCE MANUAL (NQAM), MUCH LESS THE MANUAL CONTENTS. NO FURTHER INFORMATION IN FILE. ANONYMOUS CONCERN.

NO FOLLOW-UP REQUIRED.

William S. Schaefer JAN 24 1986 -
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS x

OTHERS (SPECIFY) _____

QA
Effect

Robert S. Lipton 1-28-86
NSRS Date

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50259

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #WBM-6-004-X08

Category: 88

Confidentiality: Yes No (I&H)

Supervisor Notified: Yes No Nuclear Safety Related YES

Concern: TVA HAS POTENTIALLY FALSIFIED NIS-1 NUCLEAR IN-SERVICE FORMS, BY NOT INCLUDING ALL REQUIRED INFORMATION RELATIVE TO OUTSTANDING PROGRAMS/LETTERS OF RELIEF WHICH HAVE NOT BEEN APPROVED BY THE NRC. NO FURTHER INFORMATION IN FILE. ANONYMOUS CONCERN.

NO FOLLOW-UP REQUIRED.

William S. Schuman JAN 24 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS xl

OTHERS (SPECIFY) 06c

*welding
inspections*

Robert S. Dyer 1-28-86
NSRS Date

9 May 16

732

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50230

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern # WI-85-040-006

Category: 53

Confidentiality: NA YES NA_NO (I&H)

Supervisor Notified: YES NO NUCLEAR SAFETY RELATED YES

Concern: NCR (number known) was written to document nonconforming conditions relative to cement mortar patches in Units 1 & 2, at various locations/elevations. CI questions the validity and appropriateness of this NCR and the associated corrective actions. Details known to DFC, withheld due to confidentiality. No further information may be released.

Construction department concern.

CI has no further information.

PER/...

No follow up required.

CEH/...
MANAGER, ERT

12-17-85
DATE

NSRS has assigned responsibility for investigation of the above concern to:

ERT

NSRS/ERT

NSRS PRW

OTHERS (SPECIFY) _____

*Civil
Concrete*

Russell L. ...
NSRS

1-21-86
DATE

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50245

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 4

Concern #WI-85-066-001
2-86-20-250

Category: 86

Confidentiality: Yes No (I&H)

Supervisor Notified: Yes No Nuclear Safety Related YES

Concern: THERE IS SOME PROBLEM WITH THE QUALITY OF WORK AT WBNP. THERE IS NO ADDITIONAL INFORMATION IN THE FILE. CI DECLINED TO PROVIDE ANY FURTHER INFORMATION.

Quality of work

[Signature] JAN 17 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS _____

OTHERS (SPECIFY) _____

RA Effect

[Signature] 1-24-86
NSRS Date

PSK

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50245

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #WI-85-066-002

Category: 7

Confidentiality: ^{85-195 WGN} Yes No (IAH)

Supervisor Notified: Yes No Nuclear Safety Related YES

Concern: EMPLOYEES ARE NOT INFORMED ENOUGH ABOUT QA AND QC PROCEDURAL REQUIREMENTS. BECAUSE OF THE TIME INVOLVED. CI DECLINED TO PROVIDE ADDITIONAL INFORMATION. THERE IS NO ADDITIONAL INFORMATION IN THE FILE

Procedural Requirements

JAN 17 1986

Manager, ERT

Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS x2

OTHERS (SPECIFY) _____

Bruce L. Diefen
NSRS

1-24-86
Date

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50230

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1 Concern # XX-85-049-001

Category: 88 Confidentiality: NA_ YES NA_NO(I&H)

Supervisor Notified: ___YES _X_ NO NUCLEAR SAFETY RELATED YES_

Concern: Sequoyah: Welder certifications have been updated for welders who did not meet update requirements or backdated to give the appearance of requirement compliance.

Construction department concern.

CI declined to provide further information.

No follow up required.

copy to...

CCHilo to _____ 12-17-85
MANAGER, ERT DATE

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS 1 *PCS*

OTHERS (SPECIFY) _____

*welding
welder*

Bruce P. Hoffman _____ 1-24-86
NSRS DATE

page 16

PSR

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50257

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #XX-85-085-002

I-36-142-511

Category: 86

Confidentiality: ___Yes___No(I&H)

Supervisor Notified: ___Yes__X_No Nuclear Safety Related YES

Concern: BELLEFONTE - CI QUESTIONS SUPERVISORS MANAGEMENT TECHNIQUES AND INDEPENDENCE FROM PRODUCTION. DETAILS KNOWN TO QTC, WITHHELD DUE TO CONFIDENTIALITY. NUCLEAR POWER CONCERN. CI HAS FURTHER INFORMATION. NO FURTHER INFORMATION MAY BE RELEASED.

BLM/management concern

William M. ... JAN 22 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS PLS

OTHERS (SPECIFY) _____

QA effect

Bruce P. ... 1-24-86
NSRS Date

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50230

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern # XX-85-088-002

Category: 53

Confidentiality: NA YES NA_NO (I&H)

Supervisor Notified: ___YES _X_ NO NUCLEAR SAFETY RELATED YES_

Concern: The "standard accepted" method of making corrections to quality records by Knoxville personnel is by use of correction fluid. This method is in conflict with the methods specified as allowable by the applicable Nuclear Plant procedures. CI feels that consistent procedural requirements should be applied to the correction of quality records.

Construction department concern.

CI has no further information.

No follow up required.

correction fluid

CCNile for _____ 12-16-85
MANAGER, ERT DATE

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS _____ X1

OTHERS (SPECIFY) _____

QA Document

Bruce J. ... _____ 1-24-86
NSRS DATE

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50230

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1 Concern # XX-85-088-003
Category: 53 Confidentiality: NA YES NA_NO(I&H)
Supervisor Notified: ___YES _X_ NO NUCLEAR SAFETY RELATED YES

Concerns: Knoxville: Sequoyah Welding Certifications were altered by the use of correction fluid before they were photographed in Knoxville. Process markings such as file indexes and page counts, as well as any marks, notations, or any data that did not look like Engineering data on the back of the document, were deleted with correction fluid. Department known.

Construction department concern.

SON/correction fluid

CI has no further information.

No follow up required.

C. Hill 12-16-85
MANAGER, ERT DATE

NSRS has assigned responsibility for investigation of the above concern to:

ERT ___
NSRS/ERT _____
NSRS *✓* *DCS*
OTHERS (SPECIFY) _____

Welding Document

Bruce P. Sullivan 1-24-86
NSRS DATE

FSR

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50257

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #XX-85-095-001

Category: 05

Confidentiality: I-76-191-627 Yes ___ No (I&H)

Supervisor Notified: X Yes ___ No Nuclear Safety Related YES

Concern: CI STATED THAT AT BELLEFONTE A RESPONSIBLE ENGINEER (DESIGNATION KNOWN) WOULD HAVE INSPECTION REPORTS SIGNED OFF BY SIMPLY ATTACHING A NOTE TO THE INSPECTION RECORD STATING, "THIS IS O.K. PER ME" AND THE INSPECTOR WOULD SIGN IT OFF. THIS METHOD WAS USED ON QUALITY SYSTEMS. NO ADDITIONAL INFORMATION IS AVAILABLE IN THE FILE. CONSTRUCTION DEPARTMENT CONCERN.

BLM/INSPECTION REPORT

William [Signature] JAN 22 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS ✓ PCS

OTHERS (SPECIFY) _____

QA Document

Bruce J. [Signature] 1-24-86
NSRS Date

PSR

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50257

ERT has received the Employee concern identified below, and has assigned the indicated category and priority:

Priority: 1

Concern #XX-85-097-001

I-36-190-BLN

Category: 14

Confidentiality: ___ Yes ___ No (I&H)

Supervisor Notified: X Yes ___ No Nuclear Safety Related YES

Concern: BELLEFONTE - SEVERAL PIPE SUPPORT HANGERS ON THE EAST-WEST FLAT WALLS INSIDE CONTAINMENT RB #1 AT BELLEFONTE ARE ATTACHED TO EMBEDDED PLANTS ORIGINALLY DESIGNED FOR HIGH PRESSURE INJECTION RESTRAINTS. THE MAJORITY OF THESE EMBEDS HAVE ONLY 1 OR 2 WELDED STUDS TO HOLD THE PLATE TO THE CONCRETE. HOWEVER, THERE ARE LAST-IN-PLACE ANCHORS THROUGH THE PLATES. THERE IS NO DOCUMENTATION ON THESE ANCHORS EVER BEING UTILIZED TO HELP SUPPORT THE LOADS. NO ADDITIONAL INFORMATION IS AVAILABLE IN THE FILE. CONSTRUCTION DEPARTMENT CONCERN.

BLN/support hangers

William A. ... JAN 22 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS ✓ *PCS*

OTHERS (SPECIFY) _____

*Civil
Embeds*

Bruce F. ... 1-24-86
NSRS Date

EMPLOYEE CONCERN ASSIGNMENT REQUEST

TO: Director - NSRS

TRANSMITTAL NUMBER T50247

ERT has received the Employee concern identified below, and ~~has~~ assigned the indicated category and priority:

Priority: 1

Concern #XX-85-120-006

I-86-194-SGN

Category: 53

Confidentiality: ___ Yes ___ No (I&H)

Supervisor Notified: ___ Yes X ___ No Nuclear Safety Related YES

Concern: SEQUOYAH - HANGER CREWS WERE INSTRUCTED (SUPERVISOR KNOWN) TO GO AHEAD AND BUILD HANGERS WITHOUT DRAWINGS, AND ENGINEERING WOULD DRAW THE HANGER UP LATER. MANY OF THESE HANGERS WERE SUBSEQUENTLY REJECTED AND REWORKED. CONSTRUCTION DEPARTMENT CONCERN. CI HAS NO FURTHER INFORMATION.

SGN/Hanger installation

William M. ... JAN 17 1986
Manager, ERT Date

NSRS has assigned responsibility for investigation of the above concern to:

ERT _____

NSRS/ERT _____

NSRS ✓ *PCS*

OTHERS (SPECIFY) _____

Construction Control

Barbara P. ... 1-24-86
NSRS Date