



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

APR 13 1981

MEMORANDUM FOR: Robert L. Tedesco, Assistant Director for Licensing
Division of Licensing

FROM: Paul S. Check, Assistant Director for Plant Systems
Division of Systems Integration

SUBJECT: ICSB REVIEWS FOR NTOL WESTINGHOUSE PLANTS

The following is an outline of the program to complete the ICSB review effort for the next four NTOL applications for Westinghouse plants which come after the Summer and Comanche Peak reviews. The plants, in the order of their review priority, are Watts Bar, Callaway (SNUPPS), Seabrook, and Byron. The steps to be taken are consistent with Mr. Denton's recent instructions to expedite and shorten the review schedule. In addition to the ICSB review effort for these four plants, laboratory programs are underway to provide additional review assistance, primarily in the area of drawing reviews. The ICSB and laboratory review will be closely coordinated.

The basic steps in this program are:

1. Issue review questions. This effort will be based upon an expedited review of Chapter 7 of the FSAR. The objective will be to identify specific questions and areas of concern which are to be the topics of further discussion and clarification with the applicant. We will request that applicants be prepared to discuss their response to the review questions in subsequent meetings rather than proceed to provide written responses. We believe that this will permit us to sharpen the focus on the issues and thus avoid the lengthy process of repeated question and answer transmittals. At the conclusion of the meeting we will establish the appropriate action to be taken on each item. Possible courses of action would be to (1) revise the FSAR to provide the required clarifications, (2) provide a formal response to the question or (3) document the resolution in staff meeting notes, or (4) staff may issue a position on the concern.
2. Orientation Meeting. A one day orientation meeting would be held with the applicant in Bethesda about two weeks after the submittal of review questions. The purpose of this meeting would be to establish the schedule for the meeting dates and to outline the objectives of the review process. We would not expect to discuss the technical detail of the review questions, however we would attempt to assign priorities and schedules for addressing each item. Also we would establish contacts such that any subsequent additional questions could be factored into the review process.

8104200179 xA

288

3. NSSS System Review Meeting. This meeting would cover a span of three to five days and would concentrate on the applicant's response to questions and concerns related to the NSSS design. This meeting would not be a design review along the lines that have been conducted by the Palo Verde applicant (independent design review) but rather as a staff review meeting to have the applicant respond to staff concerns. This meeting would address interfaces between the NSSS and BOP plant design.
4. BOP System Review Meeting. This would parallel the effort noted for the NSSS system review meeting. The meeting would cover a span of three to five days.
5. Site Visit. A site visit would follow the format for site visits as noted in Chapter 7 of the Standard Review Plan.
6. Open Item Resolution Meeting. This meeting would cover a span of three to five days and would be used to resolve as many open items carried over from the NSSS and BOP review meetings as possible.
7. Draft SER Issue. A safety evaluation report would be issued to DOL. Any open items will be noted and addressed in the SSER.
8. Draft SSER Issue. The SSER will address all open items remaining from the SER.

Attached are tentative schedules for the review of these plants which address each of the above items. Please confirm that each applicant will work towards being responsive to these schedules. We would suggest that the applicants be given the schedule for these four plants and the opportunity to send observers to the meetings that precede their schedule so that they may be better prepared when their time comes up.



Paul S. Check, Assistant Director
for Plant Systems
Division of Systems Integration

cc w/enclosure:

R. Mattson
A. Schwencer
B. Youngblood
C. Moon
S. Black
R. Auluck
A. Dromerick
F. Rosa
T. Speis
O. Parr
M. Srinivasan
T. Dunning
A. Ungaro
R. Fitzpatrick
ICSB Members

DISTRIBUTION:

Docket File
ICSB R/F
F. Burrows (PF)(2)
T. Dunning
F. Rosa
Vogtle S/F

APR 12 1984

MEMORANDUM FOR: Elinor Adensam, Chief, Licensing Branch #4
Division of Licensing

FROM: Faust Rosa, Chief, Instrumentation & Control Systems Branch
Division of Systems Integration

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION AND AGENDA ITEMS
FOR MEETING WITH VOGTLE UNITS 1&2 APPLICANT

Plant Name: Vogtle, Units 1&2
Docket Nos.: 50-424/425
Licensing Status: OL
Responsible Branch: LB #4
Project Manager: M. Miller
Review Branch: ICSB
Review Status: Incomplete

In our memorandum to you dated January 4, 1984, we stated that the ICSB review for Vogtle 1&2 will use meeting discussions to resolve our concerns. Attachment 1 is a list of items which ICSB would like to discuss with the applicant. The applicant should be prepared to use detailed instrument, control and fluid system schematic drawings to explain system designs and to provide verification that design bases and regulatory criteria are met. Attachment 2 is a list of formal questions that relate to IE Bulletin concerns. We request that a written response be provided for these questions. Additional written responses may be required for some items in Attachment 1 after meeting discussions.

We request that the Project Manager arrange the review meetings to resolve these concerns for the last week in August 1984 as previously agreed to.

*Original Signed By:
Faust Rosa*

Enclosures:
As stated

Faust Rosa, Chief
Instrumentation & Control Systems Branch
Division of Systems Integration

cc: R. Mattson
R.W. Houston
T. Novak
M. Miller

Contact:
F. Burrows, ICSB
X29455

~~50-4250092~~

J.R.

OFFICE	ICSB/DSI	ICSB/DSI	ICSB/DSI				
SURNAME	EBB/DS:ct	T Dunning	FRosa				74
DATE	4/12/84	4/11/84	4/11/84				

ATTACHMENT 1

QUESTIONS FOR MEETING(S) WITH APPLICANT
ON VOGTLE UNITS 1 AND 2 INSTRUMENTATION AND CONTROLS

Following is a list of items for discussion at meetings with the applicant to provide the NRC staff with information required to understand the design bases and design implementation for the instrumentation and control systems for Vogtle Units 1 and 2. The applicant should be prepared to use detailed instrument, control, and fluid system drawings at the meetings in explaining system designs and to provide verification that design bases and regulatory criteria are met.

1. Identify any plant safety related system or portion thereof, for which (7.1) the design is incomplete at this time.

2. As called for in Section 7.1 of the Standard Review Plan, provide (7.1) information as to how your design conforms with the following TMI Action Plan Items as described in NUREG-0737:
 - (a) II.D.3 - Relief and Safety Valve Position Indication
 - (b) II.F.1 - Accident Monitoring Instrumentation (Subpart 4)
 - (c) II.K.3.10 - Proposed Anticipatory Trip Modification

3. Provide a brief overview of the plant electrical distribution system, (7.1) with emphasis on vital buses and separation divisions, as background for addressing various Chapter 7 concerns.

4. Describe design criteria and tests performed on the isolation devices (7.1) in the Balance of Plant Systems. Address results of analysis or tests

performed to demonstrate proper isolation between separation groups and between safety and non-safety systems.

5. Describe features of the Vogtle Units 1 & 2 environmental control system which insure that instrumentation sensing and sampling lines for systems important to safety are protected from freezing during extremely cold weather. Discuss the use of environmental monitoring and alarm systems to prevent loss of, or damage to systems important to safety upon failure of the environmental control system. Discuss electrical independence of the environmental control and monitoring system circuits.
(7.1)
6. Provide a list of any non-Class 1E control signals that provide input to class 1E control circuits.
(7.1)
7. Identify where microprocessors, multiplexers, or computer systems are used in or interface with safety-related systems. Also identify any "first-of-a-kind" instruments used for safety-related systems.
(7.1)
8. We request that the setpoint methodology for each Reactor Protection System (RPS) and Engineered Safeguards Features (ESF) trip setpoint values be provided for both NSSS and BOP scope of supply at the time the Technical Specifications are submitted for review.
(7.1)

9. Identify any Balance of Plant scope safety related equipment (other (7.1) than those listed in Section 7.1.2.5 of the FSAR) that cannot be tested during reactor operation. Include auxiliary relays or other components in the safety-related systems.

10. Discuss the following:
 - (7.1) (a) Response time testing of BOP and NSSS protection systems using the design criteria described in position C.5 of R.G. 1.118 and Section 6.3.4 of IEEE 338.

 - (b) Identify any temporary jumper wires or test instrumentation which will be used. Provide further discussion to describe how the test procedures for the protection systems conform to R.G. 1.118 position C.6.

 - (c) Typical response time test methods for pressure and temperature sensors.

11. Using detailed plant design drawings, discuss the reactor trip (7.2) breaker and undervoltage relay testing procedures, and the capability of independent verification of the operability of reactor trip breaker shunt and undervoltage coils.

12. Describe the steam generator level instrumentation. Identify the
(7.2) instrument channel used for protection functions and the control
(7.3) functions. Address the control and protection interaction con-
formance to Section 4.7 of IEEE Std. 279-1971 and the use of the
selector switch in steam generator level input shown in FSAR
Figure 7.2.1-1 (Sheet 13).
13. Using detailed schematics, describe the design of pressurizer PORV
(7.2) control and the block valve control, and verify that no single
(7.6) failure will preclude the automatic actuation logic for all modes
of operation.
14. The information in Section 7.2.1.1.2 for "Reactor Trip on a Turbine
(7.2) Trip" is insufficient. Please provide further design bases dis-
cussion on this subject, per BTP ICSB 26 requirements. As a minimum
you should:
- (1) Using detailed drawings, describe the routing and separation
for this trip circuitry from the sensor in the turbine building
to the final actuation in the reactor trip system (RTS).

- (2) Discuss how the routing within the non-seismic Category 1 turbine building is such that the effects of credible faults or failures in this area on these circuits will not challenge the reactor trip system and thus degrade the RTS performance. This should include a discussion of isolation devices.
- (3) Describe the power supply arrangement for the reactor trip on turbine trip circuitry.
- (4) Discuss the testing planned for the reactor trip on turbine trip circuitry.
- (5) Discuss seismic qualification of the sensors.

Identify other sensors or circuits used to provide input signals to the other protection systems which are located or routed through non-seismically qualified structures. This should include sensors or circuits providing input for reactor trip, emergency safeguards equipment such as the auxiliary feedwater system, and safety grade interlocks. Verification should be provided that the sensors and circuits meet IEEE-279 and are seismically and environmentally qualified. Testing or analyses performed to insure that failures of non-seismic structures, mountings, etc. will not cause failures which could interfere with the operation of any other portion of the protection system should be discussed.

15. Identify where instrument sensors or transmitters supplying information to more than one protection channel are located in a common instrument line or connected to a common instrument tap. The intent of this item is to verify that a single failure in a common instrument line or tap (such as break or blockage) cannot defeat required protection system redundancy. Include a discussion of the pressurizer pressure transmitters mentioned in the second paragraph on page 7.2.1-6 and the fifth paragraph on page 7.2.2-19 of the FSAR.
 - (7.2)
 - (7.3)
16. Provide specific values for the P-6, P-9, and P-13 interlocks.
 - (7.2)
17. Discuss the method of redundantly tripping the turbine following receipt of reactor protection signals requiring turbine trip.
 - (7.2)
18. Table 7.2.1-1 of the FSAR shows a 1/4 logic entry for reactor trip on low reactor coolant flow. Please discuss.
 - (7.2)
19. As discussed in Section 7.2.2.3.1 of the FSAR, an isolated output signal from protection system channels is provided for automatic rod control. Discuss how this signal is derived. Discuss what steps, if any, are taken to prevent unnecessary control action during testing of protection system channels with a test source.
 - (7.2)
20. Discuss surveillance of the RTD bypass loop flow indications.
 - (7.2) Confirm that technical specifications will include surveillance requirements for these indications.

21. Recent review of Waterford revealed heaters were used to control
(7.2) temperature and humidity within insulated cabinets housing electrical transmitters that provide inputs to the RPS. These heaters were unqualified and concern was raised that heater failure could cause transmitter degradation. Please address any similar installations at Vogtle Units 1&2. If heaters are used, describe design criteria.

22. Address the conflicts between the logic for the reactor coolant
(7.2) pump undervoltage and underfrequency trips described in Table 7.2-1-1 of the FSAR and that shown in Figure 7.2.1-1 (Sheet 5).

23. Using detailed plant design drawings, discuss the control room
(7.3) essential HVAC system.

24. Using detailed plant design drawings, discuss the containment auto-
(7.3) matic isolation system.

25. Using detailed logic and schematic diagrams, describe the combusti-
(7.3) ble gas control system initiating circuits, bypasses, interlocks and functional testing.

26. Using detailed system schematics, describe the sequence for auto-
(7.3) matic initiation, operation, reset, and control of the auxiliary
(7.4) feedwater system. The following should be included in the discussion:

- a) the effects of all switch positions on system operation,
 - b) the effects of single power supply failures including the effect of a power supply failure on auxiliary feedwater control after automatic initiation circuits have been reset in a post accident sequence.
 - c) any bypasses within the system including the means by which it is insured that the bypasses are removed.
 - d) initiation and annunciation of any interlocks or automatic isolations that could degrade system capability.
 - e) the safety classification and design criteria for any air systems required by the auxiliary feedwater system. This should include the design bases for the capacity of air reservoirs required for system operation.
 - f) design features provided to terminate auxiliary feedwater flow to a steam generator affected by either a steam line or feed line break.
 - g) system features associated with shutdown from outside the control room.
27. Section 7.3.1.1.1.1 of the FSAR does not include the turbine-
(7.3) driven auxiliary feedwater pump as relying on ESFAS initiation.
Please discuss.
28. Using detailed plant design drawings, illustrate that the com-
(7.3) ponents in the auxiliary feedwater turbine-driven pump fluid
(7.4) paths are totally independent from AC power sources. Discuss
the capability to control or terminate auxiliary feedwater flow
under a loss of AC power event.

29. Discuss the water sources of the auxiliary feedwater system and
(7.3) the capability to transfer one source to the other.
(7.4)
30. For main steam and feedwater line valve actuation, describe control
(7.3) circuits for isolation valves and include automatic, manual and test
features. Indicate whether any valve can be manually operated and
indicate specific interfaces with the safety system electrical
circuits.
31. Using detailed schematics, describe the operation of the containment
(7.3) heat removal system initiating circuits, bypasses, interlocks and
functional testing.
32. Using logic and schematic diagrams, describe the safety injection
(7.3) system initiating circuits, bypasses, interlocks and functional
testing.
33. Using logic and schematic diagrams, describe the AC emergency power
(7.3) system (diesel generators and sequencer), initiating circuits, bypasses,
interlocks and functional testing.
34. As discussed in Section 5.4.15.2 of the FSAR, the reactor vessel head
(7.3) vent system consists of two parallel flow paths with redundant isola-
tion valves in each flow path. Discuss operation of this system from
the control room. Since the redundant valves are powered from the same
vital power supply, discuss what measures (separation, grounded shield
leads, etc.) are used to satisfy item A(8) of II.B.1 of NUREG-0737.

35. Using detailed drawings, describe the ventilation systems used to
(7.3) support engineered safety features areas including areas containing systems required for safe shutdown. Discuss the design bases for these systems including redundancy, testability, etc.
36. Using detailed electrical schematics and piping diagrams, discuss
(7.3) the automatic and manual operation and control of the station service cooling water system and the component cooling water system. Discuss the interlocks, automatic switchover, testability, single failure, channel independence, indication of operability, and the isolation functions.
37. Identify any pneumatically operated valves in the ESF system. Using
(7.3) detailed schematics, describe their operation on loss of instrument air system.
38. Discuss the testing provision in the engineered safety feature
(7.3) P-4 interlocks.
39. On May 21, 1981, Westinghouse notified the Commission of a potentially
(7.3) adverse control and protection system interaction whereby a single random failure in the volume control tank (VCT) level control system could lead to a loss of redundancy in the safety injection system for certain Westinghouse plants. Discuss the VCT level control system in the Vogtle Unit 1 & 2 design.

40. Confirm that the BOP interface requirements specified in WCAP-8760, (7.3) "Failure Mode and Effects Analysis of the Engineered Safety Features Actuation System," have been met and include a statement in the FSAR to that effect.
41. On August 6, 1982, Westinghouse notified the staff of a potential (7.3) undetectable failure in online test circuitry for the master relays in the engineered safeguards systems. The undetectable failure involves the output (slave) relay continuity proving lamps and their associated shunts provided by test pushbuttons. If after testing, a shunt is not provided for any proving lamp because of a switch contact failure, any subsequent safeguards actuation could cause the lamp to burn open before its associated slave relay is energized. This would then prevent actuation of any associated safeguards devices on that slave relay. Until an acceptable circuit modification is designed, Westinghouse has provided test procedures that ensure that the slave relay circuits operate normally when testing of the master relays is completed. Discuss this issue as applied to Vogtle Units 1 and 2.
42. Use plant design drawings to discuss the main steam power operated (7.4) relief valve control scheme. Is this a safety grade system?

43. Describe the capability of achieving hot and cold shutdown from (7.4) outside the control room. As a minimum, provide the following information:

- a) Location of transfer switches and remote control stations (include layout drawings, etc.)
- b) Design criteria for the remote control station equipment including transfer switches.
- c) Description of distinct control features to both restrict and to assure access, when necessary, to the displays and controls located outside the control room.
- d) Discuss the testing to be performed during plant operation to verify the capability of maintaining the plant in a safe shutdown condition from outside the control room.
- e) Description of isolation, separation and transfer/override provisions. This should include the design basis for preventing electrical interaction between the control room and remote shutdown equipment.
- f) Description of any communication systems required to coordinate operator actions, including redundancy and separation.
- g) Description of control room annunciation of remote control or overridden status of devices under local control.

- h) Means for ensuring that cold shutdown can be accomplished.
- i) Discuss the separation arrangement between safety related and non-safety related instrumentation on the auxiliary shutdown panel.

44. Using detailed plant design drawings (schematics), discuss the (7.5) design pertaining to bypassed and inoperable status indication. As a minimum, provide the information to describe:

- 1) The design philosophy used in the selection of equipment/ systems to be monitored.
- 2) Justification for not providing bypass and inoperable status indication in accordance with position B2 of ICSB Branch Technical Position No. 21 for the fuel handling building ESF HVAC system as stated in Section 7.5.5.3 of the FSAR.

The design philosophy should describe as a minimum the criteria to be employed in the display of inter-relationships and dependencies on equipment/systems and should insure that bypassing or deliberately induced inoperability of any auxiliary or support system will automatically indicate all safety systems affected.

45. Use schematic and layout drawings to discuss the physical separation and wiring for redundant safety related instruments on the main control board.
- (7.5)
46. Provide a discussion (using detailed drawings) on the residual heat removal (RHR) system as it pertains to Branch Technical Positions ICSB 3 and RSB 5-1 requirements. Specifically, address the following as a minimum:
- (7.6)
- a) Testing of the RHR isolation valves as required by Branch Position E. of BTP RSB 5-1.
 - b) Capability of operating the RHR from the control room with either onsite or only offsite power available as required by Position A.3 of BTP RSB 5-1. This should include a discussion of how the RHR system can perform its function assuming a single failure.
 - c) Describe any operator action required outside the control room after a single failure has occurred and justify.
47. Identify points (other than RHR) of interface between the Reactor Coolant System (RCS) and other systems whose design pressure is less than that of the RCS. For each such interface, discuss the degree of conformance to the requirements of Branch Technical Position ICSB No. 3. Also discuss how the associated interlock circuitry conforms to the requirements of IEEE Standard 279. The discussion should include illustrations from applicable drawings.
- (7.6)

48. Using detailed system schematics, describe the power distribution (7.6) for the accumulator valves and associated interlocks and controls including position indication in the control room and bypass indicator light arrangement. Discuss conformance to the requirements of Branch Technical Position ICSB No. 4.

49. Discuss interlocks for RCS pressure control during low temperature (7.6) operation.

50. Describe the automatic and manual design features permitting switch- (7.6) over from the injection to the recirculation mode of emergency core cooling, including protection logic, component bypasses and overrides, parameter monitored and controlled, and test capabilities.

ATTACHMENT 2

ICSB QUESTIONS ON VOGTLE UNITS 1&2

420.2 Provide response to IE Bulletin 79-27 concerns.

(7.5) (An event requiring operator action concurrent with failure of important instrumentation upon which these operator actions should be based.)

420.3 Provide response to IE Bulletin 80-06 concerns.

(7.3) (Potential design deficiencies in bypass, override, and reset circuits of engineered safety features.)

420.4 Provide response to IE Information Notice 79-22 concerns.

(7.7) (Control system malfunction due to a high energy line break inside or outside of containment.)

420.5 Provide response to IE Bulletin 79-21 concerns.

(7.3) (Level measurement errors due to environmental temperatures effects on level instrument reference legs.)

420.6 Control System Failure concerns.

(7.7) The analyses reported in Chapter 15 of the FSAR are intended to demonstrate the adequacy of safety systems in mitigating anticipated operational occurrences and accidents.

Based on the conservative assumptions made in defining these design-basis events and the detailed review of the analyses by the staff, it is likely that they adequately bound the consequences of single control system failures.

To provide assurance that the design basis event analyses adequately bound other more fundamental credible failures, you are requested to provide the following information:

- (a) Identify those control systems whose failure or malfunction could seriously impact plant safety.
- (b) Indicate which, if any, of the control systems identified in (a) receive power from common power sources. The power sources considered should include all power sources whose failure or malfunction could lead to failure or malfunction of more than one control system and should extend to the effects of cascading power losses due to the failure of higher level distribution panels and load centers.
- (c) Indicate which, if any, of the control systems identified in (a) receive input signals from common sensors. The sensors considered should include, but should not necessarily be limited to, common hydraulic headers or impulse lines feeding pressure, temperature, level or other signals to two or more control systems.
- (d) Provide justification that any simultaneous malfunctions of the control systems identified in (b) and (c) resulting from failures or malfunctions of the applicable common power source or sensor are bounded by the analyses in Chapter 15 and would not require action or response beyond the capability of operators or safety systems.

**BOARD**

William M. Wilson, Chairman
William C. Moore, Jr., D.M.D., Vice-Chairman
I. DeQuincy Newman, Secretary
Leonard W. Douglas, M.D.
George G. Graham, D.D.S.
J. Lorin Mason, Jr., M.D.
C. Maurice Patterson

SOUTH CAROLINA DEPARTMENT OF HEALTH AND ENVIRONMENTAL CONTROL

Albert G. Randall, M.D., M.P.H.
Commissioner

Sims Aycock Building
2600 Bull Street, Columbia, SC 29201

October 25, 1978

Mr. Wayne Kerr, Assistant Director
State Agreements Program
Office of State Programs
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Kerr:

This letter is in reference to my comments made during a panel discussion on Radioactive Waste disposal at our Agreement State meeting on October 3, 1978, in Silver Springs, Maryland.

During the panel discussion, I mentioned the reactor operators are removing their standard spent fuel racks for densified racks. I assume the reason for this change is inadequate Away - From - Reactor (AFR) storage. My remarks were directed to this - As old standard racks are being shipped to low-level waste burial sites for disposal. How much attention is being given to this activity at the point of origin.

I'm not sure the total impact of the unavailability of AFR has been taken into consideration. In particular, the impact of transportation and disposal of old fuel racks. Could these fuel racks be decontaminated, stored for further use, or, if necessary, to bury, can the volume be further reduced? I feel this has probably been adequately reviewed prior to utilities expediting this type operation.

This is only one example of situations we have been confronted with in regulating a burial site. We do, on a routine basis, inspect what is being disposed of in the trenches at our Chem-Nuclear Site.

Everyone has stressed develop criteria and standards for waste burial grounds. I agree this is needed; however, the greatest need in my opinion is explicit Criteria and Standards be developed for the generators of radioactive waste. Waste generators generally view the burial site as a garbage dump that is allowed to accept any type of waste as long as it meets DOT shipping requirements. I believe our greatest problem in this respect is institutions that generate and dispose of waste.

8104200129

Mr. Wayne Kerr

-2-

October 25, 1978

Wayne, I appreciate you contacting me about this. I realize we had a full day and it just wasn't time enough to cover everything.

Should you have further questions about this, please contact me.

Very truly yours,



Heyward G. Shealy, Chief
Bureau of Radiological Health

HGS:bo

cc: Mr. Robert Ryan
Mr. Shelly Schwartz

SPENT FUEL STORAGE

In the United States most storage of spent fuel occurs in nuclear reactor basins. Excess fuel may be stored in independent spent fuel storage installations (ISFSI) collocated on the reactor site or at away-from-reactor storage installations.

Storage in Reactor Basins

Storage at spent fuel storage basins which are an integral part of a reactor facility is covered by the requirements of the Nuclear Regulatory Commission's (NRC) 10 Code of Federal Regulations (CFR) Part 50, "Licensing of Production and Utilization Facilities."

Obtaining an NRC construction permit--or a limited work authorization pending a decision on issuance of a construction permit--is the first objective of a utility or other company seeking to construct and operate a nuclear power reactor or other nuclear facility under NRC regulation 10 CFR Part 50. The process is set in motion with the filing and acceptance of the application, generally comprising material covering both safety and environmental factors, in accordance with NRC requirements and guidance. The second phase consists of safety, environmental, safeguards, and antitrust reviews undertaken by the NRC staff. Third, a safety review is conducted by the independent Advisory Committee on Reactor Safeguards (ACRS); this review is required by law. Fourth, a mandatory public hearing is conducted by a three-man Atomic Safety and Licensing Board (ASLB), which then makes an initial decision as to whether the permit should be granted. This decision is subject to appeal to an Atomic Safety and Licensing Appeal Board (ASLAB), and could ultimately go to the Commissioners for final NRC decision. The law provides for appeal beyond the Commission in the Federal courts.

In appropriate cases, NRC may grant a Limited Work Authorization to an applicant in advance of the final decision on the construction permit in order to allow certain work to begin at the site, saving as much as seven months' time. The authorization will not be given, however, until NRC staff have completed environmental impact and site suitability reviews and the appointed ASLB has conducted a public hearing on environmental impact and site suitability with a favorable finding. To enable the staff and licensing board to make these safety determinations, the applicant must submit the environmental portion of the application early.

When a plant is nearing completion, the applicant must go through virtually the same process to obtain an operating license as to obtain a construction permit. The application is filed, NRC staff and the ACRS review it, a Safety Evaluation Report and an updated Environmental Statement are issued. A public hearing is not mandatory at this stage, but one may be held if requested by affected members of the public or at the initiative of the Commission. Each license for operation of a nuclear reactor contains technical specifications which set forth the particular safety and environmental protection measures to be imposed upon the facility and the conditions that must be met for the facility to operate. Once licensed, a nuclear facility remains under NRC surveillance and undergoes periodic inspections throughout its operating life. In cases where the NRC finds that substantial, additional protection is necessary for the public health and safety or the common defense and security, the NRC may require "backfitting" of a licensed plant, that is, the addition, elimination or modification of structures, systems or components of the plant.

Storage at ISFSI

Storage at an ISFSI whether on a reactor site or a dedicated site in the US is presently licensed pursuant to 10 CFR Part 70, "Special Nuclear Material." Licensing guidance is provided by means of Regulatory Guides. Currently, three guides are in existence: 3.24.1, "Standard Format and Content of License Applications for the Storage of Spent Fuel in an Independent Spent Fuel Storage Installation (ISFSI) (Water Basin Type);" 3.24.2, "Guidance on the Siting of an Independent Spent Fuel Storage Installation (ISFSI) (Water Basin Type);" and 3.24.3, "Guidance on the Design of an Independent Spent Fuel Storage Installation (ISFSI) (Water Basin Type)." A new rule specifically addressing ISFSI has been issued for public comment by the NRC (10 CFR Part 72). This proposed rule, if adopted, is not expected to become effective before the latter part of 1979.

A Safety Analysis Report (SAR) and Environmental Report (ER) are submitted to NRC as part of the application for a Part 70 license to store spent fuel in an ISFSI.

The submitted SAR and ER are examined for completeness, docketed, and the license review is initiated. The staff reviews both technical reports and issues a Draft Environmental Statement (DES) and a Safety Evaluation Report (SER). Any outstanding items in these reviews must be resolved satisfactorily. When this is accomplished a Final Environmental Statement (FES) and a supplemental SER including staff evaluations are issued. If these evaluations are positive and if no contentions requiring public hearings are raised, the Director of the Office of Nuclear Material Safety and Safeguards decides, in accordance with § 70.23 "Requirements for the Approval of Application" pursuant to 10 CFR Part 51, "Licensing and Regulatory Policy and Procedures for Environmental Protection," whether or not a license should be issued for the construction of the installation and authorization for possession of the spent fuel.

Should contentions by intervenors require hearings, a board is convened and its decision is then forwarded to the Director for final resolution similar to the procedure noted above.

Such a license may include specific limitations to assure that construction and preoperational testing are completed in accordance with the design and procedures submitted to the NRC. Appropriate safety and environmental protection measures for both construction and operation may be included in the license. Once licensed, the ISFSI license will remain under NRC surveillance and will undergo periodic inspections throughout construction and operation. Satisfactory completion of construction and preoperational testing will be required to satisfy the specific license conditions and may result in removal of procedural restrictions barring storage of spent fuel until these conditions have been met and verified.

While the sequence delineated above is in accordance with the present regulation 10 CFR Part 70 applicable to ISFSI, it is expected that 10 CFR Part 72, will, when adopted, result in essentially the same process.