

October 24, 2008

D. J. Bannister

- 2 -

The NRC staff has reviewed the submitted information and has concluded that for the Fort Calhoun Station, Unit No. 1, your response is adequate. Based on this review, your response to GL 2007-01 is considered closed and no further action is requested of you at this time.

If you have any questions regarding this letter, please feel free to contact me at (301) 415-1445.

Sincerely,

/RA/

Alan B. Wang, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-285

cc: Distribution via Listserv

DISTRIBUTION:

- PUBLIC
- LPLIV R/F
- RidsAcrsAcnw\_MailCTR Resource
- RidsNrrDorIDpr Resource
- RidsNrrDorLpl4 Resource
- RidsNrrLAJBurkhardt Resource
- RidsNrrDeEeeb Resource
- RidsNrrPMAWang Resource
- RidsOgcRp Resource
- RidsRgn4MailCenter Resource

**ADAMS Accession No. ML082900193** (\*) See previous concurrence NRR-106

OFFICE	NRR/LPL4/PM	NRR/LPL4/PM	NRR/LPL4/LA	DE/EEEB/BC	NRR/LPL4/BC	NRR/LPL4/PM
NAME	AWang (*)	LWilkins (*)	JBurkhardt (*)	GWilson <i>GW</i>	MMarkley <i>MM</i>	AWang <i>AW</i>
DATE	10/17/08	10/20/08	10/17/08	<i>10/22/08</i>	<i>10-24-08</i>	<i>10/23/08</i>

**OFFICIAL RECORD COPY**



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

October 24, 2008

Mr. David J. Bannister  
Vice President and CNO  
Omaha Public Power District  
Fort Calhoun Station FC-2-4  
Post Office Box 550  
Fort Calhoun, NE 68023-0550

SUBJECT: FORT CALHOON STATION, UNIT NO. 1 – CLOSEOUT OF GENERIC LETTER 2007-01, "INACCESSIBLE OR UNDERGROUND POWER CABLE FAILURES THAT DISABLE ACCIDENT MITIGATION SYSTEMS OR CAUSE PLANT TRANSIENTS" (TAC NO. MD4330)

Dear Mr. Bannister:

On February 7, 2007, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2007-01, "Inaccessible or Underground Power Cable Failures That Disable Accident Mitigation Systems or Cause Plant Transients" (Agencywide Documents Access and Management System (ADAMS) Accession No. ML070360665). GL 2007-01 requested that licensees provide the following information within 90 days of the date of the GL:

- (1) A history of inaccessible or underground power cable failures for all cables that are within the scope of Section 50.65 of Title 10 of the *Code of Federal Regulations* (10 CFR 50.65, the Maintenance Rule) and for all voltage levels including the cable type, cable manufacturer, date of failure, type of service, voltage class, years of service, and the root causes for the failure; and
- (2) A description of all inspection, testing, and monitoring programs to detect the degradation of inaccessible or underground power cables that support emergency diesel generators (EDGs), offsite power, emergency service water (ESW), service water, component cooling water and other systems that are within the scope of 10 CFR 50.65 (the Maintenance Rule).

In your letter dated May 7, 2007 (ADAMS Accession No. ML071280117), you provided the information requested in GL 2007-01 including:

- (1) A history of inaccessible or underground power cable failures for all cables that are within the scope of 10 CFR 50.65 (the Maintenance Rule) and for all voltage levels including the cable type, cable manufacturer, date of failure, type of service, voltage class, years of service, and the root causes for the failure; and
- (2) A description of all inspection, testing, and monitoring programs to detect the degradation of inaccessible or underground power cables that support EDGs, offsite power, ESW, service water, component cooling water, and other systems that are within the scope of 10 CFR 50.65 (the Maintenance Rule).


D. J. Bannister

- 2 -

The NRC staff has reviewed the submitted information and has concluded that for the Fort Calhoun Station, Unit No. 1, your response is adequate. Based on this review, your response to GL 2007-01 is considered closed and no further action is requested of you at this time.

If you have any questions regarding this letter, please feel free to contact me at (301) 415-1445.

Sincerely,

A handwritten signature in black ink that reads "Alan Wang". The signature is written in a cursive style with a long, sweeping underline.

Alan B. Wang, Project Manager  
Plant Licensing Branch IV  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-285

cc: Distribution via Listserv