



DAVE BAXTER
Vice President
Oconee Nuclear Station

Duke Energy Corporation
ON01VP/7800 Rochester Highway
Seneca, SC 29672

864-885-4460
864-885-4208 fax
dabaxter@dukeenergy.com

September 25, 2008

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D. C. 20555-0001

Subject: Duke Energy Carolinas, LLC
Oconee Nuclear Site, Units 1, 2, and 3
Docket Numbers 50-269, 50-270, and 50-287
Request for Additional Information associated with the License Amendment
Request (LAR) for Approval to Mitigate Alloy 600 Concerns in the
Oconee Pressurizer
LAR No. 2008-08

In accordance with 10 CFR 50.90, Duke Energy Carolinas, LLC (Duke) proposes to amend the licensing basis for Renewed Facility Operating Licenses Nos. DPR-38, DPR-47, and DPR-55. A LAR was submitted on August 1, 2008 to the Nuclear Regulatory Commission (NRC) seeking review and approval of a design change that serves to mitigate Alloy 600 concerns in the Oconee Unit 2 Pressurizer. In concert with this change is a revision to Section 5.2.3.2 of the Updated Final Safety Analysis Report (UFSAR) to account for small areas of carbon steel and low alloy steel that are exposed to the reactor coolant system.

In an e-mail dated September 4, 2008, Duke received a request for additional information (RAI) associated with the repair and corrosion calculations. Enclosure 2 contains Duke's responses to those RAIs.

Approval of the proposed amendment is requested by October 25, 2008 to support the Unit 2 fall refueling outage. Duke will implement the amendment immediately upon receipt of NRC approval.


A110
NRR

Nuclear Regulatory Commission
RAI for License Amendment Request No. 2008-08
September 25, 2008

Page 2

Inquiries on this proposed amendment request should be directed to Sandra Severance of the Oconee Regulatory Compliance Group at (864) 885-3466.

Sincerely,



Dave Baxter, Vice President
Oconee Nuclear Site

Enclosures:

1. Notarized Affidavit
2. Requests For Additional Information

Attachments:

1. OM 201-3232.001, Rev 0 - ONS 1, 2 & 3 Pressurizer Vent Nozzle Modification
2. OM 2201-3212.001, Rev D01 - ONS3 1.5" Pressurizer Thermowell Repair Design
3. OM 1201-858.001, Rev D9 - Unit 2 Pressurizer General Arrangement
4. Corrosion Rate Calculation - AREVA Document ID 51-9001050-001 (Proprietary) - Summary Results
5. Corrosion Rate Calculation - SIA SIR-07-006, Rev 0, Appendix B (Proprietary) - Summary Results
6. Westinghouse WCAP-2855, "Yankee Vessel Cladding Penetrations." - Selected Excerpts

Nuclear Regulatory Commission
RAI for License Amendment Request No. 2008-08
September 25, 2008

Page 3

bc w/enclosures and attachments:

Mr. Luis Reyes, Regional Administrator
U. S. Nuclear Regulatory Commission - Region II
Atlanta Federal Center
61 Forsyth St., SW, Suite 23T85
Atlanta, Georgia 30303

Mr. Lenny Olshan, Project Manager
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Mail Stop O-8 G9A
Washington, D. C. 20555

Mr. Andy Hutto
Senior Resident Inspector
Oconee Nuclear Site


Mrs. Susan E. Jenkins, Manager
Infectious and Radioactive Waste Management Section
Department of Health & Environmental Control
2600 Bull Street
Columbia, SC 29201

ENCLOSURE 1

NOTARIZED AFFIDAVIT

AFFIDAVIT

Dave Baxter, being duly sworn, states that he is Vice President, Oconee Nuclear Site, Duke Energy Carolinas, LLC that he is authorized on the part of said Company to sign and file with the U. S. Nuclear Regulatory Commission this revision to the Renewed Facility Operating License Nos. DPR-38, DPR-47, and DPR-55; and that all statements and matters set forth herein are true and correct to the best of his knowledge.



Dave Baxter, Vice President
Oconee Nuclear Site

Subscribed and sworn to before me this 26th day of SEPTEMBER 2008

Bobby M. Damjanov
Notary Public

My Commission Expires:

OCTOBER 13, 2015
Date

SEAL



ENCLOSURE 2

REQUESTS FOR ADDITIONAL INFORMATION

Enclosure 2 – Evaluation of Proposed Change
RAI for License Amendment Request No. 2008-08
September 25, 2008

1.0 REQUESTS FOR ADDITIONAL INFORMATION (RAI)

RAI #1

Please provide marked-up drawings of the Pressurizers showing the exposed areas of the material that is subject to corrosion.

ANSWER:

As noted in the original LAR package, these repairs have already been completed on two units and are scheduled for implementation on Unit 2 in the fall of 2008. The drawings provided in Attachments 1, 2, and 3 are representative of the repairs on all three units. Attachments 1, 2, and 3 contain the mark-ups requested. Attachments 1 and 2, included in the original LAR, are provided in a larger format. Attachment 3 shows the physical location of the repairs in the Unit 2 pressurizer. These locations are representative for all three units.

RAI #2

Clarify whether you have considered any means of preventing corrosion on the affected carbon steel areas.

ANSWER:

The corrosion calculations developed by the vendors in support of the vent nozzle and thermowell repairs result in conservative, acceptable corrosion rates. The tight gaps and the inaccessibility of the exposed carbon or low alloy steel surfaces did not support options for further lowering of these acceptable corrosion rates with coating or other surface conditioning methods. In addition, continued Oconee Reactor Coolant System (RCS) chemistry control will ensure that the existing calculated corrosion rates remain conservative. Finally, any extension to the existing 18 month fuel cycles will improve (i.e. lower the calculated overall corrosion rate) since the ONS plants will operate in a lower corrosion rate environment for a longer period of time than that used in the current, conservative corrosion evaluations.

RAI #3:

Please provide a copy of the corrosion rate calculations stated in your letter dated August 1, 2008, for the affected areas.

Enclosure 2 – Evaluation of Proposed Change
RAI for License Amendment Request No. 2008-08
September 25, 2008

ANSWER:

AREVA was contracted for the Pressurizer vent nozzle component replacement. The corrosion evaluation for the Pressurizer vent nozzle is documented in Oconee calculation OSC-8745, Revision D5, Attachment 2C (Proprietary AREVA Document 51-9001050-001, "Oconee 1, 2 & 3 Pressurizer Vent Nozzle MOD Corrosion Evaluation").

Structural Integrity Associates (SIA) was contracted for the Pressurizer thermowell component replacement. The corrosion evaluation for the Pressurizer thermowell is documented in OSC-8745, Revision D5, Attachment 7G, Appendix B, (SIA Proprietary Appendix titled "Corrosion of Carbon Steel and Low Alloy Steel in PWR Primary Water").

As noted, both of these vendor calculations are proprietary in nature, so only the details of the calculations were outlined in the LAR. Permission was received from both vendors to include the information as stated in the LAR. During a September 8, 2008 phone conversation with the PM and the technical reviewer, the request was clarified as requesting the summary of the results from these calculations. The cover sheet and the non-proprietary summary for each are included in Attachments 4 and 5. These calculations are being submitted to aid in the staff's review and approval of this LAR. However, these calculations and the governing Oconee calculation may be subject to change and will be evaluated and controlled through normal station processes.

RAI #4:

Please provide a copy of the Westinghouse WCAP-2855, "Yankee Vessel Cladding Penetrations.

ANSWER:

Attachment 6 contains the Cover Page and Table of Contents for WCAP-2855, "Evaluation of Yankee Vessel Cladding Penetrations", dated October 15, 1965. The document is over 60 pages in length and contains an evaluation of possible failure mechanisms resulting from damage caused to the Yankee Reactor Vessel when one material irradiation capsule broke up.





Duke has reservations about sending additional portions of this document due to the stamp stating "Not approved for Public Release. Available to the AEC and its Contractors Only." The significance of the stamp is indeterminate due to the age of the document. Additionally, the rules for use established at the time of its origination are unclear. Based on the stamp, it is believed that this document is available in the NRC/AEC archives.

ATTACHMENT 1

OM 201-3232.001, Rev 0 - ONS 1, 2 & 3 Pressurizer Vent Nozzle Modification

ATTACHMENT 2

OM 2201-3212.001, Rev D01 - ONS3 1.5" Pressurizer Thermowell Repair Design



Surface Exposed to Corrosion

- Notes:
1. Break all sharp corners to leave a smooth transition.
 2. Replacement thermowell is Alloy 690 material.
 3. Replacement weld metal is Alloy S2M/152M.
 4. Replacement thermowell dimensions per WSI Drawing No. 401795, Revision 2.
 5. There is no requirement as to the radius of the replacement weld connecting the pad to the replacement thermowell.
 6. The slope of the replacement weld shown is a maximum slope. Other slopes, such as 1:3, where the first dimension is the pad thickness, are acceptable.
 7. Maximum diametrical gap is 0.020".
 8. Duke Purchase Order No. DS 2058.

Rev. 1	Date 09/06/06	Drawn By A.V. A. Vanichsarn	Checked By R. Mattson	Engineer G. Mukhim	Approved By M. Taylor
		TITLE Pressurizer 1.5" Thermowell Repair Design Oconee Nuclear Station, Unit 3			
Drawn by: A. Vanichsarn Date: 08/08/06		Checked by: R. Mattson Date: 08/08/06		DRAWING NO. ONS-15Q-05 PROJECT NO. ONS-15Q	
Engineer: G. Mukhim Date: 08/08/06		APPROVED BY: <input checked="" type="checkbox"/> YES <input type="checkbox"/> NO		FILE NO. ONS-15Q-550	
Approved by: M. Taylor Date: 08/08/06		CODE: ASME, III, NB		SCALE: None SHEET: 1 of 1 REV: 1	

OM 2201.-3212.001

QA CONDITION-1

Attachment 2 to LAR 2008-08 RAI

A	001	REVISED PER 00301377	FWP	1/3/08	LSW	1/3/08	DAK	1/15/08	-W-	-W-	-W-	---
STATUS	NO.	REVISIONS	DRN	DATE	CHKD	DATE	APPR	DATE	CIVIL	ELEC	MECH	OTHER
INSPECTED												

ATTACHMENT 3

OM 1201-858.001, Rev D9 - Unit 2 Pressurizer General Arrangement

ATTACHMENT 6

Westinghouse WCAP-2855, "Yankee Vessel Cladding Penetrations" - Selected Excerpts

(C*)

EVALUATION OF YANKEE VESSEL CLADDING
PENETRATIONS

October 15, 1965

NOT APPROVED FOR PUBLIC RELEASE. AVAILABLE
TO THE AEC AND ITS CONTRACTORS ONLY.

WESTINGHOUSE ELECTRIC CORPORATION
Atomic Power Division
P. O. Box 355
Pittsburgh 30, Pennsylvania

Table of Contents

<u>Section</u>	<u>Title</u>
I	Summary of Analysis and Conclusions
II	Mechanical Considerations
III	Corrosion of Vessel Base Metal
IV	Hydrogen Distribution and Concentration
V	Hydrogen Embrittlement
Appendix A	Vessel Material and Process Information