

CCNPP3COLA PEmails

From: John Rycyna
Sent: Wednesday, September 17, 2008 3:57 PM
To: Wrobel, George
Cc: CCNPP3COL Resource; Joseph Colaccino; Tarun Roy; David Terao; Thomas Scarbrough
Subject: Draft RAI No 13 CIB1 1221.doc
Attachments: Draft RAI No 13 CIB1 1221.doc

George,

Attached is DRAFT RAI No. 13. You have ten working days to review it and to decide whether you need a conference call to discuss it. After the call or after ten days the RAI will be finalized and sent to you. You then have 30 days to respond.

John Rycyna, PE
Project Manager
Division of New Reactor Licensing
Office of New Reactors
U.S. Nuclear Regulatory Commission
301-415-4122

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 264

Mail Envelope Properties (499C2FC6BB962446994CA8682D8ADF330DDC41E295)

Subject: Draft RAI No 13 CIB1 1221.doc
Sent Date: 9/17/2008 3:56:35 PM
Received Date: 9/17/2008 3:56:38 PM
From: John Rycyna

Created By: John.Rycyna@nrc.gov

Recipients:

"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Tarun Roy" <Tarun.Roy@nrc.gov>
Tracking Status: None
"David Terao" <David.Terao@nrc.gov>
Tracking Status: None
"Thomas Scarbrough" <Thomas.Scarbrough@nrc.gov>
Tracking Status: None
"Wrobel, George" <George.Wrobel@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	429	9/17/2008 3:56:38 PM
Draft RAI No 13 CIB1 1221.doc	24174	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 1221 Revision 0
DRAFT
9/17/2008

Calvert Cliffs Unit 3
UniStar
Docket No. 52-016
SRP Section: 05.02.01.02 - Applicable Code Cases
Application Section: 5.2.1.2

QUESTION

05.02.01.02-1

U.S. EPR FSAR Section 5.2.1.2, "Compliance with Applicable Code Cases," references U.S. EPR FSAR Table 5.2-1 for a list of American Society of Mechanical Engineers (ASME) Boiler & Pressure Vessel (BPV) Code, Section III, Code Cases used in the U.S. EPR design, and then states that the COL applicant will identify additional Code Cases to be used. Calvert Cliffs Unit 3 FSAR Section 5.2.1.2, "Compliance with Applicable Code Cases," incorporates by reference U.S. EPR FSAR Section 5.2.1.2, and includes the supplemental information that "[n]o additional ASME code cases will be utilized." The Calvert Cliffs COL Applicant is requested to clarify whether any ASME BPV Code Section XI Code Cases, or ASME Operation and Maintenance (OM) Code Cases will be applied, and to discuss their use consistent with Regulatory Guide (RG) 1.147, "Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1," and RG 1.192, "Operation and Maintenance Code Case Acceptability, ASME OM Code."