

CCNPP3COLA PEmails

From: John Rycyna
Sent: Friday, September 05, 2008 10:31 AM
To: Wrobel, George
Cc: CCNPP3COL Resource; Joseph Colaccino; Michelle Hart; Charles Cox
Subject: RAI No 11 RSAC 1015.doc
Attachments: RAI No 11 RSAC 1015.doc

Attached please find the subject request for additional information (RAI). A draft of the RAI was provided to you on August 20, 2008. You indicated no conference call was needed to discuss this RAI. The schedule we have established for review of your application assumes technically correct and complete responses within 30 days of receipt of RAIs. For any RAIs that cannot be answered within 30 days, it is expected that a date for receipt of this information will be provided to the staff within the 30 day period so that the staff can assess how this information will impact the published schedule.

John Rycyna, PE
Project Manager
Division of New Reactor Licensing
Office of New Reactors
U.S. Nuclear Regulatory Commission
301-415-4122

Hearing Identifier: CalvertCliffs_Unit3Cola_Public_EX
Email Number: 265

Mail Envelope Properties (499C2FC6BB962446994CA8682D8ADF330DDC2055FE)

Subject: RAI No 11 RSAC 1015.doc
Sent Date: 9/5/2008 10:31:19 AM
Received Date: 9/5/2008 10:31:20 AM
From: John Rycyna

Created By: John.Rycyna@nrc.gov

Recipients:

"CCNPP3COL Resource" <CCNPP3COL.Resource@nrc.gov>
Tracking Status: None
"Joseph Colaccino" <Joseph.Colaccino@nrc.gov>
Tracking Status: None
"Michelle Hart" <Michelle.Hart@nrc.gov>
Tracking Status: None
"Charles Cox" <Charles.Cox@nrc.gov>
Tracking Status: None
"Wrobel, George" <George.Wrobel@unistarnuclear.com>
Tracking Status: None

Post Office: HQCLSTR02.nrc.gov

Files	Size	Date & Time
MESSAGE	767	9/5/2008 10:31:20 AM
RAI No 11 RSAC 1015.doc	23150	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 11 Revision 0
9/5/08

Calvert Cliffs Unit 3

UniStar

Docket No. 52-016

SRP Section: 15.00.03 - Design Basis Accidents Radiological Consequence Analyses for Advanced
Light Water Reactors
Application Section: FSAR 15.0.3

QUESTIONS

15.00.03-1

FSAR Table 15.0-2 gives site-specific offsite design basis accident (DBA) doses calculated at the Low Population Zone (LPZ) boundary for CCNPP Unit 3, based on the site-specific LPZ atmospheric dispersion factors given in FSAR Table 15.0-1. Discuss the method used to calculate the site specific doses, and provide calculation inputs not included in either the EPR design FSAR or the CCNPP Unit 3 FSAR, such as time dependent isotopic activity releases for each DBA, if used in the calculation.