

PMHarrisCOL PEmails

From: Manny Comar
Sent: Tuesday, October 21, 2008 11:35 AM
To: robert.kitchen@pgnmail.com; david.waters@pgnmail.com; Wilkins, Tillie
Cc: Brian Hughes; Manny Comar; HarrisCOL Resource
Subject: Draft RAI 1358 related to SRP Section 03.02.01- Seismic Classification for Shearon Harris Units 2 and 3.
Attachments: RAI 1358.doc

To All,

Attached is a draft RAI 1358 related to SRP Section 03.02.01- Seismic Classification for Shearon Harris Units 2 and 3.

Please let me know as soon as possible if you would like to schedule a conference call to discuss this RAI,

If no request for a conference call is received, this RAI will be issued as Final.

Thanks,

Manny Comar
Senior Project Manager
NRO/DNRL/NWE1
Nuclear Regulatory Commission
301-415-3863
<mailto:manny.comar@nrc.gov>

Hearing Identifier: ShearonHarris_COL_Public
Email Number: 199

Mail Envelope Properties (3AF7DEF82ADA8944AD8247B7ED7FD6517BFBFA11C4)

Subject: Draft RAI 1358 related to SRP Section 03.02.01- Seismic Classification for Shearon Harris Units 2 and 3.
Sent Date: 10/21/2008 11:34:45 AM
Received Date: 10/21/2008 11:34:48 AM
From: Manny Comar

Created By: Manny.Comar@nrc.gov

Recipients:

"Brian Hughes" <Brian.Hughes@nrc.gov>
Tracking Status: None
"Manny Comar" <Manny.Comar@nrc.gov>
Tracking Status: None
"HarrisCOL Resource" <HarrisCOL.Resource@nrc.gov>
Tracking Status: None
"robert.kitchen@pgnmail.com" <robert.kitchen@pgnmail.com>
Tracking Status: None
"david.waters@pgnmail.com" <david.waters@pgnmail.com>
Tracking Status: None
"Wilkins, Tillie" <tillie.wilkins@pgnmail.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	523	10/21/2008 11:34:48 AM
RAI 1358.doc	31226	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information No. 1358

Shearon Harris
Progress Energy Carolinas, Inc.
Docket No. 52-022 and 52-023
SRP Section: 03.02.01 - Seismic Classification
Application Section: 3.2.1

QUESTIONS for Engineering Mechanics Branch 2 (ESBWR/ABWR Projects) (EMB2)

03.02.01-***

Although the COLA includes certain site-specific SSCs as a supplement to the referenced DCD, the application does not appear to identify and seismically classify a complete list of SSCs that were not seismically classified within scope of the DCD, such as the circulating water system, and reactor vessel insulation that may or may not be considered site-specific. Also, for SSCs identified as site-specific in the COLA, such as the raw water system, it is not clear why these SSCs are not seismically classified in the COLA as a supplement. Clarify where and when these SSCs are to be seismically classified.