



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 19, 2008

Mr. Dale E. Young, Vice President
Crystal River Nuclear Plant (NA1B)
ATTN: Supervisor, Licensing & Regulatory Programs
15760 W. Power Line Street
Crystal River, Florida 34428-6708

SUBJECT: CRYSTAL RIVER UNIT 3 NUCLEAR GENERATING PLANT - CLOSEOUT OF
GENERIC LETTER 2007-01, "INACCESSIBLE OR UNDERGROUND POWER
CABLE FAILURES THAT DISABLE ACCIDENT MITIGATION SYSTEMS OR
CAUSE PLANT TRANSIENTS" (TAC NO. MD4317)

Dear Mr. Young:

On February 07, 2007, the U.S. Nuclear Regulatory Commission (NRC) issued Generic Letter (GL) 2007-01, "Inaccessible or Underground Power Cable Failures That Disable Accident Mitigation Systems or Cause Plant Transients," (Agencywide Documents Access and Management System (ADAMS) Accession No. ML070360665). GL 2007-01 requested that licensees provide the following information within 90 days of the date of the GL:

- (1) A history of inaccessible or underground power cable failures for all cables that are within the scope of Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.65 (the Maintenance Rule) and for all voltage levels, including the cable type, cable manufacturer, date of failure, type of service, voltage class, years of service, and the root causes for the failure; and,
- (2) A description of all inspection, testing, and monitoring programs to detect the degradation of inaccessible or underground power cables that support emergency diesel generators (EDGs), offsite power, emergency service water (ESW), service water, component cooling water and other systems that are within the scope of the Maintenance Rule.

In your letter dated May 3, 2007 (ADAMS Accession No. ML071280221), you provided the information requested in GL 2007-01 including: (1) A history of inaccessible or underground power cable failures for all cables that are within the scope of 10 CFR 50.65 and for all voltage levels, including the cable type, cable manufacturer, date of failure, type of service, voltage class, years of service, and the root causes for the failure; and, (2) A description of all inspection, testing, and monitoring programs to detect the degradation of inaccessible or underground power cables that support EDGs, offsite power, ESW, service water, component cooling water and other systems that are within the scope of the Maintenance Rule.

D. Young

- 2 -

The NRC staff has reviewed the submitted information and has concluded that for Crystal River Unit 3, your response to GL 2007-01 is adequate. Based on this review, your response to GL 2007-01 is considered closed and no further action is requested of you at this time.

If you have any questions regarding this letter, please feel free to contact me at (301) 415-1447.

Sincerely,



Farideh E. Saba, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-302

cc: Distribution via ListServ

D. Young

- 2 -

The NRC staff has reviewed the submitted information and has concluded that for Crystal River Unit 3, your response to GL 2007-01 is adequate. Based on this review, your response to GL 2007-01 is considered closed and no further action is requested of you at this time.

If you have any questions regarding this letter, please feel free to contact me at (301) 415-1447.

Sincerely,

/RA/

Farideh E. Saba, Senior Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-302

cc: Distribution via ListServ

DISTRIBUTION:

PUBLIC	RidsOgcRp
LPL2-2 R/F	RidsAcrcAcnw_MailCTR
RidsNrrDorLpl2-2	RidsRgn2MailCenter
RidsNrrLACSola	RidsNrrDeEeeb
RidsNrrPMFSaba	
RidsNrrDorIDpr	

ADAMS Accession Number: ML082960724

NRR-106

OFFICE	LPL2-2\PM	LPL2-2\LA	EEEE:BC	LPL2-2\BC
NAME	FSaba	CSola	GWilson	TBoyce
DATE	11/17/08	11/17/08	11/18/08	11/19/08

OFFICIAL RECORD COPY