

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D.C. 20555-0001

November 10, 2008

Mr. M. R. Blevins Executive Vice President & Chief Nuclear Officer Luminant Generation Company LLC ATTN: Regulatory Affairs P. O. Box 1002 Glen Rose, TX 76043

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION REGARDING THE RELIEF REQUEST NO. P-2 ASSOCIATED WITH INSERVICE TESTING PLAN FOR PUMPS AND VALVES (TAC NOS. MD9722 AND MD9723)

Dear Mr. Blevins:

By letter dated September 24, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082770065), Luminant Generation Company LLC (the licensee) submitted relief request P-2 for the second 10-year pump and valve inservice testing plan for Comanche Peak Steam Electric Station, Units 1 and 2. The licensee requested relief from American Society of Mechanical Engineers Operation and Maintenance Code, 1998 Edition through 2000 Addenda, for the testing of the Safeguards Building Sump Pumps.

The U.S. Nuclear Regulatory Commission staff has reviewed the information provided in the application and determined that additional information is needed in order to complete the evaluation. The request for additional information (RAI) was discussed with Mr. Jack Hicks of Luminant Generation Company LLC on November 10, 2008 and it was agreed that RAI response will be provided within 30 days from the date of this letter.

If you have any questions, please contact me at 301-415-3016.

Sincerely,

Balwant KSingel

Balwant K. Singal, Senior Project Manager Plant Licensing Branch IV Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

Docket Nos. 50-445 and 50-446

Enclosure: As stated

cc w/encl: Distribution via Listserv

REQUEST FOR ADDITIONAL INFORMATION

RELIEF REQUEST P-2

INSERVICE TESTING PLAN FOR PUMPS AND VALVES

COMPANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2

DOCKET NOS. 50-445 AND 50-446

By letter dated September 24, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082770065), Luminant Generation Company LLC (the licensee) submitted relief request (RR) P-2 for the second 10-year pump and valve inservice testing plan for Comanche Peak Steam Electric Station, Units 1 and 2. The licensee requested relief from American Society of Mechanical Engineers Operation and Maintenance Code, 1998 Edition through 2000 Addenda, for the testing of the Safeguards Building Sump Pumps (SBSP).

The U.S. Nuclear Regulatory Commission staff has reviewed the information provided in the application and determined that the following additional information is needed in order to complete the evaluation:

- 1. The RR states a test can be performed that demonstrates the SBSP can meet its intended safety functions. Please provide a copy of the test procedure that will be used, including acceptance criteria to be utilized, to determine acceptable pump performance.
- 2. The RR states the SBSP test will require pumping the same quantity of fluid along a repeatable system path, while measuring flow and vibration. Please describe how the flow rate is measured or determined. Also, discuss any system parameters associated with the flow path that will affect the results of the test and how those parameters will be controlled such that repeatability is achieved.
- 3. The RR states the required SBSP head to pump to the Waste Holdup Tank is greater than the required head to discharge to the Floor Drain Tank, which is the normal lineup. Please discuss the safety-related lineup of the sump pumps and how the discharge head required during testing and normal operation differs from the discharge head required during emergency conditions.

Mr. M. R. Blevins Executive Vice President & Chief Nuclear Officer Luminant Generation Company LLC ATTN: Regulatory Affairs P. O. Box 1002 Glen Rose, TX 76043

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION REGARDING THE RELIEF REQUEST NO. P-2 ASSOCIATED WITH INSERVICE TESTING PLAN FOR PUMPS AND VALVES (TAC NOS. MD9722 AND MD9723)

Dear Mr. Blevins:

By letter dated September 24, 2008 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML082770065), Luminant Generation Company LLC (the licensee) submitted relief request P-2 for the second 10-year pump and valve inservice testing plan for Comanche Peak Steam Electric Station, Units 1 and 2. The licensee requested relief from American Society of Mechanical Engineers Operation and Maintenance Code, 1998 Edition through 2000 Addenda, for the testing of the Safeguards Building Sump Pumps.

The U.S. Nuclear Regulatory Commission staff has reviewed the information provided in the application and determined that additional information is needed in order to complete the evaluation. The request for additional information (RAI) was discussed with Mr. Jack Hicks of Luminant Generation Company LLC on November 10, 2008 and it was agreed that RAI response will be provided within 30 days from the date of this letter.

Sincerely,

/RA/

Balwant K. Singal, Senior Project Manager Plant Licensing Branch IV Division of Operating Reactor Licensing Office of Nuclear Reactor Regulation

*Memo dated 10/27/08

Docket Nos. 50-445 and 50-446

Enclosure: As stated

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC LPLIV Reading RidsAcrsAcnw_MailCTR Resource RidsNrrDciCptb Resource RidsNrrDorlLpl4 Resource RidsNrrPMBSingal Resource RidsNrrLAJBurkhardt Resource RidsOgcRp Resource RidsRgn4MailCenter Resource YHuang, NRR/DCI

ADAMS Accession No: ML083050636

OFFICE	NRR/LPL4/PM	NRR/LPL4/LA	NRR/DCI/CPTB/BC	NRR/LPL4/BC	NRR/LPL4/PM
NAME	BSingal DVS	JBurkhardt	JMcHale*	MMarkley www	BSingal
DATE	11-10-08	11/4/08	10/27/08	11 100 108	11-10-08

OFFICIAL AGENCY RECORD