

SECTION I
INSPECTION OBJECTIVES

1. Ensure that the test procedure is technically adequate.
2. Ensure that the described test is consistent with regulatory requirements, guidance and licensee commitments.

SECTION II
INSPECTION REQUIREMENTS

The inspector shall:

1. Obtain and review an approved copy of the test procedure(s) for technical adequacy prior to the date scheduled for the test.
2. Review the FSAR, docketed correspondence, SER, Technical Specifications, and Regulatory Guide 1.68. Verify that the test procedure adequately addresses NRC requirements and licensee commitments relating to Safety and Relief Values.
3. Review the test procedure(s) in accordance with inspection procedure MC 70300B.

SECTION III
INSPECTION GUIDANCE

1. This review should insure that important system performance functions are adequately reflected in this test procedure. Items which should be adequately tested as part of the test procedure include (but are not limited to):
 - a. inplace testing of manual and automatic actuations of the safety/relief valves, including position indication,
 - b. proper operation (remote/local and setpoints) of steam generator, pressurizer, vacuum breaker, etc., valves,
 - c. full stroke time of power operated valves,
 - d. electrical independence and redundancy, and
 - e. leakage rate at normal system parameters.

NOTE: Items may be part of other systems tests.