## Constellation Energy Group NINE MILE POINT UNIT 2 OPERATOR JOB PERFORMANCE MEASURE

Title: Determine Personnel O	vertime Availab	ility IAW GAP-FFD-02 Revision: <u>NRC 2008</u>
Approvals:		
	/	N/A – Exam Security /
General Supervisor Operations Training (Designee)	Date	General Supervisor Date Operations (Designee)
<u>N/A – Exam Security</u> Configuration Control	/ Date	
Performer:		(RO/SRO)
Trainer/Evaluator:		
Evaluation Method: Perform		
Evaluation Location: Classroom	n	
Expected Completion Time:	20/30 minutes (RO/SRO)	Time Critical Task: No Alternate Path Task: No
Start Time:	Stop Time:	Completion Time:
JPM Overall Rating:	Pass	Fail
<b><u>NOTE</u>:</b> A JPM overall rating individual competence	of fail shall be g	given if <u>any</u> critical step is graded as fail. Any grade of unsat or uires a comment.

Comments:

Evaluators Signature:\_\_\_\_\_

Date:

Recommended Start Location: Classroom

Simulator Set-up: None

Directions to the Instructor/Evaluator:

None

Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SM, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the additional / concurrent verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified in grading areas as Pass/Fail.
- 2. During Evaluated JPM:
  - Self verification shall be demonstrated.
- 3. During Training JPM:
  - Self verification shall be demonstrated.
  - <u>No other</u> verification shall be demonstrated.

References:

1. GAP-FFD-02

Tools and Equipment:

1. Calculator

Task Standard: Determine Personnel Availability for Overtime IAW GAP-FFD-02.

#### Initial Conditions:

- 1. The plant is shutdown.
- 2. In order to support critical path work required for startup, personnel overtime will be required for the night shift on October 26 from 1830-0630.
- 3. All the overtime hours will be spent performing (ROs) or supervising (SROs) field activities.

#### Initiating Cues:

- 1. From the provided list of personnel working hours, determine who is eligible to work a complete 12 hours of overtime beginning at 1830 on October 26 without requiring an Overtime Deviation Request IAW GAP-FFD-02.
- 2. If an Overtime Deviation Request would be required for individual(s), state the work hour limit(s) which would be exceeded IAW GAP-FFD-02.
- 3. Complete the appropriate sections of an Overtime Deviation Request Form for all individuals who would need a deviation approved to cover the shift.

## EXAMINER NOTE: - Provide Attachments A, B & C, and Blank Overtime Deviation Request Form.

Perf	ormance Steps	Standard	Grade
1.	Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary.	Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat
RE	CORD START TIME		
2.	Obtain a copy of the reference procedure and review/utilize the correct section of the procedure.	GAP-FFD-02 obtained	Sat/Unsat

1	RO #1 – Eligible	
	RO #2 – Not Eligible – would exceed 72 hours in 7 day period	
	RO #3 – Not Eligible – would exceed 24 hours in a 48 hour period	
FOR SROs - Reviews work hours for Reactor Operators 1 thru 3 and Senior Reactor	<u>SROs – Determines the above limitations plus</u> the following:	
Operators 1 and 2	SRO #1 – Eligible	
	SRO #2 – Not Eligible – would exceed 16 hours in a 24 hour period	
<b>FOR SROs</b> – Completes Overtime Deviation Request Form	Completes Columns 1 and 2 of Part 1 of GAP-FFD-02 Attachment 1, per attached key	Pass/Fail
	Completes Columns 3 and 4 of Part 1 of GAP-FFD-02 Attachment 1, per attached key	Sat/Unsat
	Completes Part 2 of GAP-FFD-02 Attachment 1, per attached key	Sat/Unsat

**TERMINATING CUE: FOR ROs**, JPM Attachment C completed. **FOR SROs**, JPM Attachment D and GAP-FFD-02 Attachment 1 completed

# RECORD STOP TIME \_\_\_\_\_

4.

# **ATTACHMENT A - ROs**

RO #1							
10/19	10/20	10/21	10/22	10/23	10/24	10/25	10/26
1830-0642 (includes 12 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	OFF	1830-0730 (includes 60 minutes of turnover time)	1830-0542 (includes 12 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	1830-0706 (includes 36 minutes of turnover time)	OFF

RO #2							
10/19	10/20	10/21	10/22	10/23	10/24	10/25	10/26
OFF	1830-0642 (includes 12 minutes of turnover time)	1830-0630 (includes 0 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	1830-0654 (includes 24 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	OFF

	RO #3							
10/19	10/20	10/21	10/22	10/23	10/24	10/25	10/26	
1830-0642 (includes 12 minutes of turnover time)	1830-0630 (includes 0 minutes of turnover time)	1830-0648 (includes 18 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	OFF	1830-0742 (includes 12 minutes of turnover time)	OFF	

# **ATTACHMENT B - SROs**

	SRO #1							
10/19	10/20	10/21	10/22	10/23	10/24	10/25	10/26	
1830-0642 (includes 12 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	OFF	1830-0735 (includes 65 minutes of turnover time)	OFF	1830-0642 (includes 12 minutes of turnover time)	1830-0720 (includes 50 minutes of turnover time)	OFF	

	SRO #2						
10/19	10/20	10/21	10/22	10/23	10/24	10/25	10/26
1830-0642 (includes 12 minutes of turnover time)	1830-0630 (includes 0 minutes of turnover time)	1830-0648 (includes 18 minutes of turnover time)	1830-0642 (includes 12 minutes of turnover time)	OFF	0630-1830 (includes 0 minutes of turnover time)	OFF	0500-1200 (includes 0 minutes of turnover time)

# ATTACHMENT C – SRO Answer Sheet

	Eligible to work without an Overtime Deviation Request? (Yes/No)	If No, what work hour limit(s) would be exceeded IAW GAP- FFD-02?
RO #1		
RO #2		
RO #3		
SRO #1		
SRO #2		

Initial Conditions:

- 1. The plant is shutdown.
- 2. In order to support critical path work required for startup, personnel overtime will be required for the night shift on October 26 from 1830-0630.
- 3. All the overtime hours will be spent performing (ROs) or supervising (SROs) field activities.

# Initiating Cues:

- 1. From the provided list of personnel working hours, determine who is eligible to work a complete 12 hours of overtime beginning at 1830 on October 26 without requiring an Overtime Deviation Request IAW GAP-FFD-02.
- 2. If an Overtime Deviation Request would be required for individual(s), state the work hour limit(s) which would be exceeded IAW GAP-FFD-02.
- 3. Complete the appropriate sections of an Overtime Deviation Request Form for all individuals who would need a deviation approved to cover the shift.

#### Constellation Energy Group OPERATOR JOB PERFORMANCE MEASURE

Title: Assess Reportability Re	quirements				Revision: NRC	2008
Task Number: NA						
Approvals:						
		. <u>-</u>	NA EX	(AMINA	TION SECURITY	
General Supervisor Operations Training (Designee)	Date	(	General Operation	l Superv ons (Des	isor signee)	Date
NA EXAMINATION SECURITY	/ Date					
Performer:		(	(SRO)			
Trainer/Evaluator:						
Evaluation Method: X	Perform			Simula	ate	
Evaluation Location:	Plant	>	x	Simula	ator or other location	
Expected Completion Time:	25 min Time C	ritical Ta	ask:	NO	Alternate Path Task:	NO
Start Time:	Stop Time:			Comple	etion Time:	_
JPM Overall Rating:	Pass	Fail				

**NOTE:** A JPM overall rating of fail shall be given if <u>any</u> critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluator Signature:\_\_\_\_\_

|--|

Recommended Start Location: (Completion time based on the start location)

Simulator or other designated area.

Simulator Set-up:

N/A

Directions to the Instructor/Evaluator: None

Directions to Operators: Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SM, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, the use of applicable methods of verification and checking are expected. Therefore, either another individual or I will act as the independent verifier or peer checker.

Notes to Instructor / Evaluator:

- Critical steps are identified in grading areas Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 5. During Evaluated JPM:
  - Self checking shall be demonstrated.
- 6. During Training JPM:
  - Self checking shall be demonstrated.
  - Peer checking shall be demonstrated.

References:

- 1. NIP-IRG-01
- 2. 10CFR50.72
- 3. NUREG 1022 Rev 2, Section 3.2.6
- 4. EAL Matrix

Tools and Equipment:

1. None

Task Standard:

Determine notification requirements.

Initial Conditions:

- The plant is operating at 100% power.
- Containment purge is in progress
- Maintenance is using an approved work order to perform a maintenance activity on containment purge isolation logic
- Work order identifies that the activity has the potential to cause containment purge isolation, due to the possibility of causing an electrical short.
- While the work order is being performed, the worker does create an electrical short and an automatic isolation of the containment purge system occurs. No other systems are affected.
- After conditions are stabilized, Drywell Floor Drain leakage rate rises to 10 gpm.
- Drywell pressure stabilizes below the scram setpoint but the leakage has remained at 10 gpm for the past 4 hours despite leakage reduction attempts.
- Actions to comply with Tech Specs as a result of the leakage are initiated and N2-OP-101C, Plant Shutdown is being implemented.
- Reactor power is now at 50%.
- Drywell Floor Drain leak rate is at 1gpm and Tech Spec LCO is exited.
- After conditions are stabilized, a spurious MSIV isolation occurs and the reactor automatically scrams
- All rods fully insert
- SRVs and RCIC are controlling reactor pressure
- Feedwater is controlling RPV level which is being maintained 160 to 200 inches.
- Plant conditions are stabilized and a normal cool down occurs.

Initiating cue:

perator's name), identify the applicable verbal notification requirements, the reason that they apply and the associated time limitations for reporting under that category".

Per	formance Steps	Standard	Grade
1.	Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1)	Sat/Unsat
RE	CORD START TIME		
2	•Obtain a copy of the any of the reference documents related to regulatory notifications. These are likely to include the following:	<ul> <li>Reference materials obtained.</li> </ul>	
	<ul> <li>INF-ING-01</li> <li>10CFR50.72 and 73</li> <li>NUREG1022</li> <li>EAL Matrix</li> </ul>		

Pe	rformance	Steps	Sta	andard	Grade
3.	Locate a of 50.72 LER is no requirem	nd identify applicability (b)(3)(iv)(B)(2). ot a verbal reporting ent.		Determines actuation of isolation logic is not reportable under 50.72 (b)(3)(iv)(B)(2) because the actuation is not due to a valid signal. LER is required under 50.73 (b)(2)(iv). Identification of this requirement is not required.	Pass/Fail Sat/Unsat/NA
	4.	Locate and identify applicability of 50.72(a)(1)(i). Declaration of an Emergency Class.		Identifies leak rate above 10 gpm requires EAL 2.1.1 UNUSUAL EVENT must be declared. Identify reportability per 50.72(a)(1)(i) and (a)(3), within 15 minutes of declaration, immediately after notifying State and local agencies and not later than one hour after the time of declaration.	Pass/Fail
	5.	Locate and identify applicability of 50.72(b)(2)(i). Non- emergency four hour report. Initiation of a plant shutdown required by Tech Specs. (If not already reported with the 50.72(a)(1)(i).		Refer to Tech Spec <b>3.4.5.C.</b> and determines that with specification not being met, the required action to comply with Tech Spec is to be cold shutdown within 12 hours. The plant shutdown being performed is required by Tech Specs. Identify reportability per 50.72(b)( 2)(i) within four hours, if not already reported.	Sat/Unsat Pass/Fail
	6.	Locate and identify applicability of 50.72(b)(2)(iv)(B) Non-emergency four hour report. Actuation of RPS when the reactor is critical.		Identify reportability per 50.72(b)(2)(iv)(B) within 4 hours, if not already reported.	Pass/Fail

End of JPM

# TERMINATING CUE: Determine notification requirements.

# RECORD STOP TIME\_

—

# Applicant Cue Sheet

Initial Conditions:

- The plant is operating at 100% power.
- Containment purge is in progress
- Maintenance is using an approved work order to perform a maintenance activity on containment purge isolation logic
- Work order identifies that the activity has the potential to cause containment purge isolation, due to the possibility of causing an electrical short.
- While the work order is being performed, the worker does create an electrical short and an automatic isolation of the containment purge system occurs. No other systems are affected.
- After conditions are stabilized, Drywell Floor Drain leakage rate rises to 10 gpm.
- Drywell pressure stabilizes below the scram setpoint but the leakage has remained at 10 gpm for the past 4 hours despite leakage reduction attempts.
- Actions to comply with Tech Specs as a result of the leakage are initiated and N2-OP-101C, Plant Shutdown is being implemented.
- Reactor power is now at 50%.
- Drywell Floor Drain leak rate is at 1gpm and Tech Spec LCO is exited.
- After conditions are stabilized, a spurious MSIV isolation occurs and the reactor automatically scrams
- All rods fully insert
- SRVs and RCIC are controlling reactor pressure
- Feedwater is controlling RPV level which is being maintained 160 to 200 inches.
- Plant conditions are stabilized and a normal cool down occurs.

Initiating cue:

"(Operator's name), identify the applicable verbal reportability requirements, the reason that they apply and the associated time limitations for reporting under that category".

# Attachment 1

# JPM Scorecard KEY

plicable verbal reportability requirements, the reason that they apply and the associated time limitations for reporting under that category

		1
Requirement		nt) Category Applies
B)(2). General containment isolation signals.	BLE	rge Isolation during maintenance activity. Also, only affects one system.
d (a)(3). Declaration of an Emergency Class	es of declaration, immediately after notifying state and local agencies and not later than one hour after the time of declaration	E 2.1.1
itiation of a plant shutdown required by Tech Specs	if not previously reported.	Int shutdown required by Tech Specs 3.4.5.C Unidentified leakage is above 5 gpm for >4
<ol> <li>Actuation of RPS when the reactor is critical.</li> </ol>	if not previously reported.	hours.
		or trip when the reactor is critical.

# JPM Scorecard For Applicant Use

licable verbal reportability re he associated time limitatior	equirements, the reason that they apply and ns for reporting under that category
equirement	t) Category Applies

#### Constellation Energy Group OPERATOR JOB PERFORMANCE MEASURE

Title: Offsite Dose Calculation Manual (ODCM) Assessment for Inoperable Equipment

Revision: NRC 2008

Task Number:

Approvals:

	NA	<b>EXAMINATION SECURIT</b>	Y
General Supervisor Date Operations Training (Designee)	Gene	ations (Designee)	Date
NA EXAMINATION SECURITY Configuration Control Date			
Performer:	(SRO)		
Trainer/Evaluator:			
Evaluation Method: <b>PERFORM</b>			
Evaluation Location: SIMULATOR O	R OTHER DESIGNATED	) AREA	
Expected Completion Time: 15 minut	es Time Critical Task: N	O Alternate Path	Task: NO
Start Time: Stop	Time:	Completion Time:	
JPM Overall Rating: Pass	s Fail		
NOTE: A JPM overall rating of individual competency area ur	fail shall be given if <u>any</u> Isat requires a comment.	critical step is graded as fa	ail. Any grade of unsat
ommonte:			

Comments:

Evaluator Signature:\_\_\_\_\_

Date:

or

Recommended Start Location: (Completion time based on the start location) Simulator or other designated location

Simulator Set-up: N/A

Directions to the Instructor/Evaluator

## To be performed as an administrative JPM with two parts (Part A and Part B)

#### Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SSS, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

Read Before Each <u>Evaluated</u> JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore it should not be requested.

Read Before Each <u>Training</u> JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the additional / concurrent verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified as **Pass/Fail**. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
  - Self-verification shall be demonstrated.
- 3. During Training JPM:
  - Self-verification shall be demonstrated.
  - No other verification shall be demonstrated.

#### References:

- 5. N2-OP-42, Offgas System.
- 6. ODCM D.3.3.2, Radioactive Gaseous Effluent Monitoring Instrumentation.
- 7. K/A 2.3.11, Ability to control radiation releases (3.2).

Tools and Equipment:

1. None

Task Standard:Determines that periodic OFG effluent grab samples and analyses are required<br/>per the ODCM and the time limits for the first and second grab samples.

17

Initial Conditions:

- 1. Reactor power is 45% with power ascension in progress.
- 2. Both OFG\*RE13A and OFG\*RE13B were previously OPERABLE and in-service
- 3. Both OFG\*13A and OFG\*13B indications have just failed downscale.
- 4. Troubleshooting has not yet commenced.
- 5. Ask the operator for any questions.

Initiating cue:

"(Operator's name), Determine required actions."

Performance Steps	Standard	Grade	Comments
1. Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary	Proper communications used for repeat back (GAP-OPS-O1)	Sat/Unsat	

RECORD START TIME

# <u>PART A</u>

1.	•Obtain a copy of the reference procedure and review/utilize the correct section.	ODCM obtained. Section D.3.3.2 and Bases B 3.3.2 are referenced.	Sat/Unsat	
2.	•Reference CONDITION B	Determines that the inoperable OFG Radiation Monitors must be restored to OPERABLE status within 30 days.	Sat/Unsat	
		Refers to Table 3.3.2-1	Sat/Unsat	
		Determines that CONDITION C is applicable	Sat/Unsat	

Performance Steps	St	andard	Grade	Comments
<ol> <li>•Reference CONDITION C</li> <li>NOTE: Candidate is NOT expected</li> </ol>		Determines that tripping both channels of OFG*RE13A and B would isolate OFG requiring a scram.	Sat/Unsat	
to implement REQUIRED ACTION C.1, however if implemented, must determine that OFG will isolate and a manual scram is required.				
		Determines that OFG grab samples must be taken within 12 hours and once per 12 hours thereafter.	Pass/Fail	
		Determines that the samples must be analyzed within 24 hours of sample completion.	Pass/Fail	
	Сι	ie: Acknowledge the sample requirements for OFG.		

#### Part B

NOTE: If candidate implements REQUIRED ACTION C.1 instead of C.2, the JPM PART B is not applicable.

**EVALUATOR:** When the candidate determines the ODCM sample requirements, provide the candidate with the attached PART B Initial Conditions and Initiating Cues Information Sheet.

Cue: Asked the candidate to determine when the first and second samples are due based upon a 06:00 time for the OFG\*RE13A/B inoperabilities.



Performance Steps	Standard	Grade	Comments
<ol> <li>Obtain a copy of the applicable reference documents and review/</li> </ol>	<ul> <li>Reviews ODCM Section 3.0, Applicability.</li> </ul>	Sat/Unsat	
utilize the correct sections.	<ul> <li>Reviews Tech Spec Section 1.3, Completion Times.</li> </ul>	Sat/Unsat	
<ol> <li>Determines that Example 1.3-1 applies to the first "12 Hours"</li> </ol>	□ First sample is due by 18:00 today	Pass/Fail	
<ol> <li>Determines that Example 1.3-6 applies to the next "<u>AND</u> once per 12 hours thereafter".</li> </ol>	<ul> <li>Second sample is due by 06:00 tomorrow, with an allowable extension of 3 hours (as late as 09:00)</li> </ul>	Pass/Fail	12 hours + a 25% extension of 3 hours = 15 hours

End of JPM

## **TERMINATING CUE:**

Determines that periodic OFG effluent grab samples and analyses are required per the ODCM and the time limits for the first and second grab samples.

RECORD STOP TIME

# <u>PART A</u>

Initial Conditions:

- 1. Reactor power is 45% with power ascension in progress.
- 2. Both OFG\*RE13A and OFG\*RE13B indications have failed downscale.
- 3. Troubleshooting has not yet commenced.
- 4. Ask the operator for any questions.

Initiating cue:

"(Operator's name), Determine required actions."

21

# Initial Conditions and Initiating Cue Information Sheet

nditions:

- 1. OFG\*RE13A/B were declared inoperable at 06:00 today
- 2. Ask the operator for any questions.

Initiating cue:

"(Operator's name), determine the latest time that the first sample is due. Then based upon this time, determine the **latest** time the next sample can be taken."

#### CONSTELLATION ENERGY GROUP

#### OPERATOR JOB PERFORMANCE MEASURE

Title: Emergency Classification	on With PARs				Rev: NRC 200	<u>08</u>
Task Number: N/A						
Approvals:						
		_	NA EX		ION SECURITY	
General Supervisor Operations Training (Designee)	Date		Genera Operati	l Supervis ons (Desi	sor gnee)	Date
NA EXAMINATION SECURITY	Y Date					
Performer:			<u>(</u> SRO)			
Trainer/Evaluator:						
Evaluation Method: X	Perform			Simulate	9	
Evaluation Location:	Plant		Х	Simulato	or or other location	
Expected Completion Time:	20 min Time C	ritical Ta	sk:	YES A	Alternate Path Task: N	0
Start Time:	Stop Time:			Completi	ion Time:	_
JPM Overall Rating:	Pass	Fail				

**<u>NOTE</u>**: A JPM overall rating of fail shall be given if <u>any</u> critical step is graded as fail. Any grade of unsat or individual competency area unsat requires a comment.

Comments:

Evaluators Signature:\_\_\_\_\_

Recommended Start Location: (Completion time based on the start location) Any appropriate location with proper references.

Simulator Set-up (if required): None

Directions to the Instructor/Evaluator:

Candidate is to be provided with blank SM/ED Emergency Plan packet (obtained from control room or simulator) that would be used by SM/ED during actual emergency plan implementation.

Directions to Operators: Read Before <u>Every</u> JPM Performance:

For the performance of this JPM, I will function as the SM, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

With the exception of accessing panels, NO plant equipment will be physically manipulated. Repositioning of devices will be simulated by discussion and acknowledged by my cues.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore, it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, the use of applicable methods of verification and checking are expected. Therefore, either another individual or I will act as the independent verifier or peer checker.

Notes to Instructor / Evaluator:

- Critical steps are identified in grading areas Pass/Fail. All steps are sequenced critical unless denoted by a "•".
- 8. During Evaluated JPM:
  - Self checking shall be demonstrated.
- 9. During Training JPM:
  - Self checking shall be demonstrated.
  - Peer checking shall be demonstrated.

References:

- 2. EPIP-EPP-08, Offsite Dose Assessment And Protective Action Recommendations
- 3. EPIP-EPP-20, Emergency Notifications
- 4. EAL Matrix

Tools and Equipment:

- 1. EAL Matrix
- 2. SM/ED Emergency Plan Packet

Task Standard:

Given a set of plant conditions, classify the emergency (within 15 min.), and complete the Part 1 Notification Fact sheet including PARs (within 15 min.)

Initial Conditions:

- 1. The plant is under accident conditions.
- 2. A Site Area Emergency has been declared based on plant conditions.
- 3. An Exclusion Area Evacuation has been directed and is in progress.
- 4. The Chemistry Technician has reported the following release data:
  - Dose assessment for ground level release rate is 154 Curies per second (Ci/second)
  - Dose assessment for elevated level release rate is 842 Ci/second
  - Wind speed is 12 mph
  - Wind direction is from (65°)
  - Pascal Stability Class is D

#### Initiating Cues:

"(Operator's name), Take the required actions as the Emergency Director."

Perfo	rmance	Steps	Standard	Grade
Evalu	uator No a Time	ote: Inform the Candidate that this is -Critical task		
1.	Provide repeat back of initiating cue. Evaluator Acknowledge repeat back providing correction if necessary.		Proper communications used for repeat back (GAP-OPS-O1/Operations Manual)	Sat/Unsat
REC	ORD TA	ASK 1 AL START TIME		
2.	Obtain and rev proced	a copy of the reference procedure view/utilize the correct section of the ure.	The candidate may reference any/all of the following: EAL Matrix obtained. Section 5.0 EPIP-EPP-08 Att. 1	Sat/Unsat
	3. L	Jsing given plant data and EPIP0- EPP-08 Attachment 1 Table 1.1 and Table 1.2, determine that a General Emergency exists based upon calculated total release (ground release + elevated release).	General Emergency is declared, within 15 minutes of recorded start time for Task 1. From EPP-08 Attachment 154/357 = (.431) + 842/1388 = (.607) = 1.038 (General Emergency Exists if above 1.0)	Pass/Fail
REC CRIT	ORD TA ICAL S	ASK 1 CRITICAL STOP/ TASK 2 TART TIME		
	4.	Review meteorological data and EPIP-EPP-08 and/or EPIP-EPP- 20 to determine PAR's.	PAR's made and indicated on Part I Notification Fact Sheet Block 6.B to evacuate and implement the KI Plan for ERPA's 1, 2, 3,6,11, 26, and 27. Advise the remaining	Pass/Fail
	Cue:	If asked, all evacuation routes are available for use.	ERPA's listen to Emergency Alert System, within 15 minutes of recorded start time for Task 2.	
REC	ORD TA	ASK 2 CRITICAL STOP TIME		

Terminating Cue: The event is classified as a General Emergency and PAR's are made.

RECORD STOP TIME

Initial Conditions:

- 1. The plant is under accident conditions.
- 2. A Site Area Emergency has been declared based on plant conditions.
- 3. An Exclusion Area Evacuation has been directed and is in progress.
- 4. The Chemistry Technician has reported the following release data:
  - Dose assessment for ground level release rate is 154 Curies per second (Ci/second)
  - Dose assessment for elevated level release rate is 842 Ci/second
  - Wind speed is 12 mph
  - Wind direction is from (65°)
  - Pascal Stability Class is D

Initiating Cues:

"(Operator's name), Take the required actions as the Emergency Director."

## Constellation Energy Group OPERATOR JOB PERFORMANCE MEASURE

Of High Radiation Area	ents Related to Operator s	Inspection	Revision: NRC 2008
Task Number: N/A			
Approvals:			
		NA EXAMINATION SE	CURITY
Operations Training (Designee)	Date )	Operations (Designee)	Date
<u>NA EXAMINATION SECURIT</u> Configuration Control	Y Date		
Performer:	(RO)		
Trainer/Evaluator:			
Evaluation Method: <b>PERFORM</b>			
Evaluation Location: SIMULAT	OR OR OTHER DESIGN	ATED LOCATION	
Expected Completion Time: 20	minutes Time Critical Ta	sk: NO Alternat	e Path Task: NO
Expected Completion Time: 20 Start Time:	minutes Time Critical Ta Stop Time:	sk: NO Alternat Completion Tim	e Path Task: NO e:
Expected Completion Time: 20 Start Time: JPM Overall Rating:	minutes Time Critical Ta Stop Time: Pass Fail	sk: NO Alternat _ Completion Tim	e Path Task: NO e:
Expected Completion Time: 20 Start Time: JPM Overall Rating: NOTE: A JPM overall rating individual competency a	minutes Time Critical Ta Stop Time: Pass Fail ting of fail shall be given rea unsat requires a com	Isk: NO Alternat Completion Tim if <u>any</u> critical step is grade ment.	e Path Task: NO e: ed as fail. Any grade of unsat or
Expected Completion Time: 20 Start Time: JPM Overall Rating: NOTE: A JPM overall ratindividual competency at Comments:	minutes Time Critical Ta Stop Time: Pass Fail ting of fail shall be given rea unsat requires a com	Isk: NO Alternat Completion Tim if <u>any</u> critical step is grade ment.	e Path Task: NO e: ed as fail. Any grade of unsat or
Expected Completion Time: 20 Start Time: JPM Overall Rating: NOTE: A JPM overall ra individual competency a Comments:	minutes Time Critical Ta Stop Time: Pass Fail ting of fail shall be given rea unsat requires a com	Isk: NO Alternat Completion Tim if <u>any</u> critical step is grade ment.	e Path Task: NO e: ed as fail. Any grade of unsat or
Expected Completion Time: 20 Start Time: JPM Overall Rating: NOTE: A JPM overall ra individual competency a Comments:	minutes Time Critical Ta Stop Time: Pass Fail ting of fail shall be given rea unsat requires a com	Isk: NO Alternat Completion Tim if <u>any</u> critical step is grade ment.	e Path Task: NO e: ed as fail. Any grade of unsat or
Expected Completion Time: 20 Start Time: JPM Overall Rating: NOTE: A JPM overall ra individual competency a Comments:	minutes Time Critical Ta Stop Time: Pass Fail ting of fail shall be given rea unsat requires a com	Isk: NO Alternat Completion Tim if <u>any</u> critical step is grade ment.	e Path Task: NO e: ed as fail. Any grade of unsat or
Expected Completion Time: 20 Start Time: JPM Overall Rating: NOTE: A JPM overall ra individual competency a Comments:	minutes Time Critical Ta Stop Time: Pass Fail ting of fail shall be given rea unsat requires a com	Isk: NO Alternat Completion Tim if <u>any</u> critical step is grade ment.	e Path Task: NO e: ed as fail. Any grade of unsat or
Expected Completion Time: 20 Start Time: JPM Overall Rating: NOTE: A JPM overall ra- individual competency a Comments:	minutes Time Critical Ta Stop Time: Pass Fail ting of fail shall be given rea unsat requires a com	Isk: NO Alternat _ Completion Tim if <u>any</u> critical step is grade ment.	e Path Task: NO e: ed as fail. Any grade of unsat or
Expected Completion Time: 20 Start Time: JPM Overall Rating: NOTE: A JPM overall ra- individual competency a Comments:	minutes Time Critical Ta Stop Time: Pass Fail ting of fail shall be given rea unsat requires a com	Isk: NO Alternat Completion Tim if <u>any</u> critical step is grade ment.	e Path Task: NO e: ed as fail. Any grade of unsat or

Recommended Start Location: (Completion time based on the start location)

Simulator or other designated location.

Simulator Set-up:

N/A

#### Directions to the Instructor/Evaluator: RWP and survey map to be provided with this JPM.

#### Directions to Operators:

Read Before Every JPM Performance:

For the performance of this JPM, I will function as the SM, CSO, and Auxiliary Operators. Prior to providing direction to perform this task, I will provide you with the initial conditions and answer any questions. During task performance, I will identify the steps to be simulated, or discuss and provide cues as necessary.

Read Before Each Evaluated JPM Performance:

This evaluated JPM is a measure of your ability to perform this task independently. The Control Room Supervisor has determined that a verifier is not available and that additional / concurrent verification will not be provided; therefore it should not be requested.

Read Before Each Training JPM Performance:

During this Training JPM, applicable methods of verification are expected to be used. Therefore, either another individual or I will act as the additional / concurrent verifier.

Notes to Instructor / Evaluator:

- 1. Critical steps are identified as **Pass/Fail**. All steps are sequenced critical unless denoted by a "•".
- 2. During Evaluated JPM:
  - Self-verification shall be demonstrated.
- 3. During Training JPM:
  - Self-verification shall be demonstrated.
  - No other verification shall be demonstrated.

References:

- 8. GAP-RPP-01; 3.5.
- 9. GAP-RPP-02; 3.3.
- 10. GAP-RPP-08; 3.2.
- 11. GAP-RPP-07; 3.2.5
- 12. K/A 2.3.12 (3.7) Knowledge of radiological safety principles related to licensed operator duties.

Tools and Equipment:

1. None.

Task Standard: Radiological requirements related to the performance of high radiation area inspection are met prior to and during the performance of the inspection.

Initial Conditions:

- 1. The plant is operating at 100% power.
- 2. N2-PM-M008, Monthly Checklist is scheduled for this shift.
- 3. You will be conducting an inspection of the Outer Tip Room, Reactor Bldg 250.
- 4. An RWP and survey map are provided.
- 5. Your exposure is 1690 mrem TEDE at the beginning of the shift. You have inspected 3 areas already and your ED indicated 10 mrem, 15 mrem, and 5 mrem, respectively for the 3 areas already inspected.
- 6. Ask the operator for any questions.

#### Initiating cue:

"(Operator's name), you will be performing N2-PM-M008, Monthly Checklist, for the Outer Tip, Reactor Building 250. An RWP and a survey map are provided. Address the radiological aspects of performing this inspection. Document your findings on the SCORECARD provided"

Performance Steps		Standard	Grade	Comments
2. Provide repeat b cue. Evaluator A repeat back prov if necessary	ack of initiating Acknowledge riding correction	Proper communications used for repeat back (GAP-OPS-O1)	Sat/Unsat	
RECORD START TI	ME	NOTE: A score card is attached to this JPM identifying the items for the performer to identify.		
<ol> <li>Obtain a copy or procedure and recorrect section.</li> </ol>	f the reference eview/utilize the	N2-PM-M008 obtained and referenced. <i>GAP-RPP-01; 3.5 referenced as</i> <i>required.</i> <i>GAP-RPP-02; 3.3 referenced</i> as required <i>GAP-RPP-08; 3.2 referenced</i> as required <i>GAP-RPP-07; 3.2.5 referenced</i> as <i>required</i>	Sat/Unsat	

4. • Applicable radiological precautions shall be observed. Rad Protection shall be contacted for guidance as required.

Reviews RWP / Survey Map:

- Determine radiological controls: Pass/Fail SCORECARD #1: HIGH RADIATION AREA SCORECARD #2: Area dose rates Pass/Fail up to 190 mrem/hour. Determine protective clothing: SCORECARD #3: Although no PC Pass/Fail requirements are outlined on the **RWP**, determines **PROTECTIVE CLOTHING IS REQUIRED because** the area is a contaminated area and determines that RP must be consulted for guidance. Determine entry requirements Sat/Unsat dosimetry: SCORECARD #4: Determine TLD and ED required to enter the area. Per GAP-RPP-08, Step 3.2.2, determine delta exposure: Pass/Fail SCORECARD #5: Determine required delta exposure of 300 mrem. Additional approvals ARE NOT required prior to performing the inspection.

2

October 2008

32

Performance Steps	Standard	Grade	Comments
	1690+10+15+5+300 = 2020 mrem (In excess of 2000 mrem requires RP and Dept Manager approval per GAP- RPP-07 3.2.5).		
<ol> <li>•Check the Radiation/ Contamination survey Map Entry Record Sheet for the area which require inspection.</li> </ol>	<u>SCORECARD #6:</u> Notes area with highest contamination levels.	Pass/Fail	
NOTE: X-R key is for LOCKED HIGH RAD AREAS and is controlled solely by RP. X-R keys are different than keys for HIGH RAD AREAS, which we keep locked. Needs H2D-13 key (indicated on survey map) which can be issued.	PROMPT: If determines X-R key, inform the performer that RP is not authorized to issue X-R keys to operators.		
c. •Obtain associated key(s) from radiation protection.	<u>SCORECARD #7:</u> Determine H2D-13 key is needed (indicated on survey map) and it is obtained from radiation protection.	Sat/Unsat	RP would not issue an X-R key if requested so not critical.

End of JPM

**TERMINATING CUE:** Radiological requirements related to the performance of high radiation area inspection are met prior to and during the performance of the inspection.

## RECORD STOP TIME\_

#### Initial Conditions:

- 1. The plant is operating at 100% power.
- 2. N2-PM-M008, Monthly Checklist is scheduled for this shift.
- 3. You will be conducting an inspection of the Outer Tip Room, Reactor Bldg 250.
- 4. A RWP and survey map are provided.
- 5. Your exposure is 1690 mrem TEDE at the beginning of the shift. You have inspected 3 areas already and your ED indicated 10 mrem, 15 mrem, and 5 mrem, respectively for the 3 areas already inspected.
- 6. Ask the operator for any questions.

#### Initiating cue:

"(Operator's name), you will be performing N2-PM-M008, Monthly Checklist, for the Outer Tip, Reactor Building 250. An RWP and a survey map are provided. Address the radiological aspects of performing this inspection. Document your findings on the SCORECARD provided"

## OK TO PROVIDE TO CANDIDATE

Answer the following when performing this task:					
SCORECARD #1:					
Classify the area (check one):	<ul> <li>□ Radiation Area</li> <li>□ High Radiation A</li> <li>□ Locked High Rad</li> <li>□ Very High Radiation</li> </ul>	rea liation Area on Area			
SCORECARD #2:					
Designate the highest dose rate in the ar	ea and the location:				
SCORECARD #3:					
Designate whether or not protective cloth	ning is required (check or	ne):	□ Yes □ No		
SCORECARD #4:					
Designate required dosimetry to enter the	e area:				
SCORECARD #5:					
Evaluate delta exposure (check one) and	d explain:	<ul> <li>Acceptabl</li> <li>Additional</li> </ul>	e approval(s) required		
SCORECARD #6:					
Designate the highest contamination levels in the room and the location:					
SCORECARD #7:					
Designate the key to be obtained <u>AND</u> w	ho controls the key:				

Answer the following when performing this task:					
SCORECARD #1: PASS/FAIL					
Classify the area (check one):	<ul> <li>□ Radiation Area</li> <li>✓ High Radiation Area</li> <li>□ Locked High Radiation Area</li> <li>□ Very High Radiation Area</li> </ul>				
SCORECARD #2: PASS/FAIL					
Designate the highest dose rate in the area 190 mrem/h	a and the location: hr, Between Tip Machine D & E				
SCORECARD #3: PASS/FAIL					
Designate whether or not protective clothin	Ig is required (check one): ✓ Yes □ No				
SCORECARD #4: SAT/LINSAT					
Designate required dosimetry to enter the area: TLD and ED (Electronic Dosimeter)					
SCORECARD #5: PASS/FAIL					
Evaluate delta exposure (cneck one) and e					
1690+10+15+5+300 = 2020 mrem (In excess of 2000 mrem requires RP and	Additional approval(s) required Dept Manager approval per GAP-RPP-07 3.2.5).				
SCORECARD #6: PASS/FAIL					
Designate the highest contamination levels in the room and the location: 20,000dpm/100cm2 at Tip Machine "C"					
SCORECARD #7: SAT/UNSAT					
Designate the key to be obtained <u>AND</u> who <i>H2D-13 controlled by RP</i>	o controls the key:				
	:				