## 3.1 Emergency Response Facilities

### Design Description

The technical support center (TSC) is a facility from which management and technical support is provided to main control room (MCR) personnel during emergency conditions. The operations support center (OSC) provides an assembly area where operations support personnel report in an emergency. The control support area (CSA) is an area nearby the main control room from which support can be provided to the main control room.

1. The TSC has floor space of at least 75 $ft^2$ per person for a minimum of 25 persons.

2. The TSC has voice communication equipment for communication with the MCR, emergency operations facility, OSC, and the U.S. Nuclear Regulatory Commission (NRC).

3. The plant parameters listed in Table 2.5.4-1, minimum inventory table, in subsection 2.5.4, Data Display and Processing System (DDS), with a "Yes" in the "Display" column, can be retrieved in the TSC.

4. The OSC has voice communication equipment for communication with the MCR and TSC.

5. The TSC and OSC are in different locations.

6. The CSA provides a habitable workspace environment.

### Inspections, Tests, Analyses, and Acceptance Criteria

Table 3.1-1 specifies the inspections, tests, analyses, and associated acceptance criteria for the emergency response facilities.

**Table 3.1-1**
**Inspections, Tests, Analyses, and Acceptance Criteria**

| Design Commitment | Inspections, Tests, Analyses | Acceptance Criteria |
|---|---|---|
| 1. The TSC has floor space of at least 75 $ft^2$ per person for a minimum of 25 persons. | An inspection will be performed of the TSC floor space. | The TSC has at least 1875 $ft^2$ of floor space. |
| 2. The TSC has voice communication equipment for communication with the MCR, emergency operations facility, OSC, and the NRC. | An inspection and test will be performed of the TSC voice communication equipment. | Communications equipment is installed, and voice transmission and reception are accomplished. |
| 3. The plant parameters listed in Table 2.5.4-1, minimum inventory table, in subsection 2.5.4, DDS, with a "Yes" in the "Display" column, can be retrieved in the TSC. | An inspection will be performed for retrievability of the plant parameters in the TSC. | The plant parameters listed in Table 2.5.4-1, minimum inventory table, in subsection 2.5.4, DDS, with a "Yes" in the "Display" column, can be retrieved in the TSC. |
| 4. The OSC has voice communication equipment for communication with the MCR and TSC. | Inspection will be performed of the OSC voice communication equipment. | Communications equipment is installed, and voice transmission and reception are accomplished. |
| 5. The TSC and OSC are in different locations. | An inspection will be performed of the location of the TSC and OSC. | The TSC and OSC are in different locations. |
| 6. The CSA provides a habitable workspace environment. | See Tier 1 Material, Table 2.7.1-4, items 1, 8a), 8c), 12, and 13, Nuclear Island Nonradioactive Ventilation System. | See Tier 1 Material, Table 2.7.1-4, items 1, 8a), 8c), 12, and 13, Nuclear Island Nonradioactive Ventilation System. |