

**CHAPTER 17****QUALITY ASSURANCE****17.1 Quality Assurance During the Design and Construction Phases**

See Section 17.5.

**17.2 Quality Assurance During the Operations Phase**

See Section 17.5.

**17.3 Quality Assurance During Design, Procurement, Fabrication, Inspection, and/or Testing of Nuclear Power Plant Items**

This section outlines the quality assurance program applicable to the design, procurement, fabrication, inspection, and/or testing of items and services for the AP1000 Project. The design for AP1000 is based upon employing the design of AP600 to the maximum extent possible. As a result, a continuous quality program spanning AP600 design as well as AP1000 design has been used. Westinghouse has and will continue to maintain a quality assurance program meeting the requirements of 10 CFR 50 Appendix B for the AP1000 program that will be applicable to the design, procurement, fabrication, inspection, and/or testing activities.

Effective March 31, 1996, activities affecting the quality of items and services for the AP600 Project during design, procurement, fabrication, inspection, and/or testing were being performed in accordance with the quality plan described in "Westinghouse Electric Corporation – Energy Systems Business Unit, Quality Management System," (Reference 1). The Quality Management System (QMS) has been maintained as the Quality Plan for the AP1000 program and subsequent revisions have been submitted to and accepted by the NRC as meeting the requirements of 10 CFR 50 Appendix B.

Prior to introduction of the QMS as the quality plan applicable to the AP1000 project, activities on the AP600/AP1000 program were performed in accordance with topical report WCAP 8370 (References 2 and 3), Westinghouse Energy Systems Business Unit/Power Generation Business Unit Quality Assurance Plan. WCAP 8370 was subsequently superceded by the Westinghouse QMS to describe the quality assurance plan and Westinghouse commitments to meet the requirements of 10 CFR 50 Appendix B.

The current Westinghouse quality plan for work being performed on the AP1000 is the Westinghouse Electric Company Quality Management System (QMS) (Reference 9). The referenced revision of the QMS was accepted by the NRC as meeting the requirements of 10 CFR 50, Appendix B, on September 13, 2002.

A project-specific quality plan was issued to supplement the quality management system document and the topical reports for design activities affecting the quality of structures, systems, and components for the AP600 project (Reference 4). This plan referenced the NQA-1-1989 edition through NQA-1b-1991 addenda and was applicable to work performed for the AP1000 design prior to March 16, 2007.

Effective March 16, 2007, NQA-1-1994 is the applicable revision of NQA-1 for work performed for the AP1000 project. As such, a project-specific quality plan is no longer required, and the Westinghouse Electric Company Quality Management System (QMS) (Reference 9) is the quality program for work performed for the AP1000 project.

Quality Assurance requirements for systems, structures, and components will be graded based on the safety classification as indicated in Section 3.2. Safety-related systems are classified as Equipment Classes A, B and C, and will meet the requirements of 10 CFR 50, Appendix B. For systems, structures, and components included in the regulatory treatment of nonsafety systems (RTNSS), the quality requirements are identified in Table 17-1. See Section 16.3 for systems that should be considered for designation of systems and components included in the regulatory treatment of nonsafety systems.

While Westinghouse retains the overall responsibility for the AP1000 design, portions of the design are developed by external organizations. Each organization maintains a quality assurance program that meets the NQA-1 criteria that apply to its work scope. In accordance with the QMS, Westinghouse performs an initial evaluation of these programs and monitors their continued effective implementation through audits, surveillance, and evaluation of the performance of external organizations.

#### **17.4 Design Reliability Assurance Program**

This subsection presents the AP1000 Design Reliability Assurance Program (D-RAP).

##### **17.4.1 Introduction**

The AP1000 D-RAP is implemented as an integral part of the AP1000 design process to provide confidence that reliability is designed into the plant and that the important reliability assumptions made as part of the AP1000 probabilistic risk assessment (PRA) (Reference 5) will remain valid throughout plant life. The PRA quantifies plant response to a spectrum of initiating events to demonstrate the low probability of core damage and resultant risk to the public. PRA input includes specific values for the reliability of the various structures, systems, and components (SSCs) in the plant that are used to respond to postulated initiating events.

The D-RAP, shown in Figure 17.4-1, is implemented during Design Certification. The D-RAP identifies risk-significant SSCs for inclusion into the site Operational Phase Reliability Assurance Activities (OPRAAs) using probabilistic, deterministic, and other methods.

The OPRAAs provides confidence that the operations and maintenance activities performed by the operating plant support should maintain the reliability assumptions made in the plant PRA.

##### **17.4.2 Scope**

The D-RAP includes a design evaluation of the AP1000 and identifies the aspects of plant operation, maintenance, and performance monitoring pertinent to risk-significant SSCs. In addition to the PRA, deterministic tools, industry sources, and expert opinion are used to identify and prioritize those risk-significant SSCs.

### 17.4.3 Design Considerations

As part of the design process, risk-significant components are evaluated to determine their dominant failure modes and the effects associated with those failure modes. For most components, a substantial operating history is available which defines the significant failure modes and their likely causes.

The identification and prioritization of the various possible failure modes for each component lead to suggestions for failure prevention or mitigation. This information is provided as input to the OPRAAs.

The design reflects the reliability values assumed in the design and PRA as part of procurement specifications. When an alternative design is proposed to improve performance in either area, the revised design is first reviewed to provide confidence that the current assumptions in the other areas are not violated. When a potential conflict exists between safety goals and other goals, safety goals take precedence.

### 17.4.4 Relationship to Other Administrative Programs

The D-RAP manifests itself in other administrative and operational programs. The technical specifications provide surveillance and testing frequencies for certain risk-significant SSCs, providing confidence that the reliability values assumed for them in the PRA will be maintained during plant operations. Risk-significant systems that provide defense-in-depth or result in significant improvement in the PRA evaluations are included in the scope of the D-RAP.

The OPRAAs are comprised of site administrative, maintenance, operational, and testing programs to enhance operational phase reliability throughout the designed plant life. As documented in Reference 10 and Reference 12, the following reliability assurance programs are credited as OPRAAs:

- Maintenance Rule Program (Reference 10)
- Quality Assurance Program (Section 17.2)
- Inservice Testing Program (Section 3.9)
- Inservice Inspection Program (Section 5.2 and Section 6.6)
- Technical Specifications Surveillance Test Program (Section 16.1)
- AP1000 Investment Protection Short Term Availability Controls Program (Section 16.3)
- Site Maintenance Program

### 17.4.5 The AP1000 Design Organization

The AP1000 organization of Section 1.4 formulates and implements the AP1000 D-RAP.

The AP1000 management staff is responsible for the AP1000 design and licensing.

The AP1000 staff coordinates the program activities, including those performed within Westinghouse as well as work completed by the architect-engineers and other supporting organizations listed in Section 1.4.

The AP1000 staff is responsible for development of the D-RAP and the design, analyses, and risk and reliability engineering required to support development of the program. Westinghouse is responsible for the safety analyses, the reliability analyses, and the PRA.

The reliability analyses are performed using common databases from Westinghouse and from industry sources such as INPO and EPRI.

The Risk and Reliability organization is responsible for developing the D-RAP and has direct access to the AP1000 staff. Risk and Reliability is responsible for keeping the AP1000 staff cognizant of the D-RAP risk-significant items, program needs, and status. Risk and Reliability participates in the design change control process for the purpose of providing D-RAP-related inputs to the design process. Additionally, a cognizant representative of Risk and Reliability is present at design reviews. Through these interfaces, Risk and Reliability can identify interfaces between the performance of risk-significant SSCs and the reliability assumptions in the PRA. Meetings between Risk and Reliability and the designer are then held to manage interface issues.

#### 17.4.6 Objective

The objective of the D-RAP is to design reliability into the plant and to maintain the AP1000 reliability consistent with the NRC-established PRA safety goals.

The following goals have been established for the D-RAP:

- Provide reasonable assurance that
  - The AP1000 is designed, procured, constructed, maintained and operated in a manner consistent with the assumptions and risk insights in the AP1000 PRA for these risk-significant SSCs
  - The risk-significant SSCs do not degrade to an unacceptable level during plant operations
  - The frequency of transients that challenge the AP1000 risk-significant SSCs are minimized
  - The risk-significant SSCs function reliably when they are challenged
- Provide a mechanism for establishing baseline reliability values for risk-significant SSCs identified by the risk determination methods used to implement the Maintenance Rule (10 CFR 50.65) and consistent with PRA reliability and availability design basis assumptions used for the AP1000 design
- Provide a mechanism for establishing baseline reliability values for SSCs consistent with the defense-in-depth functions to minimize challenges to the safety-related systems
- Generate design and operational information to be used for ongoing plant reliability assurance activities

Development of maintenance assessments and recommendations and the site-specific portion of the program is the responsibility of the Combined License applicant.

#### 17.4.7 D-RAP

The definition portion of the D-RAP includes the initial identification of SSCs to be included in the program, implementation of the aspects applicable to design efforts, and definition of the scope, requirements, and implementation options to be included in the later phases.

##### 17.4.7.1 SSCs Identification and Prioritization

The initial task of the D-RAP is identification of risk-significant SSCs to be included within the scope of the program. As shown in Figure 17.4-1, the AP1000 PRA is used to identify those SSCs, consistent with the criteria of Reference 7 for risk achievement worth (RAW), risk reduction worth (RRW), and Fussel-Vesely Worth (FVW). Note that, although Reference 7 was developed for AP600, it is directly applicable to AP1000. The review of light water reactor industry experience and industry notices (such as licensee event reports) supports the process. An expert panel is also employed in the selection process.

PRA-based measurements provide information that contributes to the identification and prioritization of SSCs. A component's RAW is the factor by which the plant's core damage frequency increases if the component reliability is assigned the value 0.0. Components with risk achievement worth values of 2 or greater are considered for inclusion in the D-RAP.

RRW is used in the selection process. A component's risk reduction worth is the amount by which the plant's core damage frequency decreases if the component's reliability is assigned the value 1.0. A threshold measure of 1.005 or greater is used as the cutoff. Components with RRW of 1.005 or greater are considered for inclusion in the D-RAP.

FVW is also used in the screening process. This is a measure of an event's contribution to the overall plant core damage frequency. Components with Fussel-Vesely worth of 0.5 percent or greater are considered for inclusion in the D-RAP.

Deterministic considerations are also instrumental in identifying risk-significant SSCs. The deterministic identification of risk-significant SSCs encompasses the following guidelines and considerations:

- ATWS rule (10 CFR 50.62)
- Loss of all ac power (10 CFR 50.63)
- Post-72-hour actions
- Containment performance
- Adverse interactions with the AP1000 safety-related systems
- Seismic considerations

Nonsafety-related systems identified as risk-significant are considered in the scope of the D-RAP:

- Diverse actuation system
- Non-Class 1E dc and uninterruptible power supply system
- Offsite power, main ac power, and onsite standby power systems
- Normal residual heat removal system
- Component cooling water system
- Service water system

Finally, risk-significant SSCs are selected using industry experience, regulations, and engineering judgment.

#### 17.4.7.1.1 Level 1 PRA and Shutdown Analysis

The Level 1 PRA evaluates accident sequences from initiating events and failures of safety functions to core damage events. The probability of core damage and the identification of dominant contributors to that state are also determined in this analysis.

A low-power and shutdown assessment is conducted to address concerns about risk of operations during shutdown conditions. It encompasses operation when the reactor is in a subcritical state or is in a transition between subcriticality and power operation up to 5 percent of rated power. It consists of a Level 1 PRA and an evaluation of release frequencies and magnitudes.

Included in the D-RAP are events that meet the threshold risk achievement worth, risk reduction worth, or Fussler-Vesely worth values defined in subsection 17.4.7.1.

#### 17.4.7.1.2 Level 2 Analysis

The Level 2 analysis predicts the plant response to severe accidents and offsite fission product releases. Specifically, the analysis includes the following sections:

- Evaluating severe accident phenomena and fission product source terms
- Modeling the containment event tree
- Analyzing hydrogen burn, mixing, and igniter placement
- Modeling the AP1000 utilizing the MAAP4 code

Equipment used in the prevention of severe accidents and severe post-accident boundary conditions is credited in the Level 1 and Level 2 PRA analyses. An example of this preventive equipment is the reactor coolant system automatic depressurization system (ADS). Successful depressurization leads to core cooling, and in the event that injection fails, results in a low pressure core damage sequence that has fewer uncertainties and can be more easily mitigated than high pressure core damage.

The containment event tree used in the AP1000 Level 2 PRA examines the operation of equipment which mitigates the threat to the containment from severe accident phenomena. The systems credited for the mitigation of large fission product releases are containment isolation,

passive containment cooling water (PCS), and operator action to flood the cavity by opening the recirculation valves and energizing the hydrogen igniters.

#### 17.4.7.1.3 External Event Analyses

These analyses consider the events whose cause is external to all the systems associated with normal and emergency operations situations. They include the following:

- Internal flood
- Seismic margins analysis
- External events evaluations (such as high winds and tornados, external floods, and transportation accidents)
- Fire

The internal flood analysis identifies, analyzes, and quantifies the core damage risk contribution as a result of internal flooding during at-power and shutdown conditions. The analysis models potential flood vulnerabilities in conjunction with random failures modeled as part of the internal events PRA.

The seismic margins analysis identifies potential vulnerabilities and demonstrates seismic margin beyond the safe shutdown earthquake. The capacity of those components required to bring the plant to a safe, stable shutdown is evaluated.

#### 17.4.7.1.4 Expert Panel

Meetings were held among Systems Engineering, PRA, and Reliability Engineering to perform the final selection of SSCs that should be included in the D-RAP. As shown in Figure 17.4-1, industry-wide information sources and engineering judgment were employed in considering the addition of SSCs to the D-RAP.

#### 17.4.7.1.5 SSCs to be Included in D-RAP

Table 17.4-1 lists the non-site-specific SSCs included in the D-RAP. In Figure 17.4-1, this list is denoted as "Risk-significant items (non-site-specific)." For each item listed in the "SSC" column, there is a corresponding "Rationale" given. Items whose values exceed the thresholds for RAW or RRW are included and noted as such. Other SSCs are included based upon their significance to Level 2 analysis, external event analyses, or seismic margin analysis. Additional items are included based upon an expert panel review. The "Insights and Assumptions" column provides additional insights into the selection process.

The use of Fussel-Vesely worth resulted in no SSC selections.

**17.4.7.2 Not Used****17.4.7.2.1 Not Used****17.4.7.3 Not Used****17.4.7.4 D-RAP Implementation**

The following is an example of a system that was reviewed and modified under the D-RAP. The design and analytical results presented here are intended as an example.

The automatic depressurization system, which is part of the reactor coolant system, acts in conjunction with the passive core cooling system to mitigate design basis accidents. The automatic depressurization system valves are discussed in subsection 5.4.6 of the DCD.

An earlier AP600 automatic depressurization system design contained four depressurization stages, with motor-operated valves in all stages. Preliminary PRA analysis established that fourth stage failure, in certain combination with failures of other stages, was a major contributor to core damage frequency. Thus, it was concluded that the fourth stage valves should be diverse in design from the valves in other stages to reduce common cause failure.

As a result of joint meetings among the AP600 PRA, Design, and staff organizations to discuss core melt frequency improvements, the fourth stage automatic depressurization system was changed from a motor-operated valve to a squib (explosively actuated) valve. The new configuration of the system is shown in the reactor coolant system P&ID (Figure 5.1-5 of the DCD). An example of the analytical results that reflect this change is provided in Table 17.4-2. This design feature is included in the AP1000 design to maintain the core melt frequency improvements included in the AP600 design.

As part of the evaluation of the squib valves, a failure modes and effects analysis (FMEA) was prepared to identify subcomponent failures and critical items that could lead to hazardous or abnormal conditions of the automatic depressurization system and the plant. The identification of failure modes facilitated the development of recommended maintenance and in-service testing activities to maximize valve reliability.

The squib valve is a completely static electromechanical assembly. Prior to activation, there are no moving parts. No powered components are needed to hold a stem seat or globe in place by torque, solenoid coils, or friction. The explosive actuator is a simple, passive device that is triggered by an applied voltage.

Because the automatic depressurization system fourth stage valves perform safety-related functions, they will be subject to in-service testing to verify that they are ready to function in an accident. Subsection 3.9.6 of the DCD includes in-service testing requirements for these valves.

Example FMEA results for the fourth stage squib valves and the second and third stage motor-operated valves are included in DCD Table 6.3-3. DCD subsection 3.9.6.3.1 provides testing recommendations for the second and third stage valves.



**17.4.8 Glossary of Terms**

D-RAP	Design Reliability Assurance Program – performed as part of the AP1000 design effort to assure that the reliability assumptions of the PRA remain valid throughout the plant operating lifetime.
FVW	Fussel-Vesely Worth
MR	Maintenance Rule
OPRAAs	Operational Phase Reliability Assurance Activities
PRA	Probabilistic Risk Assessment
RAW	Risk Achievement Worth
Risk-significant	Any SSC determined in the PRA or by risk-significance analysis (e.g., Level 2 PRA and shutdown risk analysis) to be a major contributor to overall plant risk
RRW	Risk Reduction Worth
RTNSS	Regulatory Treatment of Nonsafety Systems
SSC	Structures, Systems, and Components

**17.5 Combined License Information Items**

**17.5.1** The Combined License applicant or holder will address its design phase Quality Assurance program.

**17.5.2** The Combined License applicant will address its Quality Assurance program for procurement, fabrication, installation, construction and testing of structures, systems and components in the facility. The quality assurance program will include provisions for seismic Category II structures, systems, and components.

**17.5.3** The Combined License information requested in this subsection has been fully addressed in APP-GW-GLR-117 (Reference 11), and the applicable changes are incorporated in the DCD. No additional work is required by the Combined License applicant to address the aspects of the Combined License information requested in this subsection.

The following words represent the original Combined License Information Item commitment, which has been addressed as discussed above:

The COL applicant or holder will establish PRA importance measures, the expert panel process, and other deterministic methods to determine the site-specific list of SSCs under the scope of RAP.

**17.5.4** The Combined License applicant or holder will address its Quality Assurance program for operations.

**17.5.5** The Combined License information requested in this subsection has been fully addressed in APP-GW-GLR-117 (Reference 11), and the applicable changes are incorporated in the DCD. No additional work is required by the Combined License applicant to address the aspects of the Combined License information requested in this subsection.

The following words represent the original Combined License Information Item commitment, which has been addressed as discussed above:

The following activities are represented in Figure 17.4-1 as "Plant Maintenance Program."

The Combined License applicant is responsible for performing the tasks necessary to maintain the reliability of risk-significant SSCs. Reference 8 contains examples of cost-effective maintenance enhancements, such as condition monitoring and shifting time-directed maintenance to condition-directed maintenance.

**17.5.6** The Combined License information requested in this subsection has been fully addressed in APP-GW-GLR-117 (Reference 11), and the applicable changes are incorporated in the DCD. No additional work is required by the Combined License applicant to address the aspects of the Combined License information requested in this subsection.

The following words represent the original Combined License Information Item commitment, which has been addressed as discussed above:

The Maintenance Rule (10 CFR 50.65) is relevant to the Combined License applicant's maintenance activities in that it prescribes SSC performance-related goals during plant operation.

**17.5.7** The Combined License information requested in this subsection has been fully addressed in APP-GW-GLR-117 (Reference 11), and the applicable changes are incorporated in the DCD. No additional work is required by the Combined License applicant to address the aspects of the Combined License information requested in this subsection.

The following words represent the original Combined License Information Item commitment, which has been addressed as discussed above:

In addition to performing the specific tasks necessary to maintain SSC reliability at its required level, the D-RAP activities include:

- Reliability data base – Historical data available on equipment performance. The compilation and reduction of this data provides the plant with source of component reliability information.
- Surveillance and testing – In addition to maintaining the performance of the components necessary for plant operation, surveillance and testing provides a high degree of reliability for the safety-related SSCs.

- Maintenance plan – This plan describes the nature and frequency of maintenance activities to be performed on plant equipment. The plan includes the selected SSCs identified in the D-RAP.

**17.5.8** The Combined License applicant is responsible for integrating the objectives of the OPRAAs into the Quality Assurance Program developed to implement 10 CFR 50, Appendix B. This program will address failures of non-safety-related, risk-significant SSCs that result from design and operational errors in accordance with SECY-95-132, Item E.

## 17.6 References

1. "Energy Systems Business Unit – Quality Management System," Revision 2.
2. WCAP-8370, Revision 12a, "Energy Systems Business Unit - Power Generation Business Unit Quality Assurance Plan."
3. WCAP-8370/7800, Revision 11A/7A, "Energy Systems Business Unit - Nuclear Fuel Business Unit Quality Assurance Plan."
4. WCAP-12600, Revision 4, "AP600 Advanced Light Water Reactor Design Quality Assurance Program Plan," January 1998.
5. APP-GW-GL-022, Revision 0, AP1000 Probabilistic Risk Assessment.
6. Not used.
7. NRC/DCP0669, "Criteria for Establishing Risk Significant Structures, Systems, and Components (SSCs) to be Considered for the AP600 Reliability Assurance Program," January 16, 1997.
8. Lofgren, E. V., Cooper, et al., "A Process for Risk-Focused Maintenance," NUREG/CR-5695, March 1991.
9. Westinghouse Electric Company Quality Management System (QMS), Revision 5, dated October 1, 2002.
10. NEI 07-02, "Generic FSAR Template Guidance for Maintenance Rule Program Description for Plants Licensed Under 10 CFR Part 52."
11. APP-GW-GLR-117, "Incorporation of the Maintenance Rule," Westinghouse Electric Company LLC.
12. SECY 95-132, "Policy and Technical Issue With the Regulatory Treatment of Non-Safety Systems (RTNSS) in Passive Plant Designs (SECY 94-084)."

Table 17-1 (Sheet 1 of 3)

**QUALITY ASSURANCE PROGRAM REQUIREMENTS FOR  
SYSTEMS, STRUCTURES, AND COMPONENTS  
IMPORTANT TO INVESTMENT PROTECTION**

The following outlines the quality assurance program requirements for suppliers of systems, structures, or components to which the requirements for investment protection short-term availability controls apply.

1. Organization

The normal line organization may verify compliance with the requirements of this table. A separate or dedicated quality assurance organization is not required.

2. Quality Assurance Program

It is expected that the existing body of supplier’s procedures or practices will describe the quality controls applied to the subject equipment. A new or separate QA program is not required.

3. Design Control

Measures shall be established to ensure that contractually established design requirements are included in the design. Applicable design inputs shall be included or correctly translated into design documents, and deviations therefrom shall be controlled. Normal supervisory review of the designer’s work is an adequate control measure.

4. Procurement Document Control

Applicable design bases and other requirements necessary to assure component performance, including design requirements, shall be included or referenced in documents for procurement of items and services, and deviations therefrom shall be controlled.

5. Instructions, Procedures, and Drawings

Activities affecting quality shall be performed in accordance with documented instructions, procedures, or drawings of a type appropriate to the circumstances. This may include such things as written instructions, plant procedures, cautionary notes on drawings, and special instructions on work orders. Any methodology which provides the appropriate degree of guidance to personnel performing activities important to the component functional performance will satisfy this requirement.

6. Document Control

The issuance and change of documents that specify quality requirements or prescribe activities affecting quality shall be controlled to assure that correct documents are employed.

7. Control of Purchased Items and Services

Measures are to be established to ensure that all purchased items and services conform to appropriate procurement documents.

Table 17-1 (Sheet 2 of 3)

**QUALITY ASSURANCE PROGRAM REQUIREMENTS FOR  
SYSTEMS, STRUCTURES, AND COMPONENTS  
IMPORTANT TO INVESTMENT PROTECTION**

8.	<p><b>Identification and Control of Purchased Items</b></p> <p>Measures shall be established where necessary, to identify purchased items and preserve their investment protection important functional performance capability. Examples of circumstances requiring such control include the storage of environmentally sensitive equipment or material, and the storage of equipment or material that has a limited shelf-life.</p>
9.	<p><b>Control of Special Processes</b></p> <p>Measures shall be established to control special processes, including welding, heat treating, and non-destructive testing. Applicable codes, standards, specifications, criteria, and other special requirements may serve as the basis of these controls.</p>
10.	<p><b>Inspection</b></p> <p>Inspections shall be performed where necessary to verify conformance of an item or activity to specified requirements, or to verify that activities are being satisfactory accomplished.</p> <p>Inspections need not be performed by personnel who are independent of the line organization. However, inspections, where necessary, shall be performed by knowledgeable personnel.</p>
11.	<p><b>Test Control</b></p> <p>Measures shall be established, as appropriate, to test equipment prior to installation to demonstrate conformance with design requirements.</p> <p>Tests shall be performed in accordance with test procedures. Test results shall be recorded and evaluated to ensure that test requirements have been met.</p>
12.	<p><b>Control of Measuring and Test Equipment</b></p> <p>Measures shall be established to control, calibrate, and adjust measuring and test equipment at specific intervals.</p>
13.	<p><b>Handling, Storage, and Shipping</b></p> <p>Handling, storage, cleaning, packaging, shipping, and preservation of items shall be controlled to prevent damage or loss and to minimize deterioration.</p>
14.	<p><b>Inspection, Test, and Operating Status</b></p> <p>Measures shall be established to identify items that have satisfactory passed required tests and inspections, and to indicate status of inspection, test, and operability as appropriate.</p>
15.	<p><b>Control of Nonconforming Items</b></p> <p>Items that do not conform to specified requirements shall be identified and controlled to prevent inadvertent installation or use.</p>

Table 17-1 (Sheet 3 of 3)

**QUALITY ASSURANCE PROGRAM REQUIREMENTS FOR  
SYSTEMS, STRUCTURES, AND COMPONENTS  
IMPORTANT TO INVESTMENT PROTECTION**

16. Corrective Action

Measures shall be established to ensure that failures, malfunctions, deficiencies, deviations, defective components, and nonconformances are properly identified, reported, and corrected.

17. Records

Records shall be prepared and maintained to furnish evidence that the above requirements for design, procurement, document control, inspection, and test activities have been met.

18. Audits

Audits which are independent of line management are not required, if line management periodically reviews and documents the adequacy of the suppliers process and takes any necessary corrective action. Line management is responsible for determining whether reviews conducted by line management or audits conducted by an organization independent of line management are appropriate.

If performed, audits shall be conducted and documents to verify compliance with design and procurement documents, instructions, procedures, drawings, and inspection and test activities.

DCD Table 17.4-1 (Sheet 1 of 8)		
<b>RISK-SIGNIFICANT SSCs WITHIN THE SCOPE OF D-RAP</b>		
System, Structure, or Component (SSC) <sup>(1)</sup>	Rationale <sup>(2)</sup>	Insights and Assumptions
System: Component Cooling Water (CCS)		
Component Cooling Water Pumps (CCS-MP-01A/B)	EP	These pumps provide cooling of the normal residual heat removal system (RNS) and the spent fuel pool heat exchanger. Cooling the RNS heat exchanger is important to investment protection during shutdown reduced-inventory conditions. CCS valve realignment is not required for reduced-inventory conditions.
System: Containment System (CNS)		
Containment Vessel (CNS-MV-01)	EP, L2	The containment vessel provides a barrier to steam and radioactivity released to the atmosphere following accidents.
Hydrogen Igniters (VLS-EH-1 through -64)	EP, L2, Regulations	The hydrogen igniters provide a means to control H <sub>2</sub> concentration in the containment atmosphere, consistent with the hydrogen control requirements of 10 CFR 50.34f.
System: Chemical and Volume Control System (CVS)		
Makeup Pumps (CVS-MP-01A/B)	EP	These pumps provide makeup to the RCS to accommodate leaks and to provide negative reactivity for shutdowns, steam line breaks, and ATWS.
Makeup Pump Suction and Discharge Check Valves (CVS-PL-V113, -V160A/B)	EP	These CVS check valves are normally closed and have to open to allow makeup pump operation.
System: Diverse Actuation System (DAS)		
DAS Processor Cabinets and Control Panel (used to provide automatic and manual actuation) (DAS-JD-001, -002, -004, OCS-JC-020)	RAW	The DAS is diverse from the PMS and provides automatic and manual actuation of selected plant features including control rod insertion, turbine trip, passive residual heat removal (PRHR) heat exchanger actuation, core makeup tank actuation, isolation of critical containment lines, and passive containment cooling system (PCS) actuation.
Annex Building UPS Distribution Panels (EDS1-EA-1, EDS1-EA-14, EDS2-EA-1, EDS2-EA-14)	RAW	These panels distribute power to the DAS equipment.
Rod Drive MG Sets (Field Breakers) (PLS-MG-01A/B)	RAW	These breakers open on a DAS reactor trip signal demand to de-energize the control rod MG sets and allow the rods to drop.

Table 17.4-1 (Sheet 2 of 8)

**RISK-SIGNIFICANT SSCs WITHIN THE SCOPE OF D-RAP**

System, Structure, or Component (SSC) <sup>(1)</sup>	Rationale <sup>(2)</sup>	Insights and Assumptions
Containment Isolation Valves Controlled by DAS (Note 5)	RAW	These containment isolation valves are important in limiting offsite releases following core melt accidents.
System: Main ac Power System (ECS)		
Reactor Coolant Pump Switchgear (ECS-ES-31, -32, -41, -42, -51, -52, -61, -62)	EP	These breakers open automatically to allow core makeup tank operation.
Ancillary Diesel Generators (ECS-MS-01, -02)	EP	For post-72 hour actions, these generators are available to provide power for Class 1E monitoring, MCR lighting and for refilling the PCS water storage tank and spent fuel pool.
6900 Vac Buses (ECS-ES-1, -2)	RAW	These are ac power buses fed by the onsite DGs and offsite power.
System: Main and Startup Feedwater System (FWS)		
Startup Feedwater Pumps (FWS-MP-03A/B)	EP	The startup feedwater system pumps provide feedwater to the steam generator. This capability provides an alternate core cooling mechanism to the PRHR heat exchangers for non-loss-of-coolant-accidents or steam generator tube ruptures.
System: General I&C <sup>(4)</sup>		
Low Pressure/DP Sensors - IRWST level sensors (PXS-045, -046, -047, -048)	RAW/CCF	The in-containment refueling water storage tank (IRWST) level sensors support PMS functions. They are used in automatic actuation, and they provide indications to the operator. IRWST level supports IRWST recirculation actions.
High Pressure/DP Sensors - RCS Hot Leg Level (RCS-160A/B) - Pressurizer Pressure (RCS-191A/B/C/D) - Pressurizer Level (RCS-195A/B/C/D) - SG Narrow-Range Level (SGS-001, -002, -003, -004, -005, -006, -007, -008) - SG Wide-Range Level (SGS-011, -012, -013, -014, -015, -016, -017, -018)	RAW/CCF/EP	The following sensors are included in this group. These sensors support PMS and PLS functions. They are used in reactor trip and ESF functions, and provide indications to the operator. Main feedwater flow sensors support startup feedwater actuation and startup feedwater flow sensors support PRHR actuation. The hot leg level sensors automatically actuate the IRWST injection and automatic depressurization system (ADS) valves during shutdown conditions.



Table 17.4-1 (Sheet 3 of 8)

**RISK-SIGNIFICANT SSCs WITHIN THE SCOPE OF D-RAP**

System, Structure, or Component (SSC) <sup>(1)</sup>	Rationale <sup>(2)</sup>	Insights and Assumptions
<ul style="list-style-type: none"> <li>- Main Steamline Pressure (SGS-030, -031, -032, -033, -034, -035, -036, -037)</li> <li>- Main Feedwater Wide-Range Flow (SGS-050A/C/E, -051A/C/E)</li> <li>- Startup Feedwater Flow (SGS-055A/B, -056A/B)</li> </ul>		
CMT Level Sensors (PXS-011A/B/C/D, -012A/B/C/D, -013A/B/C/D, -014A/B/C/D)	RAW/CCF	These level sensors provide input for automatic actuation of the ADS. They also provide indications to the operator.
System: Class 1E DC Power and Uninterruptible Power System (IDS)		
250 Vdc 24-hour Batteries, Inverters, and Chargers (IDSA-DB-1A/B, IDSB-DB-1A/B, IDSC-DB-1A/B, IDSD-DB-1A/B, IDSA-DU-1, IDSB-DU-1, IDSC-DU-1, IDSD-DU-1, IDSA-DC-1, IDSB-DC-1, IDSC-DC-1, IDSD-DC-1)	RAW/CCF	The batteries provide power for the PMS and safety-related valves. The chargers are the preferred source of power for Class 1E dc loads and are the source of charging for the batteries. The inverters provide uninterruptible ac power to the I&C system.
250 Vdc and 120 Vac Distribution Panels (IDSA-DD-1, -EA-1/2, IDSB-DD-1, -EA-1/2/3, IDSC-DD-1, -EA-1/2/3, IDSD-DD-1, -EA-1/2)	RAW	These panels distribute power to components in the plant that require 1E power support and for the PMS.
Fused Transfer Switch Boxes (IDSA-DF-1, IDSB-DF-1/-2, IDSC-DF-1/-2, IDSD-DF-1)	RAW	The fused disconnect switches connect the different levels of Class 1E distribution panels.
250 Vdc Motor Control Centers (IDSA-DK-1, IDSB-DK-1, IDSC-DK-1, IDSD-DK-1)	EP	These buses provide power for the PMS and safety-related valve operation.

Table 17.4-1 (Sheet 4 of 8)		
<b>RISK-SIGNIFICANT SSCs WITHIN THE SCOPE OF D-RAP</b>		
System, Structure, or Component (SSC) <sup>(1)</sup>	Rationale <sup>(2)</sup>	Insights and Assumptions
System: Passive Containment Cooling System (PCS)		
Recirculation Pumps (PCS-MP-01A/B)	EP	These pumps provide the motive force to refill the PCS water storage tank during post-72 hour support actions.
PCCWST Drain Isolation Valves (PCS-PL-V001A/B/C)	EP, L2	These valves (two AOVs and one MOV) open automatically to drain water from a water storage tank onto the outside surface of the containment shell. This water provides evaporative cooling of the containment shell following accidents.
System: Plant Control System (PLS)		
PLS Actuation Hardware (Control functions listed in Note 6)	RAW/CCF	This common cause failure event is assumed to disable all logic outputs from the PLS associated with CVS reactor makeup, RNS reactor injection, spent fuel cooling, component cooling of RNS SFS heat exchangers, service water cooling of CCS heat exchangers, standby diesel generators, and hydrogen igniters.
System: Protection and Safety Monitoring System (PMS)		
PMS Actuation Software	RAW/CCF	The PMS software provides the automatic reactor trip and ESF actuation functions listed in Tables 7.2-2 and 7.3-1.
PMS Actuation Hardware	RAW/CCF	The PMS hardware provides the automatic reactor trip and ESF actuation functions listed in Tables 7.2-2 and 7.3-1.
Main Control Room (MCR) 1E Displays and System Level Controls (OCS-JC-010, -011)	RAW/CCF	This includes the Class 1E PMS (QDPS) displays and controls. These displays and system level controls provide important plant indications to allow the operator to monitor and control the plant during accidents.
Reactor Trip Switchgear (PMS-JD-RTS A01/02, B01/02, C01/02, D01/02)	RAW/CCF	These breakers open automatically to allow insertion of the control rods.
System: Passive Core Cooling System (PXS)		
IRWST Vents (PXS-MT-03)	RAW/CCF	The IRWST vents provide a pathway to vent steam from the tank into the containment. The IRWST vents also have a severe accident function to prevent the formation of standing hydrogen flames close to the containment walls. This function is accomplished by designing the vents located further from the containment walls to open with less IRWST internal pressure than the other vents.

Table 17.4-1 (Sheet 5 of 8)

**RISK-SIGNIFICANT SSCs WITHIN THE SCOPE OF D-RAP**

System, Structure, or Component (SSC) <sup>(1)</sup>	Rationale <sup>(2)</sup>	Insights and Assumptions
IRWST Screens (PXS-MY-Y01A/B)	RAW/CCF	The IRWST injection lines provide long-term core cooling following a LOCA. These screens are located inside the IRWST and prevent large particles from being injected into the RCS. They are designed so that they will not become obstructed.
Containment Recirculation Screens (PXS-MY-Y02A/B)	RAW/CCF	The containment recirculation lines provide long-term core cooling following a LOCA. The screens are located in the containment and prevent large particles from being injected into the RCS. They are designed so that they will not become obstructed.
CMT Discharge Isolation Valves (PXS-PL-V014A/B, PXS-PL-V015A/B)	RAW/CCF	These air-operated valves automatically open to allow core makeup tank injection.
CMT Discharge Check Valves (PXS-PL-V016A/B, PXS-PL-V017A/B)	RAW/CCF	These check valves are normally open. They close during rapid accumulator injection.
Accumulator Discharge Check Valves (PXS-PL-V028A/B, -V029A/B)	RAW/CCF	These check valves open when the RCS pressure drops below the accumulator pressure to allow accumulator injection.
PRHR Heat Exchanger Control Valves (PXS-PL-V108A/B)	RAW/CCF	The PRHR heat exchangers provide core cooling following non-LOCAs, steam generator tube ruptures, and anticipated transients without scram. The air-operated valves automatically open to initiate PRHR heat exchanger operation.
Containment Recirculation Squib Valves (PXS-PL-V118A/B, PXS-PL-V120A/B)	RAW/CCF	<p>The containment recirculation lines provide long-term core cooling following a LOCA. These squib valves open automatically to allow containment recirculation when the IRWST level is reduced to about the same level as the containment level. These squib valves can also allow long-term core cooling to be provided by the RNS pumps.</p> <p>These squib valves can provide a rapid flooding of the containment to support in-vessel retention during a severe accident.</p>

Table 17.4-1 (Sheet 6 of 8)

**RISK-SIGNIFICANT SSCs WITHIN THE SCOPE OF D-RAP**

System, Structure, or Component (SSC) <sup>(1)</sup>	Rationale <sup>(2)</sup>	Insights and Assumptions
IRWST Injection Check Valves (PXS-PL-V122A/B, -V124A/B)	RAW/CCF	The containment recirculation lines provide long-term core cooling following a LOCA. These check valves open when the IRWST level is reduced to approximately the same level as the containment level.
IRWST Injection Squib Valves (PXS-PL-V123A/B, -V125A/B)	RAW/CCF	The IRWST injection lines provide long-term core cooling following a LOCA. These squib valves open automatically to allow injection when the RCS pressure is reduced to below the IRWST injection head.
IRWST Gutter Bypass Isolation Valves (PXS-PL-V130A/B)	RAW/CCF	These valves direct water collected in the IRWST gutter to the IRWST. This capability extends PRHR heat exchanger operation.
System: Reactor Coolant System (RCS)		
ADS Stage 1/2/3 Valves (MOV) (RCS-PL-V001A/B, -V002A/B, -V003A/B, -V011A/B, -V012A/B, -V013A/B)	RAW/CCF	The ADS provides a controlled depressurization of the RCS following LOCAs to allow core cooling from the accumulator, IRWST injection, and containment recirculation. The ADS provides "bleed" capability for feed/bleed cooling of the core. The ADS also provides depressurization of the RCS to prevent a high-pressure core melt sequence.
ADS Stage 4 Valves (Squib) (RCS-PL-V004A/B/C/D)	RAW/CCF	The ADS provides a controlled depressurization of the RCS following LOCAs to allow core cooling from the accumulator, IRWST injection, and containment recirculation. The ADS provides "bleed" capability for feed/bleed cooling of the core. The ADS also provides depressurization of the RCS to prevent a high-pressure core melt sequence.
Pressurizer Safety Valves (RCS-PL-V005A/B)	EP	These valves provide overpressure protection of the RCS.
Reactor Vessel Insulation Water Inlet and Steam Vent Devices (RCS-MN-01)	EP	These devices provide an engineered flow path to promote in-vessel retention of the core in a severe accident.
Reactor Cavity Doorway Damper	EP	This device provides a flow path to promote in-vessel retention of the core in a severe accident.
Fuel Assemblies (157 assemblies with tag numbers beginning with RXS-FA)	SMA	The nuclear fuel assembly includes the fuel pellets, fuel cladding, and associated support structures. This equipment, which provides a first barrier for release of radioactivity and allows for effective core cooling, had the least margin in the seismic margin analysis.

Table 17.4-1 (Sheet 7 of 8)

**RISK-SIGNIFICANT SSCs WITHIN THE SCOPE OF D-RAP**

System, Structure, or Component (SSC) <sup>(1)</sup>	Rationale <sup>(2)</sup>	Insights and Assumptions
System: Normal Residual Heat Removal System (RNS)		
Residual Heat Removal Pumps (RNS-MP-01A/B)	RAW/CCF	These pumps provide shutdown cooling of the RCS. They also provide an alternate RCS lower pressure injection capability following actuation of the ADS. The operation of these pumps is important to investment protection during shutdown reduced-inventory conditions. RNS valve realignment is not required for reduced-inventory conditions.
RNS Motor-Operated Valves (RNS-PL-V011, -V022, -V023, -V055)	EP	These MOVs align a flow path for nonsafety-related makeup to the RCS following ADS operation, initially from the cask loading pit and later from the containment.
RNS Stop Check Valves (RNS-PL-V015A/B), RNS Check Valves (RNS-PL-V017 A/B)	CCF/EP	These stop check valves and check valves are in the discharge of the RNS pumps. They prevent backflow from the RCS.
RNS Check Valves (RNS-PL-V007 A/B, -V013, -V056)	L2 RAW/EP	Check valves V007 A/B and V013 provide a flow path from the RNS pumps to the RCS. Failure of these valves to open will result in the loss of long-term cooling from the RNS. Check valve V056 provides a flow path from the cask loading pit to the RNS pump inlet.
System: Spent Fuel Cooling System (SFS)		
Spent Fuel Cooling Pumps (SFS-MP-01A/B)	EP	These pumps provide flow to the heat exchangers for removal of the design basis heat load.
System: Steam Generator System (SGS)		
Main Steam Safety Valves (SGS-PL-V030A/B, -V031A/B, -V032A/B, -V033A/B, -V034A/B, -V035A/B)	EP	The steam generator main steam safety valves provide overpressure protection of the steam generator. They also provide core cooling by venting steam from the steam generator.
Main Steam and Feedwater Isolation Valves (SGS-PL-V040A/B, -V057A/B)	RAW/EP	The steam generator main steam and feedwater isolation valves provide isolation of the steam generator following secondary line breaks and steam generator tube rupture.
System: Service Water System (SWS)		
Service Water Pumps and Cooling Tower Fans (SWS-MP-01A/B, SWS-MA-01A/B)	EP	These pumps and fans provide cooling of the CCS heat exchanger which is important to investment protection during shutdown reduced-inventory conditions. Service water system valve realignment is not required for reduced-inventory conditions.

Table 17.4-1 (Sheet 8 of 8)		
RISK-SIGNIFICANT SSCs WITHIN THE SCOPE OF D-RAP		
System, Structure, or Component (SSC) <sup>(1)</sup>	Rationale <sup>(2)</sup>	Insights and Assumptions
System: Nuclear Island Nonradioactive Ventilation System (VBS)		
VBS MCR and I&C Rooms B/C Ancillary Fans (VBS-MA-10A/B, -11, -12)	EP	For post-72 hour actions, these fans are available to provide cooling of the MCR and the two I&C rooms (B/C) that provide post-accident monitoring.
System: Chilled Water System (VWS)		
Air Cooled Chillers and Pumps (VWS-MS-02, -03, VWS-MP-02, -03)	EP	This VWS subsystem provides chilled cooling water to the CVS makeup pump room. The pumps and chillers are important components of the VWS.
System: Onsite Standby Power System (ZOS)		
Onsite Diesel Generators (ZOS-MS-05A/B)	EP	These diesel generators provide ac power to support operation of nonsafety-related equipment such as the startup feedwater pumps, CVS pumps, RNS pumps, CCS pumps, SWS pumps, and the PLS. Providing ac power to the RNS and the equipment necessary to support its operation is important to investment protection during reduced inventory conditions.
Engine Room Exhaust Fans (VZS-MY-V01A/B, -V02A/B)	EP	These fans provide ventilation of the rooms containing the onsite diesel generators.

**Notes:**

- Only includes equipment at the **component** level. Other parts of the SSC or support systems are not included unless specifically listed.
- Definition of Rationale Terms:
  - CCF = Common Cause Failure (for the SSCs whose inclusion rationale is RAW/CCF, the RAW is based on common cause failure of two or more of the specified SSCs.
  - EP = Expert Panel
  - RAW = Risk Achievement Worth
  - RRW = Risk Reduction Worth
  - SMA = Seismic Margin Analysis
- Maintenance/surveillance recommendations for equipment are documented in each appropriate DCD section.
- This category captures instrumentation and control equipment common cause failures across systems.
- The following containment isolation valves are controlled by DAS:
 

Chemical and Volume Control Letdown Discharge IRC	CVS-PL-V045
Chemical and Volume Control Letdown Discharge ORC	CVS-PL-V047
Containment Purge Inlet Containment Isolation Valve ORC	VFS-PL-V003
Containment Purge Inlet Containment Isolation Valve IRC	VFS-PL-V004
Containment Purge Discharge Containment Isolation Valve IRC	VFS-PL-V009
Containment Purge Discharge Containment Isolation Valve ORC	VFS-PL-V010
Sump Discharge Containment Isolation Valve IRC	WLS-PL-V055
Sump Discharge Containment Isolation Valve ORC	WLS-PL-V057

6. The PLS provides control of the following functions:
  - CVS Reactor Makeup
  - RNS Reactor Injection from Cask Loading Pit
  - Startup Feedwater from CST
  - Spent Fuel Cooling
  - Component Cooling of RNS and SFS Heat Exchangers
  - Service Water Cooling of the CCS Heat Exchangers
  - Onsite Diesel Generators
  - Hydrogen Igniters

Table 17.4-2

**EXAMPLE OF RISK-SIGNIFICANT RANKING OF SSCs FOR THE AUTOMATIC  
DEPRESSURIZATION SYSTEM**

<b>Rank<sup>(1)</sup></b>	<b>Event Code</b>	<b>Description</b>
1	ED3MOD07	EDS3 EA1 distribution panel failure or unavailable due to testing and maintenance
2	AD4MOD07, AD4MOD08, AD4MOD09, AD4MOD10	Hardware failure of 2 of 4 automatic depressurization system Stage 4 squib valves
3	EC1BS001TM, ECBS012TM, EC1BS121TM, EC2BS002TM, EC2BS022TM, EC2BS221TM	Unavailability of bus ECS ES due to unscheduled maintenance
4	AD2MOD01, AD2MOD02, AD2MOD03, AD2MOD04	Hardware failure of 2 of 4 automatic depressurization system Stages 2 and 3 of lines 1 and 2 (includes motor-operated valves)
5	EC0MOD01	Main generator breaker ES01 fails to open
6	ED3MOD01	Fixed component fails: circuit breaker, inverter or static transfer switch
7	Z01MOD01, Z02MOD01	Diesel generator fails to start and run or breaker 102 fails to close
8	Z02DG001TM, Z02DG001TM	Standby diesel generator unavailable due to testing and maintenance

**Note:**

1. The ranking is in the order of decreasing risk achievement component importance.






Figure 17.4-1

**Design Reliability Assurance Program and Operational Phase Reliability Assurance Activities**